




Air Hygiene International, Inc.

The Clear Choice



**EMISSION PERFORMANCE TEST
FOR THE
BIOMASS BOILER STACK OUTLET AND
SPRAY DRYER ABSORBER INLET
PREPARED FOR
FIBROMINN, LLC
AT THE
FIBROMINN BIOMASS POWER PLANT
900 INDUSTRY DRIVE
BENSON, MINNESOTA
JULY 4-6, 2007**



Air Hygiene International, Inc.

Corporate Headquarters
5634 S. 122nd E. Ave. Ste. F
Tulsa, Oklahoma 74146

Las Vegas Office
5925 E. Lake Mead Blvd.
Las Vegas, Nevada 89156

Philadelphia Office
8900 State Road
Philadelphia, Pennsylvania 19136

Houston Office
1920 Treble Drive
Humble, Texas 77338

(918) 307-8865 or (888) 461-8778
www.airhygiene.com

**EMISSIONS PERFORMANCE TEST
FOR THE
BIOMASS BOILER STACK OUTLET AND
SPRAY DRYER ABSORBER INLET
PREPARED FOR
FIBROMINN, LLC
AT THE
FIBROMINN BIOMASS POWER PLANT
900 INDUSTRY DRIVE
BENSON, MINNESOTA
JULY 4-6, 2007**

Prepared and Reviewed by:



Thomas K. Graham, PE, Director of Operations



Quinn A. Bierman, President

Minn R. 7017.2040 Certification Statements

Certification of sampling procedures

I certify under penalty of law that the sampling procedures were performed in accordance with the approved test plan and that the data presented in this test report are, to the best of my knowledge and belief, true, accurate, and complete. All exceptions are listed and explained below.




Thomas K. Graham, PE, Director of Operations

Exceptions: None

Certification of analytical procedures

I certify under penalty of law that the analytical procedures were performed in accordance with the requirements of the test methods and that the data presented for use in the test report were, to the best of my knowledge and belief, true, accurate, and complete. All exceptions are listed and explained below.




Pandu Sattvika, Laboratory Manager

Exceptions: None

Certification of test report by testing company

I certify under penalty of law that this test report and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the test information submitted. Based on my inquiry of the person or persons who performed sampling and analysis relating to the performance test, the information submitted in this test report is, to the best of my knowledge and belief, true, accurate, and complete. All exceptions are listed and explained below.




Quinn A. Bierman, President

Exceptions: None

Certification of test report by owner or operator of emission facility

I certify under penalty of law that the information submitted in this test report accurately reflects the operating conditions at the emission facility during this performance test and describes the date and nature of all operational and maintenance activities that were performed on process and control equipment during the month prior to the performance test. Based on my inquiry of the person or persons who performed the operational and maintenance activities, the information submitted in this test report is, to the best of my knowledge and belief, true, accurate, and complete. All exceptions are listed and explained below.



Exceptions:

Table of Contents

1.0	INTRODUCTION	1
1.1	TEST PURPOSE AND OBJECTIVES	1
1.2	SUMMARY OF TEST PROGRAM	1
1.2.1	Participating Organizations	1
1.2.2	Industry	1
1.2.3	Air Permit	1
1.2.4	Plant Location	1
1.2.5	Equipment Tested	1
1.2.6	Emission Points	1
1.2.7	Pollutants Measured	2
1.2.8	Dates of Emission Test	2
1.3	KEY PERSONNEL	2
2.0	SUMMARY OF TEST RESULTS	2
3.0	SOURCE OPERATION	3
3.1	PROCESS DESCRIPTION	3
3.2	SAMPLING LOCATION	3
4.0	SAMPLING AND ANALYTICAL PROCEDURES	3
4.1	TEST METHODS	3
4.2	INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS	4

APPENDICES

- Appendix A Test Results and Calculations
- Appendix B Unit Operation Parameters
- Appendix C Calibration Gas Certifications
- Appendix D Quality Assurance and Quality Control Data
- Appendix E Fuel Analysis
- Appendix F Test Protocol
- Appendix G MPCA Approvals and Requested Forms

Emissions Performance Test
Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet
Fibrominn, LLC
Fibrominn Biomass Power Plant
Benson, Minnesota
July 4-6, 2007

1.0 INTRODUCTION

Air Hygiene International, Inc. (Air Hygiene) has completed the emissions testing study for dioxins (PCDDs), furans (PCDFs), and mercury (Hg) from the Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet for Fibrominn, LLC at the Fibrominn Biomass Power Plant near Benson, Minnesota. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on July 4-6, 2007.

1.1 TEST PURPOSE AND OBJECTIVES

The purpose of the test was to conduct an initial performance emission test to document levels of selected pollutants at a maximum test load (greater than 90 percent). The information will be used to establish emission baselines with the operating permit issued by the Minnesota Pollution Control Agency (MPCA). The specific objective was to determine the emission concentration of PCDDs, PCDFs, and Hg from Fibrominn, LLC's Biomass Boiler Stack Outlet and Hg entering the Spray Dryer Absorber Inlet.

1.2 SUMMARY OF TEST PROGRAM

The following list details pertinent information related to this specific project:

1.2.1 Participating Organizations

- Minnesota Pollution Control Agency (MPCA)
- Fibrominn, LLC
- SNC - Lavalin
- Air Hygiene

1.2.2 Industry

- Biomass Fired Electric Utility / Electric Services

1.2.3 Air Permit

- Permit Number: 15100038-004
- AQ Facility ID No: 4065

1.2.4 Plant Location

- Fibrominn Biomass Power Plant near Benson, Minnesota

1.2.5 Equipment Tested

- Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet (identified as EU-001)

1.2.6 Emission Points

- Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet
- For Hg, 12 sampling points from the Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet
- For all PCDD and PCDF testing, twelve sample points in the Biomass Boiler Stack Outlet (refer to Appendix B)

- 1.2.7 Pollutants Measured
 - PCDDs / PCDFs
 - Hg
- 1.2.8 Dates of Emission Test
 - July 4-6, 2007

1.3 KEY PERSONNEL

Fibrominn, LLC:	Chuck Wagoner	320-843-9013
MPCA:	Steven Gorg	651-296-8766
SNC:	Victor Myers	320-843-5170
Air Hygiene:	Thomas Graham	918-307-8865

2.0 SUMMARY OF TEST RESULTS

Results from the sampling conducted on Fibrominn, LLC's Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet located at the Fibrominn Biomass Power Plant on July 4-6, 2007 are summarized in the following table.

**TABLE 2.1
SUMMARY EMISSIONS DATA**

Parameter	Units	Run 1	Run 2	Run 3	Average
PCDDs / PCDFs (Total)	ng	0.6280	0.3957	0.2774	0.4337
	ng/dscm@7%O ₂	0.1654	0.1119	0.0744	0.1176
	kg/hr	5.25E-08	3.65E-08	2.41E-08	3.77E-08
	lbs/hr	1.16E-07	8.06E-08	5.32E-08	8.32E-08
	tons/yr	5.07E-07	3.53E-07	2.33E-07	3.64E-07
Hg (Inlet)	lbs/MMBtu	1.60E-10	1.08E-10	7.18E-11	1.13E-10
	mg	0.00052	0.00000	0.00000	0.00017
	lbs/hr	0.00036	0.00000	0.00000	0.00012
	tons/yr	0.00156	0.00000	0.00000	0.00052
Hg (Outlet)	Ibs/MMBtu	4.23E-07	0.00E+00	0.00E+00	1.41E-07
	mg	0.00000	0.00000	0.00000	0.00000
	lbs/hr	0.00000	0.00000	0.00000	0.00000
	tons/yr	0.00000	0.00000	0.00000	0.00000
	Ibs/MMBtu	0.00E+00	0.00E+00	0.00E+00	0.00E+00

All measurements and calculations were performed as stated and approved in the attached testing protocol (Appendix F) without any real or apparent errors. Unit loads during testing were at or above 90 percent of maximum.

3.0 SOURCE OPERATION

3.1 PROCESS DESCRIPTION

PowerMinn 9090, LLC (PowerMinn) owns and Fibrominn, LLC (Fibrominn) operates the Fibrominn Biomass Power Plant in Swift County, Benson, Minnesota. The plant consists of one boiler, fueled principally with poultry litter. Vegetative biomass may also be burned. The facility generates a nominal 50 megawatts (MW) of electricity for export and has a peak electrical export capacity of 55 MW with a peak gross electrical generating capacity of 65 MW.

Emissions from the boiler are controlled by a spray dryer absorber followed by a fabric filter baghouse to control particulate matter and particulate matter / particulate matter less than 10 microns in diameter (PM/PM₁₀), SO₂, sulfuric acid mist (H₂SO₄), and HCl. Selective non-catalytic reduction (SNCR) is used to control NOx. Good combustion practices are used to control CO and volatile organic compounds (VOCs).

3.2 SAMPLING LOCATION

Performance testing was performed on the unit at the spray dryer absorber (SDA) inlet and the stack outlet. The SDA inlet duct is circular and measures 10.8 feet (ft) (129 inches) in diameter at the test ports which are approximately 120 ft above grade level. The test ports are located approximately 101.8 ft (1,222 inches) downstream and approximately 29.2 ft (350 inches) upstream from the nearest disturbances.

The stack exhaust is circular and measures 9 feet (ft) (108 inches) in diameter at the test ports which are approximately 104 ft above grade level with an exit elevation of approximately 300 ft above grade level. The test ports are located approximately 75.8 ft (910 inches) downstream and approximately 196.5 ft (2,358 inches) upstream from the nearest disturbances.

All samples for Hg emissions were continuously drawn from the stack exhaust and SDA Inlet at 12 sample points. For PCDD and PCDF testing on the stack exhaust, an initial velocity traverse was performed across the stack from 12 total points. All PCDD and PCDF sampling occurred from the same 12 points by leaving the probe at each for an equal amount of time in order to draw at least 100 dry standard cubic feet of gas through the sample train.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 TEST METHODS

The emission test on the Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet at the Fibrominn Biomass Power Plant was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR) and the Ontario Hydro Method. Table 4.1 outlines the specific methods performed on July 4-6, 2007.

TABLE 4.1
SUMMARY OF SAMPLING METHODS

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Stack Flow Rate	EPA Method 2	S-Type Pitot Tube
Oxygen	EPA Method 3a	Paramagnetic Cell
Carbon Dioxide	EPA Method 3a	Nondispersive Infrared Analyzer
Stack Moisture Content	EPA Method 4	Gravimetric Analysis
PCDD and PCDF	EPA Method 23	Laboratory GC/MS
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Fuel Based F-Factor	EPA Method 19	CO ₂ Based F Factor
Mercury	Ontario Hydro	ASTM D6784-02

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 2, 3a, 4, 10, 23, and the Ontario Hydro Method.

Figure 4.1 depicts the sample system used for the CO, CO₂, and O₂ tests. A stainless steel probe was inserted into the sample ports of the stack exhaust and the SDA inlet to extract gas measurements. The gas sample was continuously pulled through the probe and transported via heat-traced Teflon® tubing to a stainless steel minimum-contact condenser designed to dry the sample and through Teflon® tubing via a stainless steel/Teflon® diaphragm pump and into the sample manifold within the mobile laboratory. From the manifold, the sample was partitioned to the CO, CO₂, and O₂ analyzers through rotameters that controlled the flow rate of the sample.

Figure 4.1 shows that the sample systems were also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling systems. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in an air-conditioned trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NOx calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System Hyperlogger which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds. Data records can be found in Appendix A and B of this report.

Figure 4.2 represent the sample system used for the wet chemistry (PCDD, PCDF, and Hg) tests. A heated stainless steel probe with a glass liner and glass nozzle was inserted into the sample ports of the stack to extract gas measurements from the emission stream through a filter and glass impinger train. Flow rates are monitored with oil filled manometers and total sample volumes are measured with a dry gas meter.


Three test runs of approximately 120 minutes each were conducted on the Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet at the maximum test load simultaneously for Hg. Three test runs pulling at least 100 dry standard cubic feet of sample were run at the maximum test load for the PCDD and PCDF testing at the stack exhaust.

The stack gas analysis for O₂ and CO₂ concentrations was performed in accordance with procedures set forth in EPA Method 3a. The O₂ analyzer uses a paramagnetic cell detector and the CO₂ analyzer uses a continuous nondispersive infrared analyzer.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

**TABLE 4.2
ANALYTICAL INSTRUMENTATION**

Parameter	Model & Manufacturer	Max. Ranges	Sensitivity	Detection Principle
CO	Outlet: THERMO 48C	User may select up to 3,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
CO ₂	Outlet: SERV 1440	0-20%	0.1%	Nondispersive infrared
O ₂	Outlet: SERV 1400 Inlet: M&C PMA 22	0-25%	0.1%	Paramagnetic cell, inherently linear.







Figure 4.2
WET CHEMISTRY ASSEMBLY
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
www.airhygiene.com
(888) 461-8778

APPENDIX A

TEST RESULTS AND CALCULATIONS

TABLE A.1: EMISSIONS TESTING SCHEDULE

Unit	Load	Component	Run	Date	Start	Stop	Time Sync
OUT-Diox	100%	Dioxins	OUT-Diox-1	07/04/07	14:52:00	20:00:00	DAHS
OUT-Diox	100%	Dioxins	OUT-Diox-2	07/04/07	22:34:00	2:47:00	DAHS
OUT-Diox	100%	Dioxins	OUT-Diox-3	07/05/07	3:15:00	7:26:00	DAHS
IN-OHM	100%	Ontario Hydro	IN-OHM-1	07/05/07	18:02:00	20:20:00	DAHS
IN-OHM	100%	Ontario Hydro	IN-OHM-2	07/05/07	21:12:00	23:30:00	DAHS
IN-OHM	100%	Ontario Hydro	IN-OHM-3	07/06/07	0:43:00	3:00:00	DAHS
OUT-OHM	100%	Ontario Hydro	OUT-OHM-1	07/05/07	18:02:00	22:10:00	DAHS
OUT-OHM	100%	Ontario Hydro	OUT-OHM-2	07/05/07	21:12:00	23:22:00	DAHS
OUT-OHM	100%	Ontario Hydro	OUT-OHM-3	07/06/07	0:43:00	2:55:00	DAHS

Note: DAHS Time (CST)

TEST RESULTS AND CALCULATIONS

PCDD and PCDF Emissions Data

METHOD 23 (DIOXINS) - RESULTS

Plant Name	Fibrominn Biomass Power Plant	Date	07/04/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TP/TKG	Stack Type	Circular

Historical Data						
Run Number		OUT-Diox-1	OUT-Diox-2	OUT-Diox-3	Average	
Run Start Time		14:52	22:34	3:15		hh:mm
Run Stop Time		20:00	2:47	7:26		hh:mm
Meter Calibration Factor	(Y)	1.005	1.005	1.005		
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840		
Average Nozzle Diameter	(D _{na})	0.184	0.175	0.184		in
Stack Test Data						
Initial Meter Volume	(V _m) _i	357.914	480.392	602.870		ft ³
Final Meter Volume	(V _m) _f	479.322	592.900	721.378		ft ³
Total Meter Volume	(V _m)	121.408	112.508	118.508	117.475	ft ³
Total Sampling Time	(θ)	240.0	240.0	240.0	240.0	min
Average Meter Temperature	(t _m) _{avg}	83.8	80.5	80.6	81.6	oF
Average Stack Temperature	(t _s) _{avg}	297.9	299.5	297.7	298.4	oF
Barometric Pressure	(P _b)	29.53	29.52	29.52	29.52	in Hg
Stack Static Pressure	(P _{static})	-0.23	-0.23	-0.23	-0.23	in H ₂ O
Absolute Stack Pressure	(P _s)	29.51	29.50	29.50	29.51	in Hg
Average Orifice Pressure Drop	(ΔH) _{avg}	0.80	0.68	0.83	0.77	in H ₂ O
Absolute Meter Pressure	(P _m)	29.66	29.65	29.65	29.66	in Hg
Avg Square Root Pitot Pressure	(Δp ^{1/2}) _{avg}	1.19	1.20	1.21	1.20	(in H ₂ O) ^{1/2}
Moisture Content Data						
Impingers 1-3 Water Volume Gain	(V _n)	777.3	643.7	735.4	718.8	ml
Impinger 4 Silica Gel Weight Gain	(W _n)	37.9	42.7	46.0	42.2	g
Total Water Volume Collected	(V _{lc})	815.3	686.4	781.5	761.1	ml
Standard Water Vapor Volume	(V _w) _{std}	38.375	32.311	36.786	35.824	scf
Standard Meter Volume	(V _m) _{std}	117.195	109.165	115.012	113.791	dscf
Calculated Stack Moisture	(B _{ws(calc)})	24.67	22.84	24.23	23.91	%
Saturated Stack Moisture	(B _{ws(svp)})	100.0	100.0	100.0	100.0	%
Reported Stack Moisture Content	(B _{ws})	24.67	22.84	24.23	23.91	%
Gas Analysis Data						
Carbon Dioxide Percentage	(%CO ₂)	14.0	14.0	14.0	14.0	%
Oxygen Percentage	(%O ₂)	5.0	5.0	5.0	5.0	%
Carbon Monoxide Percentage	(%CO)	0.0	0.0	0.0	0.0	%
Nitrogen Percentage	(%N ₂)	81.0	81.0	81.0	81.0	%
Dry Gas Molecular Weight	(M _d)	30.44	30.44	30.44	30.44	lb/lb-mole
Wet Stack Gas Molecular Weight	(M _s)	27.37	27.60	27.43	27.47	lb/lb-mole
Calculated Fuel Factor	(F _o)	1.135	1.135	1.135	1.135	
Fuel F-Factor	(F _c)	1890	1890	1890	1890	dscf/MMBtu
Percent Excess Air	(%EA)	30.5	30.5	30.5	30.5	%
Volumetric Flow Rate Data						
Average Stack Gas Velocity	(v _s)	82.66	83.23	83.84	83.24	ft/sec
Stack Cross-Sectional Area	(A _s)	63.62	63.62	63.62	63.62	ft ²
Actual Stack Flow Rate	(Q _{aw})	315,509	317,707	320,013	317,743	acf m
Wet Standard Stack Flow Rate	(Q _{sw})	13,009	13,067	13,194	13,090	wkscfh
Dry Standard Stack Flow Rate	(Q _{sd})	163,324	168,055	166,616	165,998	dscfm
Percent of Isokinetic Rate	(I)	102.8	103.9	99.1	101.9	%

METHOD 23 (DIOXINS) - RESULTS

Plant Name	Fibrominn Biomass Power Plant	Date	07/04/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TP/TKG	Stack Type	Circular

Historical Data						
Run Number		OUT-Diox-1	OUT-Diox-2	OUT-Diox-3	Average	
Total TCDDs						
Stack Total TCDDs Concentration	(c _{pe})	0.0264	0.0140	0.0000	0.0135	ng
	(c _{pe})	0.0070	0.0040	0.0000	0.0037	ng/dscm@7%O ₂
Total TCDDs Emission Rate	(E)	2.21E-09	1.29E-09	0.00E+00	1.17E-09	kg/hr
	(E _{pe})	4.87E-09	2.85E-09	0.00E+00	2.57E-09	lbs/hr
	(E _{pe})	2.13E-08	1.25E-08	0.00E+00	1.13E-08	tons/yr
	(E ^{'''})	1.23E-12	7.03E-13	0.00E+00	6.46E-13	lbs/MMBtu
Total PeCDDs						
Stack Total PeCDDs Concentration	(c _{pe})	0.1240	0.0245	0.0204	0.0563	ng
	(c _{pe})	0.0327	0.0069	0.0055	0.0153	ng/dscm@7%O ₂
Total PeCDDs Emission Rate	(E)	1.04E-08	2.26E-09	1.77E-09	4.80E-09	kg/hr
	(E _{pe})	2.29E-08	4.99E-09	3.91E-09	1.06E-08	lbs/hr
	(E _{pe})	1.00E-07	2.19E-08	1.71E-08	4.64E-08	tons/yr
	(E ^{'''})	5.80E-12	1.23E-12	9.72E-13	2.67E-12	lbs/MMBtu
Total HxCDDs						
Stack Total HxCDDs Concentration	(c _{pe})	0.0614	0.0266	0.0530	0.0470	ng
	(c _{pe})	0.0162	0.0075	0.0142	0.0127	ng/dscm@7%O ₂
Total HxCDDs Emission Rate	(E)	5.13E-09	2.46E-09	4.61E-09	4.07E-09	kg/hr
	(E _{pe})	1.13E-08	5.42E-09	1.02E-08	8.96E-09	lbs/hr
	(E _{pe})	4.96E-08	2.37E-08	4.45E-08	3.93E-08	tons/yr
	(E ^{'''})	2.87E-12	1.33E-12	2.52E-12	2.24E-12	lbs/MMBtu
Total HpCDDs						
Stack Total HpCDDs Concentration	(c _{pe})	0.0438	0.0000	0.0000	0.0146	ng
	(c _{pe})	0.0115	0.0000	0.0000	0.0040	ng/dscm@7%O ₂
Total HpCDDs Emission Rate	(E)	3.66E-09	0.00E+00	0.00E+00	1.22E-09	kg/hr
	(E _{pe})	8.07E-09	0.00E+00	0.00E+00	2.69E-09	lbs/hr
	(E _{pe})	3.54E-08	0.00E+00	0.00E+00	1.18E-08	tons/yr
	(E ^{'''})	2.05E-12	0.00E+00	0.00E+00	6.82E-13	lbs/MMBtu
Total OCDDs						
Stack Total OCDDs Concentration	(c _{pe})	0.0527	0.0000	0.0000	0.0176	ng
	(c _{pe})	0.0139	0.0000	0.0000	0.0048	ng/dscm@7%O ₂
Total OCDDs Emission Rate	(E)	4.41E-09	0.00E+00	0.00E+00	1.47E-09	kg/hr
	(E _{pe})	9.71E-09	0.00E+00	0.00E+00	3.24E-09	lbs/hr
	(E _{pe})	4.26E-08	0.00E+00	0.00E+00	1.42E-08	tons/yr
	(E ^{'''})	2.46E-12	0.00E+00	0.00E+00	8.21E-13	lbs/MMBtu
Total PCDDs						
Stack Total PCDDs Concentration	(c _{pe})	0.3083	0.0651	0.0734	0.1489	ng
	(c _{pe})	0.0812	0.0184	0.0197	0.0404	ng/dscm@7%O ₂
Total PCDDs Emission Rate	(E)	2.58E-08	6.01E-09	6.38E-09	1.27E-08	kg/hr
	(E _{pe})	5.68E-08	1.33E-08	1.41E-08	2.81E-08	lbs/hr
	(E _{pe})	2.49E-07	5.81E-08	6.16E-08	1.23E-07	tons/yr
	(E ^{'''})	1.44E-11	3.27E-12	3.50E-12	7.06E-12	lbs/MMBtu

METHOD 23 (DIOXINS) - RESULTS					
--------------------------------------	--	--	--	--	--

Plant Name	Fibrominn Biomass Power Plant	Date	07/04/07		
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1		
Operator	TP/TKG	Stack Type	Circular		

Historical Data						
Run Number		OUT-Diox-1	OUT-Diox-2	OUT-Diox-3	Average	
Total TCDFs						
Stack Total TCDFs Concentration	(c _{pe})	0.1060	0.0155	0.0189	0.0468	ng
	(c _{pe})	0.0279	0.0044	0.0051	0.0127	ng/dscm@7%O ₂
Total TCDFs Emission Rate	(E)	8.86E-09	1.43E-09	1.64E-09	3.98E-09	kg/hr
	(E _{pe})	1.95E-08	3.16E-09	3.62E-09	8.77E-09	lbs/hr
	(E _{pe})	8.56E-08	1.38E-08	1.59E-08	3.84E-08	tons/yr
	(E ["])	4.95E-12	7.78E-13	9.00E-13	2.21E-12	lbs/MMBtu
Total PeCDFs						
Stack Total PeCDFs Concentration	(c _{pe})	0.0933	0.0301	0.0000	0.0411	ng
	(c _{pe})	0.0246	0.0085	0.0000	0.0112	ng/dscm@7%O ₂
Total PeCDFs Emission Rate	(E)	7.80E-09	2.78E-09	0.00E+00	3.53E-09	kg/hr
	(E _{pe})	1.72E-08	6.13E-09	0.00E+00	7.78E-09	lbs/hr
	(E _{pe})	7.53E-08	2.68E-08	0.00E+00	3.41E-08	tons/yr
	(E ["])	4.36E-12	1.51E-12	0.00E+00	1.96E-12	lbs/MMBtu
Total HxCDFs						
Stack Total HxCDFs Concentration	(c _{pe})	0.0769	0.0495	0.0387	0.0550	ng
	(c _{pe})	0.0202	0.0140	0.0104	0.0149	ng/dscm@7%O ₂
Total HxCDFs Emission Rate	(E)	6.43E-09	4.57E-09	3.36E-09	4.79E-09	kg/hr
	(E _{pe})	1.42E-08	1.01E-08	7.42E-09	1.06E-08	lbs/hr
	(E _{pe})	6.21E-08	4.42E-08	3.25E-08	4.62E-08	tons/yr
	(E ["])	3.59E-12	2.48E-12	1.84E-12	2.64E-12	lbs/MMBtu
Total HpCDFs						
Stack Total HpCDFs Concentration	(c _{pe})	0.0394	0.0943	0.0462	0.0600	ng
	(c _{pe})	0.0104	0.0267	0.0124	0.0163	ng/dscm@7%O ₂
Total HpCDFs Emission Rate	(E)	3.29E-09	8.71E-09	4.02E-09	5.34E-09	kg/hr
	(E _{pe})	7.26E-09	1.92E-08	8.85E-09	1.18E-08	lbs/hr
	(E _{pe})	3.18E-08	8.41E-08	3.88E-08	5.16E-08	tons/yr
	(E ["])	1.84E-12	4.73E-12	2.20E-12	2.92E-12	lbs/MMBtu
Total OCDFs						
Stack Total OCDFs Concentration	(c _{pe})	0.0041	0.1412	0.1002	0.0818	ng
	(c _{pe})	0.0011	0.0399	0.0269	0.0222	ng/dscm@7%O ₂
Total OCDFs Emission Rate	(E)	3.43E-10	1.30E-08	8.71E-09	7.36E-09	kg/hr
	(E _{pe})	7.56E-10	2.88E-08	1.92E-08	1.62E-08	lbs/hr
	(E _{pe})	3.31E-09	1.26E-07	8.41E-08	7.11E-08	tons/yr
	(E ["])	1.92E-13	7.09E-12	4.77E-12	4.02E-12	lbs/MMBtu
Total PCDFs						
Stack Total PCDFs Concentration	(c _{pe})	0.3197	0.3306	0.2040	0.2848	ng
	(c _{pe})	0.0842	0.0935	0.0547	0.0772	ng/dscm@7%O ₂
Total PCDFs Emission Rate	(E)	2.67E-08	3.05E-08	1.77E-08	2.50E-08	kg/hr
	(E _{pe})	5.89E-08	6.73E-08	3.91E-08	5.51E-08	lbs/hr
	(E _{pe})	2.58E-07	2.95E-07	1.71E-07	2.41E-07	tons/yr
	(E ["])	1.49E-11	1.66E-11	9.72E-12	1.38E-11	lbs/MMBtu

Note: Sample concentrations reported as zero for ND, the EMPC if present, or the measured amount.

Note: HpCDFs (0.0387 ng) and OCDFs (0.0688 ng) are blank corrected. All other blanks ND.

METHOD 23 (DIOXINS) SOURCE SAMPLING TITLE PAGE			
---	--	--	--

Source Information			
Plant Name	Fibrominn Biomass Power Plant		
Sampling Location	Stack Outlet		
Fuel or Source Type	Biomass		
Fuel F-Factor	1890	1890	1890

Test Information			
Starting Test Date			07/04/07
Project #			snc-07-benson.mn-comp#1
Operator			TP/TKG
Standard Temperature			68 oF
Standard Pressure			29.92 in Hg
Minimum Required Sample Vol.	indust. spec.		scf
Run Duration	chk Subpart	240	minutes
Unit Number			OUT-Diox
Load	% or w/DB	100%	
Base Run Number			OUT-Diox
Number of Ports Available			4
Number of Ports Used			4
Port Inside Diameter			5.00 in
Circular Stack			

Test Equipment Information				
Run	1	2	3	
Meter Box Number	from ACS	SAMP-CP-0017	SAMP-CP-0017	SAMP-CP-0017
Meter Calibration Factor	(Y)	1.005	1.005	1.005
Orifice Meter Coefficient	(ΔH@)	1.814	1.814	1.814 in H ₂ O
Pitot Identification	from ACS	SAMP-HP-0034	SAMP-HP-0033	SAMP-HP-0034
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840
Orsat Identification	from ACS	N/A	N/A	N/A
Nozzle Number	from ACS	#6B-2	#6B-2	#5B-2
Nozzle Diameter	(D _n)	0.184	0.175	0.184 in
Probe Number	from ACS	SAMP-HP-0034	SAMP-HP-0033	SAMP-HP-0034
Probe Length		60.00	60.00	60.00 in
(SS, Glass) Liner Material	from list	glass	glass	glass
Sample Case / Oven Number	from ACS	SAMP-BH-0004	SAMP-BH-0004	SAMP-BH-0004
Impinger Case Number	from ACS	SAMP-BC-0032	SAMP-BC-0031	SAMP-BC-0032
Acetone Lot Number	from bottle	C38B11	C38B11	C38B11

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	5634 S. 122nd East Ave., Suite F
City, State Country Zip	Tulsa, Oklahoma 74146
Project Manager	Thomas K. Graham
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

METHOD 1 - SAMPLE AND VELOCITY TRAVERSSES FOR CIRCULAR SOURCES

Plant Name	Fibrominn Biomass Power Plant		Date	07/04/07
Sampling Location	Stack Outlet		Project #	snc-07-benson.mn-comp#1
Operator	TP/TKG		# of Ports Available	4
Stack Type	Circular		# of Ports Used	4
Stack Size	Large		Port Inside Diameter	5.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	129.00	in
Distance to Near Wall of Stack	(L _{nw})	21.00	in
Diameter of Stack	(D)	108.00	in
Area of Stack	(A _s)	63.62	ft ²


Distance from Port to Disturbances			
Distance Upstream	(A)	2358.00	in
Diameters Upstream	(A _D)	21.83	diameters
Distance Downstream	(B)	910.00	in
Diameters Downstream	(B _D)	8.43	diameters

Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of Traverse Points	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²
Upstream Spec		12	12
Downstream Spec		12	12
Traverse Pts Required		12	12

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

² 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

Location of Traverse Points in Circular Stacks									
Traverse		(Fraction of Stack Dimension from Inside Wall to Traverse Point)							
Point		Number of Traverse Points Across the Stack							
Number	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6				.956	.806	.658	.356	.269	.220
7					.895	.774	.644	.366	.283
8						.968	.854	.750	.634
9							.918	.823	.731
10								.625	.382
11								.780	.704
12									.764



Number of Traverse Points Used			
4	Ports by	3	Across
12	Pts Used	12	Required
			Particulate Traverse

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
		in	in
1	0.04	4 6/8	25 6/8
2	0.15	15 6/8	36 6/8
3	0.30	32	53
4			
5			
6			
7			
8			
9			
10			
11			
12			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant Name	Fibrominn Biomass Power Plant			Date	06/30/07	
Sampling Location	Stack Outlet			Project #	snc-07-benson.mn-comp#1	
Operator	TP/TKG			# of Ports Used	4	
Stack Type	Circular			Pitot Identification	SAMP-HP-0034	
Pitot Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Pitot Coefficient (C_p)	0.84

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER								
---	--	--	--	--	--	--	--	--

Plant Name	Fibrominn Biomass Power Plant				Date	07/04/07		
Sampling Location	Stack Outlet				Project #	snc-07-benson.mn-comp#1		
Operator	TP/TKG				# of Ports Used	4		
Fuel Type	Biomass		Minimum Fuel Factor	1.000		Maximum Fuel Factor	1.120	
Orsat Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Orsat Identification	N/A		

Gas Analysis Data									
Run Number		OUT-Diox-1		Run Start Time		14:52	Run Stop Time		20:00
Sample Analysis Time	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N2)	Dry Molecular Weight (M_d)	Molecular Weight Deviation (ΔM_d)
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole
5:08	14.0	5.0	100.0	14.0	5.0	0.0	81.0	30.44	0.00
Results		Averages	14.0	5.0	0.0	81.0	30.44		
Average Calculated Fuel Factor		(F_o)avg	1.135			Molecular Wt Deviation < 0.3?			<input checked="" type="checkbox"/>
Average Excess Air		(%EA)avg	30.5	percent	Fuel Factor in Handbook Range?				<input checked="" type="checkbox"/>

Gas Analysis Data									
Run Number		OUT-Diox-2		Run Start Time		22:34	Run Stop Time		2:47
Sample Analysis Time	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N2)	Dry Molecular Weight (M_d)	Molecular Weight Deviation (ΔM_d)
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole
4:13	14.0	5.0	100.0	14.0	5.0	0.0	81.0	30.44	0.00
Results		Averages	14.0	5.0	0.0	81.0	30.44		
Average Calculated Fuel Factor		(F_o)avg	1.135			Molecular Wt Deviation < 0.3?			<input checked="" type="checkbox"/>
Average Excess Air		(%EA)avg	30.5	percent	Fuel Factor in Handbook Range?				<input checked="" type="checkbox"/>

Gas Analysis Data									
Run Number		OUT-Diox-3		Run Start Time		3:15	Run Stop Time		7:26
Sample Analysis Time	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N2)	Dry Molecular Weight (M_d)	Molecular Weight Deviation (ΔM_d)
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole
4:11	14.0	5.0	100.0	14.0	5.0	0.0	81.0	30.44	0.00
Results		Averages	14.0	5.0	0.0	81.0	30.44		
Average Calculated Fuel Factor		(F_o)avg	1.135			Molecular Wt Deviation < 0.3?			<input checked="" type="checkbox"/>
Average Excess Air		(%EA)avg	30.5	percent	Fuel Factor in Handbook Range?				<input checked="" type="checkbox"/>

Fuel Factor Fo		
Fuel Type	Minimum	Maximum
Coal, Anthracite	1.016	1.130
Coal, Lignite	1.016	1.130
Coal, Bituminous	1.083	1.230
Oil, Distillate	1.260	1.413
Oil, Residual	1.210	1.370
Gas, Natural	1.600	1.836
Gas, Propane	1.434	1.586
Gas, Butane	1.405	1.553
Biomass	1.000	1.120
Wood Bark	1.003	1.130

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES						
---	--	--	--	--	--	--

Plant Name	Fibrominn Biomass Power Plant			Date	07/04/07	
Sampling Location	Stack Outlet			Project #	snc-07-benson.mn-comp#1	
Operator	TP/TKG			# of Ports Used	4	
Stack Type	Circular			Meter Box Number	SAMP-CP-0017	
Train Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Meter Cal Factor (Y)	1.005

Moisture Content Data							
Run Number	OUT-Diox-1		Run Start Time	14:52	Run Stop Time		20:00
Total Meter Volume	(V _m)	121.408	dcf	Barometric Press.	(P _b)	29.53	in Hg
Avg Stack Temp	(t _s) _{avg}	298	oF	Stack Static Press.	(P _{static})	-0.23	in H ₂ O
Avg Meter Temp	(t _m) _{avg}	84	oF	Avg Orifice Press.	(ΔH) _{avg}	0.80	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents	g	g	g	g	g	g	g
Final Value	(V _f),(W _f)	1027.60	961.00	908.10	646.50	653.50	941.30
Initial Value	(V _i),(W _i)	622.40	731.30	774.00	641.70	651.40	903.40
Net Value	(V _n),(W _n)	405.2	229.7	134.1	4.8	2.1	37.9
Results							
Total Weight	(W _i)	813.80	g	Water Vol Weighed	(V _{wsg(std)})	38.371	scf
Std Meter Volume	(V _{m(std)})	117.170	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws(calc)})	24.7	%	Final Moisture Content	(B _{ws})	24.7	%

Moisture Content Data							
Run Number	OUT-Diox-2		Run Start Time	22:34	Run Stop Time		2:47
Total Meter Volume	(V _m)	112.508	dcf	Barometric Press.	(P _b)	29.52	in Hg
Avg Stack Temp	(t _s) _{avg}	300	oF	Stack Static Press.	(P _{static})	-0.23	in H ₂ O
Avg Meter Temp	(t _m) _{avg}	81	oF	Avg Orifice Press.	(ΔH) _{avg}	0.68	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents	g	g	g	g	g	g	g
Final Value	(V _f),(W _f)	1003.80	640.50	746.40	756.90	638.60	974.10
Initial Value	(V _i),(W _i)	362.90	638.40	747.60	757.50	637.30	931.40
Net Value	(V _n),(W _n)	640.9	2.1	-1.2	-0.6	1.3	42.7
Results							
Total Weight	(W _i)	685.20	g	Water Vol Weighed	(V _{wsg(std)})	32.307	scf
Std Meter Volume	(V _{m(std)})	109.163	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	22.8	%	Final Moisture Content	(B _{ws})	22.8	%

Moisture Content Data							
Run Number	OUT-Diox-3		Run Start Time	3:15	Run Stop Time		7:26
Total Meter Volume	(V _m)	118.508	dcf	Barometric Press.	(P _b)	29.52	in Hg
Avg Stack Temp	(t _s) _{avg}	298	oF	Stack Static Press.	(P _{static})	-0.23	in H ₂ O
Avg Meter Temp	(t _m) _{avg}	81	oF	Avg Orifice Press.	(ΔH) _{avg}	0.83	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents	g	g	g	g	g	g	g
Final Value	(V _f),(W _f)	1213.80	756.20	771.10	643.40	645.50	963.30
Initial Value	(V _i),(W _i)	503.30	733.60	772.10	641.40	645.50	917.30
Net Value	(V _n),(W _n)	710.5	22.6	-1.0	2.0	0.0	46.0
Results							
Total Weight	(W _i)	780.10	g	Water Vol Weighed	(V _{wsg(std)})	36.782	scf
Std Meter Volume	(V _{m(std)})	115.010	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	24.2	%	Final Moisture Content	(B _{ws})	24.2	%

METHOD 23 (DIOXINS) ISOKINETIC SAMPLING DATA

Plant Name	Fibrominn Biomass Power Plant				Date	7/4/2007				Ideal Nozzle Diameter and IsoKinetic Factor Setup									
Sampling Location	Stack Outlet				Project #	snc-07-benson.mn-comp#1				Pitot Tube Coefficient	(C _p)	0.84							
Operator	TP/TKG				Run #	OUT-Diox-1				Avg Stack Temp	(t _s)	298	oF						
# of Points Across	3				# of Ports Used	4				Avg Gas Meter Temp	(t _m)	84							
Leak Checks								Sampling Equipment								Pressures			
Train	Pre	0.01	ft3/min @	15	in Hg	Meter #	SAMP-CP-0017				Barometric Pressure	(P _b)	29.53	in Hg					
OK?	<input checked="" type="checkbox"/>	Post	0.0025	ft3/min @	15	in Hg	Meterbox Cal. Factor	(Y)	1.005		Stack Static Pressure	(P _{static})	-0.23	in H2O					
Pitot	Pre	5.1/5.5	in. H ₂ O for	15	sec	Nozzle #	#6B-2				Absolute Stack Pressure	(P _s)	29.51	in Hg					
OK?	<input checked="" type="checkbox"/>	Post	6.2/7.4	in. H ₂ O for	15	sec	Average Nozzle Diameter	(D _{na})	0.1843	in	Absolute Meter Pressure	(P _m)	29.66	in Hg					
Orsat	OK?	<input checked="" type="checkbox"/>				Rec. Nozzle Diameter	(D _{ri})	0.2371	in										
Nozzle Measurements								Probe # / Length	SAMP-HP-0034	/ 60	in					Filter #			
Pre	0.184	0.185	0.184	PASS	Liner Material	glass				Wash	H ₂ O	50.0	ml				OUT-Diox-1-F		
Post	0.184	0.185	0.184	PASS	Sample Case / Oven #	SAMP-BH-0004				Volume	MeCl	ml							
Run Time								Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8				
Start	14:52	End	20:00		Weights	Pre	622.40	731.30	774.00	641.70	651.40	903.40							
						Post	1027.60	961.00	908.10	646.50	653.50	941.30							
Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumulative Meter Volume (V _m) _{std}	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}
	min	hh:mm:ss	ft3	in H ₂ O	in H ₂ O	in H ₂ O	oF	oF	oF	oF	oF	oF	oF	in Hg	(in H ₂ O) ^{1/2}	ft/sec	scf	%	scf
A-1	0.0	0:00:00	357.914	1.700	0.962	0.960	297	259	254	68		79	79	12.5	1.30	90.64	11.799	113.0	141.586
A-2	20.0	0:20:00	370.028	1.500	0.849	0.850	295	257	246	68		80	80	10.0	1.22	85.03	21.850	108.1	131.102
A-3	40.0	0:40:00	380.370	1.600	0.905	0.910	295	254	250	65		82	82	10.0	1.26	87.82	31.765	104.9	127.058
B-1	60.0	1:00:00	390.607	1.100	0.622	0.620	295	253	247	68		83	83	8.5	1.05	72.81	40.703	105.2	122.108
B-2	80.0	1:20:00	399.860	1.400	0.792	0.790	297	248	248	62		84	84	10.0	1.18	82.25	50.243	104.3	120.583
B-3	100.0	1:40:00	409.750	1.200	0.679	0.680	299	238	246	67		86	86	9.5	1.10	76.25	59.014	103.7	118.029
C-1	120.0	2:00:00	418.879	1.500	0.849	0.850	295	249	234	68		86	86	10.5	1.22	85.03	68.777	103.1	117.903
C-2	140.0	2:20:00	429.035	1.500	0.849	0.850	299	252	245	67		87	87	10.5	1.22	85.25	78.707	102.9	118.061
C-3	160.0	2:40:00	439.385	1.400	0.792	0.790	300	249	247	68		87	87	10.5	1.18	82.42	88.278	102.7	117.704
D-1	180.0	3:00:00	449.362	1.300	0.735	0.740	306	234	223	68		84	84	10.0	1.14	79.73	97.444	102.5	116.933
D-2	200.0	3:20:00	458.865	1.400	0.792	0.790	298	255	242	65		83	83	10.5	1.18	82.31	107.214	102.6	116.961
D-3	220.0	3:40:00	468.975	1.400	0.792	0.790	299	252	247	63		84	84	10.5	1.18	82.36	117.195	102.8	117.195
Last Pt	240.0	4:00:00	479.322																
Final Val	240.0	4:00:00	479.322																
Average Values				1.42		0.80	298	250	244	66		84	84	1.19	82.66				
												84							

METHOD 23 (DIOXINS) ISOKINETIC SAMPLING DATA

Plant Name					Date					Ideal Nozzle Diameter and IsoKinetic Factor Setup																	
Fibrominn Biomass Power Plant					7/4/2007					Pitot Tube Coefficient		(C_p)		0.84													
Sampling Location					Project #					snc-07-benson.mn-comp#1		Avg Stack Temp		(t_s)		300		oF									
Operator					Run #					OUT-Diox-2		Avg Gas Meter Temp		(t_m)		81											
# of Points Across					# of Ports Used					DH @ 0.75 SCFM		$(\Delta H@)$		1.81		in H ₂ O											
3					4					Avg Pitot Tube Diff. Pressure		(Δp_{avg})		1.20		in H ₂ O											
Leak Checks					Sampling Equipment					Stack Moisture Content		(B_{ws})		22.84		%											
Train	Pre	0	ft3/min @	15	in Hg	Meter #		SAMP-CP-0017			Stack Dry Molecular Weight		(M_d)		30.44		lb/lb-mole										
	OK?	<input checked="" type="checkbox"/>	Post	0	ft3/min @	15	in Hg	Meterbox Cal. Factor		(Y) 1.005			Estimated Orifice Flow Rate		(Q_m)		0.506 acfm										
Pitot	Pre	4/4	in. H ₂ O for	15	sec	Nozzle #		#6B-2			DP to DH Isokinetic Factor		(K)		0.47												
	OK?	<input checked="" type="checkbox"/>	Post	4/4	in. H ₂ O for	15	sec	Average Nozzle Diameter		(D_{na}) 0.1747 in																	
Orsat	OK?	<input checked="" type="checkbox"/>	Pre	0.174	0.175	0.175	PASS	Rec. Nozzle Diameter		(D_{ri}) 0.1930 in																	
	Post	0.174	0.175	0.175	PASS	Probe # / Length		SAMP-HP-0033 / 60 in																			
Nozzle Measurements					Liner Material					glass		Pressures															
Pre	0.174	0.175	0.175	PASS	Sample Case / Oven #		SAMP-BH-0004			Barometric Pressure		(P_b)		29.52		in Hg											
Post	0.174	0.175	0.175	PASS	Impinger Case #		SAMP-BC-0031			Stack Static Pressure		(P_{static})		-0.23		in H ₂ O											
Run Time					Weights					Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8	Absolute Stack Pressure		(P_s)		29.50		in Hg			
Start	22:34	End	2:47		Pre	362.90	638.40	747.60	757.50	637.30	931.40					Wash	H_2O	50.0	ml	Absolute Meter Pressure		(P_m)		29.65		in Hg	
					Post	1003.80	640.50	746.40	756.90	638.60	974.10					Volume	MeCl		ml	Filter #		OUT-Diox-2-F					
Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V_m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH_d)	Actual Orifice ΔH (ΔH_a)	Stack Temp (t_s)	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t_{mi})	Meter Outlet Temp (t_{mo})	Pump Vacuum	Square Root ΔP $(\Delta p^{1/2})$	Local Stack Velocity (v_s)	Cumulative Meter Volume $(V_m)_{std}$	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume $(V_m)_{std}$								
	min	hh:mm:ss	ft3	in H ₂ O	in H ₂ O	in H ₂ O	oF	oF	oF	oF	oF	oF	oF	in Hg	(in H ₂ O) ^{1/2}	ft/sec	scf	%	scf								
A-1	0.0	0:00:00	480.392	1.500	0.706	0.710	295	238	246	67		79	79	5.0	1.22	84.69	9.355	104.0	112.258								
A-2	20.0	0:20:00	490.006	1.600	0.753	0.750	299	249	234	62		80	80	6.0	1.26	87.70	18.915	103.6	113.489								
A-3	40.0	0:40:00	499.848	1.500	0.706	0.710	300	252	245	55		80	80	5.0	1.22	84.97	28.275	103.9	113.099								
B-1	60.0	1:00:00	509.485	1.400	0.659	0.660	306	249	247	56		80	80	4.0	1.18	82.41	37.163	103.7	111.490								
B-2	80.0	1:20:00	518.638	1.400	0.659	0.660	298	248	248	57		80	80	4.0	1.18	81.98	45.991	103.3	110.378								
B-3	100.0	1:40:00	527.728	1.300	0.612	0.610	299	238	246	58		81	81	4.0	1.14	79.05	53.966	102.2	107.933								
C-1	120.0	2:00:00	535.957	1.400	0.659	0.660	295	249	234	61		81	81	4.0	1.18	81.82	62.939	102.3	107.895								
C-2	140.0	2:20:00	545.213	1.500	0.706	0.710	299	252	247	62		81	81	5.0	1.22	84.91	72.972	103.6	109.459								
C-3	160.0	2:40:00	555.563	1.400	0.659	0.660	300	249	247	60		81	81	4.0	1.18	82.09	81.868	103.5	109.157								
D-1	180.0	3:00:00	564.740	1.300	0.612	0.610	306	234	223	58		81	81	4.0	1.14	79.41	91.078	104.3	109.294								
D-2	200.0	3:20:00	574.243	1.500	0.706	0.710	298	255	242	58		81	81	5.0	1.22	84.86	99.134	103.1	108.147								
D-3	220.0	3:40:00	582.553	1.500	0.706	0.710	299	252	247	57		81	81	5.0	1.22	84.91	109.165	103.9	109.165								
Last Pt	240.0	4:00:00	592.900																								
Final Val	240.0	4:00:00	592.900																								
Average Values				1.44		0.68	300	247	242	59		81	81														
												81	81														

METHOD 23 (DIOXINS) ISOKINETIC SAMPLING DATA

Plant Name					Date					Ideal Nozzle Diameter and IsoKinetic Factor Setup																	
Fibrominn Biomass Power Plant					7/5/2007					Pitot Tube Coefficient		(C_p)		0.84													
Sampling Location					Project #					snc-07-benson.mn-comp#1		Avg Stack Temp		(t_s)		298		oF									
Operator					Run #					OUT-Diox-3		Avg Gas Meter Temp		(t_m)		81											
# of Points Across					# of Ports Used					DH @ 0.75 SCFM		$(\Delta H@)$		1.81		in H ₂ O											
3					4					Avg Pitot Tube Diff. Pressure		(ΔP_{avg})		1.21		in H ₂ O											
Leak Checks					Sampling Equipment					Stack Moisture Content		(B_{ws})		24.23		%											
Train	Pre	0	ft3/min @	15	in Hg	Meter #		SAMP-CP-0017			Stack Dry Molecular Weight		(M_d)		30.44		lb/lb-mole										
	OK?	<input checked="" type="checkbox"/>	Post	0	ft3/min @	15	in Hg	Meterbox Cal. Factor		(Y) 1.005			Estimated Orifice Flow Rate		(Q_m)		0.469 acfm										
Pitot	Pre	4/4	in. H ₂ O for	15	sec	Nozzle #		#5B-2			DP to DH Isokinetic Factor		(K)		0.57												
	OK?	<input checked="" type="checkbox"/>	Post	4/4	in. H ₂ O for	15	sec	Average Nozzle Diameter		(D_{na}) 0.1843 in																	
Orsat	OK?	<input checked="" type="checkbox"/>	Pre	0.184	0.185	0.184	PASS	Rec. Nozzle Diameter		(D_{ri}) 0.1868 in																	
	Post	0.184	0.185	0.184	PASS	Probe # / Length		SAMP-HP-0034 / 60 in																			
Nozzle Measurements					Liner Material					glass		Pressures															
Pre	0.184	0.185	0.184	PASS	Sample Case / Oven #		SAMP-BH-0004			Barometric Pressure		(P_b)		29.52		in Hg											
Post	0.184	0.185	0.184	PASS	Impinger Case #		SAMP-BC-0032			Stack Static Pressure		(P_{static})		-0.23		in H ₂ O											
Run Time					Weights					Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8	Absolute Stack Pressure		(P_s)		29.50		in Hg			
Start	3:15	End	7:26		Pre	503.30	733.60	772.10	641.40	645.50	917.30					Wash	H_2O	50.0	ml	Absolute Meter Pressure		(P_m)		29.65		in Hg	
					Post	1213.80	756.20	771.10	643.40	645.50	963.30					Volume	MeCl		ml	Filter #		OUT-Diox-3-F					
Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V_m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH_d)	Actual Orifice ΔH (ΔH_a)	Stack Temp (t_s)	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t_{mi})	Meter Outlet Temp (t_{mo})	Pump Vacuum	Square Root ΔP $(\Delta p^{1/2})$	Local Stack Velocity (v_s)	Cumulative Meter Volume $(V_m)_{std}$	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume $(V_m)_{std}$								
	min	hh:mm:ss	ft3	in H ₂ O	in H ₂ O	in H ₂ O	oF	oF	oF	oF	oF	oF	oF	in Hg	(in H ₂ O) ^{1/2}	ft/sec	scf	%	scf								
A-1	0.0	0:00:00	602.870	1.600	0.909	0.910	297	238	246	61		80	80	5.0	1.26	87.86	10.120	99.4	121.435								
A-2	20.0	0:20:00	613.284	1.400	0.795	0.800	299	249	234	59		80	80	4.0	1.18	82.29	19.681	100.0	118.084								
A-3	40.0	0:40:00	623.126	1.400	0.795	0.800	297	252	247	59		80	80	4.0	1.18	82.19	29.528	101.1	118.114								
B-1	60.0	1:00:00	633.263	1.300	0.738	0.740	299	249	247	58		81	81	4.0	1.14	79.30	38.402	100.2	115.207								
B-2	80.0	1:20:00	642.416	1.200	0.682	0.680	295	234	223	63		81	81	4.0	1.10	75.99	47.796	101.4	114.710								
B-3	100.0	1:40:00	652.106	1.600	0.909	0.910	299	255	242	64		81	81	5.0	1.26	87.98	56.553	99.0	113.106								
C-1	120.0	2:00:00	661.135	1.600	0.909	0.910	295	252	247	66		82	82	5.0	1.26	87.74	66.289	98.5	113.638								
C-2	140.0	2:20:00	671.191	1.500	0.852	0.850	299	252	245	60		80	80	5.0	1.22	85.18	76.248	98.9	114.371								
C-3	160.0	2:40:00	681.441	1.600	0.909	0.910	299	249	247	57		80	80	5.0	1.26	87.98	85.942	98.5	114.590								
D-1	180.0	3:00:00	691.418	1.400	0.795	0.800	295	234	223	55		80	80	4.0	1.18	82.08	95.174	98.3	114.209								
D-2	200.0	3:20:00	700.921	1.400	0.795	0.800	299	255	242	58		81	81	4.0	1.18	82.29	104.978	98.8	114.521								
D-3	220.0	3:40:00	711.031	1.500	0.852	0.850	299	252	247	58		81	81	5.0	1.22	85.18	115.012	99.1	115.012								
Last Pt	240.0	4:00:00	721.378																								
Final Val	240.0	4:00:00	721.378														Max Vac	5.0	Final Values	115.012	99.1						
Average Values				1.458		0.830	298	248	241	60		81	81				1.21	83.84									
												81															

METHOD 23 (DIOXINS) - SAMPLE RECOVERY AND INTEGRITY DATA SHEET					
---	--	--	--	--	--

Plant Name	Fibrominn Biomass Power Plant			Date	07/04/07
Sampling Location	Stack Outlet			Project #	snc-07-benson.mn-comp#1
Operator	TP/TKG			Acetone Lot Number	C38B11

Run History Data				
Run Number	OUT-Diox-1	OUT-Diox-2	OUT-Diox-3	
Run Start Time	14:52	22:34	3:15	(hh:mm)
Run Stop Time	20:00	2:47	7:26	(hh:mm)
Train Prepared By	KV/SK	KV/SK	KV/SK	
Train Recovered By	KV/SK	KV/SK	KV/SK	
Recovery Date	7/4/2007	7/4/2007	7/5/2007	(mm/dd/yy)
Relinquished By	TG	TG	TG	
Received By	PS	PS	PS	
Relinquished Date	7/7/2007	7/7/2007	7/7/2007	(mm/dd/yy)
Relinquished Time	19:00	19:00	19:00	(hh:mm)

Equipment Identification Numbers			
Filter	OUT-Diox-1-F	OUT-Diox-2-F	OUT-Diox-3-F
Acetone Wash	ok	ok	ok
Silica Gel	ok	ok	ok
Impinger Case	SAMP-BC-0032	SAMP-BC-0031	SAMP-BC-0032
Sample Box	SAMP-BH-0004	SAMP-BH-0004	SAMP-BH-0004
Oven	ok	ok	ok

Sample Blank Taken YES

Moisture Content Data					
Impingers 1, 2, 3, 4 and 5 - Liquid Volume					
Final Volume	(V _f)	4204.3	3793.0	4037.3	ml
Initial Volume	(V _i)	3427.0	3149.4	3301.8	ml
Net Volume	(V _n)	777.3	643.7	735.4	ml
Comments					
Impinger 6 - Silica Gel Weight					
Final Weight	(W _f)	941.3	974.1	963.3	g
Initial Weight	(W _i)	903.4	931.4	917.3	g
Net Weight	(W _n)	37.9	42.7	46.0	g
Comments					
Total Water Collected					
Total Volume	(V _{tc})	815.3	686.4	781.5	ml

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

L_{fw} = distance to far wall of stack (in.)

L_{nw} = distance to near wall of stack (in.) [reference]

D = diameter of stack (in.)

A_s = area of stack (ft^2)

B = distance downstream (in.)

B_D = stack diameters downstream (dia.)

A = distance upstream (in.)

A_D = stack diameters upstream (dia.)

Area of Stack (ft^2)

$$A_s (\text{ft}^2) = \pi \times \left(\frac{D}{2 \times 12} \right)^2$$

$$A_s (\text{ft}^2) = 3.14 \times \left(\frac{108.0 \text{ in.}}{2 \times 12 \text{ in./ft}} \right)^2 = 63.62 \text{ ft}^2$$

Diameter of Stack (in.)

$$D (\text{in.}) = L_{fw} - L_{nw}$$

$$D (\text{in.}) = 129 \text{ in.} - 21 \text{ in.} = 108 \text{ in.}$$

Stack Diameters Downstream

$$B_D (\text{dia.}) = \frac{B}{D}$$

$$B_D (\text{dia.}) = \frac{910 \text{ in.}}{108 \text{ in.}} = 8.43 \text{ diameters}$$



Stack Diameters Upstream

$$A_D (\text{dia.}) = \frac{A}{D}$$

$$A_D (\text{dia.}) = \frac{2358 \text{ in.}}{108 \text{ in.}} = 21.83 \text{ diameters}$$

Number of Traverse Points

Based on 40 CFR Part 60, Appendix A, Method 1, Section 2.2



Traverse Point Locations

Based on 40 CFR Part 60, Appendix A, Method 1, Section 2.3

Traverse Point	Location of Traverse Points in Circular Stacks (Fraction of Stack Dimension from Inside Wall to Traverse Point)											
	2	4	6	8	10	12	14	16	18	20	22	24
1	.146	.067	.044	.032	.026	.021	.018	.016	.014	.013	.011	.011
2	.854	.250	.146	.105	.082	.067	.057	.049	.044	.039	.035	.032
3	.750	.296	.194	.146	.118	.098	.085	.075	.067	.060	.056	.055
4	.933	.704	.323	.226	.177	.146	.125	.109	.097	.087	.079	.079
5	.854	.677	.342	.250	.201	.169	.146	.129	.116	.116	.105	.105
6	.956	.806	.658	.566	.466	.366	.283	.236	.204	.180	.161	.132
7	.896	.774	.644	.566	.486	.406	.326	.256	.204	.180	.161	.132
8	.968	.854	.750	.634	.535	.435	.336	.250	.218	.194	.174	.144
9	.918	.823	.731	.625	.525	.425	.325	.225	.180	.156	.132	.105
10	.974	.882	.799	.717	.618	.518	.418	.318	.218	.194	.174	.144
11	.933	.854	.760	.674	.574	.474	.374	.274	.180	.156	.132	.105
12	.979	.901	.831	.764	.694	.624	.554	.484	.384	.354	.323	.293
13	.943	.875	.812	.750	.688	.626	.564	.502	.440	.408	.376	.344
14	.962	.915	.854	.796	.736	.677	.617	.557	.497	.466	.435	.404
15	.951	.891	.835	.782	.728	.674	.617	.564	.511	.468	.435	.404
16	.964	.925	.871	.820	.770	.717	.664	.611	.564	.521	.488	.455
17	.956	.903	.854	.806	.758	.705	.652	.604	.557	.515	.482	.449
18	.968	.933	.884	.839	.791	.741	.688	.641	.591	.551	.518	.485
19	.967	.961	.913	.869	.821	.773	.725	.677	.631	.591	.551	.518
20	.987	.940	.895	.851	.806	.758	.711	.664	.621	.581	.548	.515
21		.965	.921	.877	.833	.785	.737	.691	.647	.607	.574	.541
22		.969	.945	.901	.857	.811	.763	.717	.673	.633	.599	.566
23		.968	.968	.924	.878	.832	.784	.738	.694	.654	.621	.588
24		.969	.969	.935	.891	.845	.797	.751	.707	.667	.634	.591

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2)

P_b = barometric pressure (in. Hg)
 P_{static} = static pressure (in. H₂O)
 P_s = absolute stack pressure (in. Hg)
%N₂ = nitrogen concentration (%)
%CO₂ = carbon dioxide concentration (%)
%O₂ = oxygen concentration (%)
%CO = carbon monoxide concentration (%)
MW = molecular weight (lb/lb-mole)
B_{ws} = stack moisture content (%)
M_d = stack dry molecular weight (lb/lb-mole)
M_s = stack wet molecular weight (lb/lb-mole)
T_{std} = standard temperature, 68°F, 528°R
P_{std} = standard pressure, 29.92 in. Hg
v_{sl} = local velocity (ft/sec)
v_s = average stack gas velocity (ft/sec)
Q_{sd} = average stack dry standard flow rate (dscf/hr)
Q_{aw} = average stack wet flow rate (ascf/min)

C_p = pitot tube coefficient
Δp = velocity head (in. H₂O)
A_s = area of stack (ft²)
N_a = null angle (deg.)
t_s = stack temperature (°F)
T_u = temperature offset, 460°R
K_p = pitot tube constant,
85.49 (ft/sec)((lb/lb-mole)(in. Hg)/((°R)(in. Hg)))^{1/2}

Absolute Stack Pressure (in. Hg)

$$P_s (\text{in. Hg}) = P_b + \frac{P_{\text{static}}}{13.6}$$

$$P_s (\text{in. Hg}) = 29.92 \text{ in. Hg} + \frac{-0.23 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 29.90 \text{ in. Hg}$$

Nitrogen Concentration (%)

$$\% N_2 = 100 - \% CO_2 - \% O_2 - \% CO$$

$$\% N_2 (\%) = 100 - 14.39 \% - 4.83 \% - 0 \% = 80.78 \%$$

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d (\text{lb / lb - mol}) = \sum \left(\frac{MW_{\text{comp}}}{100} \times \% \text{ component} \right)$$

$$M_d (\text{lb/lb-mol}) = \left[\frac{44 \text{ lb/lb-mol}}{100} \times 14.39 \% \right] + \left[\frac{32 \text{ lb/lb-mol}}{100} \times 4.83 \% \right] + \text{etc.} = \frac{30.5 \text{ lb}}{\text{lb-mol}}$$

Stack Wet Molecular Weight (lb/lb-mole)

$$M_s (\text{lb / lb - mol}) = \left[M_d \times \left(1 - \frac{B_{ws}}{100} \right) \right] + \left[MW_{H_2O} \times \frac{B_{ws}}{100} \right]$$

$$M_s (\text{lb/lb-mol}) = \left[\frac{30.5 \text{ lb}}{\text{lb-mol}} \times \left(1 - \frac{30 \%}{100} \right) \right] + \left[\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{30 \%}{100} \right] = \frac{26.75 \text{ lb}}{\text{lb-mol}}$$

Local Velocity (ft/sec)

$$v_{sl(l)} (\text{ft / sec}) = K_p \times C_p \times \sqrt{\Delta p} \times \sqrt{\frac{t_s + T_u}{P_s \times M_s}}$$

$$v_{sl} (\text{ft/sec}) = \frac{85.49 \text{ ft}}{\text{sec}} \left[\frac{(\text{lb/lb-mol})(\text{in. Hg})}{(\text{°R})(\text{in. H}_2\text{O})} \right]^{1/2} \times 0.84 \times \sqrt{1.00 \text{ in. H}_2\text{O}} \times \sqrt{\frac{291 + 460 \text{ °R}}{29.9 \text{ in. Hg} \times 26.75 \text{ lb/lb-mol}}} = \frac{69.59 \text{ ft}}{\text{sec}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2)

P_b = barometric pressure (in. Hg)
 P_{static} = static pressure (in. H₂O)
 P_s = absolute stack pressure (in. Hg)
%N₂ = nitrogen concentration (%)
%CO₂ = carbon dioxide concentration (%)
%O₂ = oxygen concentration (%)
%CO = carbon monoxide concentration (%)
MW = molecular weight (lb/lb-mole)
B_{ws} = stack moisture content (%)
M_d = stack dry molecular weight (lb/lb-mole)
M_s = stack wet molecular weight (lb/lb-mole)
K_p = pitot tube constant,

$85.49 \text{ (ft/sec)}(((\text{lb/lb-mole})(\text{in. Hg}))(({}^{\circ}\text{R})(\text{in. Hg})))^{1/2}$
T_{STD} = standard temperature, 68°F
P_{STD} = standard pressure, 29.92 in. Hg
v_{sl} = local velocity (ft/sec)
v_s = average stack gas velocity (ft/sec)
Q_{SD} = average stack dry standard flow rate (dscf/hr)
Q_{AW} = average stack wet flow rate (ascf/min)

C_p = pitot tube coefficient
Δp = velocity head (in. H₂O)
A_s = area of stack (ft²)
N_A = null angle (deg.)
t_s = stack temperature (°F)
T_u = temperature offset, 460°R

Average Stack Gas Velocity (ft/sec)

$$v_s (\text{ft/sec}) = K_p \times C_p \times \left(\sqrt{\Delta p} \right)_{\text{avg}} \times \sqrt{\frac{(t_s)_{\text{avg}} + T_u}{P_s \times M_s}}$$

$$v_{\text{sl}} (\text{ft/sec}) = \frac{85.49 \text{ ft}}{\text{sec}} \left[\frac{(\text{lb/lb-mol})(\text{in. Hg})}{({}^{\circ}\text{R})(\text{in. H}_2\text{O})} \right] \times 0.84 \times 1.05 \text{ in. H}_2\text{O}^{1/2} \times \sqrt{\frac{291 + 460 {}^{\circ}\text{R}}{29.9 \text{ in. Hg} \times 26.75 \text{ lb/lb-mol}}} = \frac{72.74 \text{ ft}}{\text{sec}}$$

Average Stack Dry Standard Flow Rate (dscfh)

$$Q_{sd} (\text{dscfh}) = \frac{60 \times 60 \times \left(1 - \frac{B_{ws}}{100} \right) \times v_s \times A_s \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sd} (\text{dscf/hr}) = \frac{3600 \text{ sec}}{\text{hr}} \times \left[1 - \frac{30.0 \%}{100} \right] \times \frac{72.74 \text{ ft}}{\text{sec}} \times 63.62 \text{ ft}^2 \times \frac{68 + 460 {}^{\circ}\text{R}}{291 + 460 {}^{\circ}\text{R}} \times \frac{29.90 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{8,192,279 \text{ dscf}}{\text{hr}}$$

Average Stack Wet Flow Rate (acf m)

$$Q_{aw} (\text{acf m}) = 60 \times v_s \times A_s$$

$$Q_{aw} (\text{acf/min}) = \frac{60 \text{ sec}}{\text{min}} \times \frac{72.74 \text{ ft}}{\text{sec}} \times 63.62 \text{ ft}^2 = \frac{277,654 \text{ acf}}{\text{min}}$$

Average Stack Wet Standard Flow Rate (ascfh)

$$Q_{sw} (\text{ascfh}) = \frac{60 \times Q_{aw} \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sw} (\text{ascf/hr}) = \frac{60 \text{ min}}{\text{hr}} \times \frac{277,654 \text{ acf}}{\text{min}} \times \frac{68 + 460 {}^{\circ}\text{R}}{291 + 460 {}^{\circ}\text{R}} \times \frac{29.90 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{11,703,256 \text{ ascf}}{\text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 3a)

$\%N_2$ = nitrogen concentration (%)
 $\%CO_2$ = carbon dioxide concentration (%)
 $\%O_2$ = oxygen concentration (%)
 $ppmCO$ = carbon monoxide concentration (ppm)
 $\%CO$ = carbon monoxide concentration (%)
 M_d = stack dry molecular weight (lb/lb-mole)
 $(F_o)_{avg}$ = average calculated fuel factor
 $(\%EA)_{avg}$ = average excess air (%)

Carbon Monoxide Concentration (%)

$$\% CO = \frac{ppmCO}{10,000}$$

$$\% CO (\%) = \frac{100.00 \text{ ppm}}{10,000 \text{ ppm/\%}} = 1.0E-02 \text{ \%}$$

Nitrogen Concentration (%)

$$\% N_2 = 100 - \% CO_2 - \% O_2 - \% CO$$

$$\% N_2 (\%) = 100 - 14 \% - 5 \% - 0.01 \% = 80.99 \%$$

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d (\text{lb / lb - mol}) = \sum \left(\frac{MW_{comp}}{100} \times \% \text{ component} \right)$$

$$M_d (\text{lb/lb-mol}) = \left[\frac{44 \text{ lb/lb-mol}}{100} \times 14 \% \right] + \left[\frac{32 \text{ lb/lb-mol}}{100} \times 5 \% \right] + \text{etc.} = \frac{30.44 \text{ lb}}{\text{lb-mol}}$$

Average Calculated Fuel Factor

$$F_{o(avg)} = \frac{|20.9 - (\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})|}{(\% CO_2)_{avg} + (\% CO)_{avg}}$$

$$F_{o(avg)} = \frac{20.9 \% - 5 \% - [0.5 \times 0.01 \%]}{14 \% + 0.01 \%} = 1.135$$

Average Excess Air (%)

$$\% EA_{avg} (\%) = \frac{100 \times [(\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})]}{(0.264 \times (N_2)_{avg}) - [(\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})]}$$

$$(\% EA)_{AVG} = \frac{100 \times \{ 5 \% - [0.5 \times 0.01 \%] \}}{\{ 0.264 \times 80.99 \% \} - \{ 5 \% - [0.5 \times 0.01 \%] \}} = 30.5 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4)

V_{mf} = final dry gas meter reading (dcf)

V_{mi} = initial dry gas meter reading (dcf)

V_m = total meter volume (dcf)

$t_{m(\text{avg})}$ = average meter temp. ($^{\circ}\text{F}$)

$t_{s(\text{avg})}$ = average stack temp. ($^{\circ}\text{F}$)

P_b = barometric pressure (in. Hg)

P_{static} = static pressure (in. H_2O)

ΔH_{avg} = average orifice pressure (in. H_2O)

V_i = initial impinger volume (ml)

V_f = final impinger volume (ml)

W_i = initial impinger weight (g)

W_f = final impinger weight (g)

V_t = total impinger volume (ml) = $\Sigma(V_f - V_i)$

W_t = total impinger weight (g) = $\Sigma(W_f - W_i)$

K_5 = water mass to std water vapor, 0.04715 ft^3/g

K_1 = standard volume correction, 17.65 $^{\circ}\text{R}/\text{in. Hg}$

Y = meter calibration factor

T_u = absolute temperature offset, 460 $^{\circ}\text{R}$

B_{ws} = final moisture content (%) = min of $B_{ws(\text{calc})}$ and $B_{ws(\text{svp})}$

Water Volume Weighed (dscf)

$$V_{wsg(\text{std})} (\text{dscf}) = W_t \times K_5$$

$$V_{wsg(\text{std})} = 813.80 \text{ g} \times 0.04715 \text{ ft}^3/\text{g} = 38.371 \text{ dscf}$$

Standard Meter Volume (dscf)

$$V_{m(\text{std})} (\text{dscf}) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{\text{avg}}}{13.6} \right)}{(t_m)_{\text{avg}} + T_u}$$

$$V_{m(\text{std})} = \frac{\frac{17.65 \text{ } ^{\circ}\text{R}}{\text{in. Hg}} \times 1.01 \times 121.408 \text{ dcf} \times \left[\frac{29.53 \text{ in. Hg} + \frac{0.80 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O / in. Hg}}}{84 \text{ } ^{\circ}\text{F} + 460 \text{ } ^{\circ}\text{R}} \right]}{= 117.17 \text{ dscf}}$$

Calculated Moisture Content (%)

$$B_{ws(\text{calc})} (\%) = 100 \times \frac{V_{wsg(\text{std})}}{V_{wsg(\text{std})} + V_{m(\text{std})}}$$

$$B_{ws(\text{calc})} = 100 \times \frac{38.37067 \text{ dscf}}{38.37067 \text{ dscf} + 117.1699 \text{ dscf}} = 24.66924 \%$$

Saturated Moisture Content (%)

$$B_{ws(\text{svp})} (\%) = 100 \times \frac{10 \frac{3144}{t_{s(\text{avg})} + 390.86}}{P_b + \frac{P_{\text{static}}}{13.6}} \leq 100$$

$$B_{ws(\text{svp})} = 100 \times \frac{10 \left[\frac{3144}{298 \text{ } ^{\circ}\text{F} + 390.86} - \frac{0.23 \text{ in. H}_2\text{O}}{29.53 \text{ in. Hg} + \frac{13.6 \text{ in. H}_2\text{O / in. Hg}}{}} \right]}{\leq 100 = 100 \%}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling)

C_n = nozzle diameter constant, 0.03575

Q_m = estimated orifice flow rate, 0.750 acfm

else V_m/Θ from previous run

V_m = total meter volume (acf)

Θ = total sampling time (min)

t_m = average gas meter temperature ($^{\circ}$ F)

T_u = absolute temperature offset, 460 $^{\circ}$ R

C_p = pitot tube coefficient

B_{wm} = meter moisture content (%)

B_{ws} = stack moisture content (%)

t_s = average stack temperature ($^{\circ}$ F)

M_d = stack dry molecular weight (lb/lb-mole)

P_s = absolute stack pressure (in. Hg)

C_k = K Factor Constant, 849.8

Δp_{avg} = average pitot tube differential pressure (in. H₂O)

$\Delta H@ = DH @ 0.75 \text{ SCFM (in. H}_2\text{O)}$

D_{na} = actual nozzle diameter (in.)

Δp = velocity head (in. H₂O)

Desired Orifice (in. H₂O)

$$\Delta H_d (\text{in. H}_2\text{O}) = K \times \Delta p$$

$$\Delta H_d (\text{in. H}_2\text{O}) = 0.57 \times 1.7 \text{ in. H}_2\text{O} = 0.962 \text{ in. H}_2\text{O}$$

Absolute Meter Pressure (in. Hg)

$$P_m (\text{in. Hg}) = P_b + \frac{\Delta H @}{13.6}$$

$$P_m (\text{in. Hg}) = 29.53 \text{ in. Hg} + \frac{1.81 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 29.66 \text{ in. Hg}$$

Recommended Nozzle Diameter (in.)

$$D_{ni} (\text{in.}) = \sqrt{\frac{C_n \times Q_m \times P_m}{(t_m + T_u) \times C_p} \times \left(\frac{1 - \frac{B_{wm}}{100}}{1 - \frac{B_{ws}}{100}} \right) \times \sqrt{(t_s + T_u) \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + (18 \times B_{ws})}{P_s \times \Delta p_{avg}} \right]}}$$

$$D_{ni} (\text{in.}) = \frac{0.03575 \text{ (lb-mole}^{\circ}\text{R} \cdot \text{in. H}_2\text{O})^{1/2} \cdot \text{min} \cdot \text{in.}^2}{\text{acf} \cdot \text{in. Hg}^{3/4} \cdot \text{lb}^{1/2}} \times \frac{0.75 \text{ acf} \times 29.66 \text{ in. Hg}}{\left(84 \text{ }^{\circ}\text{F} + 460 \text{ }^{\circ}\text{R} \right) \times 0.84} \times \frac{\left(\begin{array}{c} 0.0 \\ 1 - \frac{0.0}{100} \end{array} \right) \times \left(\begin{array}{c} 24.7 \\ 1 - \frac{24.7}{100} \end{array} \right)}{\left(\begin{array}{c} 1 - \frac{24.7}{100} \\ 1 - \frac{0.0}{100} \end{array} \right)} \times$$

$$\sqrt{\left(298 \text{ }^{\circ}\text{F} + 460 \text{ }^{\circ}\text{R} \right) \times \frac{\frac{30.44 \text{ lb}}{\text{lb-mole}} \times \left(1 - \frac{24.7}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times 24.7 \% \right)}{29.51 \text{ in. Hg} \times 1.19 \text{ in. H}_2\text{O}}} = 0.237 \text{ in.}$$

DP to DH Isokinetic Factor

$$K = C_k \times C_p^2 \times \Delta H @ \times D_{na}^4 \times \left[\frac{M_d \times \left(1 - \frac{B_{wm}}{100} \right) + (18 \times \frac{B_{wm}}{100})}{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + (18 \times \frac{B_{ws}}{100})} \right] \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{wm}}{100}} \right)^2 \times \left(\frac{t_m + T_u}{t_s + T_u} \right) \times \frac{P_s}{P_m}$$

$$K = \frac{849.8}{\text{in. H}_2\text{O} \cdot \text{in.}^4} \times 0.84^2 \times 1.81 \text{ in. H}_2\text{O} \times 0.184333^4 \times \left(\frac{24.7}{100} \right)^2 \times \left(\frac{84 \text{ }^{\circ}\text{F} + 460 \text{ }^{\circ}\text{R}}{298 \text{ }^{\circ}\text{F} + 460 \text{ }^{\circ}\text{R}} \right) \times$$

$$\left(\frac{\frac{30.44 \text{ lb}}{\text{lb/mole}} \times \left(1 - \frac{0.0}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0.0}{100} \right)}{\frac{30.44 \text{ lb}}{\text{lb/mole}} \times \left(1 - \frac{24.7}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{24.7}{100} \right)} \right) \times \frac{29.51 \text{ in. Hg}}{29.66 \text{ in. Hg}} = 0.57$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 23)

Total Dioxin and Furan Emissions Rate (ng/dscm@7%O₂)

$$E(\text{ng} / \text{dscm} @ \%) = C_{PE} \times \left(\frac{20.9\% - 7\%}{20.9\% - CRA_{O_2}} \right)$$

$$E (\text{ng/dscm@7\%O}_2) = \frac{0.489 \text{ ng}}{114 \text{ dscf}} \times \frac{35.3 \text{ ft}^3}{\text{m}^3} \times \left[\frac{20.9\% - 7\%}{20.9\% - 5\%} \right] = \frac{0.133 \text{ ng}}{\text{dscm}} @ 7\%O_2$$

Total Dioxin and Furan Emissions Rate (lb/hr)

$$E' (\text{lb} / \text{hr}) = \frac{M_n \times Q_{sd}}{V_{m(std)}} \times \frac{60}{453.592 \times 1000}$$

$$E' (\text{lb/hr}) = \frac{\text{g}}{1000 \text{ mg}} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{\text{lb}}{453.592 \text{ g}} \times \frac{4.89E-07 \text{ mg}}{113.79 \text{ dscf}} \times \frac{165,998 \text{ dscf}}{\text{min}} = \frac{9.39E-08 \text{ lb}}{\text{hr}}$$

Total Dioxin and Furan Emissions Rate (ton/yr)

$$E'' (\text{ton} / \text{yr}) = E' \times \frac{8760}{2000}$$

$$E'' (\text{ton/yr}) = \frac{\text{ton}}{2000 \text{ lb}} \times \frac{8760 \text{ hr}}{\text{yr}} \times \frac{9.39E-08 \text{ lb}}{\text{hr}} = \frac{4.11E-07 \text{ ton}}{\text{yr}}$$

Total Dioxin and Furan Emissions Rate (lb/MMBtu)

$$E''' (\text{lb} / \text{MMBtu}) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \% O_2} \right)$$

$$E''' (\text{lb/MMBtu}) = \frac{\text{g}}{1000 \text{ mg}} \times \frac{\text{lb}}{453.592 \text{ g}} \times \frac{4.89E-07 \text{ mg}}{113.79 \text{ dscf}} \times \frac{1,890 \text{ dscf}}{\text{MMBtu}} \times \left[\frac{20.9}{20.9 - 5.0\%} \right] = \frac{2.35E-11 \text{ lb}}{\text{MMBtu}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.



Table of Contents

Section 1: Cover Letter/Case Narrative

Contains the Table of Contents, a project narrative, the client and PAL project identifiers, the number and type of samples, the methodology used to process the samples, and a summary table of sample results. A listing of current certifications by state, a table of abbreviations and qualifiers and the Toxic Equivalent Factors (TEF) are also supplied.

Section 2: Project Information

Contains the chain-of-custody(s), internal chain-of-custody(s) if applicable, sample login summary, sample receipt checklist, and any other project/client specific information.

Section 3: Sample Analytical Results

Contains results for client samples. Sample results include two pages of summarized analytical data and the associated raw data. The raw data includes a quantitation report from the instrumentation used that lists, ion areas, ratios, retention times, concentrations, and signal-to-noise ratios. It also has the selected ion current profiles (SICPs) for all homolog groups and any manual integrations.

Section 4: Quality Control Analytical Results

Contains results for each analytical workgroup associated with the submitted samples. A workgroup consists of the Lab Method Blank (LMB) and the Ongoing Precision and Recovery sample (OPR). All sample preparation data, including dry weight determinations, extraction logs, clean-up logs and observation notes are also documented. Any other supporting QC data will be documented here upon client request.

Section 5: Initial Calibration

Contains a table summarizing calibration data such as relative response factors, concentrations, and percent relative standard deviation. This section also contains related daily instrument QC information: GC performance data, mass resolution check, windows defining mix, and SICPs for all homolog groups and any manual integrations as well as the injection prep and instrument run logs.

Section 6: Continuing Calibration Data

Contains all daily instrument quality control information. This includes mass resolution checks, a table summarizing the window defining peaks, SICPs for the first and last eluters for each homolog group, SICPs documenting GC performance, a summary quantitation report showing RRFs for the Ccal and Ical, and SICPs for all homolog groups and any manual integrations, injection prep and instrumentation runlogs.



List of Qualifiers: Dioxin's

B Analyte was detected in the Lab Method Blank at a level above the Reporting Limit.

EDL "Estimated Detection Limit"

EMPC "Estimated Maximum Possible Concentration"

ppt Parts-per-trillion (pg/g; ng/L)

V Recovery is below quality control limit. The data has been validated based on a favorable signal-to-noise and detection limit.

Outside quality control limits

* Indicates that the ion-ratio fails high or low; analyte reported as an EMPC

An average uncertainty of 30% can be routinely achieved as concluded from the evaluation of HRGC-HRMS standard operating procedures. The following flags warn the data user of situations where the uncertainty may be greater than stated.

A Amount detected is less than the Lower Method Calibration Limit.

J Amount detected is between the Method Detection Limit and the Lower Calibration Limit.

O The recovery of this analyte in the OPR is above the Method QC Limits and the reported concentration in the sample may be biased high.

E Amount detected is greater than the Upper Calibration Limit.

S The amount of analyte present has saturated the detector. This situation results in an underestimation of the affected analyte(s).

Q Indicates the presence of a quantitative interference. This situation may result in an underestimation of the affected analyte(s).

I Indicates the presence of a qualitative interference that could cause a false positive or an overestimation of the affected analyte(s).

DPE Indicates the presence of a peak in the polychlorinated diphenylether channel that could cause a false positive or an overestimation of the affected analyte(s).



Toxic Equivalency Factors

<u>Analyte</u>	<u>WHO*</u> 1998	<u>WHO*</u> 2005	<u>International-89</u>	<u>MADEP*</u>
2,3,7,8-TCDD	1	1	1	1
1,2,3,7,8-PeCDD	1	1	0.5	0.5
1,2,3,4,7,8-HxCDD	0.1	0.1	0.1	0.1
1,2,3,6,7,8-HxCDD	0.1	0.1	0.1	0.1
1,2,3,7,8,9-HxCDD	0.1	0.1	0.1	0.1
1,2,3,4,6,7,8-HpCDD	0.01	0.01	0.01	0.1
OCDD	0.0001	0.0003	0.001	0.001
2,3,7,8-TCDF	0.1	0.1	0.1	0.1
1,2,3,7,8-PeCDF	0.05	0.03	0.05	0.5
2,3,4,7,8-PeCDF	0.5	0.3	0.5	0.5
1,2,3,4,7,8-HxCDF	0.1	0.1	0.1	0.1
1,2,3,6,7,8-HxCDF	0.1	0.1	0.1	0.1
2,3,4,6,7,8-HxCDF	0.1	0.1	0.1	0.1
1,2,3,7,8,9-HxCDF	0.1	0.1	0.1	0.1
1,2,3,4,6,7,8-HpCDF	0.01	0.01	0.01	0.1
1,2,3,4,7,8,9-HpCDF	0.01	0.01	0.01	0.1
OCDF	0.0001	0.0003	0.001	0.001

* World Health Organization

* Massachusetts Department of Environmental Protection

Air Hygiene International, Inc.
 5634 S. 122nd East Ave, Suite F
 Tulsa, Oklahoma 74146
 (888) 461-8778
www.airhygiene.com



SAMPLE DESCRIPTION AND CHAIN OF CUSTODY RECORD

6431-15

Project Number:

snc-07-benson.mn-comp#1

Person Taking Samples:

TP/TKG

Sample Number	Location	Reference Method 23 (Dioxins)			Analysis Method
		Date	Volume	RM 23	
OUT-Diox-1-F	Outlet-Dioxins-Run 1-Filter	7/4/2007	N/A	X	
OUT-Diox-2-F	Outlet-Dioxins-Run 2-Filter	7/4/2007	N/A	X	
OUT-Diox-3-F	Outlet-Dioxins-Run 3-Filter	7/4/2007	N/A	X	
OUT-Diox-1-#2	Outlet-Dioxins-Run 1-Acetone&MeCl Rinse	7/4/2007	as marked	X	
OUT-Diox-2-#2	Outlet-Dioxins-Run 2-Acetone&MeCl Rinse	7/4/2007	as marked	X	
OUT-Diox-1-#2	Outlet-Dioxins-Run 3-Acetone&MeCl Rinse	7/4/2007	as marked	X	
OUT-Diox-1-#3	Outlet-Dioxins-Run 1-Toluene Rinse	7/4/2007	as marked	X	
OUT-Diox-2-#3	Outlet-Dioxins-Run 2-Toluene Rinse	7/4/2007	as marked	X	
OUT-Diox-3-#3	Outlet-Dioxins-Run 3-Toluene Rinse	7/4/2007	as marked	X	
OUT-Diox-1-XAD	Outlet-Dioxins-Run 1-Cartridge	7/4/2007	as marked	X	
OUT-Diox-2-XAD	Outlet-Dioxins-Run 2-Cartridge	7/4/2007	as marked	X	
OUT-Diox-3-XAD	Outlet-Dioxins-Run 3-Cartridge	7/4/2007	as marked	X	
A-B	Acetone Blank	7/4/2007	as marked	X	
MC-B	MeCl Blank	7/4/2007	as marked	X	
T-B	Toluene Blank	7/4/2007	as marked	X	
X-B	XAD Blank	7/4/2007	X		

snc-07-benson.mn-comp#1-Outlet-Dioxins

John K. Schaefer 07/07/07 19:00 *John K. Schaefer* 07/07/07 19:00
Authenticated by: (Signature) _____ Date: _____ Time: _____
John K. Schaefer 07/07/07 1000 *John K. Schaefer* 07/07/07 1000
Authenticated by: (Signature) _____ Date: _____ Time: _____

SGS Environmental Services, Inc.

Cust Proj ID: snc-07-benson.mn-comp#1
 Client Name: Air-Hygiene

G431-15

Due Date: 2007-08-01 17:00:00
 Login Date: 2007-07-11 15:26:35

Sample ID	Cust Sample ID	PRJ	Date Collected	Date Received	Date Due	Matrix	LOC	Report	Analysis	Status
G431-15-1 A	OUT-Diox-1-F	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	Filter	W2	Full	M23 Ext Prep	LG::REVW
G431-15-2 A	OUT-Diox-1-#2	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	DCP/Acetone Rinse	W2	Full	M23 Ext Prep	LG::REVW
G431-15-3 A	OUT-Diox-1-#3	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	Toluene Rinse	W2	Full	M23 Ext Prep	LG::REVW
G431-15-4 A	OUT-Diox-1-XAD	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	XAD	W2	Full	M23 Ext Prep	LG::REVW
G431-15-5 A	OUT-Diox-1	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	Air	W2	Full	M23 Ext Prep	LG::REVW
G431-15-6 A	OUT-Diox-2-F	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	Filter	W2	Full	M23 Ext Prep	LG::REVW
G431-15-7 A	OUT-Diox-2-#2	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	DCP/Acetone Rinse	W2	Full	M23 Ext Prep	LG::REVW
G431-15-8 A	OUT-Diox-2-#3	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	Toluene Rinse	W2	Full	M23 Ext Prep	LG::REVW
G431-15-9 A	OUT-Diox-2-XAD	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	XAD	W2	Full	M23 Ext Prep	LG::REVW
G431-15-10 A	OUT-Diox-2	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	Air	W2	Full	M23 Ext Prep	LG::REVW
G431-15-11 A	OUT-Diox-3-F	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	Filter	W2	Full	M23 Ext Prep	LG::REVW
G431-15-12 A	OUT-Diox-3-#2	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	DCP/Acetone Rinse	W2	Full	M23 Ext Prep	LG::REVW
G431-15-13 A	OUT-Diox-3-#3	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	Toluene Rinse	W2	Full	M23 Ext Prep	LG::REVW
G431-15-14 A	OUT-Diox-3-XAD	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	XAD	W2	Full	M23 Ext Prep	LG::REVW
G431-15-15 A	OUT-Diox-3	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	Air	W2	Full	M23 Ext Prep	LG::REVW
G431-15-16 A	A-B	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	DCP/Acetone Rinse	W2	Full	M23 Ext Prep	LG::REVW
G431-15-17 A	MC-B	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	DCP/Acetone Rinse	W2	Full	M23 Ext Prep	LG::REVW
G431-15-18 A	T-B	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	XAD	W2	Full	M23 Ext Prep	LG::REVW
G431-15-19 A	X-B	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01	Air	W2	Full	M23	LG::REVW
G431-15-20 A	B	STD	2007-07-04 00:00:00	2007-07-11	2007-08-01					

Sample Receipt Checklist (SRC)
SGS Environmental Services

Client: Air Hygiene

Lab Proj. ID: G431-15

Client Proj. ID: snc-07-benson.mn-comp#1

1. Shipped Notes: _____
 Hand Delivered

2. Proper, full, and complete documentation
(unique sample identification on durable label with indelible ink,
location of collection, date/time of collection, collector's name,
preservation type, sample type (method/matrix))
 Acceptable documentation (but, incomplete)
 Unacceptable documentation

3. Custody Tape on Container Notes: _____
 X No Custody Tape

4. Samples Intact* Notes: _____
(are in appropriate container, are not damaged, and do not show signs
of contamination)
 Samples Broken / Leaking
 VOA Vials Checked for Air Bubbles

5. Chilled on Receipt* Actual Temp.(s) in °C: 4.2 4.8
 Ambient on Receipt
 Walk-in on Ice; Coming down to temp.
 Received out of temperature protocol

6. Sufficient Sample Submitted Notes: _____
 Insufficient Sample Submitted

7. Samples Preserved Correctly*
(see preservative checklist where applicable)
 Improper Preservative(s)
 None recommended (N/A)

8. Received Within Holding Time Notes: _____
 Not Received Within Holding Time
 N/A

9. No Discrepancies Noted Notes: _____
 Discrepancies Noted

Comments: Received three unmarked XADs, one designated as Blank.
Received several unmarked filters, not used.
No COC with samples, COC received by fax.

* = Rejection of sample is required when not marked; Contact client services immediately for a resolution.

Inspected and Logged in by: [Signature]
Date / Time: Wed-7/11/07 15:47

DC27.040307.4

Method M23
OUT-Diox-1
Air Hygiene

Analytical Data Summary Sheet

Analyte	Amount (ng)	EDL (ng)	EMPC (ng)	RT (min.)	Ratio	Qualifier
2,3,7,8-TCDD	ND	0.00449				
1,2,3,7,8-PeCDD	ND	0.00500				
1,2,3,4,7,8-HxCDD	ND	0.00658				
1,2,3,6,7,8-HxCDD	ND	0.00670				
1,2,3,7,8,9-HxCDD	ND	0.00680				
1,2,3,4,6,7,8-HpCDD	0.0240			40:37	1.05	
OCDD	EMPC	0.0216	0.0527	45:07	1.11	*
2,3,7,8-TCDF	0.00804			31:09	0.82	A
1,2,3,7,8-PeCDF	0.00608			33:37	1.75	A
2,3,4,7,8-PeCDF	EMPC	0.00500	0.00852	34:15	1.07	*
1,2,3,4,7,8-HxCDF	0.0202			36:22	1.28	A
1,2,3,6,7,8-HxCDF	EMPC	0.00500	0.00780	36:28	1.47	*
2,3,4,6,7,8-HxCDF	EMPC	0.00500	0.00604	37:00	0.88	*
1,2,3,7,8,9-HxCDF	ND	0.00510				
1,2,3,4,6,7,8-HpCDF	0.0781			39:21	0.92	A
1,2,3,4,7,8,9-HpCDF	ND	0.00798				
OCDF	0.0729			45:25	0.82	A
Total TCDDs	0.0264					
Total PeCDDs	0.110		0.124			
Total HxCDDs	0.0614					
Total HpCDDs	0.0240		0.0438			
Total TCDFs	0.0978		0.106			
Total PeCDFs	0.0608		0.0933			
Total HxCDFs	0.0600		0.0769			
Total HpCDFs	0.0781					
WHO-2005 TEQ (ND=0)	0.00405		0.00801			
WHO-2005 TEQ (ND=½)	0.0113		0.0140			

Client Information		Sample Information	
Project Name:	snc-07-benson.mn-comp#1	Matrix:	Air
Sample ID:	OUT-Diox-1	Weight / Volume:	1 train
Laboratory Information		Solids / Lipids:	NA %
Project ID:	G431-15	Original pH :	NA
Sample ID:	G431-15-5B	Batch ID:	WG14370
Collection Date/Time:	07/04/07	Instrument:	HRMS1
Receipt Date/Time:	07/11/07 10:00	Filename:	a24jul07a-5
Extraction Date:	07/22/07	Retchk:	a24jul07a-1
Analysis Date/Time:	07/24/07 19:19	Begin ConCal:	a24jul07a-1
		End ConCal:	a24jul07a-11
		Initial Cal:	m8290-071007a

<i>Method M23</i> OUT-Diox-1 Air Hygiene

Labeled Standard	Expected Amount (ng)	Measured Amount (ng)	Percent Recovery (%)	RT (min.)	Ratio	Qualifier
Extraction Standards						
13C12-2,3,7,8-TCDD	4.0	3.57	89.3	31:39	0.79	
13C12-1,2,3,7,8-PeCDD	4.0	3.32	83.0	34:25	1.57	
13C12-1,2,3,6,7,8-HxCDD	4.0	4.00	99.9	37:10	1.24	
13C12-1,2,3,4,6,7,8-HpCDD	4.0	3.76	94.1	40:37	1.06	
13C12-OCDD	8.0	5.82	72.8	45:06	0.90	
13C12-2,3,7,8-TCDF	4.0	3.97	99.3	31:07	0.79	
13C12-1,2,3,7,8-PeCDF	4.0	3.10	77.6	33:37	1.58	
13C12-1,2,3,6,7,8-HxCDF	4.0	3.53	88.2	36:28	0.52	
13C12-1,2,3,4,6,7,8-HpCDF	4.0	3.32	83.0	39:19	0.45	
Sampling Standards						
37Cl4-2,3,7,8-TCDD	4.0	4.29	107	31:40	-	
13C12-2,3,4,7,8-PeCDF	4.0	3.87	96.8	34:15	1.57	
13C12-1,2,3,4,7,8-HxCDD	4.0	3.92	98.0	37:07	1.26	
13C12-1,2,3,4,7,8-HxCDF	4.0	4.07	102	36:22	0.52	
13C12-1,2,3,4,7,8,9-HpCDF	4.0	3.52	88.1	41:19	0.45	
Injection Standards						
13C12-1,2,3,4-TCDD	2.0	-	-	31:15	0.79	
13C12-1,2,3,7,8,9-HxCDD	2.0	-	-	37:27	1.26	

Client Information		Sample Information	
Project Name:	snc-07-benson.mn-comp#1	Matrix:	Air
Sample ID:	OUT-Diox-1	Weight / Volume:	1 train
Laboratory Information		Solids / Lipids:	NA %
Project ID:	G431-15	Original pH :	NA
Sample ID:	G431-15-5B	Batch ID:	WG14370
Collection Date/Time:	07/04/07	Instrument:	HRMS1
Receipt Date/Time:	07/11/07	Filename:	a24jul07a-5
Extraction Date:	07/22/07	Retchk:	a24jul07a-1
Analysis Date/Time:	07/24/07	Begin ConCal:	a24jul07a-1
		End ConCal:	a24jul07a-11
		Initial Cal:	m8290-071007a

Form Version: [8290_DB_2.14] Report

Analyzed by: HMP
Date: 26/07/07Reviewed by: GW
Date: 27/07/07

Filename : a24;jul07a
 Sample : 5 Acquired : 24-JUL-07 19:19:49
 Processed : 25-JUL-07 08:10:45
 Sample ID : G431-15-5B
 Cal Table : m8290-071007a
 Results Table : m8290-072407a

(1.131)(1)
(1.087)(1.073)
 = 0.98381

Comments ;
 Ent; Name; Resp; Ion 1; Ion 2; RA;?; RT; Conc; EDL; S/N1;?; S/N2;?;M; Signal1; Noise 1; Signal2; Noise 2;
 1 ; 2,3,7,8-TCD; *; *; *; *; NotFnd; *; 0.2243; *; n;n; *; 4.90e+03; *; 5.19e+03;
 2 ; 1,2,3,7,8-PecD; *; *; *; *; NotFnd; *; 0.2287; *; n;n; *; 5.74e+03; *; 3.91e+03;
 3 ; 1,2,3,4,7,8-HxCDD; *; *; *; *; NotFnd; *; 0.291; *; n;n; *; 4.9e+03; *; 5.18e+03;
 4 ; 1,2,3,6,7,8-HxCDD; *; *; *; *; NotFnd; *; 0.3350; *; n;n; *; 4.92e+03; *; 5.18e+03;
 5 ; 1,2,3,7,8-HxCDD; *; *; *; *; NotFnd; *; 0.3399; *; n;n; *; 4.92e+03; *; 5.18e+03;
 6 ; 1,2,3,4,6,7,8-HpCDD; 1.31e+05; 6.42e+04; 1.05;Y; 40:38; 0.599; 0.6946; 4;Y; 4;Y; 1.89e+04; 5.26e+03; 1.77e+04; 4.18e+03;
 7 ; OCDD; 1.90e+05; 1.00e+05; 8.99e+04; 1.11;N; 45:07; 1.317; 1.0805; 3;Y; 3;Y; 1.41e+04; 4.39e+03; 1.53e+04; 4.75e+03;
 8 ; 2,3,7,8-TCDF; 1.19e+05; 5.36e+04; 6.54e+04; 0.82;Y; 31:09; 0.201; 0.2018; 2;n; 2;n; 0.2018;
 9 ; 1,2,3,7,8-PecDF; 6.51e+04; 4.14e+04; 2.37e+04; 1.75;Y; 33:38; 0.152; 0.1635; 3;Y; 2;n;Y; 1.69e+04; 5.29e+03; 9.55e+03; 5.09e+03;
 10 ; 2,3,4,7,8-PecDF; 9.45e+04; 4.88e+04; 4.57e+04; 1.07;N; 34:15; 0.213; 0.1577; 3;Y; 3;n;Y; 1.33e+04; 5.29e+03; 1.52e+04; 5.09e+03;
 11 ; 1,2,3,4,7,8-HxCDF; 1.85e+05; 1.04e+05; 8.12e+04; 1.28;Y; 36:23; 0.505; 0.2204; 8;Y; 7;Y;Y; 3.86e+04; 4.72e+03; 3.22e+04; 4.93e+03;
 12 ; 1,2,3,6,7,8-HxCDF; 7.55e+04; 4.49e+04; 3.06e+04; 1.47;N; 36:29; 0.195; 0.2076; 3;Y; 3;n;n; 1.54e+04; 4.72e+03; 1.24e+04; 4.93e+03;
 13 ; 2,3,6,7,8-HxCDF; 5.56e+04; 2.60e+04; 2.95e+04; 0.88;N; 37:00; 0.151; 0.2189; 2;n; 2;n;Y; 9.76e+03; 4.72e+03; 1.29e+04; 4.93e+03;
 14 ; 1,2,3,7,8,9-HxCDF; *; *; *; *; NotFnd; *; 0.2550; *; n;n; *; 4.72e+03; *; 4.93e+03;
 15 ; 1,2,3,4,6,7,8-HpCDF; 6.35e+05; 3.04e+05; 3.31e+05; 0.92;Y; 39:21; 1.952; 0.3146; 19;Y; 19;Y; 9.20e+04; 4.96e+03; 9.69e+04; 5.02e+03;
 16 ; 1,2,3,4,7,8,9-HpCDF; *; *; *; *; NotFnd; *; 0.3991; *; n;n; *; 4.96e+03; *; 5.02e+03;
 17 ; OCDF; 3.19e+05; 1.44e+05; 1.76e+05; 0.82;Y; 45:25; 1.823; 0.8306; 6;Y; 7;Y;Y; 2.73e+04; 4.21e+03; 3.16e+04; 4.32e+03;
 Extraction Standards
 18 ; 13C-2,3,7,8-TCD; 3.64e+07; 1.60e+07; 2.04e+07; 0.79;Y; 31:39; 89.332; 0.1941; 1400;Y; 1770;Y; 6.03e+06; 4.31e+03; 7.91e+06; 4.47e+03;
 19 ; 13C-1,2,3,7,8-PecDF; 2.79e+07; 1.71e+07; 1.08e+07; 1.57;Y; 34:26; 82.966; 0.2265; 1746;Y; 1120;Y; 7.42e+06; 4.25e+03; 4.72e+06; 4.22e+03;
 20 ; 13C-1,2,3,6,7,8-HxCDD; 2.82e+07; 1.57e+07; 1.26e+07; 1.24;Y; 37:11; 99.931; 0.2897; 1170;Y; 905;Y; 5.14e+06; 4.39e+03; 5.21e+06; 4.65e+03;
 21 ; 13C-1,2,3,4,6,7,8-HpCDD; 2.08e+07; 1.07e+07; 1.01e+07; 1.06;Y; 40:38; 94.107; 0.3262; 830;Y; 577;Y; 2.77e+06; 3.34e+03; 2.64e+06; 4.58e+03;
 22 ; 13C-OCDD; 2.66e+07; 1.27e+07; 1.41e+07; 0.90;Y; 45:06; 145.612; 0.4394; 563;Y; 504;Y; 2.21e+06; 3.92e+03; 2.50e+06; 4.97e+03;
 23 ; 13C-2,3,7,8-TCDF; 5.27e+07; 2.32e+07; 2.95e+07; 0.79;Y; 31:07; 99.338; 0.1746; 1430;Y; 1692;Y; 7.19e+06; 5.03e+03; 8.91e+06; 5.26e+03;
 24 ; 13C-1,2,3,7,8-PecDF; 4.29e+07; 2.63e+07; 1.66e+07; 1.58;Y; 33:38; 77.608; 0.2060; 2057;Y; 1064;Y; 1.15e+07; 5.60e+03; 5.749e+06; 7.04e+03;
 25 ; 13C-1,2,3,6,7,8-HxCDF; 3.35e+07; 1.15e+07; 2.19e+07; 0.52;Y; 36:29; 88.219; 0.2519; 775;Y; 1525;Y; 7.18e+06; 5.39e+03; 7.81e+06; 5.12e+03;
 26 ; 13C-1,2,3,4,6,7,8-HpCDF; 2.34e+07; 7.27e+06; 1.61e+07; 0.45;Y; 39:20; 83.023; 0.3027; 436;Y; 1048;Y; 2.14e+06; 4.90e+03; 4.70e+06; 4.48e+03;
 Injection Standards
 27 ; 13C-1,2,3,4-TCD; 3.85e+07; 1.70e+07; 2.15e+07; 0.79;Y; 31:15; 47.284; -; 1323;Y; 1594;Y; 5.70e+06; 4.31e+03; 7.12e+06; 4.47e+03;
 28 ; 13C-1,2,3,7,8-HxCDD; 2.72e+07; 1.52e+07; 1.20e+07; 1.26;Y; 37:27; 38.289; -; 1154;Y; 845;Y; 5.07e+06; 4.39e+03; 3.93e+06; 4.65e+03;
 Cleanup Standards
 29 ; 37Cl-2,3,7,8-TCD; 3.98e+07; 3.98e+07; 3.98e+07; 3.98e+07; 3.98e+07; 31:40; 95.821; 0.0920; 3806;Y; -;-;n; 1.62e+07; 4.25e+03; -;
 30 ; 13C-2,3,4,7,8-PecDF; 4.08e+07; 2.49e+07; 1.58e+07; 1.58e+07; 1.57;Y; 34:15; 75.200; 0.2099; 1919;Y; 953;Y; 7.04e+03; 5.60e+03; 6.71e+06; 7.04e+03;
 31 ; 13C-1,2,3,4,7,8-HxCDD; 2.64e+07; 1.47e+07; 1.17e+07; 1.26;Y; 37:07; 97.893; 0.3049; 1128;Y; 861;Y; 4.95e+06; 4.39e+03; 4.00e+06; 4.65e+03;
 32 ; 13C-1,2,3,4,7,8-HxCDF; 3.06e+07; 1.05e+07; 2.02e+07; 0.52;Y; 36:23; 89.705; 0.2800; 699;Y; 1400;Y; 3.77e+06; 5.39e+03; 7.17e+06; 5.12e+03;
 33 ; 13C-1,2,3,4,7,8-HpCDF; 1.84e+07; 5.69e+06; 1.27e+07; 0.45;Y; 41:20; 73.105; 0.3394; 277;Y; 673;Y; 1.36e+06; 4.90e+03; 3.01e+06; 4.48e+03;
 Sampling Standards
 34 ; 37Cl-2,3,7,8-TCD; 3.98e+07; 3.98e+07; 3.98e+07; 3.98e+07; 3.98e+07; 31:40; 107.273; 0.0897; 3806;Y; -;-;n; 1.62e+07; 4.25e+03; -;
 35 ; 13C-2,3,4,7,8-PecDF; 4.08e+07; 2.49e+07; 1.58e+07; 1.57;Y; 34:15; 96.848; 0.2025; 1919;Y; 953;Y; 7.04e+03; 5.60e+03; 6.71e+06; 7.04e+03;
 36 ; 13C-1,2,3,4,7,8-HxCDD; 2.64e+07; 1.47e+07; 1.17e+07; 1.26;Y; 37:07; 97.959; 0.3052; 1128;Y; 861;Y; 4.95e+06; 4.39e+03; 4.00e+06; 4.65e+03;
 37 ; 13C-1,2,3,4,7,8-HpCDF; 3.06e+07; 1.05e+07; 2.02e+07; 0.52;Y; 36:23; 101.034; 0.2915; 699;Y; 1400;Y; 3.77e+06; 5.39e+03; 7.17e+06; 5.12e+03;
 38 ; 13C-1,2,3,4,7,8-HpCDF; 1.84e+07; 5.69e+06; 1.27e+07; 0.45;Y; 41:20; 88.058; 0.4611; 277;Y; 673;Y; 1.36e+06; 4.90e+03; 3.01e+06; 4.48e+03

Totals Report

SGS Environmental Services, INC. Thu Jul 26 14:46:08 EDT 2007
File name: a22jul07a-5 Acquired: 2007-07-24 19:19:49
Results: Processed: 2007-07-25 08:10:45
Sample Text: G431-15-B

Total Tetra-Dioxins																
Ent	Type	Name	AreaSum	lon1Area	lon2Area	IR	?	RT	Conc	EDL	Status	Height1	SN1	Height2	Noise2	SN2 Mod
		2378-TCDD	0.00E+00	0.00E+00	0.00E+00	N	0	0.00	0	0.2243	S2N	0.00E+00	4900	0	0.00E+00	5190
		Tetradioxins	2.33E+05	9.95E+04	1.34E+05	0.74	Y	28:40	0.661	0.2243	OK	2.03E+04	4904	4.1	2.73E+04	5192
		Tetradioxins	1.35E+04	6.70E+03	6.80E+03	0.99	N	28:46	0.038	0.2243	S2N	3.40E+03	4904	0.7	3.35E+03	5192
		Tetradioxins	4.38E+04	9.65E+03	3.42E+04	0.28	N	31:31	0.124	0.2243	S2N	4.43E+03	4904	0.9	7.47E+03	5192

Total Tetra+Urans				SN2 Mod			
Ent	Type	Name	AreaSum	SN1	Height2	Noise2	SN2
Tetrafurans	lon1Area	lon2Area	1.17E+05	1.65E-05	0.71	Y	28.57
Tetrafurans	lon1Area	lon2Area	4.35E+04	5.48E-04	0.79	Y	27.55
Tetrafurans	lon1Area	lon2Area	1.09E+05	1.36E-05	0.8	Y	28.18
Tetrafurans	lon1Area	lon2Area	8.21E+04	3.44E-04	0.72	Y	28.30
Tetrafurans	lon1Area	lon2Area	7.37E+04	6.78E-04	0.9	N	28.37
Tetrafurans	lon1Area	lon2Area	2.97E+04	4.75E-04	0.63	N	29.42
Tetrafurans	lon1Area	lon2Area	2.47E+05	1.14E-05	0.85	Y	29.54
Tetrafurans	lon1Area	lon2Area	1.39E+05	6.54E-04	0.89	N	30.22
Tetrafurans	lon1Area	lon2Area	9.04E+04	4.38E-04	0.94	N	30.37
Tetrafurans	lon1Area	lon2Area	4.06E+04	3.44E-04	1.18	N	30.48
Tetrafurans	lon1Area	lon2Area	8.08E+04	3.28E-04	0.68	Y	30.58
Tetrafurans	lon1Area	lon2Area	2.91E+04	3.37E-04	0.86	Y	31.04
2378-TCDF	lon1Area	lon2Area	5.36E+04	6.54E-04	0.82	Y	31.09
Tetrafurans	lon1Area	lon2Area	1.16E+05	4.36E-04	7.20E-04	0.61	N
					0.196		31:22
					0.2108		EMPC
					1.65E+04		6432
					2.48E+04		5712

Total Penta-Furans

Totals Report

	SN2 Mod													
Name	AreaSum	Ion1Area	Ion2Area	IR	R	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2
Pentafurans	1.82E-05	7.76E+04	1.04E+05	0.74	N	32:13	0.417	0.1507	EMPC	3.24E+04	5052	6.4	5.11E+04	4692
Pentafurans	1.50E-05	9.08E+04	5.93E+04	1.53	Y	32:58	0.344	0.1605	OK	2.73E+04	5288	5.2	1.93E+04	5092
Pentafurans	1.46E-05	1.04E+05	1.41	Y	33:04	0.573	0.1605	OK	4.68E+04	5288	8.9	2.95E+04	5092	
Pentafurans	1.16E-05	5.60E+04	5.05E+05	2.9	N	33:24	0.265	0.1605	S2N	1.96E+04	5288	3.7	1.15E+04	5092
Pentafurans	3.21E-04	1.83E+04	1.38E+04	1.33	Y	33:31	0.074	0.1605	S2N	8.99E+03	5288	1.7	8.54E+03	5092
Pentafurans	6.51E-04	4.14E+04	2.37E+04	1.75	Y	33:37	0.152	0.1635	S2N	1.69E+04	5290	3	9.55E+03	5090
Pentafurans	8.08E-04	4.08E+04	3.33E+04	1.43	Y	33:46	0.185	0.1605	S2N	1.60E+04	5288	3	1.01E+04	5092
Pentafurans	8.04E-04	4.08E+04	3.96E+04	1.03	N	34:10	0.184	0.1605	EMPC	1.85E+04	5288	3.5	1.61E+04	5092
Pentafurans	9.45E-04	4.88E+04	4.57E+04	1.07	N	34:15	0.213	0.1577	EMPC	1.83E+04	5290	3	1.52E+04	5090

Total Hexa-Dioxins										SN2 Mod							
Ent	Type	Name	AreaSum	IonArea	Ion2Area	IR	?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	
		123789-HxCDD	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.3389	S2N	0.00E+00	4920	0	0.00E+00	5180	0
		123678-HxCDD	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.3345	S2N	0.00E+00	4920	0	0.00E+00	5180	0
		123478-HxCDD	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.3291	S2N	0.00E+00	4920	0	0.00E+00	5180	0
		Hexadioxins	3.48E+04	2.28E+04	1.20E+04	1.9	Y	35.51	0.127	0.3346	S2N	8.75E-13	4920	1.8	5.81E-13	5176	1.1
		Hexadioxins	3.27E+05	1.84E+05	1.42E+05	1.29	Y	36.19	1.191	0.3346	S2N	6.75E-04	4920	12.7	4.57E-04	5176	8.8
		Hexadioxins	9.40E+04	5.80E+04	3.59E+04	1.62	N	36.31	0.343	0.3346	S2N	1.46E-04	4920	3	1.11E-04	5176	2.2


Total Hexa+Urans										SN2 Mod				
Ent	Type	Name	AreaSum	lon1Area	lon2Area	IR	?	RT	Conc	EDL	Status	Height1	Height2	Noise2
123780-H+CDF	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.255	S2N	0.00E+00	4720	0	0.00E+00	4930
Hexafurans	8.17E+04	4.02E+04	4.16E+04	0.97	N	35.25	0.227	0.2242	EMPC	1.42E+04	4720	3	1.61E+04	4928
Hexafurans	2.48E+05	1.40E+05	1.08E+05	1.3	Y	35.31	0.689	0.2242	OK	5.30E+04	4720	11.2	3.76E+04	4928
Hexafurans	5.60E+04	3.41E+04	2.18E+04	1.56	N	36.18	0.156	0.2242	OK	1.22E+04	4720	26	8.08E+04	4928
123478-H+CDF	1.85E+05	1.04E+05	8.12E+04	1.28	Y	36.22	0.505	0.2204	OK	3.86E+04	4720	8	3.22E+04	4930
123678-H+CDF	7.55E+04	4.49E+04	3.06E+04	1.47	N	36.28	0.195	0.2076	EMPC	1.54E+04	4720	3	1.24E+04	4930
234678-H+CDF	5.56E+04	2.60E+04	2.95E+04	0.88	N	37.00	0.151	0.2189	NS2N	9.76E-03	4720	2	1.29E+04	4930

Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status	Height1	SN1	Height2	Noise2	SN2 Mod
Hepatidoxins	1.09E+05	6.18E+04	4.71E+04	1.31	N	39:40	0.496	0.4946	EMPC	1.61E+04	5284	3.1	1.33E+04	3.2
1234678-HpCDD	1.31E+05	6.73E+04	6.42E+04	1.05	Y	40:37	0.598	0.4946	OK	1.89E+04	5250	4	1.77E+04	4
									EDL					
									Total Hepta-Dioxins	0.4946				1
									Total EMPC Hepta-Dioxins	0.599			Peaks	2
										1.095			Peaks	

Totals Report

Page 3 of 3

File: A24JUL07A #1-399 Acq: 24-JUL-2007 19:19:49 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#5 Text: G431-15-5B Exp: EXP_DB5MS
 319.8965 S:5 BSUB (256,15,-3.0) PKD (3,2,1,0.018,4904.0,5.00%,F,T)
 100% 28:41



File:A24JUL07A #1-184 Acq:24-JUL-2007 19:49 GC EI+ Voltage SIR Autospec-Ultimate

Sample#5 Text:G431-15-5B

Exp:EXP_DB5MS


PKD(3,2,1,0.01%,5.00%,F,T)


355.8546 S:5 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5.00%,F,T)
100%

357.8517 S:5 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5.00%,F,T)
100%

367.8949 S:5 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5.00%,F,T)
100%

369.8919 S:5 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5.00%,F,T)
100%







File:A24JUL07A #1-293 Acq:24-JUL-2007 19:49 GC EI+ Voltage SIR Autospec-Ultimate

Sample#5 Text:G431-15-5B Exp:EXP_DB5MS


423.7767 S:5 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5264.0,5.00%,F,T)
100%




425.7737 S:5 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4180.0,5.00%,F,T)
100%





435.8169 S:5 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,33336.0,5.00%,F,T)
100%





437.8140 S:5 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4580.0,5.00%,F,T)
100%




430.9728 S:5 F:4 SMO(1,3) PKD(3,2,1,100.00%,0,0,5.00%,F,T)
100%





FILE:A24JUL07A #1-293 Accq:24-JUL-2007 19:19:49 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#5 Text:G431-15-5B
 423.7767 S:5 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5264.0,5.00%,F,T)
 100%







File:A24JUL07A #1-367 Accq:24-JUL-2007 19:19:49 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#5 Text:G431-15-5B
 Exp:EXP_DB5MS
 457.7377 S:5 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4388.0,5.00%,F,T)
 100%












File:A24JUL07A #1-184 Accq:24-JUL-2007 19:19:49 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#5 Text:G431-15-5B Exp:EXP_DB5MS
 339.8597 S:5 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.018,5288.0,5.00%,F,T)
 33:04 100%






File:A24JUL07A #1-252 Accq:24-JUL-2007 19:19:49 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#5 Text:G431-15-5B
 373.8207 S:5 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4720.0,5.00%,F,T)
 35:33 100%




File:A24JUL07A #1-293 Acq:24-JUL-2007 19:19:49 GC EI+ Voltage SIR Autospec-Ultimate

Sample#5 Text:G431-15-5B





407.7818 S:5 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4964.0,5.00%,F,T)
100%



417.8253 S:5 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4904.0,5.00%,F,T)
39:20



479.7165 S:5 F:4 BSUB(128,15,-3.0) PKD(3,2,1,100.008,4400.0,5.00%,F,T)
39:32




File:A24JUL07A #1-367 Acq:24-JUL-2007 19:49 GC EI+ Voltage SIR Autospec-UltimaE

Sample#5 Text:G431-15-5B


Exp:EXP_DB5MS

441.7427 S:5 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4208.0,5.00%,F,T)


100%




100%



100%




100%




File:A24JUL07A #1-367 Acq:24-JUL-2007 19:19:49 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#5 Text:G431-15-5B Exp:EXP_DB5MS
 441.7427 S:5 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4208.0,5.00%,F,T)
 100%
 90
 80
 70
 60
 50
 40
 30
 20
 10

OCD




Manual Int
24Jul07 HMP



File:A24JUL07A #1-399 Acq:24-JUL-2007 19:19:49 GC EI+ Voltage SIR Autospec-UltimaE

Sample#5 Text:G431-15-5B Exp:EXP_DB5MS

341.8568 S:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5052.0,5.00%,F,T)



Method M23

OUT-Diox-2

Air Hygiene

Analytical Data Summary Sheet

Analyte	Amount (ng)	EDL (ng)	EMPC (ng)	RT (min.)	Ratio	Qualifier
2,3,7,8-TCDD	ND	0.00359				
1,2,3,7,8-PeCDD	ND	0.00500				
1,2,3,4,7,8-HxCDD	ND	0.00658				
1,2,3,6,7,8-HxCDD	ND	0.00670				
1,2,3,7,8,9-HxCDD	ND	0.00680				
1,2,3,4,6,7,8-HpCDD	ND	0.0103				
OCDD	ND	0.0191				
2,3,7,8-TCDF	ND	0.00386				
1,2,3,7,8-PeCDF	ND	0.00500				
2,3,4,7,8-PeCDF	EMPC	0.00500	0.00488	34:15	0.98	*
1,2,3,4,7,8-HxCDF	0.0189			36:24	1.35	A
1,2,3,6,7,8-HxCDF	0.00760			36:28	1.14	A
2,3,4,6,7,8-HxCDF	ND	0.00500				
1,2,3,7,8,9-HxCDF	ND	0.00566				
1,2,3,4,6,7,8-HpCDF	0.133			39:21	1.05	
1,2,3,4,7,8,9-HpCDF	ND	0.00846				
OCDF	0.210			45:25	0.82	
Total TCDDs	ND	0.00359	0.0140			
Total PeCDDs	0.0245					
Total HxCDDs	0.0266					
Total HpCDDs	ND	0.0103				
Total TCDFs	0.0155					
Total PeCDFs	0.0237		0.0301			
Total HxCDFs	0.0495					
Total HpCDFs	0.133					
WHO-2005 TEQ (ND=0)	0.00404		0.00551			
WHO-2005 TEQ (ND=½)	0.0110		0.0117			

Client Information		Sample Information	
Project Name:	snc-07-benson.mn-comp#1	Matrix:	Air
Sample ID:	OUT-Diox-2	Weight / Volume:	1 train
Laboratory Information		Solids / Lipids:	NA %
Project ID:	G431-15	Original pH :	NA
Sample ID:	G431-15-10B	Batch ID:	WG14370
Collection Date/Time:	07/04/07	Instrument:	HRMS1
Receipt Date/Time:	07/11/07	Filename:	a24jul07a-6
Extraction Date:	07/22/07	Retchk:	a24jul07a-1
Analysis Date/Time:	07/24/07	Begin ConCal:	a24jul07a-1
		End ConCal:	a24jul07a-11
		Initial Cal:	m8290-071007a

Method M23
OUT-Diox-2
Air Hygiene

Labeled Standard	Expected Amount (ng)	Measured Amount (ng)	Percent Recovery (%)	RT (min.)	Ratio	Qualifier
Extraction Standards						
13C12-2,3,7,8-TCDD	4.0	3.65	91.2	31:39	0.79	
13C12-1,2,3,7,8-PeCDD	4.0	3.19	79.8	34:25	1.56	
13C12-1,2,3,6,7,8-HxCDD	4.0	3.93	98.2	37:12	1.27	
13C12-1,2,3,4,6,7,8-HpCDD	4.0	3.72	93.0	40:37	1.05	
13C12-OCDD	8.0	6.02	75.2	45:06	0.89	
13C12-2,3,7,8-TCDF	4.0	3.97	99.2	31:07	0.78	
13C12-1,2,3,7,8-PeCDF	4.0	3.08	77.1	33:37	1.59	
13C12-1,2,3,6,7,8-HxCDF	4.0	3.52	88.1	36:28	0.53	
13C12-1,2,3,4,6,7,8-HpCDF	4.0	3.41	85.2	39:19	0.45	
Sampling Standards						
37Cl4-2,3,7,8-TCDD	4.0	4.25	106	31:40	-	
13C12-2,3,4,7,8-PeCDF	4.0	4.03	101	34:13	1.58	
13C12-1,2,3,4,7,8-HxCDD	4.0	3.96	99.0	37:06	1.26	
13C12-1,2,3,4,7,8-HxCDF	4.0	4.11	103	36:22	0.52	
13C12-1,2,3,4,7,8,9-HpCDF	4.0	3.91	97.7	41:19	0.45	
Injection Standards						
13C12-1,2,3,4-TCDD	2.0	-	-	31:15	0.78	
13C12-1,2,3,7,8,9-HxCDD	2.0	-	-	37:27	1.25	

Client Information		Sample Information	
Project Name:	snc-07-benson.mn-comp#1	Matrix:	Air
Sample ID:	OUT-Diox-2	Weight / Volume:	1 train
Laboratory Information		Solids / Lipids:	NA %
Project ID:	G431-15	Original pH :	NA
Sample ID:	G431-15-10B	Batch ID:	WG14370
Collection Date/Time:	07/04/07	Instrument:	HRMS1
Receipt Date/Time:	07/11/07	Filename:	a24jul07a-6
Extraction Date:	07/22/07	Retchk:	a24jul07a-1
Analysis Date/Time:	07/24/07	Begin ConCal:	a24jul07a-1
		End ConCal:	a24jul07a-11
		Initial Cal:	m8290-071007a

Analyzed by: HMP
Date: 26Jul07

Reviewed by: CLO
Date: 7/24/07

Report Version:[8290_DB_2.14]Report

; *8290*

; Inst: HRMS1

~~(1,817) (18)~~
~~(25.0) (1,3018)~~
= 0.30410

Filename : a24ju107a
 Sample : 6
 Acquired : 24-JUL-07 20:08:10
 Processed : 25-JUL-07 08:11:06
 Sample ID : G431-15-10B
 Cal Table : m8290-071007a
 Results Table : m8290-072407a

Comments ;	Name;	Resp;	Ion 1;	Ion 2;	RA;?;	RT;	Conc;	EDL;	S/N1;?;	S/N2;?;M;	Signal1; Noise 1;	Signal2; Noise 2
Brt;		*	*	*	*	*	*	*	0.1797;	*;n;	*;4.56e+03;	*;3.84e-03
1 ;	2,3,7,8-TCDDF;	8.27e+04;	5.01e+04;	3.26e+04;	1.54;n;	31:08;	0.147;	0.1928;	2;n;	2;n;y;1.34e+04;5.93e+03;1.14e+04;5.75e+03		
2 ;	1,2,3,7,8-PeCDF;	*	*	*	*	*	*	*	0.1945;	*;n;	*;5.26e+03;	*;6.62e+03
3 ;	2,3,4,7,8-PeCDF;	5.12e+04;	2.53e+04;	2.59e+04;	0.98;n;	34:15;	0.122;	0.1875;	2;n;	2;n;y;1.17e+04;5.26e+03;1.02e+04;6.62e+03		
4 ;	1,2,3,4,7,8-HxCDD;	*	*	*	*	*	*	*	0.3290;	*;n;	*;4.90e+03;	*;4.30e+03
5 ;	1,2,3,6,7,8-HxCDD;	*	*	*	*	*	*	*	0.3348;	*;n;	*;4.90e+03;	*;4.30e+03
6 ;	1,2,3,7,8,9-HxCDD;	*	*	*	*	*	*	*	0.3398;	*;n;	*;4.90e+03;	*;4.22e+03
7 ;	1,2,3,4,6,7,8-HxCDD;	*	*	*	*	*	*	*	0.5141;	*;n;	*;4.81e+03;	*;4.48e+03
	OCDD;	*	*	*	*	*	*	*	0.9538;	*;n;	*;3.63e+03;	
8 ;	2,3,7,8-TCDF;	8.27e+04;	5.01e+04;	3.26e+04;	1.54;n;	31:08;	0.147;	0.1928;	2;n;	2;n;y;1.34e+04;5.93e+03;1.14e+04;5.75e+03		
9 ;	1,2,3,7,8-PeCDF;	*	*	*	*	*	*	*	0.1945;	*;n;	*;5.26e+03;	*;6.62e+03
10 ;	2,3,4,7,8-HxCDD;	5.12e+04;	2.53e+04;	2.59e+04;	0.98;n;	34:15;	0.122;	0.1875;	2;n;	2;n;y;1.17e+04;5.26e+03;1.02e+04;6.62e+03		
11 ;	1,2,3,4,7,8-HxCDD;	1.60e+05;	9.20e+04;	6.79e+04;	1.35;y;	36:24;	0.473;	0.2448;	7;y;	4;Y;Y;3.26e+04;4.48e+03;2.24e+04;5.02e+03		
12 ;	1,2,3,6,7,8-HxCDD;	6.81e+04;	3.63e+04;	3.18e+04;	1.14;Y;	36:29;	0.190;	0.2306;	3;n;	2;n;y;1.24e+04;4.48e+03;9.12e+03;5.02e+03		
13 ;	2,3,4,6,7,8-HxCDD;	*	*	*	*	*	*	*	0.2432;	*;n;	*;5.02e+03;	*;5.02e+03
14 ;	1,2,3,7,8,9-HxCDF;	*	*	*	*	*	*	*	0.2832;	*;n;	*;4.48e+03;	*;4.48e+03
15 ;	1,2,3,4,6,7,8-HpCDF;	1.03e+06;	5.27e+05;	5.00e+05;	1.05;y;	39:21;	3.326;	0.2333;	30;y;	28;Y;Y;1.45e+05;4.86e+03;1.41e+05;5.01e+03		
16 ;	1,2,3,4,7,8,9-HpCDF;	*	*	*	*	*	*	*	0.4229;	*;n;	*;4.86e+03;	*;5.01e+03
17 ;	OCDF;	8.77e+05;	3.94e+05;	4.83e+05;	0.82;y;	45:25;	5.244;	0.9338;	18;y;	17;Y;Y;7.77e+04;4.38e+03;8.69e+04;5.27e+03		
Extraction Standards												
18 ;	13C-2,3,7,8-TCDD;	3.55e+07;	1.56e+07;	1.98e+07;	0.79;y;	31:39;	91.184;	0.2194;	1205;Y;	2161;Y;Y;6.38e+06;5.29e+03;8.07e+06;3.74e+03		
19 ;	13C-1,2,3,7,8-PeCDF;	2.57e+07;	1.56e+07;	1.00e+07;	1.56;y;	34:26;	79.811;	0.2204;	2618;Y;	952;Y;Y;7.05e+06;2.62e+03;4.57e+06;4.80e+03		
20 ;	13C-1,2,3,6,7,8-HxCDD;	2.58e+07;	1.44e+07;	1.14e+07;	1.27;y;	37:12;	98.194;	0.3253;	1079;Y;	809;Y;Y;4.73e+06;4.38e+03;3.80e+06;4.70e+03		
21 ;	13C-1,2,3,4,6,7,8-HpCDF;	1.90e+07;	9.72e+06;	9.26e+06;	1.05;y;	40:38;	93.022;	0.4196;	570;Y;	525;Y;Y;2.55e+06;4.46e+03;2.43e+06;4.64e+03		
22 ;	13C-OCDD;	2.56e+07;	1.21e+07;	1.35e+07;	0.89;y;	45:06;	150.404;	0.4267;	683;Y;	564;Y;Y;2.22e+06;3.24e+03;2.52e+06;4.47e+03		
23 ;	13C-2,3,7,8-TCDF;	5.03e+07;	2.21e+07;	2.83e+07;	0.78;y;	31:07;	99.224;	0.1710;	1659;Y;	1823;Y;Y;7.15e+06;4.31e+03;9.07e+06;4.98e+03		
24 ;	13C-1,2,3,7,8-PeCDF;	4.07e+07;	2.49e+07;	1.57e+07;	1.59;y;	33:38;	77.052;	0.2168;	1778;Y;	1226;Y;Y;1.12e+07;6.28e+03;7.14e+06;5.82e+03		
25 ;	13C-1,2,3,6,7,8-HxCDD;	3.09e+07;	1.06e+07;	2.03e+07;	0.53;y;	36:29;	88.109;	0.2547;	798;Y;	1424;Y;Y;3.65e+06;4.58e+03;7.01e+06;4.92e+03		
26 ;	13C-1,2,3,4,6,7,8-HpCDF;	2.22e+07;	6.84e+06;	1.54e+07;	0.45;y;	39:20;	85.222;	0.3688;	379;Y;	883;Y;Y;1.97e+06;5.19e+03;4.42e+06;5.01e+03		
Injection Standards												
27 ;	13C-1,2,3,4-TCDD;	3.68e+07;	1.61e+07;	2.06e+07;	0.78;y;	31:15;	45.171;	-;	958;Y;	1772;Y;Y;5.07e+06;5.29e+03;6.62e+06;3.74e+03		
28 ;	13C-1,2,3,7,8,9-HxCDD;	2.52e+07;	1.40e+07;	1.12e+07;	1.28;y;	37:27;	35.412;	-;	1022;Y;	756;Y;Y;4.48e+06;4.38e+03;3.55e+06;4.70e+03		
Cleanup Standards												
29 ;	37Cl-2,3,7,8-TCDD;	3.85e+07;	3.85e+07;	-;	-;	31:40;	96.957;	0.0852;	4339;Y;	-;Y;Y;1.55e+07;3.58e+03;		
30 ;	13C-2,3,4,7,8-PeCDF;	4.02e+07;	2.46e+07;	1.56e+07;	1.56;y;	34:14;	77.653;	0.2203;	1595;Y;	1116;Y;Y;1.00e+07;6.28e+03;6.50e+06;5.82e+03		
31 ;	13C-1,2,3,4,7,8-HxCDD;	2.42e+07;	1.35e+07;	1.07e+07;	1.26;y;	37:06;	97.241;	0.3424;	1082;Y;	815;Y;Y;4.74e+06;4.38e+03;3.83e+06;4.70e+03		
32 ;	13C-1,2,3,4,7,8-HpCDF;	2.86e+07;	9.79e+06;	1.88e+07;	0.52;y;	36:23;	90.682;	0.2832;	743;Y;	1323;Y;Y;3.40e+06;4.58e+03;6.51e+06;4.92e+03		
33 ;	13C-1,2,3,4,7,8,9-HpCDF;	1.93e+07;	6.00e+06;	1.33e+07;	0.45;y;	41:20;	83.225;	0.4126;	280;Y;	651;Y;Y;1.46e+06;5.19e+03;3.26e+06;5.01e+03		
Sampling Standards												
34 ;	37Cl-2,3,7,8-TCDD;	3.85e+07;	3.85e+07;	3.85e+07;	3.85e+07;	-;	31:40;	106.340;	0.0728;	4339;Y;	-;Y;Y;1.55e+07;3.58e+03;	
35 ;	13C-2,3,4,7,8-PeCDF;	4.02e+07;	2.46e+07;	1.56e+07;	1.56;y;	34:14;	100.720;	0.2016;	1596;Y;	1116;Y;Y;1.00e+07;6.28e+03;6.50e+06;5.82e+03		
36 ;	13C-1,2,3,4,7,8-HxCDD;	2.42e+07;	1.35e+07;	1.07e+07;	1.26;y;	37:06;	99.027;	0.3358;	1082;Y;	815;Y;Y;4.74e+06;4.38e+03;3.83e+06;4.70e+03		
37 ;	13C-1,2,3,4,7,8-HpCDF;	2.86e+07;	9.79e+06;	1.88e+07;	0.52;y;	36:23;	102.869;	0.2974;	743;Y;	1323;Y;Y;3.40e+06;4.58e+03;6.51e+06;4.92e+03		
38 ;	13C-1,2,3,4,7,8,9-HpCDF;	1.93e+07;	6.00e+06;	1.33e+07;	0.45;y;	41:20;	97.663;	0.5369;	280;Y;	651;Y;Y;1.46e+06;5.19e+03;3.26e+06;5.01e+03		

Totals Report

Total Hexa-Dioxins																			
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	SN2	Mod	
		123789-HxCDD	0.00E+00	0.00E+00	0	N	0:00	0	0.3398	S2N	0.00E+00	4900	0	0.00E+00	4300	0	n		
		123478-HxCDD	0.00E+00	0.00E+00	0	N	0:00	0	0.3229	S2N	0.00E+00	4900	0	0.00E+00	4300	0	n		
		123678-HxCDD	0.00E+00	0.00E+00	0	N	0:00	0	0.3348	S2N	0.00E+00	4900	0	0.00E+00	4300	0	n		
		Hexadioxins	1.65E-05	9.72E+04	6.83E+04	1.42	Y	36:19	0.664	OK	3.27E+04	4904	6.7	2.57E+04	4304	6	n		
Total Hexa-Dioxins										EDL	0.3398	Peaks	1						
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	SN2	Mod	
		123789-HxCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0:00	0	0.2432	S2N	0.00E+00	4480	0	0.00E+00	5020	0	n	
		123789-HxCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0:00	0	0.2832	S2N	0.00E+00	4480	0	0.00E+00	5020	0	n	
		Hexafurans	3.82E-04	1.83E+04	2.01E+04	0.9	N	35:24	0.115	OK	0.249	S2N	9.30E+03	4476	2.1	8.37E+03	5020	1.7	n
		Hexafurans	1.49E-05	7.72E+04	7.21E+04	1.07	Y	35:31	0.45	OK	0.249	S2N	3.15E+04	4476	7	2.28E+04	5020	4.5	n
		Hexafurans	4.13E-04	1.80E+04	2.33E+04	0.77	N	36:18	0.124	OK	0.249	S2N	6.33E+03	4476	1.4	7.55E+03	5020	1.5	n
		123478-HxCDF	1.60E-05	9.20E+04	6.79E+04	1.35	Y	36:24	0.473	OK	0.2448	S2N	3.26E+04	4480	7	2.24E+04	5020	4	y
		123678-HxCDF	6.81E-04	3.63E+04	3.18E+04	1.14	Y	36:28	0.19	OK	0.2306	S2N	1.24E+04	4480	3	9.12E+03	5020	2	y
										EDL	0.2832	Peaks	2						
Total EMPC Hexa-Furans										EDL	0.2832	Peaks	2						
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	SN2	Mod	
		1234678-HpCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0:00	0	0.5141	S2N	0.00E+00	4810	0	0.00E+00	4220	0	n	
										Total EMPC Hexa-Furans	0	Peaks	0						
Total Hepta-Dioxins																			
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	SN2	Mod	
		1234789-HpCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0:00	0	0.5141	S2N	0.00E+00	4810	0	0.00E+00	4220	0	n	
		12346789-HpCDF	1.03E+06	5.27E+05	5.00E+05	1.05	Y	39:21	3.326	OK	1.45E+05	S2N	0.00E+00	4860	30	1.41E+05	5010	28	n
										Total EMPC Hepta-Furans	0.4229	Peaks	1						
Total Hepta-Furans																			
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	SN2	Mod	
		1234789-HpCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0:00	0	0.4229	S2N	0.00E+00	4860	0	0.00E+00	5010	0	n	
		12346789-HpCDF	1.03E+06	5.27E+05	5.00E+05	1.05	Y	39:21	3.326	OK	1.45E+05	S2N	0.00E+00	4860	30	1.41E+05	5010	28	n
										Total EMPC Hepta-Furans	3.326	Peaks	1						


File:A24JUL07A #1-399 Acq:24-JUL-2007 20:08:10 GC EI+ Voltage SIR Autospec-Ultimate

Sample#6 Text:G431-15-10B

Exp:EXP_DB5MS


319.8965 S:6 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,4556.0,5.00%,F,T)

28:40




321.8936 S:6 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,3844.0,5.00%,F,T)

28:40




331.9368 S:6 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5292.0,5.00%,F,T)

100%





333.9339 S:6 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3736.0,5.00%,F,T)


100%





327.8847 S:6 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3580.0,5.00%,F,T)

100%











File:A24JUL07A #1-252 Acq:24-JUL-2007 20:08:10 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#6 Text:G431-15-10B Exp:EXP_DB5MS
 389.8156 S:6 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4904.0,5.00%,F,T)
 100% 36:18




File:A24JUL07A #1-292 Acq:24-JUL-2007 20:08:10 GC EI+ Voltage SIR Autospec-UltimaE

Sample#6 Text:G431-15-10B Exp:EXP_DB5MS


423.7767 S:6 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4812.0,5.00%,F,T)
100%




425.7737 S:6 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4220.0,5.00%,F,T)




435.8169 S:6 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4464.0,5.00%,F,T)



437.8140 S:6 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4640.0,5.00%,F,T)



430.9728 S:6 F:4 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)
100% 38:28 38:46 39:04 39:26 39:45 40:04 40:19 40:48 41:08 41:39 41:54 41:54
0 50




File:A24JUL07A #1-369 Accq:24-JUL-2007 20:08:10 GC EI+ Voltage SIR Autospec-Ultimate

Sample#6 Text:G431-15-10B

Exp:EXP_DB5MS


457.7377 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.018,3632.0,5.00%,F,T)

100%




469.7780 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.018,3244.0,5.00%,F,T)

100%



471.7750 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4468.0,5.00%,F,T)

100%



454.9728 S:6 F:5 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)

100% 42:23 42:46 43:10 43:26 43:48



File:A24JUL07A #1-399 Acq:24-JUL-2007 20:08:10 GC EI+ Voltage SIR Autospec-UltimaE

Sample#6 Text:G431-15-10B

Exp:EXP_DB5MS

303.9016 S:6 BSUB(256,15,-3.0) PKD(3,2,1,0.018,5932.0,5.008,F,T)

100%

2.5E4

1.3E4

1.0E4

0.0E0

26:24 26:40

27:24

28:18

28:37 28:58

29:32

29:55

30:22

30:59

31:09

31:14

32:23

Time

305.8987 S:6 BSUB(256,15,-3.0) PKD(3,2,1,0.018,5748.0,5.008,F,T)

100%

3.1E4

1.5E4

1.0E0

26:47 27:07

27:23

27:56

28:18

28:37

28:57

29:34

30:21

30:59

31:23

31:53

32:14

Time

315.9419 S:6 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4308.0,5.008,F,T)

100%

7.2E6

3.6E6

0.0E0

27:00

28:00

29:00

30:00

31:00

32:00

Time

317.9389 S:6 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4976.0,5.008,F,T)

100%

9.1E6

4.5E6

0.0E0

31:08

31:23

32:00

33:00

34:00

35:00

36:00

37:00

38:00

39:00

40:00

41:00

42:00

43:00

44:00

45:00

46:00

47:00

48:00

49:00

50:00

51:00

52:00

53:00

54:00

55:00

56:00

57:00

58:00

59:00

60:00

61:00

62:00

63:00

64:00

65:00

66:00

67:00

68:00

69:00

70:00

71:00

72:00

73:00

74:00

75:00

76:00

77:00

78:00

79:00

80:00

81:00

82:00

83:00

84:00

85:00

86:00

87:00

88:00

89:00

90:00

91:00

92:00

93:00

94:00

95:00

96:00

97:00

98:00

99:00

100:00

101:00

102:00

103:00

104:00

105:00

106:00

107:00

108:00

109:00

110:00

111:00

112:00

113:00

114:00

115:00

116:00

117:00

118:00

119:00

120:00

121:00

122:00

123:00

124:00

125:00

126:00

127:00

128:00

129:00

130:00

131:00

132:00

133:00

134:00

135:00

136:00

137:00

138:00

139:00

140:00

141:00

142:00

143:00

144:00

145:00

146:00

147:00

148:00

149:00

150:00

151:00

152:00

153:00

154:00

155:00

156:00

157:00

158:00

159:00

160:00

161:00

162:00

163:00

164:00

165:00

166:00

167:00

168:00

169:00

170:00

171:00

172:00

173:00

174:00

175:00

176:00

177:00

178:00

179:00

180:00

181:00

182:00

183:00

184:00

185:00

186:00

187:00

188:00

189:00

190:00

191:00

192:00

193:00

194:00

195:00

196:00

197:00

198:00

199:00

200:00

201:00

202:00

203:00

204:00

205:00

206:00

207:00

208:00

209:00

210:00

211:00

212:00

213:00

214:00

215:00

216:00

217:00

218:00

219:00

220:00

221:00

222:00

223:00

224:00

225:00

226:00

227:00

228:00

229:00

230:00

231:00

232:00

233:00

234:00

235:00

236:00

237:00

238:00

239:00

240:00

241:00

242:00

243:00

244:00

245:00

246:00

247:00

248:00

249:00

250:00

251:00

252:00

253:00

254:00

2

File:A24JUL07A #1-399 Acc:24-JUL-2007 20:08:10 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#6 Text:G431-15-10B
 303.9016 S:6 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,5932.0,5.00%,F,T)
 100%
 26:56

2.5E4

2.3E4

2.0E4

1.8E4

1.5E4

1.3E4

1.0E4


7.5E3

5.0E3

2.5E3

TUDF

31:09



Time

3.1E4

2.8E4

2.5E4

2.2E4

1.9E4

1.5E4

1.2E4

9.3E3

6.2E3

3.1E3

0.0E0

• Manualint.

26Jul07 HMP

Time

3.1E4

2.8E4

2.5E4

2.2E4

31:23

29:54

28:18

27:56

30:21

31:09

30:59

31:30

30:38

29:34

31:53

31:50

30:09

32:21

32:23

31:46

31:39

31:46

32:14

32:23

32:23

31:53

31:50

31:50

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21

32:21

32:21

31:53

31:53

31:53

32:21


32:21

32:21



31:53


31:53


31:53




File:A24JUL07A #1-184 Acq:24-JUL-2007 20:08:10 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#6 Text:G431-15-10B
 339.8597 S:6 F:2 BSTB(128,15,-3.0) PKD(3,2,1,0.01%,5256.0,5.00%,F,T)
 100%
 33:03










File:A24JUL07A #1-369 Acq:24-JUL-2007 20:08:10 GC EI+ Voltage SIR Autospec-UltimaE

Sample#6 Text:G431-15-10B


441.7427 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4376.0,5.00%,F,T)

100%



443.7398 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.018,5268.0,5.00%,F,T)

100%




469.7780 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.018,3244.0,5.00%,F,T)

100%




471.7750 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4468.0,5.00%,F,T)

100%




513.6775 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,100.008,5356.0,5.00%,F,T)

100%



454.9728 S:6 F:5 SMO(1,3) PKD(3,2,1,100.008,0,0.5.00%,F,T)

100%




File:A24JUL07A #1-399 Acq:24-JUL-2007 20:08:10 GC EI+ Voltage SIR Autospec-Ultimate

Sample#6 Text:G431-15-10B

Exp:EXP_DB5MS

341.8568 S:6 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4792.0,5.00%,F,T)

100%



Method M23

OUT-Diox-3

Air Hygiene

Analytical Data Summary Sheet

Analyte	Amount (ng)	EDL (ng)	EMPC (ng)	RT (min.)	Ratio	Qualifier
2,3,7,8-TCDD	ND	0.00883				
1,2,3,7,8-PeCDD	ND	0.0108				
1,2,3,4,7,8-HxCDD	ND	0.0115				
1,2,3,6,7,8-HxCDD	ND	0.0117				
1,2,3,7,8,9-HxCDD	ND	0.0119				
1,2,3,4,6,7,8-HpCDD	ND	0.0201				
OCDD	ND	0.0378				
2,3,7,8-TCDF	ND	0.00680				
1,2,3,7,8-PeCDF	ND	0.00679				
2,3,4,7,8-PeCDF	ND	0.00654				
1,2,3,4,7,8-HxCDF	EMPC	0.00686	0.0126	36:24	0.98	*
1,2,3,6,7,8-HxCDF	ND	0.00647				
2,3,4,6,7,8-HxCDF	ND	0.00682				
1,2,3,7,8,9-HxCDF	ND	0.00794				
1,2,3,4,6,7,8-HpCDF	0.0849			39:22	1.01	A
1,2,3,4,7,8,9-HpCDF	ND	0.0133				
OCDF	0.169			45:27	0.98	A
Total TCDDs	ND	0.00883				
Total PeCDDs	0.0204					
Total HxCDDs	ND	0.0119	0.0530			
Total HpCDDs	ND	0.0201				
Total TCDFs	0.0189					
Total PeCDFs	ND	0.00679				
Total HxCDFs	0.0217		0.0387			
Total HpCDFs	0.0849					
WHO-2005 TEQ (ND=0)	0.000900		0.00216			
WHO-2005 TEQ (ND=½)	0.0155		0.0164			

Client Information		Sample Information	
Project Name:	snc-07-benson.mn-comp#1	Matrix:	Air
Sample ID:	OUT-Diox-3	Weight / Volume:	1 train
Laboratory Information		Solids / Lipids:	NA %
Project ID:	G431-15	Original pH :	NA
Sample ID:	G431-15-15B	Batch ID:	WG14370
Collection Date/Time:	07/04/07	Instrument:	HRMS1
Receipt Date/Time:	07/11/07 10:00	Filename:	a24jul07a-7
Extraction Date:	07/22/07	Retchk:	a24jul07a-1
Analysis Date/Time:	07/24/07 20:56	Begin ConCal:	a24jul07a-1
		End ConCal:	a24jul07a-11
		Initial Cal:	m8290-071007a

<i>Method M23</i> OUT-Diox-3 Air Hygiene

Labeled Standard	Expected Amount (ng)	Measured Amount (ng)	Percent Recovery (%)	RT (min.)	Ratio	Qualifier
Extraction Standards						
13C12-2,3,7,8-TCDD	4.0	3.11	77.7	31:39	0.78	
13C12-1,2,3,7,8-PeCDD	4.0	2.93	73.2	34:25	1.58	
13C12-1,2,3,6,7,8-HxCDD	4.0	3.73	93.3	37:12	1.26	
13C12-1,2,3,4,6,7,8-HpCDD	4.0	3.38	84.5	40:37	1.06	
13C12-OCDD	8.0	5.43	67.9	45:07	0.91	
13C12-2,3,7,8-TCDF	4.0	3.49	87.3	31:07	0.81	
13C12-1,2,3,7,8-PeCDF	4.0	2.82	70.5	33:37	1.59	
13C12-1,2,3,6,7,8-HxCDF	4.0	3.43	85.6	36:28	0.53	
13C12-1,2,3,4,6,7,8-HpCDF	4.0	3.26	81.4	39:21	0.45	
Sampling Standards						
37Cl4-2,3,7,8-TCDD	4.0	4.22	106	31:40	-	
13C12-2,3,4,7,8-PeCDF	4.0	3.88	97.0	34:15	1.57	
13C12-1,2,3,4,7,8-HxCDD	4.0	3.70	92.5	37:07	1.27	
13C12-1,2,3,4,7,8-HxCDF	4.0	3.97	99.4	36:22	0.53	
13C12-1,2,3,4,7,8,9-HpCDF	4.0	3.66	91.6	41:21	0.45	
Injection Standards						
13C12-1,2,3,4-TCDD	2.0	-	-	31:15	0.79	
13C12-1,2,3,7,8,9-HxCDD	2.0	-	-	37:27	1.23	

Client Information		Sample Information	
Project Name:	snc-07-benson.mn-comp#1	Matrix:	Air
Sample ID:	OUT-Diox-3	Weight / Volume:	1 train
Laboratory Information		Solids / Lipids:	NA %
Project ID:	G431-15	Original pH :	NA
Sample ID:	G431-15-15B	Batch ID:	WG14370
Collection Date/Time:	07/04/07	Instrument:	HRMS1
Receipt Date/Time:	07/11/07	Filename:	a24jul07a-7
Extraction Date:	07/22/07	Retchk:	a24jul07a-1
Analysis Date/Time:	07/24/07 20:56	Begin ConCal:	a24jul07a-11
		End ConCal:	a24jul07a-11
		Initial Cal:	m8290-071007a

Analyzed by: HMP
 Date: 26Jul07

Reviewed by: WJL
 Date: 7.24.07

Form Version: [S290_DB_2.14]Report

Filename : a24jul07a
 Sample : 7 Acquired : 24-JUL-07 20:56:31
 Processed : 25-JUL-07 08:11:27
 Sample ID : G431-15.15B
 Cal Table : m8290-071007a
 Results Table : m8290-072407a

Comments ;


Ent;	Name;	Resp;	Ion 1;	Ion 2;	RA;?	RT;	Conc;	EDL;	S/N1;?	S/N2;?	M;	Signal1;	Noise 1;	Signal2;	Noise 2
1 ;	2,3,7,8-TCDI;	*;	*	*	*;n;	NotFnd;	*;	0.4414;	*;n;	*;n,n;	*;4.86e+03;	*;4.43e+03;	*;4.86e+03;	*;4.43e+03;	
2 ;	1,2,3,7,8-PeCDD;	*;	*	*	*;n;	NotFnd;	*;	0.5415;	*;n;	*;n,n;	*;5.84e+03;	*;5.12e+03;	*;5.84e+03;	*;5.12e+03;	
3 ;	1,2,3,4,7,8-HxCDD;	*;	*	*	*;n;	NotFnd;	*;	0.5772;	*;n;	*;n,n;	*;4.71e+03;	*;4.49e+03;	*;4.71e+03;	*;4.49e+03;	
4 ;	1,2,3,6,7,8-HxCDD;	*;	*	*	*;n;	NotFnd;	*;	0.5875;	*;n;	*;n,n;	*;4.71e+03;	*;4.49e+03;	*;4.71e+03;	*;4.49e+03;	
5 ;	1,2,3,7,8,9-HxCDD;	*;	*	*	*;n;	NotFnd;	*;	0.5962;	*;n;	*;n,n;	*;4.71e+03;	*;4.49e+03;	*;4.71e+03;	*;4.49e+03;	
6 ;	1,2,3,4,6,7,8-HpCDD;	*;	*	*	*;n;	NotFnd;	*;	1.0059;	*;n;	*;n,n;	*;4.49e+03;	*;4.78e+03;	*;4.49e+03;	*;4.78e+03;	
7 ;	OCDD;	*;	*	*	*;n;	NotFnd;	*;	1.8876;	*;n;	*;n,n;	*;4.78e+03;	*;3.52e+03;	*;4.78e+03;	*;3.52e+03;	
8 ;	2,3,7,8-TCDF;	*;	*	*	*;n;	NotFnd;	*;	0.3399;	*;n;	*;n,n;	*;4.57e+03;	*;5.78e+03;	*;4.57e+03;	*;5.78e+03;	
9 ;	1,2,3,7,8-PeCDF;	*;	*	*	*;n;	NotFnd;	*;	0.3394;	*;n;	*;n,n;	*;5.26e+03;	*;5.21e+03;	*;5.26e+03;	*;5.21e+03;	
10 ;	2,3,4,7,8-PeCDF;	*;	*	*	*;n;	NotFnd;	*;	0.3272;	*;n;	*;n,n;	*;5.26e+03;	*;5.21e+03;	*;5.26e+03;	*;5.21e+03;	
11 ;	1,2,3,4,7,8-HxCDF;	6.22e+04;	3.08e+04;	3.15e+04;	0.98;n;	36:24;	0.315;	0.3432;	2;n;	3;Y;r;9.76e+03;4.35e+03;1.40e+04;4.08e+03	2;n;	2;n;	2;n;	2;n;	
12 ;	1,2,3,6,7,8-HxCDF;	3.87e+04;	2.17e+04;	1.70e+04;	1.28;y;	36:29;	0.185;	0.3233;	2;n;	2;n;	2;n;	2;n;	2;n;	2;n;	2;n;
13 ;	2,3,4,6,7,8-HxCDF;	*;	*	*	*;n;	NotFnd;	*;	0.3409;	*;n;	*;n,n;	*;4.35e+03;	*;4.35e+03;	*;4.35e+03;	*;4.35e+03;	
14 ;	1,2,3,7,8,9-HxCDF;	*;	*	*	*;n;	NotFnd;	*;	0.3971;	*;n;	*;n,n;	*;4.35e+03;	*;4.35e+03;	*;4.35e+03;	*;4.35e+03;	
15 ;	1,2,3,4,6,7,8-HpCDF;	3.77e+05;	1.90e+05;	1.87e+05;	1.01;y;	39:22;	2.122;	0.5246;	11:y;	12;Y;r;5.35e+04;4.68e+03;5.54e+04;4.49e+03	11:y;	11:y;	11:y;	11:y;	
16 ;	1,2,3,4,7,8,9-HpCDF;	*;	*	*	*;n;	NotFnd;	*;	0.6656;	*;n;	*;n,n;	*;4.68e+03;	*;4.68e+03;	*;4.68e+03;	*;4.68e+03;	
17 ;	OCDF;	3.83e+05;	1.90e+05;	1.93e+05;	0.98;y;	45:27;	4.220;	1.9679;	7;y;	8;Y;r;3.79e+04;5.44e+03;3.91e+04;5.08e+03	7;y;	7;y;	7;y;	7;y;	
Extraction Standards															
18 ;	13C-2,3,7,8-TCDI;	1.81e+07;	7.95e+06;	1.02e+07;	0.78;y;	31:39;	77.712;	0.3884;	537;y;	720;Y;r;2.85e+06;5.31e+03;3.66e+06;5.08e+03	537;y;	537;y;	537;y;	537;y;	
19 ;	13C-1,2,3,7,8-PeCDD;	1.41e+07;	8.65e+06;	5.48e+06;	1.58;y;	34:26;	73.225;	0.4056;	782;Y;r;	512;Y;r;3.49e+06;4.47e+03;2.30e+06;4.50e+03	782;Y;r;	782;Y;r;	782;Y;r;	782;Y;r;	
20 ;	13C-1,2,3,6,7,8-HxCDD;	1.47e+07;	8.20e+06;	6.53e+06;	1.26;y;	37:12;	93.314;	0.4902;	672;Y;r;	473;Y;r;2.69e+06;4.00e+03;2.17e+06;4.58e+03	672;Y;r;	672;Y;r;	672;Y;r;	672;Y;r;	
21 ;	13C-1,2,3,4,6,7,8-HpCDD;	1.04e+07;	5.34e+06;	5.03e+06;	1.06;y;	40:38;	84.493;	0.6742;	273;Y;r;	297;Y;r;1.35e+06;4.95e+03;1.26e+06;4.22e+03	273;Y;r;	273;Y;r;	273;Y;r;	273;Y;r;	
22 ;	13C-OCDD;	1.39e+07;	6.60e+06;	7.29e+06;	0.91;y;	45:07;	135.733;	0.7594;	250;Y;r;	325;Y;r;1.17e+06;4.69e+03;1.28e+06;3.92e+03	250;Y;r;	250;Y;r;	250;Y;r;	250;Y;r;	
23 ;	13C-2,3,7,8-TCDF;	2.66e+07;	1.18e+07;	1.47e+07;	0.81;y;	31:08;	87.278;	0.2611;	733;Y;r;	1089;Y;r;3.62e+06;4.94e+03;4.54e+06;4.17e+03	733;Y;r;	733;Y;r;	733;Y;r;	733;Y;r;	
24 ;	13C-1,2,3,7,8-PeCDF;	2.23e+07;	1.37e+07;	8.61e+06;	1.59;y;	33:38;	70.54;	0.2949;	924;Y;r;	784;Y;r;5.64e+06;6.10e+03;3.61e+06;4.60e+03	924;Y;r;	924;Y;r;	924;Y;r;	924;Y;r;	
25 ;	13C-1,2,3,6,7,8-HxCDF;	1.81e+07;	6.24e+06;	1.18e+07;	0.53;y;	36:29;	85.629;	0.3228;	724;Y;r;	1018;Y;r;2.34e+06;3.23e+03;4.40e+06;4.32e+03	724;Y;r;	724;Y;r;	724;Y;r;	724;Y;r;	
26 ;	13C-1,2,3,4,6,7,8-HpCDF;	1.28e+07;	3.97e+06;	8.79e+06;	0.45;y;	39:21;	81.375;	0.6002;	227;Y;r;	492;Y;r;1.17e+06;5.16e+03;2.60e+06;5.28e+03	227;Y;r;	227;Y;r;	227;Y;r;	227;Y;r;	
Injection Standards															
27 ;	13C-1,2,3,4,7,8,9-HxCDD;	2.21e+07;	9.71e+06;	1.24e+07;	0.79;y;	31:15;	27.105;	-;	629;Y;r;	836;Y;r;3.34e+06;5.31e+03;4.25e+06;5.08e+03	629;Y;r;	629;Y;r;	629;Y;r;	629;Y;r;	
28 ;	13C-1,2,3,7,8,9-HxCDD;	1.51e+07;	8.37e+06;	6.78e+06;	1.23;y;	37:27;	21.15;	-;	688;Y;r;	498;Y;r;2.75e+06;4.00e+03;2.28e+06;4.58e+03	688;Y;r;	688;Y;r;	688;Y;r;	688;Y;r;	
Cleanup Standards															
29 ;	37Cl-2,3,7,8-TCDD;	1.95e+07;	1.95e+07;	8.27e+06;	1.57;y;	31:40;	82.016;	0.1515;	1958;Y;r;	-;-;T;8.10e+06;4.14e+03;	1958;Y;r;	1958;Y;r;	1958;Y;r;	1958;Y;r;	
30 ;	13C-2,3,4,7,8-PeCDF;	2.13e+07;	1.30e+07;	8.27e+06;	1.57;y;	34:15;	68.407;	0.3004;	927;Y;r;	768;Y;r;5.66e+06;6.10e+03;3.54e+06;4.60e+03	927;Y;r;	927;Y;r;	927;Y;r;	927;Y;r;	
31 ;	13C-1,2,3,4,7,8-HxCDD;	1.29e+07;	7.25e+06;	5.70e+06;	1.27;y;	37:07;	86.334;	0.5160;	646;Y;r;	435;Y;r;2.59e+06;4.00e+03;1.99e+06;4.58e+03	646;Y;r;	646;Y;r;	646;Y;r;	646;Y;r;	
32 ;	13C-1,2,3,4,6,7,8-HxCDF;	1.62e+07;	5.62e+06;	1.06e+07;	0.53;y;	36:23;	85.123;	0.3588;	652;Y;r;	922;Y;r;2.11e+06;3.23e+03;3.99e+06;3.32e+03	652;Y;r;	652;Y;r;	652;Y;r;	652;Y;r;	
33 ;	13C-1,2,3,4,7,8,9-HpCDF;	1.04e+07;	3.22e+06;	7.21e+06;	0.45;y;	41:21;	74.525;	0.6729;	155;Y;r;	341;Y;r;8.01e+05;5.16e+03;1.80e+06;5.28e+03	155;Y;r;	155;Y;r;	155;Y;r;	155;Y;r;	
Sampling Standards															
34 ;	37Cl-2,3,7,8-TCDD;	1.95e+07;	1.95e+07;	8.27e+06;	1.57;y;	31:40;	105.547;	0.1870;	1958;Y;r;	-;-;T;8.10e+06;4.14e+03;	1958;Y;r;	1958;Y;r;	1958;Y;r;	1958;Y;r;	
35 ;	13C-2,3,4,7,8-PeCDF;	2.13e+07;	1.30e+07;	8.27e+06;	1.57;y;	34:15;	97.046;	0.3529;	927;Y;r;	768;Y;r;5.66e+06;6.10e+03;3.54e+06;4.60e+03	927;Y;r;	927;Y;r;	927;Y;r;	927;Y;r;	
36 ;	13C-1,2,3,4,7,8-HxCDD;	1.29e+07;	7.25e+06;	5.70e+06;	1.27;y;	37:07;	92.517;	0.5574;	646;Y;r;	435;Y;r;2.59e+06;4.00e+03;1.99e+06;4.58e+03	646;Y;r;	646;Y;r;	646;Y;r;	646;Y;r;	
37 ;	13C-1,2,3,4,7,8-HpCDF;	1.62e+07;	5.62e+06;	1.06e+07;	0.53;y;	36:23;	99.360;	0.3722;	652;Y;r;	922;Y;r;2.11e+06;3.23e+03;3.99e+06;3.32e+03	652;Y;r;	652;Y;r;	652;Y;r;	652;Y;r;	
38 ;	13C-1,2,3,4,7,8,9-HpCDF;	1.04e+07;	3.22e+06;	7.21e+06;	0.45;y;	41:21;	91.586;	0.9315;	155;Y;r;	341;Y;r;8.01e+05;5.16e+03;1.80e+06;5.28e+03	155;Y;r;	155;Y;r;	155;Y;r;	155;Y;r;	

Totals Report

SGS Environmental Services, INC.			Thu Jul 26 15:25:49 EDT 2007									
			Acquired: 2007-07-24 20:56:31									
			Processed: 2007-07-25 08:11:27									
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	? RT	Conc	EDL	Status	Height1	Noise1
Total Tetra-Dioxins		2378-TCDD	0.00E+00	0.00E+00	0.00E+00	0 N	0.00	0	0.4414	S2N	0.00E+00	4860
Total Tetra-Dioxins									0.4414		0	0.00E+00
Total EMPC Tetra-Dioxins									0	Peaks	0	
Total Tetra-Furans										EDL		
Total Tetra-Furans	Ent	Name	AreaSum	Ion1Area	Ion2Area	IR	? RT	Conc	EDL	Status	Height1	Noise1
Total Tetra-Furans		2378-TCDF	0.00E+00	0.00E+00	0 N	0.00	0	0	0.3399	S2N	0.00E+00	4570
Tetrafurans		1.41E+05	6.04E+04	8.04E+04	0.75 Y	26.55	0.473	0.3399	OK	1.47E+04	4572	3.2
Tetrafurans		8.47E+04	4.15E+04	4.32E+04	0.96 N	28.18	0.285	0.3399	S2N	6.29E+03	4572	1.4
Tetrafurans		8.01E+04	3.69E+04	4.32E+04	0.85 Y	29.54	0.269	0.3399	S2N	7.67E+03	4572	1.7
Tetrafurans		7.51E+04	4.03E+04	3.49E+04	1.16 N	30.22	0.253	0.3399	S2N	8.20E+03	4572	1.8
Tetrafurans		4.87E+04	2.09E+04	2.78E+04	0.75 Y	31.22	0.164	0.3399	S2N	6.16E+03	4572	1.3
Total EMPC Tetra-Furans									0.3399	Peaks	1	
Total EMPC Tetra-Furans									0.473	Peaks	1	
Total EMPC Tetra-Furans									0.473	Peaks	1	
Total Penta-Dioxins										EDL		
Total Penta-Dioxins	Ent	Name	AreaSum	Ion1Area	Ion2Area	IR	? RT	Conc	EDL	Status	Height1	Noise1
Total Penta-Dioxins		12378-PeCDD	0.00E+00	0.00E+00	0.00E+00	0 N	0.00	0	0.5415	S2N	0.00E+00	5840
Pentadioxins		7.51E+04	4.77E+04	2.74E+04	1.74 Y	33.06	0.51	0.5415	S2N	1.96E+04	5840	3.4
Pentadioxins		9.86E+04	5.44E+04	4.42E+04	1.23 N	33.39	0.689	0.5415	G	2.31E+04	5840	4
Pentadioxins		4.47E+04	2.61E+04	1.86E+04	1.4 Y	33.49	0.304	0.5415	S2N	1.00E+04	5840	1.7
Pentadioxins		4.01E+04	2.38E+04	1.62E+04	1.47 Y	34.09	0.272	0.5415	S2N	1.01E+04	5840	1.7
Total EMPC Penta-Dioxins									0.669	Peaks	0	
Total EMPC Penta-Dioxins									0	Peaks	0	
Total Penta-Furans										EDL		
Total Penta-Furans	Ent	Name	AreaSum	Ion1Area	Ion2Area	IR	? RT	Conc	EDL	Status	Height1	Noise1
Total Penta-Furans		23478-PeCDF	0.00E+00	0.00E+00	0.00E+00	0 N	0.00	0	0.3394	S2N	0.00E+00	5260
Total Penta-Furans		12378-PeCDF	0.00E+00	0.00E+00	0.00E+00	0 N	0.00	0	0.3394	S2N	0.00E+00	5260
Total Penta-Furans									0.3394	Peaks	0	
Total Hexa-Dioxins										EDL		
Total Hexa-Dioxins	Ent	Name	AreaSum	Ion1Area	Ion2Area	IR	? RT	Conc	EDL	Status	Height1	Noise1

Totals Report

123478-HxCDD	0.00E+00	0.00E+00	0.00E+00	0 N	0.00	0	0.5772	S2N	0.00E+00	4710	0	0.00E+00	4490	0	n		
123789-HxCDD	0.00E+00	0.00E+00	0.00E+00	0 N	0.00	0	0.5962	S2N	0.00E+00	4710	0	0.00E+00	4490	0	n		
123678-HxCDD	0.00E+00	0.00E+00	0.00E+00	0 N	0.00	0	0.5875	S2N	0.00E+00	4710	0	0.00E+00	4490	0	n		
Hexadioxins	1.89E+05	9.34E+04	9.54E+04	0.98 N	36.19	1.3224	0.5868	EMPC	3.53E+04	4708	7.5	3.41E+04	4492	7.6	n		
							EDL										
				Total EMPC Hexa-Dioxins		0.5962											
				Total Hexa-Dioxins		1.324		Peaks	1								
						0		Peaks	0								
Total Hexa-Furans																	
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	SN2 Mod
		234678-HxCDF	0.00E+00	0.00E+00	0 N	0.00	0	0.3409	S2N	0.00E+00	4350	0	0.00E+00	4080	0	n	
		123789-HxCDF	0.00E+00	0.00E+00	0 N	0.00	0	0.3971	S2N	0.00E+00	4350	0	0.00E+00	4080	0	n	
		Hexafurans	4.42E+04	2.25E+04	2.18E+04	0.03	N	35.24	0.228	0.3491	S2N	1.10E+04	4352	2.5	8.75E+03	4084	2.2 y
		Hexafurans	8.25E+04	4.15E+04	4.09E+04	1.02	N	35.31	0.425	0.3491	EMPC	1.51E+04	4352	3.5	1.16E+04	4084	2.8 y
		123478-HxCDF	6.22E+04	3.08E+04	3.15E+04	0.98	N	36.24	0.315	0.3432	S2N	9.76E+03	4350	2	1.48E+04	4080	3 y
		123678-HxCDF	3.87E+04	2.11E+04	1.70E+04	1.28	Y	36.28	0.185	0.3233	S2N	8.49E+03	4350	2	6.34E+03	4080	2 y
				Total Hexa-Furans		0.3971		Peaks	0								
				Total EMPC Hexa-Furans		0.425		Peaks	1								
Total Hepta-Dioxins																	
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	SN2 Mod
		1234678-HpCDF	0.00E+00	0.00E+00	0.00E+00	0 N	0:00	0	1.0069	S2N	0.00E+00	4490	0	0.00E+00	4780	0	n
				Total EMPC Hepta-Dioxins		EDL											
				Total Hepta-Dioxins		1.0069		Peaks	0								
Total Hepta-Furans																	
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	SN2 Mod
		123478-HpCDF	0.00E+00	1.90E+05	1.87E+05	1.01	Y	39.22	2.122	0.5246	OK	0.6656	4680	0	0.00E+00	4490	0
		1234678-HpCDF	3.77E+05									5.35E+04	4680	11	5.54E+04	4490	12 n
				Total EMPC Hepta-Furans		EDL											
				Total Hepta-Furans		0.6656		Peaks	1								



File:A24JUL07A #1-184 Acq:24-JUL-2007 20:56:31 GC EI+ Voltage SIR Autospec-Ultimate

Sample#7 Text:G431-15-15B

355.8546 S:7 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5840.0,5.00%,F,T)

100% 33:06 33:39

2.6E4

1.3E4

0.0E0

Time

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00

357.8517 S:7 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5120.0,5.00%,F,T)

100% 33:06 33:39

2.0E4

9.9E3

0.0E0

Time

32:44 32:57 33:21 33:49 34:10 34:57 34:41 34:50

367.8949 S:7 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4468.0,5.00%,F,T)

100% 33:06 33:39

2.0E4

9.9E3

0.0E0

Time

32:44 32:55 33:13 33:30 33:45 34:09 34:31 34:57

369.8919 S:7 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4504.0,5.00%,F,T)

100% 34:26

3.5E6

1.7E6

0.0E0

Time

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00

366.9792 S:7 F:2 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)

100% 32:40 33:00

2.3E6

1.2E6

0.0E0

Time

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00


34:00 34:10 34:22 34:39 34:49

7.5E5


0.0E0

Time

File:A24JUL07A #1-184 Accq:24-JUL-2007 20:56:31 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#7 Text:G431-15-15B
 355.8546 S:7 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5840.0,5.00%,F,T)
 100% 33:39



File:A24JUL07A #1-252 Acq:24-JUL-2007 20:56:31 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#7 Text:G431-15B Exp:EXP_DE5MS
 389.8156 S:7 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4708.0,5.00%,F,T)
 100%
 36:19









File:A24JUL07A #1-292 Acq:24-JUL-2007 20:56:31 GC EI+ Voltage SIR Autospec-Ultimate

Sample#7 Text:G431-15-15B Exp:EXP_DB5MS

423.7767 S:7 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4488.0,5.00%,F,T)

100% 39:40 40:38 41:32 42:03 5.1E3 0.0E0 Time



File:A24JUL07A #1-368 Acq:24-JUL-2007 20:56:31 GC EI+ Voltage SIR Autospec-UltimaE

Sample#7 Text:G431-15-15B

457.7377 S:7 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4784.0,5.00%,F,T)


Exp:EXP_DB5MS

459.7348 S:7 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.018,3524.0,5.00%,F,T)


469.7780 S:7 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4688.0,5.00%,F,T)

471.7750 S:7 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.018,3924.0,5.00%,F,T)

454.9728 S:7 F:5 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)



File:A24JUL07A #1-399 Acq:24-JUL-2007 20:56:31 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#7 Text:G431-15-15B Exp:EXP_DB5MS
 303.9016 S:7 BSUB(256,15,-3.0) PKD(3,2,1,0.018,4572.0,5.00%,F,T)
 100%



File:A24JUL07A #1-399 Acq:24-JUL-2007 20:56:31 GC EI+ Voltage SIR Autospec-Ultimate




Sample#7 Text:G431-15-15B

303.9016 S:7 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,4572.0,5.00%,F,T)

100%

90
80
70
60
50
40
30
20
10
0

1.7E4
1.5E4
1.4E4
1.2E4





File:A24JUL07A #1-184 Accq:24-JUL-2007 20:56:31 GC EI+ Voltage SIR Autospec-UltimaE

Sample#7 Test:G431-15-15B


339.8597 S:7 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5260.0,5.00%,F,T)

100% 33:03 32:58 33:24 33:38 33:48 34:16 34:19 34:36 34:53 7.0E3 1.4E4





File:A24JUL07A #1-252 Accq:24-JUL-2007 20:56:31 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#7 Text:G431-15-15B
 Exp:EXP_DB5MS
 373.8207 S:7 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4352.0,5.00%,F,T)
 100%
 35:33



File:A24JUL07A #1-292 Accq:24-JUL-2007 20:56:31 GC EI+ Voltage SIR Autospec-Ultimate

Sample#7 Text:G431-15-15B

Exp:EXP_DB5MS

407.7818 S:7 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4676.0,5.00%,F,T)

100% 39:21

5.9E4

2.9E4

0.0E0

Time

42:00

41:00

40:00

39:00

38:39

39:08

39:42

39:54

40:13

40:39

40:57

41:21

41:34

41:47

42:05

5.9E4

3.0E4

0.0E0

Time

42:00

41:00

40:00

39:00

38:33

38:46

39:04

39:53

40:08

40:35

40:56

41:21

41:45

41:59

5.9E4

3.0E4

0.0E0

Time

42:00

41:00

40:00

39:00

38:39

38:56

39:17

39:24

39:49

40:17

40:57

41:21

41:45

41:59

5.9E4

3.0E4

0.0E0

Time

42:00

41:00

40:00

39:00

38:39

38:56

39:17

39:24

39:49

40:17

40:57

41:21

41:45

41:59

5.9E4

3.0E4

0.0E0

Time

42:00

41:00

40:00

39:00

38:39

38:56

39:17

39:24

39:49

40:17

40:57

41:21

41:45

41:59

5.9E4

3.0E4

0.0E0

Time

42:00

41:00

40:00

39:00

38:39

38:56

39:17

39:24

39:49

40:17

40:57

41:21

41:45

41:59

5.9E4

3.0E4

0.0E0

Time

42:00

41:00

40:00

39:00

38:39

38:56

39:17

39:24

39:49

40:17

40:57

41:21

41:45

41:59

5.9E4

3.0E4

0.0E0

Time

42:00

41:00

40:00

39:00

38:39

38:56

39:17

39:24

39:49

40:17


40:57

41:21

41:45

41:59


File:A24JUL07A #1-368 Acq:24-JUL-2007 20:56:31 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#7 Text:G431-15-15B
 441.7427 S:7 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5436.0,5.00%,F,T)
 100%
 50%
 0%



File:A24JUL07A #1-399 Acq:24-JUL-2007 20:56:31 GC EI+ Voltage SIR Autospec-Ultimate

Sample#7 Text:G431-15-15B Exp:EXP_DB5MS

341.8568 S:7 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4948.0,5.00%,F,T)



Method M23**B****Air Hygiene****Analytical Data Summary Sheet**

Analyte	Amount (ng)	EDL (ng)	EMPC (ng)	RT (min.)	Ratio	Qualifier
2,3,7,8-TCDD	ND	0.00550				
1,2,3,7,8-PeCDD	ND	0.00704				
1,2,3,4,7,8-HxCDD	ND	0.00718				
1,2,3,6,7,8-HxCDD	ND	0.00730				
1,2,3,7,8,9-HxCDD	ND	0.00741				
1,2,3,4,6,7,8-HpCDD	ND	0.0134				
OCDD	ND	0.0231				
2,3,7,8-TCDF	ND	0.00365				
1,2,3,7,8-PeCDF	ND	0.00500				
2,3,4,7,8-PeCDF	ND	0.00500				
1,2,3,4,7,8-HxCDF	ND	0.00693				
1,2,3,6,7,8-HxCDF	ND	0.00653				
2,3,4,6,7,8-HxCDF	ND	0.00688				
1,2,3,7,8,9-HxCDF	ND	0.00802				
1,2,3,4,6,7,8-HpCDF	0.0387			39:19	1.02	A
1,2,3,4,7,8,9-HpCDF	ND	0.0103				
OCDF	0.0688			45:25	0.97	A
Total TCDDs	ND	0.00550				
Total PeCDDs	ND	0.00704				
Total HxCDDs	ND	0.00741				
Total HpCDDs	ND	0.0134				
Total TCDFs	ND	0.00365				
Total PeCDFs	ND	0.00500				
Total HxCDFs	ND	0.00802				
Total HpCDFs	0.0387					
WHO-2005 TEQ (ND=0)	0.000408		0.000408			
WHO-2005 TEQ (ND=½)	0.0103		0.0103			

Client Information		Sample Information	
Project Name:	snc-07-benson.mn-comp#1	Matrix:	Air
Sample ID:	B	Weight / Volume:	1 train
Laboratory Information		Solids / Lipids:	NA %
Project ID:	G431-15	Original pH :	NA
Sample ID:	G431-15-20B	Batch ID:	WG14370
Collection Date/Time:	07/04/07	Instrument:	HRMS1
Receipt Date/Time:	07/11/07 10:00	Filename:	a24jul07a-8
Extraction Date:	07/22/07	Retchk:	a24jul07a-1
Analysis Date/Time:	07/24/07 21:44	Begin ConCal:	a24jul07a-1
		End ConCal:	a24jul07a-11
		Initial Cal:	m8290-071007a

<i>Method M23</i>						
B						
Air Hygiene						

Labeled Standard	Expected Amount (ng)	Measured Amount (ng)	Percent Recovery (%)	RT (min.)	Ratio	Qualifier
Extraction Standards						
13C12-2,3,7,8-TCDD	4.0	3.11	77.8	31:39	0.79	
13C12-1,2,3,7,8-PeCDD	4.0	2.32	58.1	34:25	1.58	
13C12-1,2,3,6,7,8-HxCDD	4.0	3.49	87.4	37:12	1.27	
13C12-1,2,3,4,6,7,8-HpCDD	4.0	3.45	86.2	40:37	1.04	
13C12-OCDD	8.0	6.12	76.5	45:06	0.89	
13C12-2,3,7,8-TCDF	4.0	3.58	89.5	31:07	0.80	
13C12-1,2,3,7,8-PeCDF	4.0	2.29	57.2	33:37	1.57	
13C12-1,2,3,6,7,8-HxCDF	4.0	2.98	74.6	36:28	0.53	
13C12-1,2,3,4,6,7,8-HpCDF	4.0	2.91	72.7	39:19	0.45	
Sampling Standards						
37Cl4-2,3,7,8-TCDD	4.0	4.70	117	31:40	-	
13C12-2,3,4,7,8-PeCDF	4.0	4.05	101	34:15	1.57	
13C12-1,2,3,4,7,8-HxCDD	4.0	4.21	105	37:06	1.28	
13C12-1,2,3,4,7,8-HxCDF	4.0	4.60	115	36:22	0.52	
13C12-1,2,3,4,7,8,9-HpCDF	4.0	4.83	121	41:19	0.45	
Injection Standards						
13C12-1,2,3,4-TCDD	2.0	-	-	31:15	0.78	
13C12-1,2,3,7,8,9-HxCDD	2.0	-	-	37:27	1.24	

Client Information		Sample Information	
Project Name:	snc-07-benson.mn-comp#1	Matrix:	Air
Sample ID:	B	Weight / Volume:	1 train
Laboratory Information		Solids / Lipids:	NA %
Project ID:	G431-15	Original pH :	NA
Sample ID:	G431-15-20B	Batch ID:	WG14370
Collection Date/Time:	07/04/07	Instrument:	HRMS1
Receipt Date/Time:	07/11/07	Filename:	a24jul07a-8
Extraction Date:	07/22/07	Retchk:	a24jul07a-1
Analysis Date/Time:	07/24/07	Begin ConCal:	a24jul07a-1
		End ConCal:	a24jul07a-11
		Initial Cal:	m8290-071007a

Form Version:[8290_DB_2.14]Report

Analyzed by: HMP
Date: 26jul07Reviewed by: SPJ
Date: 7/30/07


Filename : a24jul07a
Sample : 8
Acquired : 24-JUL-07
Processed : 25-JUL-07
Sample ID : G431-15-20
Cal Table : nr8290-0710
Results Table : nr8290-0724


Totals Report


SCS Environmental Services, INC.		Thu Jul 26 15:28:52 EDT 2007									
		Acquired: 2007-07-24 21:44:52									
		Processed: 2007-07-25 08:11:48									
Results:											
File name:	a24ju07a-8	Name	AreaSum	Ion1Area	Ion2Area	IR ?	RT	Conc	EDL	Status	Height1
Results:		2378-TCDD	0.00E+00	0.00E+00	0.00E+00	0 N	0:00	0	0.2748	S2N	0.00E+00
Sample Text:	G431-15-20B										
Total Tetra-Dioxins	Ent Type										
Total Tetra-Furans	Ent Type										
Total Penta-Dioxins	Ent Type										
Total Penta-Furans	Ent Type										
Total Hexa-Dioxins	Ent Type										


Totals Report


Total Hexa-Furans											
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status
		234678-HxCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.3442	S2N
		123478-HxCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.3464	S2N
		123799-HxCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.4008	S2N
		123678-HxCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.3264	S2N
		Total EMPC Hexa-Furans				EDL		0.4008		Peaks	0
		Total EMPC Hexa-Furans						0		Peaks	0
Total Hepta-Dioxins											
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status
		1234678-HpCDD	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.6689	S2N
		Total EMPC Hepta-Dioxins				EDL		0.6689		Peaks	0
		Total EMPC Hepta-Dioxins						0		Peaks	0
Total Hepta-Furans											
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status
		123478-HpCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.5139	S2N
		1234678-HpCDF	2.26E+05	1.14E+05	1.12E+05	1.02	Y	39.19	0.968	0.4051	OK
		Total EMPC Hepta-Furans				EDL		0.5139		Peaks	1
		Total EMPC Hepta-Furans						0.5139		Peaks	1
		Total EMPC Hepta-Furans						0.968		Peaks	1
Total Hexa-Furans											
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status
		234678-HxCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.00E+00	Noise1
		123478-HxCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.00E+00	SN1
		123799-HxCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.00E+00	SN1
		123678-HxCDF	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.00E+00	SN1
		Total EMPC Hexa-Furans				EDL		0.4770		Peaks	0
		Total EMPC Hexa-Furans						0.4770		Peaks	0
		Total EMPC Hexa-Furans						0.4770		Peaks	0
Total Hepta-Furans											
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status
		234678-HpCDD	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.00E+00	Noise1
		123478-HpCDF	2.26E+05	1.14E+05	1.12E+05	1.02	Y	39.19	0.968	0.4051	SN2
		Total EMPC Hepta-Furans				EDL		0.5139		Peaks	1
		Total EMPC Hepta-Furans						0.5139		Peaks	1
Total Hepta-Dioxins											
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status
		234678-HpCDD	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.00E+00	Noise1
		123478-HpCDF	2.26E+05	1.14E+05	1.12E+05	1.02	Y	39.19	0.968	0.4051	SN2
		Total EMPC Hepta-Dioxins				EDL		0.6689		Peaks	0
		Total EMPC Hepta-Dioxins						0.6689		Peaks	0
Total Hexa-Dioxins											
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status
		234678-HpCDD	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.00E+00	Noise1
		123478-HpCDF	2.26E+05	1.14E+05	1.12E+05	1.02	Y	39.19	0.968	0.4051	SN2
		Total EMPC Hexa-Dioxins				EDL		0.6689		Peaks	0
		Total EMPC Hexa-Dioxins						0.6689		Peaks	0
Total Hepta-Dioxins											
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status
		234678-HpCDD	0.00E+00	0.00E+00	0.00E+00	0	N	0.00	0	0.00E+00	Noise1
		123478-HpCDF	2.26E+05	1.14E+05	1.12E+05	1.02	Y	39.19	0.968	0.4051	SN2
		Total EMPC Hepta-Dioxins				EDL		0.6689		Peaks	0
		Total EMPC Hepta-Dioxins						0.6689		Peaks	0














File:A24JUL07A #1-399 Acq:24-JUL-2007 21:44:52 GC EI+ Voltage SIR Autospec UltimaE
 Sample#8 Text:G431-15-20B Exp:EXP_DB5MS
 303.9016 S:8 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,4044.0,5.00%,F,T)
 100%




305.8987 S:8 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,5236.0,5.00%,F,T)
 100%




315.9419 S:8 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4144.0,5.00%,F,T)
 100%



317.9389 S:8 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5352.0,5.00%,F,T)
 100%



375.8364 S:8 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,5600.0,5.00%,F,T)
 100%



304.9824 S:8 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)
 100%



File:A24JUL07A #1-184 Acq:24-JUL-2007 21:44:52 GC EI+ Voltage SIR Autospec-UltimaE

Sample#8 Text:G431-15-20B

339.8597 S:8 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5300.0,5.00%,F,T)

100%

33:05 33:24 33:32 33:38 33:48 33:48 34:01 34:10 34:39 34:48

50 50

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00

0 0

341.8568 S:8 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4220.0,5.00%,F,T)

100%

32:58 33:14 33:20 33:32 33:38 33:44 33:54 34:10 34:15 34:24 34:30 34:47

50 50

32:44 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00

0 0

351.9000 S:8 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5764.0,5.00%,F,T)

100%

33:38 34:15

50 50

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00

0 0

353.8970 S:8 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5232.0,5.00%,F,T)

100%

33:38 34:14

50 50

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00

0 0

409.7974 S:8 F:2 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,5572.0,5.00%,F,T)

100%

32:58 33:19 33:28 33:38 33:48 34:05 34:02 34:23 34:44

50 50

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00

0 0

366.9792 S:8 F:2 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)


100%

33:29 33:47 33:56 33:47 33:56 34:04 34:21 34:33 34:46


50 50

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00



0 0




File:A24JUL07A #1-292 Acq:24-JUL-2007 21:44:52 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#8 Text:G431-15-20B Exp:EXP_DB5MS
 407.7818 S:8 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4016.0,5.00%,F,T)
 100%
 39:22





File:A24JUL07A #1-292 Acq:24-JUL-2007 21:44:52 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#8 Text:G431-15-20B Exp:EXP_DB5MS
 407.7818 S:8 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4016.0,5.00%,F,T)
 100% 39:22





File:A24JUL07A #1-369 Accq:24-JUL-2007 21:44:52 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#8 Text:G431-15-20B Exp:EXP_DB5MS
 441.7427 S:8 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4228.0,5.00%,F,T)
 100%





Method M23
Lab Method Blank

Analytical Data Summary Sheet

Analyte	Amount (ng)	EDL (ng)	EMPC (ng)	RT (min.)	Ratio	Qualifier
2,3,7,8-TCDD	ND	0.00478				
1,2,3,7,8-PeCDD	ND	0.00523				
1,2,3,4,7,8-HxCDD	ND	0.00732				
1,2,3,6,7,8-HxCDD	ND	0.00745				
1,2,3,7,8,9-HxCDD	ND	0.00756				
1,2,3,4,6,7,8-HpCDD	ND	0.0138				
OCDD	ND	0.0230				
2,3,7,8-TCDF	ND	0.00374				
1,2,3,7,8-PeCDF	ND	0.00500				
2,3,4,7,8-PeCDF	ND	0.00500				
1,2,3,4,7,8-HxCDF	ND	0.00525				
1,2,3,6,7,8-HxCDF	ND	0.00500				
2,3,4,6,7,8-HxCDF	ND	0.00522				
1,2,3,7,8,9-HxCDF	ND	0.00607				
1,2,3,4,6,7,8-HpCDF	0.0176			39:21	1.00	A
1,2,3,4,7,8,9-HpCDF	ND	0.00731				
OCDF	ND	0.0236				
Total TCDDs	ND	0.00478				
Total PeCDDs	ND	0.00523				
Total HxCDDs	ND	0.00756				
Total HpCDDs	ND	0.0138				
Total TCDFs	ND	0.00374				
Total PeCDFs	ND	0.00500				
Total HxCDFs	ND	0.00607				
Total HpCDFs	0.0176					
WHO-2005 TEQ (ND=0)	0.000176		0.000176			
WHO-2005 TEQ (ND=½)	0.00850		0.00850			

Client Information		Sample Information	
Project Name:			
Sample ID:	Lab Method Blank	Matrix:	Air
		Weight / Volume:	1 train
		Solids / Lipids:	NA %
		Original pH :	NA
		Batch ID:	WG14370
Laboratory Information		Instrument:	HRMS1
Project ID:		Filename:	a24jul07a-4
Sample ID:		Retchk:	a24jul07a-1
Collection Date/Time:		Begin ConCal:	a24jul07a-1
Receipt Date/Time:		End ConCal:	a24jul07a-11
Extraction Date:	07/22/07	Initial Cal:	m8290-071007a
Analysis Date/Time:	07/24/07 18:31		

Method M23
Lab Method Blank

Labeled Standard	Expected Amount (ng)	Measured Amount (ng)	Percent Recovery (%)	RT (min.)	Ratio	Qualifier
Extraction Standards						
13C12-2,3,7,8-TCDD	4.0	3.42	85.4	31:39	0.78	
13C12-1,2,3,7,8-PeCDD	4.0	3.22	80.4	34:25	1.58	
13C12-1,2,3,6,7,8-HxCDD	4.0	3.87	96.7	37:12	1.25	
13C12-1,2,3,4,6,7,8-HpCDD	4.0	3.52	87.9	40:37	1.04	
13C12-OCDD	8.0	5.63	70.4	45:06	0.89	
13C12-2,3,7,8-TCDF	4.0	3.78	94.6	31:07	0.79	
13C12-1,2,3,7,8-PeCDF	4.0	2.87	71.8	33:37	1.58	
13C12-1,2,3,6,7,8-HxCDF	4.0	3.57	89.2	36:28	0.52	
13C12-1,2,3,4,6,7,8-HpCDF	4.0	3.17	79.3	39:19	0.44	
Sampling Standards						
37Cl4-2,3,7,8-TCDD	4.0	4.54	113	31:40	-	
13C12-2,3,4,7,8-PeCDF	4.0	4.55	114	34:15	1.57	
13C12-1,2,3,4,7,8-HxCDD	4.0	4.22	105	37:07	1.26	
13C12-1,2,3,4,7,8-HxCDF	4.0	4.31	108	36:22	0.52	
13C12-1,2,3,4,7,8,9-HpCDF	4.0	3.93	98.4	41:19	0.45	
Injection Standards						
13C12-1,2,3,4-TCDD	2.0	-	-	31:15	0.80	
13C12-1,2,3,7,8,9-HxCDD	2.0	-	-	37:27	1.24	

Client Information		Sample Information	
Project Name:			
Sample ID:	Lab Method Blank	Matrix:	Air
		Weight / Volume:	1 train
		Solids / Lipids:	NA %
		Original pH :	NA
Laboratory Information		Batch ID:	WG14370
Project ID:		Instrument:	HRMS1
Sample ID:		Filename:	a24jul07a-4
Collection Date/Time:		Retchk:	a24jul07a-1
Receipt Date/Time:		Begin ConCal:	a24jul07a-1
Extraction Date:	07/22/07	End ConCal:	a24jul07a-11
Analysis Date/Time:	07/24/07 18:31	Initial Cal:	m8290-071007a

Analyzed by: HMP
Date: 26jul07

Reviewed by: CDP
Date: 7/24/07

Form Version: [8290_DB_2.14]Report


Filename : a24jul07a
 Sample : 4
 Acquired : 24-JUL-07 18:31:27
 Processed : 25-JUL-07 08:10:24
 Sample ID : LMB14370
 Cal Table : n8290-071007a
 Results Table : n8290-072407a
 Comments :
 Resp: Ion 1; Ion 2; RA;?; RT;
 Conc: EDL; S/N1;?; S/N2;?;M; Signal1; Noise 1; Signal2; Noise 2
 Ent; Name:
 1 ; 2,3,7,8-TCDD; *; *; *; *; NotFnd; *; 0.2392; *; 4.71e+03; *; 5.21e-03
 1 ; 1,2,3,7,8-PeCDF; *; *; *; *; NotFnd; *; 0.2614; *; 5.65e+03; *; 5.00e-03
 2 ; 1,2,3,4,7,8-HxCDD; *; *; *; *; NotFnd; *; 0.3658; *; 4.94e+03; *; 5.05e-03
 3 ; 1,2,3,4,7,8-HxCDF; *; *; *; *; NotFnd; *; 0.3723; *; 4.94e+03; *; 5.05e-03
 4 ; 1,2,3,6,7,8-HxCDD; *; *; *; *; NotFnd; *; 0.3779; *; 4.94e+03; *; 5.05e-03
 5 ; 1,2,3,7,8,9-HxCDD; *; *; *; *; NotFnd; *; 0.6875; *; 5.19e+03; *; 5.28e-03
 6 ; 1,2,3,4,6,7,8-HpCDFD; *; *; *; *; NotFnd; 0.210; 1.1476; 1;n;n; 4.65e+03; 4.25e+03; 5.88e+03; 4.00e+03
 7 ; OCDD; 2.55e+04; 4.99e+03; 2.05e+04; 0.24;n; 45:07; *; *; *; *; NotFnd; *; 0.1870; *; n;n;
 8 ; 2,3,7,8-TCDF; *; *; *; *; NotFnd; *; 0.1673; *; n;n;
 9 ; 1,2,3,7,8-PeCDF; *; *; *; *; NotFnd; *; 0.1613; *; n;n;
 10 ; 2,3,4,7,8-PeCDF; *; *; *; *; NotFnd; *; 0.2625; *; n;n;
 11 ; 1,2,3,4,7,8-HxCDF; *; *; *; *; NotFnd; *; 0.2473; *; n;n;
 12 ; 1,2,3,6,7,8-HxCDF; *; *; *; *; NotFnd; *; 0.2608; *; n;n;
 13 ; 2,3,4,6,7,8-HxCDF; *; *; *; *; NotFnd; *; 0.3037; *; n;n;
 14 ; 1,2,3,7,8,9-HxCDF; *; *; *; *; NotFnd; *; 0.441; 0.2881; 5;Y; 5;Y; 1.89e+04; 3.66e+03; 1.87e+04; 3.83e+03
 15 ; 1,2,3,4,6,7,8-HpCDF; 1.19e+05; 5.95e+04; 5.97e+04; 1.00;Y; 39:21; *; *; *; *; NotFnd; *; 0.3655; *; n;n;
 16 ; 1,2,3,4,7,8-HpCDF; 1.31e+05; 5.74e+04; 7.37e+04; 0.78;Y; 45:26; 0.891; 1.1799; 2;n; 3;N;Y; 9.39e+03; 5.20e+03; 1.33e+04; 5.10e+03
 17 ; OCDF; 1.31e+05; 5.74e+04; 7.37e+04; 0.78;Y; 45:26; 0.891; 1.1799; 2;n;
 Extraction Standards
 18 ; 13C-2,3,7,8-TcDD; 3.21e+07; 1.40e+07; 1.81e+07; 0.78;Y; 31:39; 85.443; 0.2007; 1247;Y; 1758;Y;n; 5.55e+06; 4.46e+03; 7.28e+06; 4.14e+03
 19 ; 13C-1,2,3,7,8-PeCDF; 2.50e+07; 1.53e+07; 9.68e+06; 1.58;Y; 34:26; 80.332; 0.2420; 1818;Y; 981;Y;n; 7.21e+06; 3.96e+03; 4.52e+06; 4.60e+03
 20 ; 13C-1,2,3,6,7,8-HxCDD; 2.38e+07; 1.32e+07; 1.06e+07; 1.25;Y; 37:12; 96.679; 0.3697; 897;Y; 761;Y;n; 4.60e+06; 5.12e+03; 3.73e+06; 4.90e+03
 21 ; 13C-1,2,3,4,6,7,8-HpCDF; 1.68e+07; 8.60e+06; 8.24e+06; 1.04;Y; 40:38; 87.885; 0.4454; 461;Y; 458;Y;n; 2.21e+06; 4.76e+03; 2.11e+06; 4.61e+03
 22 ; 13C-1,2,3,4,6,7,8-HpCDF; 2.25e+07; 1.06e+07; 1.19e+07; 0.89;Y; 45:06; 140.709; 0.5441; 389;Y; 449;Y;n; 1.90e+06; 4.88e+03; 2.10e+06; 4.68e+03
 23 ; 13C-2,3,7,8-TCDF; 4.64e+07; 2.05e+07; 2.59e+07; 0.79;Y; 31:07; 94.621; 0.1638; 1223;Y; 2325;Y;n; 6.79e+06; 5.56e+03; 8.36e+06; 3.50e+03
 24 ; 13C-1,2,3,7,8-PeCDF; 3.66e+07; 2.24e+07; 1.42e+07; 1.58;Y; 33:38; 71.796; 0.2106; 1332;Y; 1344;Y;n; 9.89e+06; 7.42e+03; 6.47e+06; 4.82e+03
 25 ; 13C-1,2,3,6,7,8-HxCDF; 2.94e+07; 1.01e+07; 1.93e+07; 0.52;Y; 36:29; 89.219; 0.2892; 619;Y; 1352;Y;n; 3.49e+06; 5.61e+03; 6.57e+06; 4.86e+03
 26 ; 13C-1,2,3,4,6,7,8-HpCDF; 1.94e+07; 5.92e+06; 1.35e+07; 0.44;Y; 39:20; 79.338; 0.3562; 351;Y; 824;Y;n; 1.72e+06; 4.90e+03; 3.87e+06; 4.69e+03
 Injection Standards
 27 ; 13C-1,2,3,4-TcDD; 3.56e+07; 1.58e+07; 1.98e+07; 0.80;Y; 31:15; 43.690; -; 1228;Y; 1611;Y;n; 5.47e+06; 4.46e+03; 6.57e+06; 4.14e+03
 28 ; 13C-1,2,3,7,8,9-HxCDD; 2.36e+07; 1.31e+07; 1.06e+07; 1.24;Y; 37:27; -; 848;Y; 707;Y;n; 4.35e+06; 5.12e+03; 3.47e+06; 4.90e+03
 Cleanup Standards
 29 ; 37C1-2,3,7,8-TcDD; 3.72e+07; 3.72e+07; 1.59e+07; -; 31:40; 96.889; 0.1236; 2803;Y; -;-;n; 1.52e+07; 7.5.41e+03; -; -;
 30 ; 13C-2,3,4,7,8-PeCDF; 4.09e+07; 2.50e+07; 1.57;Y; 34:15; 81.7145; 0.2145; 1434;Y; 1440;Y;n; 1.06e+07; 7.42e+03; 6.93e+06; 4.82e+03
 31 ; 13C-1,2,3,4,7,8-HxCDD; 2.39e+07; 1.33e+07; 1.06e+07; 1.26;Y; 37:07; 101.984; 0.3891; 847;Y; 703;Y;n; 4.34e+06; 5.12e+03; 3.44e+06; 4.90e+03
 32 ; 13C-1,2,3,4,7,8-HpCDF; 2.85e+07; 9.74e+06; 1.88e+07; 0.52;Y; 36:23; 96.271; 0.3225; 622;Y; 1368;Y;n; 3.50e+06; 5.63e+03; 6.44e+06; 4.86e+03
 33 ; 13C-1,2,3,4,7,8,9-HpCDF; 1.70e+07; 5.26e+06; 1.18e+07; 0.45;Y; 41:20; 78.039; 0.3994; 271;Y; 611;Y;n; 1.33e+06; 4.90e+03; 2.87e+06; 4.69e+03
 Sampling Standards
 34 ; 37C1-2,3,7,8-TcDD; 3.72e+07; 3.72e+07; 1.59e+07; 1.57;Y; 34:15; 113.405; 0.1240; 2803;Y; -;-;n; 1.52e+07; 7.5.41e+03; -; -;
 35 ; 13C-2,3,4,7,8-PeCDF; 4.09e+07; 2.50e+07; 1.57;Y; 34:15; 113.762; 0.2277; 1434;Y; 1440;Y;n; 1.06e+07; 7.42e+03; 6.93e+06; 4.82e+03
 36 ; 13C-1,2,3,4,7,8-HxCDD; 2.39e+07; 1.33e+07; 1.06e+07; 1.26;Y; 37:07; 105.485; 0.3800; 847;Y; 703;Y;n; 4.34e+06; 5.12e+03; 3.44e+06; 4.90e+03
 37 ; 13C-1,2,3,4,7,8-HpCDF; 2.85e+07; 9.74e+06; 1.88e+07; 0.52;Y; 36:23; 107.851; 0.3468; 622;Y; 1368;Y;n; 3.50e+06; 5.63e+03; 6.44e+06; 4.86e+03
 38 ; 13C-1,2,3,4,7,8,9-HpCDF; 1.70e+07; 5.26e+06; 1.18e+07; 0.45;Y; 41:20; 98.367; 0.5756; 271;Y; 611;Y;n; 1.33e+06; 4.90e+03; 2.87e+06; 4.69e+03

Totals Report


SGS Environmental Services, INC.		Thu Jul 26 14:36:57 EDT 2007															
Acquired: 2007-07-24 18:31:27		Processed: 2007-07-25 08:10:24															
Cat: m8280-071007a																	
Sample Text: LMB14370																	
Total Tetra-Dioxins	Ent Type	Name	AreaSum	Ion1Area	Ion2Area	IR ?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	SN2	Mod
		2378-TCDD	0.00E+00	0.00E+00	0.00E+00	0 N	0.00	0	0.2392	S2N	0.00E+00	4710	0	0.00E+00	5210	0	n
									Total EMPC Tetra-Dioxins								
									EDL	0	Peaks	0					
Total Tetra-Furans	Ent Type	Name	AreaSum	Ion1Area	Ion2Area	IR ?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	SN2	Mod
		2378-TCDF	0.00E+00	0.00E+00	0.00E+00	0 N	0.00	0	0.187	S2N	0.00E+00	5420	0	0.00E+00	5170	0	n
									Total EMPC Tetra-Furans								
									EDL	0	Peaks	0					
Total Penta-Dioxins	Ent Type	Name	AreaSum	Ion1Area	Ion2Area	IR ?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	SN2	Mod
		12378-PeCDF	0.00E+00	0.00E+00	0.00E+00	0 N	0.00	0	0.2614	S2N	0.00E+00	5650	0	0.00E+00	5000	0	n
									Total EMPC Penta-Dioxins								
									EDL	0	Peaks	0					
Total Penta-Furans	Ent Type	Name	AreaSum	Ion1Area	Ion2Area	IR ?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	SN2	Mod
		12378-PeCDF	0.00E+00	0.00E+00	0.00E+00	0 N	0.00	0	0.1673	S2N	0.00E+00	4480	0	0.00E+00	4660	0	n
									Total EMPC Penta-Furans								
									EDL	0	Peaks	0					
Total Hexa-Dioxins	Ent Type	Name	AreaSum	Ion1Area	Ion2Area	IR ?	RT	Conc	EDL	Status	Height1	Noise1	SN1	Height2	Noise2	SN2	Mod
		123678-HxCDD	0.00E+00	0.00E+00	0.00E+00	0 N	0.00	0	0.3723	S2N	0.00E+00	4940	0	0.00E+00	5050	0	n
									Total Hexa-Dioxins								
									EDL	0	Peaks	0					
									Total EMPC Hexa-Dioxins								
									EDL	0	Peaks	0					

Totals Report

Total Hexa-Furans															
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status	Height1	SN1	Height2	Noise2
234678-HxCDF	0.00E+00	0.00E+00	0.00E+00	0 N	0:00	0				S2N	0.00E+00	5110	0	0.00E+00	4530
123678-HxCDF	0.00E+00	0.00E+00	0.00E+00	0 N	0:00	0				S2N	0.00E+00	5110	0	0.00E+00	4530
123478-HxCDF	0.00E+00	0.00E+00	0.00E+00	0 N	0:00	0				S2N	0.00E+00	5110	0	0.00E+00	4530
123789-HxCDF	0.00E+00	0.00E+00	0.00E+00	0 N	0:00	0				S2N	0.00E+00	5110	0	0.00E+00	4530
						EDL									
				Total EMPC	Hexa-Furans			0	Peaks	0					
				Total EMPC	Hexa-Furans			0	Peaks	0					
Total Hepta-Dioxins															
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status	Height1	SN1	Height2	Noise2
1234678-HpCDF	0.00E+00	0.00E+00	0.00E+00	0 N	0:00	0				S2N	0.00E+00	5190	0	0.00E+00	5280
						EDL									
				Total EMPC	Hepta-Dioxins			0	Peaks	0					
				Total EMPC	Hepta-Dioxins			0	Peaks	0					
Total Hepta-Furans															
Ent	Type	Name	AreaSum	Ion1Area	Ion2Area	IR	?	RT	Conc	EDL	Status	Height1	SN1	Height2	Noise2
1234789-HpCDF	0.00E+00	0.00E+00	0.00E+00	0 N	0:00	0				S2N	0.00E+00	3660	0	0.00E+00	3830
1234678-HpCDF	1.19E+05	5.95E+04	5.97E+04	1 Y	39:21	0.441				OK	1.89E+04	3660	5	1.87E+04	3830
						EDL									
				Total EMPC	Hepta-Furans			0.441	Peaks	1					
				Total EMPC	Hepta-Furans			0.441	Peaks	1					




File #I-184 Acq:24-JUL-2007 18:31:27 GC EI+ Voltage SIR Autospec-UltimaE
Text:LMB14370 Exp:EXP_DB5MS




File:A24JUL07A #1-252 Acq:24-JUL-2007 18:31:27 GC EI+ Voltage SIR Autospec-Ultimate

Sample#4 Text:LMB14370


389.8156 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4940.0,5.00%,F,T)




391.8127 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.018,5052.0,5.00%,F,T)




401.8559 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.018,5124.0,5.00%,F,T)



403.8530 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4900.0,5.00%,F,T)








380.9760 S:4 F:3 SMO(1,3) PKD(3,2,1,100.00%,0,5.00%,F,T)




File:A24JUL07A #1-292 Acq:24-JUL-2007 18:31:27 GC EI+ Voltage SIR Autospec-Ultimate

Sample#4 Text:LMB14370 Exp:EXP_DB5MS


423.7767 S:4 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,5188.0,5.00%,F,T)






File:A24JUL07A #1-399 Acq:24-JUL-2007 18:31:27 GC EI+ Voltage SIR Autospec-Ultimate


Sample#4 Text:LMB14370 Exp:EXP_DB5MS
303.9016 S:4 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,5420.0,5.00%,F,T)




305.8987 S:4 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,5172.0,5.00%,F,T)
26:15 26:57 27:24 27:52 28:17 28:37 29:09 29:55 30:30 30:40 31:09 31:22 31:48 32:08




315.9419 S:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5556.0,5.00%,F,T)
100%




317.9389 S:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3596.0,5.00%,F,T)
100%




375.83364 S:4 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,5380.0,5.00%,F,T)
100% 26:26:46 27:28 28:08 28:32 28:57 29:20 29:46 30:07 30:35 31:01 31:23 31:42 32:23 7.6E3



304.9824 S:4 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)
26:34 26:54 27:16 27:45 28:28 29:02 29:22 29:46 30:13 30:50 31:27 31:57 32:27 4.3E6
100%





File:A24JUL07A #1-252 Acq:24-JUL-2007 18:31:27 GC EI+ Voltage SIR Autospec-Ultimate

Sample#4 Text:LMB14370 Exp:EXP DB5MS

373.8207 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.018,5112.0,5.00%,F,T)

100%

36:25

1.0E4

5.2E3

0.0E0

37:54

37:02

Time



375.8178 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4528.0,5.00%,F,T)

100%

36:23

7.9E3


4.0E3

0.0E0

38:10

37:56

Time



383.8639 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.018,5632.0,5.00%,F,T)

100%

36:23

3.5E6

1.8E6

0.0E0

38:12

37:56

Time



385.8610 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4856.0,5.00%,F,T)

100%

36:23

6.6E6

3.3E6

0.0E0

38:12

37:56

Time



445.7555 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,5580.0,5.00%,F,T)

100%


35:42

7.8E3

37:05

38:05

Time



380.9760 S:4 F:3 SMO(1,3) PKD(3,2,1,100.00%,0,5.00%,F,T)

100%

36:14

7.6E6


3.8E6

0.0E0

38:15

37:55

Time



File:A24JUL07A #1-292 Acq:24-JUL-2007 18:31:27 GC EI+ Voltage SIR Autospec-Ultimate

Sample#4 Text:LMB14370

407.7818 S:4 F:4 BSUB(128,15,-3.0)

100%

PRD(3,2,1,0.01%,3656.0,5.00%,F,T)


39:21

Exp:EXP DB5MS

2.2E4

1.1E4

0.0E0



409.7788 S:4 F:4 BSUB(128,15,-3.0)

100%

PRD(3,2,1,0.01%,3832.0,5.00%,F,T)

39:21

Exp:EXP DB5MS

2.2E4

1.1E4

0.0E0



417.8253 S:4 F:4 BSUB(128,15,-3.0)

100%

PRD(3,2,1,0.01%,4904.0,5.00%,F,T)


39:20

Exp:EXP DB5MS

2.2E4

1.1E4

0.0E0



419.82220 S:4 F:4 BSUB(128,15,-3.0)

100%

PRD(3,2,1,0.01%,4692.0,5.00%,F,T)

39:20

Exp:EXP DB5MS

2.2E4

1.1E4

0.0E0



479.7165 S:4 F:4 BSUB(128,15,-3.0)

100%

PRD(3,2,1,100.00%,5756.0,5.00%,F,T)


39:00

Exp:EXP DB5MS

2.2E4

1.1E4


0.0E0



8.4E3

4.2E3

0.0E0



8.4E3

4.2E3

0.0E0




8.4E3

4.2E3

0.0E0

File:A24JUL07A #1-292 Acq:24-JUL-2007 18:31:27 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#4 Text:LMB14370
 Exp:EXP_DB5MS
 407.7818 S:4 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3656.0,5.00%,F,T)
 100% 39:21




File:A24JUL07A #1-368 Acq:24-JUL-2007 18:31:27 GC EI+ Voltage SIR Autospec-Ultimae

Sample#4 Text: LMB14370

Exp: EXP_DBSMS

441.7427 S:4 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5196.0,5.00%,F,T)

100%




443.7398 S:4 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5096.0,5.00%,F,T)

100%




469.7780 S:4 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4876.0,5.00%,F,T)

100%




471.7750 S:4 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4684.0,5.00%,F,T)

100%



513.6775 S:4 F:5 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,4392.0,0.5.00%,F,T)

100%




454.9728 S:4 F:5 SMO (1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)

100%







File:A24JUL07A #1-368 Acq:24-JUL-2007 18:31:27 GC EI+ Voltage SIR Autospec-Ultimae
 Sample#4 Text:LMB14370
 Exp:EXP_DB5MS
 441.7427 S:4 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5196.0,5.00%,F,T)
 100%



File:A24JUL07A #1-399 Accq:24-JUL-2007 18:31:27 GC EI+ Voltage SIR Autospec-UltimaE

Sample#4 Test:JMB14370

341.8568 S:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5460.0,5.00%,F,T)



Analytical Results
for
Ongoing Precision Result (OPR)

Analyte	Spiked (pg/ μ L)	AMT (pg/ μ L)	REC %	Range %	Qualifier
				Lower	Upper
2,3,7,8-TCDD	10	10.7	107	70.0	130
1,2,3,7,8-PeCDD	50	49.9	99.7	70.0	130
1,2,3,4,7,8-HxCDD	50	48.2	96.3	70.0	130
1,2,3,6,7,8-HxCDD	50	49.8	99.7	70.0	130
1,2,3,7,8,9-HxCDD	50	48.8	97.7	70.0	130
1,2,3,4,6,7,8-HpCDD	50	50.5	101	70.0	130
OCDD	100	100	100	70.0	130
2,3,7,8-TCDF	10	9.26	92.6	70.0	130
1,2,3,7,8-PeCDF	50	50.6	101	70.0	130
2,3,4,7,8-PeCDF	50	47.6	95.2	70.0	130
1,2,3,4,7,8-HxCDF	50	49.5	98.9	70.0	130
1,2,3,6,7,8-HxCDF	50	49.3	98.6	70.0	130
2,3,4,6,7,8-HxCDF	50	47.6	95.2	70.0	130
1,2,3,7,8,9-HxCDF	50	44.7	89.4	70.0	130
1,2,3,4,6,7,8-HpCDF	50	51.7	103	70.0	130
1,2,3,4,7,8,9-HpCDF	50	47.1	94.2	70.0	130
OCDF	100	91.4	91.4	70.0	130

= Outside range limits

* = Ion Ratio Out

QC Information

OPR Project No: OPR14370
 Extraction Date: 22-Jul-07
 Analysis Date: 24-Jul-07
 Method: M23

File Information

OPR Filename: a24jul07a-2
 Retchk: a24jul07a-1
 Begin ConCal: a24jul07a-1
 End ConCal: a24jul07a-11
 Initial Cal: m8290-071007a

Sample Information

Matrix: Air

Analytical Results
for
Ongoing Precision Result (OPR)

Labeled Standard	Expected Amount (ng)	Measured Amount (ng)	Percent Recovery (%)	RT (min.)	Ratio	Qualifier
Extraction Standards						
13C12-2,3,7,8-TCDD	4	3.48	86.9	31:39	0.78	
13C12-1,2,3,7,8-PeCDD	4	3.13	78.3	34:25	1.58	
13C12-1,2,3,6,7,8-HxCDD	4	3.97	99.2	37:12	1.25	
13C12-1,2,3,4,6,7,8-HpCDD	4	3.66	91.4	40:37	1.05	
13C12-OCDD	8	5.93	74.2	45:06	0.89	
13C12-2,3,7,8-TCDF	4	3.90	97.6	31:07	0.79	
13C12-1,2,3,7,8-PeCDF	4	3.03	75.7	33:37	1.58	
13C12-1,2,3,6,7,8-HxCDF	4	3.73	93.4	36:28	0.52	
13C12-1,2,3,4,6,7,8-HpCDF	4	3.37	84.3	39:19	0.45	
Sampling Standards						
37Cl4-2,3,7,8-TCDD	4.0	4.62	116	31:40	-	
13C12-2,3,4,7,8-PeCDF	4.0	4.21	105	34:15	1.58	
13C12-1,2,3,4,7,8-HxCDD	4.0	4.12	103	37:07	1.26	
13C12-1,2,3,4,7,8-HxCDF	4.0	4.36	109	36:22	0.52	
13C12-1,2,3,4,7,8,9-HpCDF	4.0	4.19	105	41:19	0.46	
Injection Standards						
13C12-1,2,3,4-TCDD	2	-	-	31:15	0.78	
13C12-1,2,3,7,8,9-HxCDD	2	-	-	37:27	1.24	

<u>QC Information</u>	<u>File Information</u>
OPR Project No:	OPR14370
Extraction Date:	22-Jul-07
Analysis Date:	24-Jul-07
Method:	M23
	OPR Filename : a24jul07a-2
	Retchk: a24jul07a-1
	Begin ConCal: a24jul07a-1
	End ConCal: a24jul07a-11
	Initial Cal: m8290-071007a
<u>Sample Information</u>	
Matrix:	Air

Form Version:[8290_DB_2.14]OPR

Reviewed By: DR

Date Reviewed: 7/24/07


Filename : a24jul07a
 Sample : 2
 Acquired : 24-JUL-07 16:54:46
 Processed : 25-JUL-07 08:09:42
 Sample ID : OPR14370
 Cal. Table : m8290-071007a
 Results Table : M8290-072407A
 Comments :

Ent;	Name;	Resp;	Ion 1;	Ion 2;	RA;?	RT;	Conc;	EDL;	S/NL;?	S/N2;?	M; Signal1; Noise 1; Signal2; Noise 2
1 ;	2,3,7,8-TCDFF; 3.65e+06; 1.61e+06; 2.04e+06; 0.79;Y;	31:40;	10.709;	0.2533;	125;Y;	159;Y;n:6.59e-05;5.28e+03;8.49e+05;5.34e+03					
2 ;	1,2,3,7,8-PeCDF; 1.36e+07; 8.35e+06; 5.29e+06; 1.58;Y;	34:27;	49.863;	0.2351;	711;Y;	535;Y;n:3.57e+06;5.01e+03;2.28e+06;4.26e+03					
3 ;	1,2,3,4,7,8-HxCDD; 1.22e+07; 6.80e+06; 5.49e+06; 1.26;Y;	37:07;	48.165;	0.2924;	532;Y;	464;Y;n:2.36e+06;4.00e+03;1.95e+06;4.21e+03					
4 ;	1,2,3,6,7,8-HxCDD; 1.24e+07; 6.89e+06; 5.49e+06; 1.25;Y;	37:12;	49.828;	0.2976;	572;Y;	425;Y;n:2.28e+06;4.00e+03;1.79e+06;4.21e+03					
5 ;	1,2,3,7,8-HxCDD; 1.20e+07; 6.60e+06; 5.35e+06; 1.23;Y;	37:28;	48.844;	0.3020;	556;Y;	422;Y;n:2.22e+06;4.00e+03;1.77e+06;4.21e+03					
6 ;	1,2,3,4,6,7,8-HpCDF; 9.84e+06; 5.05e+06; 4.79e+06; 1.05;Y;	40:39;	50.478;	0.5667;	280;Y;	296;Y;n:1.34e+06;4.76e+03;1.27e+06;4.31e+03					
7 ;	OCDD; 1.34e+07; 6.35e+06; 7.08e+06; 0.90;Y;	45:07;	99.977;	1.1473;	247;Y;	277;Y;n:1.12e+06;4.54e+03;1.23e+06;4.44e+03					
8 ;	2,3,7,8-TCDFF; 5.34e+06; 2.41e+06; 2.93e+06; 0.82;Y;	31:09;	9.257;	0.1722;	140;Y;	194;Y;n:7.65e+05;5.48e+03;9.51e+05;4.90e+03					
9 ;	1,2,3,7,8-PeCDF; 2.10e+07; 1.30e+07; 8.04e+06; 1.61;Y;	33:38;	50.615;	0.1755;	1003;Y;	739;Y;n:5.62e+06;5.60e+03;3.53e+06;4.78e+03					
10 ;	2,3,4,7,8-PeCDF; 2.05e+07; 1.26e+07; 7.88e+06; 1.60;Y;	34:15;	47.575;	0.1632;	981;Y;	731;Y;n:5.50e+06;5.60e+03;3.50e+06;4.78e+03					
11 ;	1,2,3,4,7,8-HxCDF; 1.75e+07; 9.71e+06; 7.77e+06; 1.25;Y;	36:24;	49.453;	0.2208;	653;Y;	797;Y;n:3.63e+06;5.55e+03;2.83e+06;3.55e+03					
12 ;	1,2,3,6,7,8-HxCDF; 1.85e+07; 1.03e+07; 8.25e+06; 1.24;Y;	36:30;	49.322;	0.2081;	635;Y;	785;Y;n:3.52e+06;5.55e+03;2.79e+06;3.55e+03					
13 ;	2,3,4,6,7,8-HxCDF; 1.69e+07; 9.37e+06; 7.56e+06; 1.24;Y;	37:00;	47.585;	0.2194;	615;Y;	779;Y;n:3.41e+06;5.57e+03;2.77e+06;3.55e+03					
14 ;	1,2,3,7,8,9-HxCDF; 1.37e+07; 7.68e+06; 5.97e+06; 1.29;Y;	37:48;	44.689;	0.2555;	412;Y;	499;Y;n:2.29e+06;5.55e+03;1.77e+06;3.55e+03					
15 ;	1,2,3,4,6,7,8-HpCDF; 1.56e+07; 7.98e+06; 7.62e+06; 1.05;Y;	39:21;	51.709;	0.2936;	522;Y;	541;Y;n:2.37e+06;4.55e+03;2.23e+06;4.13e+03					
16 ;	1,2,3,4,7,8,9-HpCDF; 1.12e+07; 5.75e+06; 5.45e+06; 1.05;Y;	41:21;	47.114;	0.3725;	287;Y;	308;Y;n:1.31e+06;4.55e+03;1.27e+06;4.13e+03					
17 ;	OCDF; 1.49e+07; 7.15e+06; 7.74e+06; 0.92;Y;	45:26;	91.372;	0.6611;	771;Y;	287;Y;n:1.22e+06;1.58e+03;1.35e+06;4.70e+03					
Extraction Standards											
18 ;	13C-2,3,7,8-TCDFF; 3.52e+07; 1.55e+07; 1.97e+07; 0.78;Y;	31:39;	86.886;	0.2080;	1323;Y;	1386;Y;n:5.62e+06;4.25e+03;7.37e+06;5.32e+03					
19 ;	13C-1,2,3,7,8-PeCDF; 2.62e+07; 1.61e+07; 1.02e+07; 1.58;Y;	34:26;	78.333;	0.2234;	1588;Y;	1067;Y;n:6.99e+06;4.40e+03;4.37e+06;4.09e+03					
20 ;	13C-1,2,3,6,7,8-HxCDD; 2.57e+07; 1.43e+07; 1.14e+07; 1.25;Y;	37:12;	99.202;	0.2765;	1164;Y;	1000;Y;n:4.74e+06;4.07e+03;3.82e+06;3.82e+03					
21 ;	13C-1,2,3,4,6,7,8-HpCDF; 1.84e+07; 9.43e+06; 8.98e+06; 1.05;Y;	40:38;	91.403;	0.3808;	531;Y;	546;Y;n:2.31e+06;4.34e+03;2.24e+06;4.10e+03					
22 ;	13C-OCDD; 2.49e+07; 1.17e+07; 1.32e+07; 0.89;Y;	45:06;	148.357;	0.4455;	472;Y;	592;Y;n:2.05e+06;4.34e+03;2.30e+06;3.89e+03					
23 ;	13C-2,3,7,8-TCDFF; 5.15e+07; 2.28e+07; 0.79;Y;	31:08;	97.598;	0.1550;	1645;Y;	1811;Y;n:7.20e+06;4.38e+03;8.92e+06;4.92e+03					
24 ;	13C-1,2,3,7,8-PeCDF; 4.16e+07; 2.55e+07; 1.61e+07; 1.58;Y;	33:38;	75.676;	0.1674;	2167;Y;	1271;Y;n:1.07e+07;4.96e+03;6.98e+06;5.49e+03					
25 ;	13C-1,2,3,6,7,8-HxCDF; 3.23e+07; 1.11e+07; 2.12e+07; 0.52;Y;	36:29;	93.360;	0.2123;	789;Y;	2364;Y;n:3.93e+06;4.99e+03;7.35e+06;3.11e+03					
26 ;	13C-1,2,3,4,6,7,8-HpCDF; 2.17e+07; 6.75e+06; 1.49e+07; 0.45;Y;	39:20;	84.279;	0.2652;	571;Y;	1087;Y;n:1.99e+06;3.48e+03;4.39e+06;4.04e+03					
Injection Standards											
27 ;	13C-1,2,3,4-TCDFF; 3.83e+07; 1.68e+07; 0.78;Y;	31:15;	47.021;	-;	1367;Y;	1359;Y;n:5.81e+06;4.25e+03;7.23e+06;5.32e+03					
28 ;	13C-1,2,3,7,8,9-HxCDD; 2.49e+07; 1.38e+07; 1.11e+07; 1.24;Y;	37:27;	34.975;	-;	1118;Y;	960;Y;n:4.55e+06;4.07e+03;3.66e+06;3.82e+03					
Cleanup Standards											
29 ;	37Cl-2,3,7,8-TCDFF; 4.15e+07; 2.63e+07; 1.67e+07; 1.58;Y;	31:40;	100.429;	0.1109;	3294;Y;	-; -; -; n:1.72e+07;5.21e+03;					
30 ;	13C-2,3,4,7,8-PeCDF; 4.30e+07; 2.52e+07; 1.40e+07; 1.11e+07; 1.26;Y;	34:15;	79.781;	0.1705;	2279;Y;	-; -; -; n:1.13e+07;4.96e+03;7.02e+06;5.49e+03					
31 ;	13C-1,2,3,4,7,8-HxCDD; 3.18e+07; 1.08e+07; 2.10e+07; 0.52;Y;	37:07;	102.204;	0.2910;	1247;Y;	1042;Y;n:5.07e+06;4.07e+03;3.98e+06;3.82e+03					
32 ;	13C-1,2,3,4,7,8-HpCDF; 3.18e+07; 1.08e+07; 2.03e+07; 0.46;Y;	36:23;	101.916;	0.2360;	808;Y;	2449;Y;n:4.03e+06;4.99e+03;7.61e+06;3.11e+03					
33 ;	13C-1,2,3,4,7,8-HpCDF; 2.03e+07; 6.34e+06; 1.39e+07; 0.46;Y;	41:20;	88.358;	0.2973;	430;Y;	802;Y;n:1.49e+06;3.48e+03;3.24e+06;4.04e+03					
Sampling Standards											
34 ;	37Cl-2,3,7,8-TCDFF; 4.15e+07; 2.63e+07; 1.67e+07; 1.58;Y;	31:40;	115.596;	0.1180;	3294;Y;	-; -; -; n:1.72e+07;5.21e+03;					
35 ;	13C-2,3,4,7,8-PeCDF; 4.30e+07; 2.52e+07; 1.40e+07; 1.11e+07; 1.26;Y;	34:15;	105.372;	0.1795;	2279;Y;	-; -; -; n:1.13e+07;4.96e+03;7.02e+06;5.49e+03					
36 ;	13C-1,2,3,4,7,8-HxCDD; 3.18e+07; 1.08e+07; 2.10e+07; 0.52;Y;	37:07;	103.024;	0.2910;	1247;Y;	1042;Y;n:5.07e+06;4.07e+03;3.98e+06;3.82e+03					
37 ;	13C-1,2,3,4,7,8-HpCDF; 3.18e+07; 1.08e+07; 2.10e+07; 0.52;Y;	36:23;	109.110;	0.2385;	808;Y;	2449;Y;n:4.03e+06;4.99e+03;7.61e+06;3.11e+03					
38 ;	13C-1,2,3,4,7,8,9-HpCDF; 2.03e+07; 6.34e+06; 1.39e+07; 0.46;Y;	41:20;	104.845;	0.3963;	430;Y;	802;Y;n:1.49e+06;3.48e+03;3.24e+06;4.04e+03					

File:A24JUL07A #1-399 Acq:24-JUL-2007 16:54:46 GC EI+ Voltage SIR Autospec-Ultimate

Sample#2 Text:OPR14370 Exp:EXP_DB5MS

319.8965 S:2 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,5280.0,5.00%,F,T)




321.8936 S:2 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,5344.0,5.00%,F,T)



331.9368 S:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4248.0,5.00%,F,T)



333.9339 S:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5320.0,5.00%,F,T)



327.8847 S:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5208.0,5.00%,F,T)



304.9824 S:2 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)



File:A24JUL07A #1-184 Acq:24-JUL-2007 16:54:46 GC EI+ Voltage SIR Autospec-UltimaE

Sample#2 Text:OPR14370

355.8546 S:2 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5012.0,5.00%,F,T)

100%

3.6E6

1.8E6

357.8517 S:2 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4260.0,5.00%,F,T)

100%

2.3E6

1.1E6

367.8949 S:2 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4404.0,5.00%,F,T)

100%

7.0E6

3.5E6

369.8919 S:2 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4092.0,5.00%,F,T)

100%

4.4E6

2.2E6

366.9792 S:2 F:2 SMO(1,3) PKD(3,2,1,100.00%,0,0,5.00%,F,T)

100%

2.7E6

1.4E6

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

34:27

0.0E0

34:27

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

34:26

0.0E0

34:26

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

34:25

0.0E0

34:25

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

34:24

0.0E0

34:24

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

34:23

0.0E0

34:23

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

34:22

0.0E0

34:22

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

34:21

0.0E0

34:21

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

34:20

0.0E0

34:20

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

34:19

0.0E0

34:19

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

34:18

0.0E0

34:18


32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

34:17


0.0E0

34:17


112




File:A24JUL07A #1-292 Accq:24-JUL-2007 16:54:46 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#2 Text:OPR14370
 423.7767 S:2 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4784.0,5.00%,F,T)
 100%
 425.7737 S:2 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4308.0,5.00%,F,T)
 100%
 435.8169 S:2 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4340.0,5.00%,F,T)
 100%
 437.8140 S:2 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4104.0,5.00%,F,T)
 100%




File:A24JUL07A #1-367 Accq:24-JUL-2007 16:54:46 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#2 Text:OPR14370
 Exp:EXP_D5MS
 457.7377 S:2 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4540.0,5.00%,F,T)
 100%
 459.7348 S:2 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4440.0,5.00%,F,T)
 100%
 469.7780 S:2 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4340.0,5.00%,F,T)
 100%
 471.7750 S:2 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3892.0,5.00%,F,T)
 100%



File:A24JUL07A #1-399 Acq:24-JUL-2007 16:54:46 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#2 Text:OPR14370
 Exp:EXP_DB5MS
 303.9016 S:2 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,5480.0,5.00%,F,T)
 100%
 50%





File:A24JUL07A #1-252 Accq:24-JUL-2007 16:54:46 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#2 Text:OPR14370
 373.8207 S:2 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5552.0,5.00%,F,T)
 100%
 36:24 37:00 37:48

375.8178 S:2 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3552.0,5.00%,F,T)
 100%
 36:24 37:00 37:48


383.8639 S:2 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4988.0,5.00%,F,T)
 100%
 36:23 37:00 37:48

385.8610 S:2 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3108.0,5.00%,F,T)
 100%
 36:23 37:00 37:48


445.7555 S:2 F:3 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,3960.0,5.00%,F,T)
 100%
 35:19 35:35 36:02 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12


380.9760 S:2 F:3 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)
 100%
 35:18 35:44 36:10 36:28 36:42 37:00 37:19 37:30 37:47 37:59

File:A24JUL07A #1-292 Accq:24-JUL-2007 16:54:46 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#2 Text:OPR14370 Exp:EXP_DB5MS
 407.7818 S:2 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4548.0,5.00%,F,T)
 100% 39:21



File:A24JUL07A #1-367 Acq:24-JUL-2007 16:54:46 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#2 Text:OPR14370 Exp:EXP_DB5MS
 441.7427 S:2 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4700.0,5.00%,F,T)
 100%
 100%





Analytical Results
for
Ongoing Precision & Recovery Duplicate Results (OPRD)

Analyte	Spiked (pg/ μ L)	AMT (pg/ μ L)	Recovery %	#	Range Lower	Upper	OPR Rec(%)	#	RPD ($\pm 20\%$)	Qualifier
2,3,7,8-TCDD	10.0	10.3	103		70.0	130	107		3.68	
1,2,3,7,8-PeCDD	50.0	48.7	97.4		70.0	130	99.7		2.41	
1,2,3,4,7,8-HxCDD	50.0	47.5	94.9		70.0	130	96.3		1.46	
1,2,3,6,7,8-HxCDD	50.0	49.3	98.7		70.0	130	99.7		1.03	
1,2,3,7,8,9-HxCDD	50.0	48.7	97.4		70.0	130	97.7		0.351	
1,2,3,4,6,7,8-HpCDD	50.0	49.6	99.2		70.0	130	101		1.80	
OCDD	100	99.9	99.9		70.0	130	100		0.0550	
2,3,7,8-TCDF	10.0	9.02	90.2		70.0	130	92.6		2.66	
1,2,3,7,8-PeCDF	50.0	49.8	99.6		70.0	130	101		1.39	
2,3,4,7,8-PeCDF	50.0	47.0	94.1		70.0	130	95.2		1.21	
1,2,3,4,7,8-HxCDF	50.0	48.3	96.7		70.0	130	98.9		2.28	
1,2,3,6,7,8-HxCDF	50.0	49.5	99.0		70.0	130	98.6		0.420	
2,3,4,6,7,8-HxCDF	50.0	48.7	97.4		70.0	130	95.2		2.21	
1,2,3,7,8,9-HxCDF	50.0	44.5	89.1		70.0	130	89.4		0.391	
1,2,3,4,6,7,8-HpCDF	50.0	52.1	104		70.0	130	103		1.13	
1,2,3,4,7,8,9-HpCDF	50.0	44.8	89.6		70.0	130	94.2		5.12	
OCDF	100	92.0	92.0		70.0	130	91.4		0.627	

= Outside range limits

* = Ion Ratio Out

<u>QC Information</u>		<u>File Information</u>	
OPR Project No:	OPRD14370	OPRD Filename :	a24jul07a-3
Extraction Date:	22-Jul-07	Retchk:	a24jul07a-1
Analysis Date:	24-Jul-07	Begin ConCal:	a24jul07a-1
Method:	M23	End ConCal:	a24jul07a-11
<u>Sample Information</u>		Initial Cal:	m8290-071007a
Matrix:	Air		

Analytical Results
for
Ongoing Precision & Recovery Duplicate Results (OPRD)

Labeled Standard	Expected Amount (ng)	Measured Amount (ng)	Percent Recovery (%)	RT (min.)	Ratio	Qualifier
Extraction Standards						
13C12-2,3,7,8-TCDD	4	2.89	72.2	31:39	0.78	
13C12-1,2,3,7,8-PeCDD	4	2.67	66.8	34:25	1.58	
13C12-1,2,3,6,7,8-HxCDD	4	3.22	80.5	37:12	1.25	
13C12-1,2,3,4,6,7,8-HpCDD	4	2.96	73.9	40:37	1.06	
13C12-OCDD	8	4.74	59.2	45:06	0.90	
13C12-2,3,7,8-TCDF	4	3.20	80.1	31:07	0.78	
13C12-1,2,3,7,8-PeCDF	4	2.51	62.8	33:37	1.59	
13C12-1,2,3,6,7,8-HxCDF	4	2.94	73.6	36:28	0.53	
13C12-1,2,3,4,6,7,8-HpCDF	4	2.75	68.8	39:19	0.45	
Sampling Standards						
37Cl4-2,3,7,8-TCDD	4.0	4.51	113	31:40	-	
13C12-2,3,4,7,8-PeCDF	4.0	4.18	104	34:15	1.59	
13C12-1,2,3,4,7,8-HxCDD	4.0	4.04	101	37:07	1.28	
13C12-1,2,3,4,7,8-HxCDF	4.0	4.22	105	36:22	0.52	
13C12-1,2,3,4,7,8,9-HpCDF	4.0	4.06	101	41:19	0.45	
Injection Standards						
13C12-1,2,3,4-TCDD	2	-	-	31:15	0.78	
13C12-1,2,3,7,8,9-HxCDD	2	-	-	37:27	1.25	

QC Information		File Information	
OPR Project No:	OPRD14370	OPRD Filename :	a24jul07a-3
Extraction Date:	22-Jul-07	Retchk:	a24jul07a-1
Analysis Date:	24-Jul-07	Begin ConCal:	a24jul07a-1
Method:	M23	End ConCal:	a24jul07a-11
Sample Information		Initial Cal:	m8290-071007a
Matrix:	Air		
Form Version:[8290_DB_2.14]OPRD			

Reviewed By: MR

Date Reviewed: 7/26/07

Filename : a24jul07a

Sample : 3

Acquired : 24-JUL-07 17:43:07

Processed : 25-JUL-07 08:10:03

Sample ID : OPD14370

Cal Table : mb290-071007a

Results Table : MB290-072407a


Comments :

```


Name;      Resp;    Ion 1;    Ion 2;    RA;?;    RT;    Conc;    EDL;    S/N1;?;    S/N2;?;    Signal1;    Noise 1;    Signal2;    Noise 2
2,3,7,8-TCD; 2.79e+06; 1.19e+06; 1.59e+06; 0.75;Y; 31:40; 0.320; 0.2987; 90;Y; 129;Y; n;4.75e+05;5.25e+03;6.45e+05;5.00e+03
1 ; 1.2,3,7,8-PeCDF; 1.08e+07; 6.65e+06; 4.16e+06; 1.60;Y; 34:27; 48.679; 0.3104; 573;Y; 340;Y; n;2.82e+06;4.9e+03;1.74e+06;5.12e+03
2 ; 1,2,3,4,7,8-HxCDD; 1.01e+07; 5.58e+06; 4.47e+06; 1.25;Y; 37:07; 47.459; 0.4257; 403;Y; 299;Y; n;1.93e+06;4.78e+03;1.55e+06;5.17e+03
3 ; 1,2,3,6,7,8-HxCDD; 1.03e+07; 5.68e+06; 4.59e+06; 1.24;Y; 37:12; 49.340; 0.4332; 407;Y; 313;Y; n;1.95e+06;4.78e+03;1.62e+06;5.17e+03
4 ; 1,2,3,7,8,9-HxCDD; 9.98e+06; 5.58e+06; 4.40e+06; 1.27;Y; 37:28; 48.679; 0.4397; 377;Y; 274;Y; n;1.81e+06;4.78e+03;1.52e+06;5.17e+03
5 ; 1,2,3,4,6,7,8-HpCDF; 8.07e+06; 4.15e+06; 3.92e+06; 1.06;Y; 40:39; 49.608; 0.7180; 215;Y; 203;Y; n;1.03e+06;4.81e+03;9.55e+05;4.71e+03
6 ; 1,2,3,4,7,8-HpCDF; 5.21e+07; 5.84e+06; 0.89;Y; 45:07; 99.945; 1.3538; 236;Y; 218;Y; n;9.10e+05;3.866e+03;1.04e+06;4.78e+03
7 ; OCDF; 1.11e+07; 2,3,7,8-TCDF; 4.06e+06; 1.78e+06; 2.29e+06; 0.78;Y; 31:09; 9.020; 0.2151; 117;Y; 136;Y; n;5.69e+05;4.86e+03;7.42e+05;5.46e+03
8 ; 1,2,3,7,8-PeCDF; 1.63e+07; 1.00e+07; 6.31e+06; 1.59;Y; 33:38; 49.810; 0.2792; 642;Y; 484;Y; n;4.40e+06;6.8e+03;2.81e+06;5.80e+03
9 ; 2,3,4,7,8-PeCDF; 1.60e+07; 9.89e+06; 6.10e+06; 1.62;Y; 34:15; 47.029; 0.2691; 637;Y; 480;Y; n;4.36e+06;6.84e+03;2.78e+06;5.80e+03
10 ; 1,2,3,4,7,8-HxCDF; 1.39e+07; 7.76e+06; 6.14e+06; 1.26;Y; 36:24; 48.347; 0.4139; 371;Y; 360;Y; n;2.82e+06;7.59e+03;2.24e+06;6.24e+03
11 ; 1,2,3,6,7,8-HxCDF; 1.51e+07; 8.38e+06; 6.73e+06; 1.25;Y; 36:30; 49.508; 0.5900; 382;Y; 379;Y; n;2.90e+06;7.59e+03;2.31e+06;6.24e+03
12 ; 2,3,4,6,7,8-HxCDF; 1.41e+07; 7.88e+06; 6.21e+06; 1.27;Y; 37:00; 48.678; 0.4112; 349;Y; 329;Y; n;2.65e+06;7.59e+03;2.05e+06;6.24e+03
13 ; 1,2,3,7,8,9-HxCDF; 1.11e+07; 6.16e+06; 4.91e+06; 1.26;Y; 37:48; 44.526; 0.4789; 247;Y; 239;Y; n;1.87e+06;7.59e+03;1.49e+06;6.24e+03
14 ; 1,2,3,4,6,7,8-HpCDF; 1.32e+07; 6.78e+06; 6.45e+06; 1.05;Y; 39:21; 52.091; 0.4216; 441;Y; 320;Y; n;1.88e+06;4.26e+03;1.82e+06;5.68e+03
15 ; 1,2,3,4,7,8,9-HpCDF; 8.97e+06; 4.58e+06; 1.05;Y; 41:21; 44.806; 0.5350; 261;Y; 184;Y; n;1.11e+06;4.26e+03;1.04e+06;5.68e+03
16 ; 1,2,3,4,7,8,9-HpCDF; 8.97e+06; 5.85e+07; 5.85e+06; 6.49e+06; 0.90;Y; 45:26; 91.977; 1.1624; 218;Y; 270;Y; n;1.03e+06;4.75e+03;1.14e+06;4.25e+03
17 ; Extraction Standards
18 ; 13C-2,3,7,8-TCD; 2.78e+07; 1.22e+07; 1.56e+07; 0.78;Y; 31:39; 72.223; 0.2309; 974;Y; 1228;Y; n;4.61e+06;4.73e+03;6.02e+06;4.90e+03
19 ; 13C-1,2,3,7,8-PeCDF; 2.13e+07; 1.30e+07; 8.25e+06; 1.58;Y; 34:26; 66.848; 0.2811; 1177;Y; 744;Y; n;5.70e+06;4.81e+03;3.61e+06;4.85e+03
20 ; 13C-1,2,3,6,7,8-HxCDD; 2.15e+07; 1.20e+07; 9.56e+06; 1.25;Y; 37:12; 80.524; 0.3270; 877;Y; 656;Y; n;3.93e+06;4.48e+03;3.19e+06;4.87e+03
21 ; 13C-1,2,3,4,6,7,8-HpCDF; 1.54e+07; 7.90e+06; 7.46e+06; 1.06;Y; 40:38; 73.956; 0.4318; 446;Y; 347;Y; n;1.93e+06;4.32e+03;1.83e+06;5.28e+03
22 ; 13C-OCDD; 2.05e+07; 9.73e+06; 1.08e+07; 0.90;Y; 45:06; 118.432; 0.4952; 343;Y; 437;Y; n;1.68e+06;4.91e+03;1.86e+06;4.26e+03
23 ; 13C-2,3,7,8-TCD; 4.02e+07; 1.77e+07; 2.26e+07; 0.78;Y; 31:07; 80.092; 0.1648; 1327;Y; 1528;Y; n;5.68e+06;4.28e+03;7.16e+06;4.68e+03
24 ; 13C-1,2,3,7,8-PeCDF; 3.28e+07; 2.02e+07; 1.27e+07; 1.59;Y; 33:38; 62.804; 0.2183; 1305;Y; 882;Y; n;8.25e+06;6.32e+03;5.32e+06;6.03e+03
25 ; 13C-1,2,3,6,7,8-HxCDF; 2.63e+07; 9.11e+06; 1.72e+07; 0.53;Y; 36:29; 73.590; 0.2470; 611;Y; 1411;Y; n;3.18e+06;5.20e+03;5.99e+06;4.25e+03
26 ; 13C-1,2,3,4,6,7,8-HpCDF; 1.83e+07; 5.64e+06; 1.26e+07; 0.45;Y; 39:20; 68.771; 0.3721; 329;Y; 605;Y; n;1.57e+06;4.78e+03;3.50e+06;5.79e+03
Injection Standards
27 ; 13C-1,2,3,4,7,8,9-HpCDF; 3.64e+07; 1.60e+07; 2.04e+07; 0.78;Y; 31:15; 44.744; -; 1092;Y; 1362;Y; n;5.17e+06;4.73e+03;6.68e+06;4.90e+03
28 ; 13C-1,2,3,7,8,9-HxCDD; 2.56e+07; 1.42e+07; 1.14e+07; 1.25;Y; 37:27; 36.092; -; 1015;Y; 755;Y; n;4.55e+06;4.48e+03;3.58e+06;4.87e+03
Cleanup Standards
29 ; 37C1-2,3,7,8-TCD; 3.20e+07; 3.20e+07; -; 31:40; 81.406; 0.1212; 2516;Y; -; -; 1.30e+07; 5.16e+03; -; -
30 ; 13C-2,3,4,7,8-PeCDF; 3.37e+07; 2.07e+07; 1.30e+07; 1.59;Y; 34:15; 65.600; 0.2224; 1388;Y; 882;Y; n;8.78e+06;6.32e+03;5.32e+06;6.03e+03
31 ; 13C-1,2,3,4,7,8-HxCDD; 2.07e+07; 1.16e+07; 9.09e+06; 1.28;Y; 37:07; 81.406; 0.3442; 886;Y; 646;Y; n;3.97e+06;4.48e+03;3.14e+06;4.87e+03
32 ; 13C-1,2,3,4,7,8-HxCDF; 2.50e+07; 8.52e+06; 1.64e+07; 0.52;Y; 36:23; 77.605; 0.2746; 589;Y; 1362;Y; n;3.06e+06;5.20e+03;5.79e+06;4.25e+03
33 ; 13C-1,2,3,4,7,8,9-HpCDF; 1.65e+07; 5.14e+06; 1.14e+07; 0.45;Y; 41:20; 69.733; 0.4172; 262;Y; 473;Y; n;1.25e+06;4.78e+03;2.74e+06;5.79e+03
Sampling Standards
34 ; 37C1-2,3,7,8-TCD; 3.20e+07; 3.20e+07; -; 31:40; 112.724; 0.1430; 2516;Y; -; -; 1.30e+07; 5.16e+03; -; -
35 ; 13C-2,3,4,7,8-PeCDF; 3.37e+07; 2.07e+07; 1.30e+07; 1.59;Y; 34:15; 104.400; 0.2774; 1388;Y; 882;Y; n;8.78e+06;6.32e+03;5.32e+06;6.03e+03
36 ; 13C-1,2,3,4,7,8-HxCDD; 2.07e+07; 1.16e+07; 9.09e+06; 1.28;Y; 37:07; 101.033; 0.4142; 886;Y; 646;Y; n;3.97e+06;4.48e+03;3.14e+06;4.87e+03
37 ; 13C-1,2,3,4,7,8-HpCDF; 2.50e+07; 8.52e+06; 1.64e+07; 0.52;Y; 36:23; 105.407; 0.3434; 589;Y; 1362;Y; n;3.06e+06;5.20e+03;5.79e+06;4.25e+03
38 ; 13C-1,2,3,4,7,8,9-HpCDF; 1.65e+07; 5.14e+06; 1.14e+07; 0.45;Y; 41:20; 101.405; 0.6937; 262;Y; 473;Y; n;1.25e+06;4.78e+03;2.74e+06;5.79e+03

```

File:A24JUL07A #1-399 Acq:24-JUL-2007 17:43:07 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#3 Text:OPRD14370
 319.8965 S:3 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,5252.0,5.00%,F,T)
 100%
 50%
 0%




File:A24JUL07A #1-184 Acq:24-JUL-2007 17:43:07 GC EII+ Voltage SIR Autospec-UltimaE
 Sample#3 Text:OPRD14370 Exp:EXP_DB5MS
 355.8546 S:3 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4924.0,5.00%,F,T)
 100%




File:A24JUL07A #1-252 Acq:24-JUL-2007 17:43:07 GC EI+ Voltage SIR Autospec-UltimaE


Sample#3 Text OPRD14370
3.389 8156 S:3 F:3 BSUB(1228,15,-3.0) PKD(3,2,1,0.018,4784.0,5.00%,F,T)
Exp:EXP_DB5MS



File:A24JUL07A #1-292 Acc:24-JUL-2007 17:43:07 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#3 Text:OPRD14370 Exp:EXP_DB5MS
 423.7767 S:3 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4808.0,5.00%,F,T)
 100% 40:39



File: A24JUL07A #1-368 Acq: 24-JUL-2007 17:43:07 GC E1+ Voltage SIR Autospec-Ultimate
Sample#3 Text OPRD14370 Exp: EXP_DB5MS
457.7377 S:3 F:5 BSUB (128,15,-3,0) PKD (3,2,1,0.01%,3856.0,5.00%,F,T)
 1000.



File:A24JUL07A #1-399 Acq:24-JUL-2007 17:43:07 GC EI+ Voltage SIR Autospec-UltimaE

Sample#3 Text:OPRD14370

Exp:EXP_DB5MS

303.9016 S:3 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,4860.0,5.00%,F,T)

100%

31:09



305.8987 S:3 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,5456.0,5.00%,F,T)

100%

31:09



315.9419 S:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4280.0,5.00%,F,T)

100%


31:08



317.9389 S:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4684.0,5.00%,F,T)

100%

31:08



375.8364 S:3 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,4296.0,5.00%,F,T)

100%


31:08



304.9824 S:3 SMO(1,3) PKD(3,2,1,100.00%,0,0,5.00%,F,T)

100%


26:36




304.9824 S:3 SMO(1,3) PKD(3,2,1,100.00%,0,0,5.00%,F,T)


100%

27:02



File:A24JUL07A #1-184 Acq:24-JUL-2007 17:43:07 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#3 Text:OPRD14370
 339.8597 S:3 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,6844.0,5.00%,F,T)
 100%
 341.8568 S:3 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5796.0,5.00%,F,T)
 100%
 351.9000 S:3 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,6324.0,5.00%,F,T)
 100%
 353.8970 S:3 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,6032.0,5.00%,F,T)
 100%





File:A24JULL07A #1-292 Accq:24-JUL-2007 17:43:07 GC EI+ Voltage SIR Autospec-UltimaE

Sample#3 Text:OPRD14370

407.7818 S:3 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4256.0,5.00%,F,T)


100%

1.9E6

9.4E5

0.0E0

41:21



1.8E6

9.1E5

0.0E0

41:21




1.6E6

7.9E5

0.0E0

41:20



3.5E6

1.8E6

0.0E0

41:20




8.5E3

4.3E3

0.0E0

41:20




5.1E6


2.5E6


0.0E0

41:00



File:A24JUL07A #1-368 Acq:24-JUL-2007 17:43:07 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#3 Text:OPRD14370
 441.7427 S:3 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4748.0,5.00%,F,T)
 100%
 0





Extraction by Modified Method 3540 (Soxhlet with Dean-Stark Adapter - SDS)

Analytical Method M23 TO-9A
1668A 680

QC Batch*	Prev. WG	Workgroup*	Logbook#	Page#
22-Jul-07	N/A	WG	14	370

Start Date/Time: 22 July 07 1600

Finish Date/Time: 23 July 07 0800

Comments: Filter not present for
15-20. Trap Prep no.:
(8431)-14.

Item	Lot #'s		
Toluene	CS800		
Tridecane	SPL2-021		
Salt	SPL2-020	Conc.	Witness
Thimbles	618036	(ng/ μ L)	
Extraction Std.	S27-333	0.05	CRN
Matrix Spk.	S27-338	0.005	CRN

DC6.121503.5

* = To be entered in the Prep Table.

Data in prep table? ✓

Air Sample Witness Program Guide

SOX Position	PAL ID	Client ID verified	Tridecane	Boiling Chips	Stopcock Position	Standard Additions	
						ES	MX
1	LMB14370	OKL	✓	✓	✓	80 ✓	
2	431-15-5		✓	✓	✓	80 ✓	
3	431-15-10		✓	✓	✓	80 ✓	
4	431-15-15		✓	✓	✓	80 ✓	
5	431-15-20		✓	✓	✓	80 ✓	
6	OPR14370		✓	✓	✓	80 ✓	80 ✓
7	OPRD14370	↓	✓	✓	—	80 ✓	80 ✓
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
Witness			✓	✓	✓	CW	CW

Chiller temperature: 14

Mantle Percentage Verified: 65%

DCxxx.012903.0

Extract cleanup by modified method 3630/3620 Silica/florisil

Sample Identification				Train	CS Amt. [#]	Witness [Initials]	Analyzed [%]	Date	Method	Matrix
Client ID	Project ID	Sample ID	Container ID							
A	N/A	N/A	LMB14370	B	1	0	N/A	50	✓	23-Jul-07 M23 Air
	G431	15	5	B	2	0	N/A	50	✓	23-Jul-07 M23 Air
	G431	15	10	B	3	0	N/A	50	✓	23-Jul-07 M23 Air
	G431	15	15	B	4	0	N/A	50	✓	23-Jul-07 M23 Air
	G431	15	20	B	5	0	N/A	50	✓	23-Jul-07 M23 Air
B	N/A	N/A	OPR14370	B	6	0	N/A	50	✓	23-Jul-07 M23 Air
	N/A	N/A	OPRD14370	B	7	0	N/A	50	✓	23-Jul-07 M23 Air
					8					
C								9	10	11
										12

Comments:

PCU 1

Item	Lot #'s	Conc. (ng/µL)
Hexane	CU073	
Methylene Chloride	CS851	
Acid Silica	SPL2-025	
Base Silica	SPL1-226	
Silica	SPL1-199	
Florisil	SP8350	
Salt	SPL2-028	
Tridecane	N/A	
Cleanup Std.	N/A	

DC1 090203.6

* = to be entered in the Prep table.

Cleanup Observation Form

Reference: PCU Log
Log: 14 Page: 272

		Train					
		1	2	3	4	5	6
Silica	Acid	Base	Florescent	Extract	Comments		
1	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow
Travel 1	Travel 1	Travel 1	Travel 1	Travel 1	Travel 1	Travel 1	Travel 1
2	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow
Travel 2	Travel 2	Travel 2	Travel 2	Travel 2	Travel 2	Travel 2	Travel 2
3	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow
Travel 3	Travel 3	Travel 3	Travel 3	Travel 3	Travel 3	Travel 3	Travel 3
4	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow
Travel 4	Travel 4	Travel 4	Travel 4	Travel 4	Travel 4	Travel 4	Travel 4
5	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow
Travel 5	Travel 5	Travel 5	Travel 5	Travel 5	Travel 5	Travel 5	Travel 5
6	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow
Travel 6	Travel 6	Travel 6	Travel 6	Travel 6	Travel 6	Travel 6	Travel 6

DC29.071105.4

139

□ Continued on next page.

Cleanup Observation Form

Reference: PCU Log
Page: 242
Log: 14

DC29.071105.4

Cal: m8290-071007a

Page 1 of 1

Ent	Name	Mean	RRF Std	Results:				
				a10jul07a-2 RRF#1	a10jul07a-2 RRF#2	a10jul07a-4 RRF#3	a10jul07a-5 RRF#4	a10jul07a-6 RRF#5
1	2,3,7,8-TCDD	0.9703	18	3.23 %	0.95	0.94	0.96	1.00
2	1,2,3,7,8-PeCDD	1.0431	19	3.99 %	0.99	1.02	1.05	1.09
3	1,2,3,4,7,8-HxCDD	0.9838	20	4.92 %	0.91	0.96	1.00	1.04
4	1,2,3,6,7,8-HxCDD	0.9667	20	3.39 %	0.92	0.94	1.00	0.99
5	1,2,3,7,8,9-HxCDD	0.9525	20	3.52 %	0.92	0.97	0.99	0.97
6	1,2,3,4,6,7,8-HpCDD	1.0583	21 ✓	3.53 %	1.03 ✓	1.06 ✓	1.09 ✓	1.09 ✓
7	OCDD	1.0783	22	5.40 %	1.00	1.03	1.11	1.13
8	2,3,7,8-TCDF	1.1201	23	4.96 %	1.06	1.08	1.11	1.18
9	1,2,3,7,8-PeCDF	0.9985	24	1.67 %	0.98	0.98	1.01	1.02
10	2,3,4,7,8-PeCDF	1.0357	24	2.88 %	0.99	1.02	1.07	1.05
11	1,2,3,4,7,8-HxCDF	1.0927	25	2.18 %	1.10	1.06	1.08	1.10
12	1,2,3,6,7,8-HxCDF	1.1598	25	2.71 %	1.14	1.11	1.17	1.20
13	2,3,4,6,7,8-HxCDF	1.0999	25	2.74 %	1.08	1.06	1.11	1.17
14	1,2,3,7,8,9-HxCDF	0.9444	25	2.51 %	0.93	0.91	0.96	0.96
15	1,2,3,4,6,7,8-HpCDF	1.3907	26	3.31 %	1.32	1.37	1.41	1.44
16	1,2,3,4,7,8,9-HpCDF	1.0961	26	2.78 %	1.06	1.07	1.10	1.13
17	OCDF	1.3088	22	7.86 %	1.21	1.21	1.30	1.43
18	13C-2,3,7,8-TCDD	1.0572	27	4.39 %	1.13	1.01	1.02	1.06
19	13C-1,2,3,7,8-PeCDD	0.8739	27	7.50 %	0.99	0.85	0.83	0.84
20	13C-1,2,3,6,7,8-HxCDD	1.0423	28	1.06 %	1.03	1.05	1.03	1.04
21	13C-1,2,3,4,6,7,8-HpCDD	0.8106	28	2.16 %	0.78	0.81	0.82	0.83
22	13C-OCDD	0.6753	28	5.10 %	0.63	0.66	0.69	0.72
23	13C-2,3,7,8-TCDF	1.3787	27	1.48 %	1.39	1.35	1.37	1.40
24	13C-1,2,3,7,8-PeCDF	1.4346	27	6.91 %	1.60	1.40	1.34	1.40
25	13C-1,2,3,6,7,8-HxCDF	1.3941	28	2.97 %	1.32	1.42	1.41	1.43
26	13C-1,2,3,4,6,7,8-HpCDF	1.0354	28	2.79 %	0.99	1.03	1.04	1.05
27	13C-1,2,3,4-TCDD	-	-	- %	-	-	-	-
28	13C-1,2,3,7,8,9-HxCDD	-	-	- %	-	-	-	-
29	37C1-2,3,7,8-TCDD	1.0795	27	5.30 %	1.13	1.01	1.02	1.11
30	13C-2,3,4,7,8-PeCDD	1.4082	27	6.08 %	1.56	1.37	1.35	1.36
31	13C-1,2,3,4,7,8-HxCDD	0.9902	28	1.73 %	0.96	0.99	1.00	1.01
32	13C-1,2,3,4,7,8-HxCDF	1.2540	28	1.66 %	1.23	1.25	1.24	1.28
33	13C-1,2,3,4,7,8,9-HpCDF	0.9236	28	3.21 %	0.87	0.94	0.92	0.94
34	37C1-2,3,7,8-TCDD	1.0210	18	2.73 %	1.00	1.00	1.01	1.04
35	13C-2,3,4,7,8-PeCDF	0.9821	24	1.42 %	0.97	0.98	1.01	0.97
36	13C-1,2,3,4,7,8-HxCDD	0.9501	20	1.58 %	0.93	0.94	0.97	0.94
37	13C-1,2,3,4,7,8-HxCDF	0.8999	25	2.49 %	0.93	0.88	0.88	0.91
38	13C-1,2,3,4,7,8,9-HpCDF	0.8920	26	1.24 %	0.88	0.91	0.89	0.89
39	Total Tetra-Furans	1.1201		4.96 %	1.06	1.08	1.11	1.18
40	Total Tetra-Dioxins	0.9703		3.23 %	0.95	0.94	0.96	1.01
41	Total Penta-Furans Fn1	1.0171	9 10	2.20 %	0.99	1.00	1.04	1.04
42	Total Penta-Furans Fn2	1.0171		2.20 %	0.99	1.00	1.04	1.04
43	Total Penta-Dioxins	1.0431		3.99 %	0.99	1.02	1.05	1.07
44	Total Hexa-Furans	1.0742		2.36 %	1.06	1.04	1.10	1.10
45	Total Hexa-Dioxins	0.9677		3.84 %	0.92	0.94	0.99	0.99

Paradigm Sample Log

Data File	S	Sample ID	Analyst	Acq. Date	Time
a10jul07a;1		;RETCON S27-120E	;JWP	10-JUL-07	08:53:05
a10jul07a;2		;CS0.5 S25-26L	;JWP	10-JUL-07	09:41:26
a10jul07a;3		;CS1 S25-26A	;JWP	10-JUL-07	10:29:49
a10jul07a;4		;CS2 S25-26B	;JWP	10-JUL-07	11:18:06
a10jul07a;5		;CS3 S25-26C	;JWP	10-JUL-07	12:06:23
a10jul07a;6		;CS4 S25-26D	;JWP	10-JUL-07	12:54:41
a10jul07a;7		;CS5 S25-26E	;JWP	10-JUL-07	13:42:57

Tool passes

Filename : a10jul07a
Sample : 1
Acquired : 10-JUL-07 08:53:05
Processed : 10-JUL-07 14:44:41
Sample ID : RETCON S27-120E

Name	First Eluter RT	Last Eluter RT
TCDD	28:33	32:07
PecDD	33:01	34:38
HxCDD	35:45	37:21
HpCDD	39:33	40:30
QCDD	44:53	
TCDF	26:49	32:11
PacDF	32:10	34:50
HxCDF	35:19	37:42
HpCDF	39:13	41:12
QCDF	45:11	


File:A10JUL07A #1-399 Acq:10-JUL-2007 08:53:05 GC EI+ Voltage SIR Autospec-Ultimae

Sample#1 Text:RETCON S27-120E


303.9016,319.8965,339.8597

100%


Exp:EXP_DB5MS




File:A10JUL07A #1-399 Acq:10-JUL-2007 08:53:05 GC EI+ Voltage SIR Autospec-Ultimate
Sample#1 Test:RETCON S27-120E
303.9016,315.9419
321.8936,333.9339
100%




Peak Locate Examination:10-JUL-2007:08:50 File:A10JUL07A
Experiment:EXP_DB5MS Function:1 Reference:PFK




Peak Locate Examination:10-JUL-2007:08:51 File:A10JUL07A
Experiment :EXP_DB5MS Function:2 Reference:PFK




Peak Locate Examination:10-JUL-2007:08:51 File:A10JUL07A
Experiment:EXP_DB5MS Function:3 Reference:PFK




Peak Locate Examination:10-JUL-2007:08:51 File:A10JUL07A
Experiment:EXP_DB5MS Function:4 Reference:PFK




Peak Locate Examination:10-JUL-2007:08:52 File:A10JUL07A
Experiment:EXP_DB5MS Function:5 Reference:PFK




Peak Locate Examination:10-JUL-2007:14:31 File:A10JUL07A_RES_CHECK
 Experiment:EXP_DB5MS Function:1 Reference:PFK




Peak Locate Examination:10-JUL-2007:14:32 File:A10JUL07A_RES_CHECK
Experiment:EXP_DB5MS Function:2 Reference:PFK




Peak Locate Examination:10-JUL-2007:14:33 File:A10JUL07A_RES_CHECK
Experiment:EXP_DB5MS Function:3 Reference:PFK



Peak Locate Examination:10-JUL-2007:14:34 File:A10JUL07A.RES_CHECK
Experiment:EXP_DB5MS Function:4 Reference:PFK



Peak Locate Examination:10-JUL-2007:14:35 File:A10JUL07A_RES_CHECK
Experiment:EXP_DB5MS Function:5 Reference:PFK




Filename: a10jul07a - 2
 Analyte: m8290-070507a Cal: m8290-071007a
 Sample text: CS0.5 S25-26L






Page 1 of 5

Acquired: 10-JUL-07 09:41:26 Processed: 10-JUL-07 14:08:59


Type	Name	Amount	Resp	Ion1	Ion2	RA	RT	S/N1?	S/N2?	RRF	Mod?
1	Unk	2,3,7,8-TCDD	0.25	2.12e+05	1.05e+05	1.27e+05	0.82 Y 31:35	13 Y	14 Y	0.9454	n
2	Unk	1,2,3,7,8-PeCDD	1.25	1.06e+06	6.49e+05	4.09e+05	1.58 Y 34:22	86 Y	51 Y	0.9662	n
3	Unk	1,2,3,4,7,8-HxCDD	1.25	9.93e+05	5.56e+05	4.37e+05	1.27 Y 37:01	59 Y	46 Y	0.9116	n
4	Unk	1,2,3,6,7,8-HxCDD	1.25	1.01e+06	5.65e+05	4.43e+05	1.28 Y 37:06	59 Y	48 Y	0.9246	n
5	Unk	1,2,3,7,8,9-HxCDD	1.25	9.98e+05	5.53e+05	4.46e+05	1.24 Y 37:21	54 Y	43 Y	0.9152	n
6	Unk	1,2,3,4,6,7,8-HpCDD	1.25	8.56e+05	4.46e+05	4.10e+05	1.09 Y 40:30	40 Y	34 Y	1.0338	n
7	Unk	OCDD	2.50	1.33e+06	6.30e+05	7.02e+05	0.90 Y 44:53	44 Y	48 Y	1.0018	n
8	Unk	2,3,7,8-TCDF	0.25	3.19e+05	1.40e+05	1.79e+05	0.78 Y 31:02	17 Y	17 Y	1.0554	n
9	Unk	1,2,3,7,8-PeCDF	1.25	1.71e+06	1.04e+06	6.69e+05	1.56 Y 33:34	141 Y	95 Y	0.9832	n
10	Unk	2,3,4,7,8-PeCDF	1.25	1.73e+06	1.06e+06	6.70e+05	1.58 Y 34:11	146 Y	93 Y	0.9940	n
11	Unk	1,2,3,4,7,8-HxCDF	1.25	1.54e+06	8.40e+05	6.96e+05	1.21 Y 36:18	81 Y	63 Y	1.0972	n
12	Unk	1,2,3,6,7,8-HxCDF	1.25	1.60e+06	8.81e+05	7.19e+05	1.22 Y 36:24	93 Y	76 Y	1.1424	n
13	Unk	2,3,4,6,7,8-HxCDF	1.25	1.51e+06	8.58e+05	6.49e+05	1.32 Y 36:53	82 Y	59 Y	1.0758	n
14	Unk	1,2,3,7,8,9-HxCDF	1.25	1.31e+06	7.52e+05	5.56e+05	1.35 Y 37:41	68 Y	50 Y	0.9346	n
15	Unk	1,2,3,4,6,7,8-HpCDF	1.25	1.38e+06	7.10e+05	6.69e+05	1.06 Y 39:12	64 Y	57 Y	1.3209	n
16	Unk	1,2,3,4,7,8,9-HpCDF	1.25	1.10e+06	5.62e+05	5.11e+05	1.04 Y 41:11	44 Y	37 Y	1.0563	n
17	Unk	OCDF	2.50	1.61e+06	7.69e+05	8.39e+05	0.92 Y 45:11	43 Y	65 Y	1.2084	n
18	ES/RT	13C-2,3,7,8-TCDD	100.00	9.80e+07	4.32e+07	5.49e+07	0.79 Y 31:34	4031 Y	4826 Y	1.1279	n
19	ES	13C-1,2,3,7,8-PeCDD	100.00	8.58e+07	5.26e+07	3.33e+07	1.58 Y 34:21	5582 Y	5693 Y	0.9873	n
20	ES	13C-1,2,3,6,7,8-HxCDD	100.00	8.72e+07	4.86e+07	3.86e+07	1.26 Y 37:05	4962 Y	4009 Y	1.0303	n
21	ES	13C-1,2,3,4,6,7,8-HpCDD	100.00	6.62e+07	3.42e+07	3.21e+07	1.07 Y 40:29	3363 Y	2816 Y	0.7828	n
22	ES	13C-OCDD	200.00	8.35e+07	5.04e+07	5.61e+07	0.90 Y 44:52	3795 Y	3462 Y	0.6289	n
23	ES/RT	13C-2,3,7,8-TCDF	100.00	1.21e+08	5.32e+07	6.77e+07	0.79 Y 31:01	4804 Y	5802 Y	1.3899	n
24	ES	13C-1,2,3,7,8-PeCDF	100.00	1.39e+08	8.56e+07	5.36e+07	1.60 Y 33:33	2936 Y	2536 Y	1.6013	n
25	ES	13C-1,2,3,6,7,8-HxCDF	100.00	1.12e+08	3.88e+07	7.32e+07	0.53 Y 36:23	3462 Y	7424 Y	1.3239	n
26	ES	13C-1,2,3,4,6,7,8-HpCDF	100.00	8.35e+07	2.58e+07	5.77e+07	0.45 Y 39:12	1779 Y	3443 Y	0.9871	n
27	JS	13C-1,2,3,4-TCDD	100.00	8.69e+07	3.81e+07	4.88e+07	0.78 Y 31:10	3121 Y	3931 Y	-	n
28	JS	13C-1,2,3,7,8-HxCDD	100.00	8.46e+07	4.70e+07	3.77e+07	1.25 Y 37:21	4385 Y	3652 Y	-	n
29	CS	37Cl-1,2,3,7,8-TCDD	0.25	2.45e+05	2.45e+05	2.45e+05	1.58 Y 34:10	3024 Y	2583 Y	1.1265	n
30	CS	13C-2,3,4,7,8-PeCDF	100.00	1.35e+08	8.29e+07	5.25e+07	1.27 Y 37:00	4859 Y	3889 Y	1.5568	n
31	CS	13C-1,2,3,4,7,8-HxCDD	100.00	8.14e+07	4.56e+07	3.58e+07	0.52 Y 36:17	3273 Y	7086 Y	0.9623	n
32	CS	13C-1,2,3,4,7,8-HpCDF	100.00	1.04e+08	3.59e+07	6.84e+07	0.45 Y 41:11	1409 Y	2689 Y	1.2326	n
33	CS	13C-1,2,3,4,7,8,9-HpCDF	100.00	7.38e+07	2.29e+07	5.09e+07	0.45 Y 41:11	1409 Y	2689 Y	0.8721	n
34	SS	37Cl-2,3,7,8-TCDF	0.25	2.45e+05	2.45e+05	2.45e+05	1.58 Y 34:07	3135 Y	29 Y	0.9988	n
35	SS	13C-2,3,4,7,8-PeCDF	100.00	1.35e+08	8.29e+07	5.25e+07	1.27 Y 37:00	4859 Y	2583 Y	0.9722	n
36	SS	13C-1,2,3,4,7,8-HxCDD	100.00	8.14e+07	4.56e+07	3.58e+07	0.52 Y 36:17	3273 Y	3889 Y	0.9340	n
37	SS	13C-1,2,3,4,7,8-HpCDF	100.00	1.04e+08	3.59e+07	6.84e+07	0.45 Y 41:11	1409 Y	7086 Y	0.9310	n
38	SS	13C-1,2,3,4,7,8,9-HpCDF	100.00	7.38e+07	2.29e+07	5.09e+07	0.45 Y 41:11	1409 Y	2689 Y	0.8835	n
39	Tot	Total Tetra-Furans	0.00	-	-	-	-	-	-	-	n
40	Tot	Total Tetra-Dioxins	0.00	-	-	-	-	-	-	-	n
41	Tot	Total Penta-Furans Fn1	0.00	-	-	-	-	-	-	-	n
42	Tot	Total Penta-Dioxins Fn2	0.00	-	-	-	-	-	-	-	n
43	Tot	Total Penta-Furans	0.00	-	-	-	-	-	-	-	n
44	Tot	Total Hexa-Furans	0.00	-	-	-	-	-	-	-	n




File:A10JUL07A #1-184 Acq:10-JUL-2007 09:41:26 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#2 Text:CS0.5 S25-26L Exp:EXP_DB5MS
 355.8546 S:2 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.018,3120.0,5.00%,F,T)
 100%
 34:22 2.7E5
 1.4E5
 0.0E0




File:A10JUL07A #1-252 Acq:10-JUL-2007 09:41:26 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#2 Text:CS0.5 S25-26L
 389.8156 S:2 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3288.0,5.00%,F,T)
 100%
 0 50 0 50 0 50 0 50 0 50




File:A10JUL07A #1-292 Acq:10-JUL-2007 09:41:26 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#2 Text:CS0.5 S25-26L
 423.7767 S:2 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,3160.0,5.00%,F,T)
 100%
 1.3E5




File:A10JUL07A #1-362 Acq:1.0-JUL-2007 09:41:26 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#2 Text:CS0.5 S25-26L Exp:EXP_DB5MS
 457.7377 S:2 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,2980.0,5.00%,F,T)
 100%
 50
 0



File:A10JUL07A #1-399 Acq:10-JUL-2007 09:41:26 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#2 Text:CS0.5 S25-26L
 Exp:EXP_DB5MS
 303.9016 S:2 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,2456.0,5.00%,F,T)
 100%
 31:03



File:A10JUL07A #1-184 Acq:10-JUL-2007 09:41:26 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#2 Text:CS0.5 S25-26L
 339.8597 S:2 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3152.0,5.00%,F,T)
 100%
 33:34 34:11



File:A10-JUL07A #1-252 Acq:10-JUL-2007 09:41:26 GC EI+ Voltage SIR Autospec-Ultimate

Sample#2 Text:CS0.5 S25-26L Exp:EXP_DB5MS

373.8207 S:2 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3728.0,5.00%,F,T)
100%

36:24 36:54 37:41
50 0 3.5E5
1.8E5
0.0E0 Time

35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12
375.8178 S:2 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3936.0,5.00%,F,T)
100%

36:24 36:54 37:41
50 0 2.7E5
1.3E5
0.0E0 Time

35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12
383.8639 S:2 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3928.0,5.00%,F,T)
100%

36:23 36:53 37:41
50 0 1.4E7
6.9E6
0.0E0 Time

35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12
385.8610 S:2 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3440.0,5.00%,F,T)
100%

36:23 36:53 37:41
50 0 2.6E7
1.3E7
0.0E0 Time

35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12
445.7555 S:2 F:3 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,3540.0,5.00%,F,T)
100%

36:13 36:33 37:23 37:32 37:41 37:55 38:15
50 0 5.6E3
2.8E3
0.0E0 Time

35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12
380.9760 S:2 F:3 SM0(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)
100%

35:56 35:42 37:11 37:21 37:41 37:55 38:07 1.9E7
50 0 9.5E6
0.0E0 Time

File:AI0JUL07A #1-292 Acq:10-JUL-2007 09:41:26 GC EI+ Voltage SIR Autospec-Ultimate

Sample#2 Text:CS0.5 S25-26L

407.7818 S:2 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3344.0,5.00%,F,T)

100%

2.2E5

1.1E5

0.0E0

41:11

Time

42:00

41:00

40:00

39:00

38:00

37:00

36:00

35:00

34:00

33:00

32:00

31:00

30:00

29:00

28:00

27:00

26:00

25:00

24:00

23:00

22:00

21:00

20:00

19:00

18:00

17:00

16:00

15:00

14:00

13:00

12:00

11:00

10:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00


09:00

08:00

07:00

06:00


05:00




Filename: a10jul07a - 4
 Analyte: m8290-070507a Cal: m8290-071007a
 Sample text: CS2 S25-26B

Acquired: 10-JUL-07 11:18:06 Processed: 10-JUL-07 14:13:16


Typ	Name	Amount	Resp	Ion1	Ion2	RA	RT	S/N1?	S/N2?	RRF	Mod?	
1	Unk	2,3,7,8-TCDD	2.00	1.46e+06	6.19e+05	8.43e+05	0.73 Y 31:35	56 Y	79 Y	0.9429	n	
2	Unk	1,2,3,7,8-PeCDD	10.00	6.62e+06	4.05e+06	2.57e+06	1.58 Y 34:22	458 Y	368 Y	1.0180	n	
3	Unk	1,2,3,4,7,8-HxCDD	10.00	6.67e+06	3.73e+06	2.94e+06	1.27 Y 37:01	350 Y	277 Y	0.9645	n	
4	Unk	1,2,3,6,7,8-HxCDD	10.00	6.49e+06	3.67e+06	2.82e+06	1.30 Y 37:06	341 Y	268 Y	0.9381	n	
5	Unk	1,2,3,7,8,9-HxCDD	10.00	6.35e+06	3.55e+06	2.79e+06	1.27 Y 37:21	331 Y	261 Y	0.9180	n	
6	Unk	1,2,3,4,6,7,8-HpCDD	10.00	5.42e+06	2.80e+06	2.62e+06	1.07 Y 40:30	234 Y	189 Y	1.0076	n	
7	Unk	OCDD	20.00	8.96e+06	4.24e+06	4.72e+06	0.90 Y 44:53	433 Y	394 Y	1.0305	n	
8	Unk	2,3,7,8-TCDF	2.00	2.23e+06	1.01e+06	1.22e+06	0.82 Y 31:02	79 Y	97 Y	1.0841	n	
9	Unk	1,2,3,7,8-PeCDF	10.00	1.05e+07	6.42e+06	4.07e+06	1.58 Y 33:34	621 Y	340 Y	0.9782	n	
10	Unk	2,3,4,7,8-PeCDF	10.00	1.09e+07	6.67e+06	4.24e+06	1.57 Y 34:10	618 Y	330 Y	1.0173	n	
11	Unk	1,2,3,4,7,8-HxCDF	10.00	9.94e+06	5.57e+06	4.36e+06	1.28 Y 36:17	296 Y	348 Y	1.0628	n	
12	Unk	1,2,3,6,7,8-HxCDF	10.00	1.04e+07	5.72e+06	4.70e+06	1.22 Y 36:24	300 Y	356 Y	1.1148	n	
13	Unk	2,3,4,6,7,8-HxCDF	10.00	9.92e+06	5.55e+06	4.37e+06	1.27 Y 36:53	282 Y	321 Y	1.0610	n	
14	Unk	1,2,3,7,8,9-HxCDF	10.00	8.48e+06	4.73e+06	3.75e+06	1.26 Y 37:41	211 Y	251 Y	0.9073	n	
15	Unk	1,2,3,4,6,7,8-HpCDF	10.00	9.34e+06	4.82e+06	4.52e+06	1.07 Y 39:12	327 Y	313 Y	1.3702	n	
16	Unk	1,2,3,4,7,8,9-HpCDF	10.00	7.33e+06	3.76e+06	3.57e+06	1.05 Y 41:11	223 Y	217 Y	1.0743	n	
17	Unk	OCDF	20.00	1.05e+07	5.02e+06	5.52e+06	0.91 Y 45:11	316 Y	375 Y	1.2113	n	
18	ES/RT	13C-2,3,7,8-TCDD	100.00	7.75e+07	3.42e+07	4.33e+07	0.79 Y 31:34	3217 Y	4506 Y	1.0145	n	
19	ES	13C-1,2,3,7,8-PeCDD	100.00	6.50e+07	3.98e+07	2.52e+07	1.58 Y 34:21	4722 Y	3127 Y	0.8515	n	
20	ES	13C-1,2,3,6,7,8-HxCDD	100.00	9.02e+07	3.86e+07	3.05e+07	1.26 Y 37:05	4212 Y	2643 Y	1.0473	n	
21	ES	13C-1,2,3,4,6,7,8-HpCDD	100.00	5.38e+07	2.77e+07	2.60e+07	1.06 Y 40:29	1993 Y	2249 Y	0.8145	n	
22	ES	13C-OCDD	200.00	8.70e+07	4.11e+07	4.59e+07	0.90 Y 44:51	3441 Y	4386 Y	0.6585	n	
23	ES/RT	13C-2,3,7,8-TCDF	100.00	1.03e+08	4.55e+07	5.75e+07	0.79 Y 31:01	3583 Y	4665 Y	1.3486	n	
24	ES	13C-1,2,3,6,7,8-PeCDF	100.00	1.07e+08	6.58e+07	4.15e+07	1.59 Y 33:33	3215 Y	2354 Y	1.4039	n	
25	ES	13C-1,2,3,4,6,7,8-HxCDF	100.00	9.35e+07	3.23e+07	6.12e+07	0.53 Y 36:23	3792 Y	5764 Y	1.4158	n	
26	ES	13C-1,2,3,4,6,7,8-HpCDF	100.00	6.82e+07	2.10e+07	4.72e+07	0.45 Y 39:12	1484 Y	2578 Y	1.0328	n	
27	JS	13C-1,2,3,4-TCDD	100.00	7.64e+07	3.37e+07	4.27e+07	0.79 Y 31:10	2787 Y	3882 Y	-	n	
28	JS	13C-1,2,3,7,8,9-HxCDD	100.00	6.60e+07	3.68e+07	2.93e+07	1.26 Y 37:20	4110 Y	2607 Y	-	n	
29	CS	37C1-2,3,7,8-TCDD	2.00	1.55e+06	1.55e+06	4.06e+07	31:35	141 Y	1970 Y	2211 Y	1.0127	n
30	CS	13C-2,3,4,7,8-PeCDD	100.00	1.05e+08	6.43e+07	4.06e+07	1.58 Y 34:10	1970 Y	4067 Y	2524 Y	0.9866	n
31	CS	13C-1,2,3,4,7,8-HxCDD	100.00	6.51e+07	3.65e+07	2.87e+07	1.27 Y 37:00	3561 Y	5417 Y	1.4452	n	
32	CS	13C-1,2,3,4,7,8-HxCDF	100.00	8.22e+07	2.84e+07	5.39e+07	0.53 Y 36:17	1125 Y	1961 Y	0.9402	n	
33	CS	13C-1,2,3,4,7,8,9-HpCDF	100.00	6.21e+07	1.92e+07	4.29e+07	0.45 Y 41:11	1125 Y	1125 Y	-	n	
34	SS	37C1-2,3,7,8-TCDF	2.00	1.55e+06	1.55e+06	4.06e+07	31:35	141 Y	1970 Y	2211 Y	0.9982	n
35	SS	13C-2,3,4,7,8-PeCDF	100.00	1.05e+08	6.43e+07	4.06e+07	1.58 Y 34:10	2.87e+07	4067 Y	2524 Y	0.9429	n
36	SS	13C-1,2,3,4,7,8-HxCDD	100.00	6.51e+07	3.65e+07	2.87e+07	1.27 Y 37:00	3561 Y	5417 Y	0.9420	n	
37	SS	13C-1,2,3,4,7,8-HxCDF	100.00	8.22e+07	2.84e+07	5.39e+07	0.53 Y 36:17	1125 Y	1961 Y	0.9978	n	
38	SS	13C-1,2,3,4,7,8,9-HpCDF	100.00	6.21e+07	1.92e+07	4.29e+07	0.45 Y 41:11	1125 Y	1125 Y	1.0180	n	
39	Tot	Total Tetra-Furans	0.00	-	-	-	-	-	-	-	1.0841	n
40	Tot	Total Tetra-Dioxins	0.00	-	-	-	-	-	-	-	0.9979	n
41	Tot	Total Penta-Furans Fn1	0.00	-	-	-	-	-	-	-	0.9429	n
42	Tot	Total Penta-Furans Fn2	0.00	-	-	-	-	-	-	-	0.9978	n
43	Tot	Total Penta-Dioxins	0.00	-	-	-	-	-	-	-	0.9975	n
44	Tot	Total Hexa-Furans	0.00	-	-	-	-	-	-	-	1.0265	n




File:A10JUL07A #1-184 Acq:10-JUL-2007 11:18:06 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#4 Text:CS2 S25-26B Exp:EXP DB5MS
 355.8546 S:4 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3848.0,5.00%,F,T)
 100% 34:22




File:A10JUL07A #1-252 Acq:10-JUL-2007 11:18:06 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#4 Text:CS2 S25-26B Exp:EXP_DB5MS
 389.8156 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3576.0,5.00%,F,T)
 100%
 35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time
 391.8127 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3576.0,5.00%,F,T)
 100%
 35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time
 401.8559 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,2980.0,5.00%,F,T)
 100%
 35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time
 403.8530 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3836.0,5.00%,F,T)
 100%
 35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time
 380.9760 S:4 F:3 SMO(1,3) PKD(3,2,1,100.00%,0,5.00%,F,T)
 100%
 35:12 35:23 35:34 36:00 36:17 36:41 37:06 37:21 37:57 38:12 Time



FILE:A10JUL07A #1-292 Acq:10-06 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#4 Text:CS2 S25-26B
 423.7767 S:4 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,3316.0,5.00%,F,T)
 100% 40:30





File:A10JUL07A #1-362 Accq:10-JUL-2007 11:18:06 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#4 Text:CS2 S25-26B
 Exp:EXP_DB5MS
 457.7377 S:4 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,1908.0,5.00%,F,T)
 100%
 100%



100%

File: A10JUL07A #1-399 Acq: 10-JUL-2007 11:18:06 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#4 Text:CS2 S25-26B
 Exp:EXP_DB5MS
 303.9016 S:4 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,3776.0,5.00%,F,T)
 100%
 0 50 100







File:A10JUL07A #1-252 Accq:10-JUL-2007 11:18:06 GC EI+ Voltage SIR Autospec-Ultimate

Sample#4 Text:CS2 S25-26B Exp:EXP_DB5MS


373.8207 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,7076.0,5.00%,F,T)
100%




375.8178 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4756.0,5.00%,F,T)
100%




383.8639 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3008.0,5.00%,F,T)
100%






385.8610 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3700.0,5.00%,F,T)
100%




445.7555 S:4 F:3 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,4280.0,5.00%,F,T)
100%



380.9760 S:4 F:3 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)
100%



File:AI0JUL07A #1-292 Acq:10-JUL-2007 11:18:06 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#4 Text:CS2 S25-26B Exp:EXP_DB5MS
 407.7818 S:4 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4288.0,5.00%,F,T)
 100% 39:12



File: A10JUL07A #1-362 Accq: 10-JUL-2007 11:18:06 GC EI+ Voltage SIR Autospec-Ultimae

Sample#4 Text:CS2 S25-26B

Exp: EXP_DB5MS

441.7427 S:4 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3012.0,5.00%,F,T)

100%

45:11

9.6E5

4.8E5

0.0E0

Time

46:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

45:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

44:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

43:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

42:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

41:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

40:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

39:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

38:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

37:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

36:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

35:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

34:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

33:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

32:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

31:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

30:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

29:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

28:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

27:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

26:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

25:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

24:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

23:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

22:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

21:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

20:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

19:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

18:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

17:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

16:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

15:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

14:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

13:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

12:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

11:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

10:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

09:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

08:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

07:00

4.8E5

4.0E6

5.2E5

1.0E6

0.0E0

Time

06:00

4.8E5

4.0E6


Filename: a10jul07a
 Analyte: m8290-070507a
 Sample text: CS3 S25-26C

Acquired: 10-JUL-07 12:06:23 Processed: 10-JUL-07 14:15:11


Page 3 of 5

TYP	Name	Amount	Resp	Ion1	Ion2	RA	RT	S/N1?	S/N2?	RRF	Mod?	
1	Unk	2, 3, 7, 8-TCDD	10.00	7.74e+06	3.39e+06	4.36e+06	0.78 Y 31:35	689 Y	892 Y	0.9557	n	
2	Unk	1, 2, 3, 7, 8-PeCDF	50.00	3.47e+07	2.13e+07	1.34e+07	1.58 Y 34:22	3834 Y	3052 Y	1.0536	n	
3	Unk	1, 2, 3, 4, 7, 8-HxCDD	50.00	3.39e+07	1.93e+07	1.45e+07	1.33 Y 37:01	3211 Y	2958 Y	0.9955	n	
4	Unk	1, 2, 3, 6, 7, 8-HxCDD	50.00	3.39e+07	1.85e+07	1.54e+07	1.20 Y 37:06	3107 Y	2817 Y	0.9965	n	
5	Unk	1, 2, 3, 7, 8, 9-HxCDD	50.00	3.29e+07	1.82e+07	1.47e+07	1.24 Y 37:21	2983 Y	2784 Y	0.9663	n	
6	Unk	1, 2, 3, 4, 6, 7, 8-HpCDF	50.00	2.88e+07	1.48e+07	1.40e+07	1.06 Y 40:30	1981 Y	2013 Y	1.0644	n	
7	Unk	OCDD	100.00	5.01e+07	2.37e+07	2.65e+07	0.89 Y 44:52	3167 Y	3045 Y	1.1075	n	
8	Unk	2, 3, 7, 8-TCDF	10.00	1.21e+07	5.24e+06	6.87e+06	0.76 Y 31:02	743 Y	1034 Y	1.1056	n	
9	Unk	1, 2, 3, 7, 8-PeCDF	50.00	5.36e+07	3.29e+07	2.08e+07	1.58 Y 33:34	2165 Y	1897 Y	1.0058	n	
10	Unk	2, 3, 4, 7, 8-PeCDF	50.00	5.70e+07	3.50e+07	2.20e+07	1.59 Y 34:10	2311 Y	2028 Y	1.0679	n	
11	Unk	1, 2, 3, 4, 7, 8-HxCDF	50.00	4.98e+07	2.76e+07	2.22e+07	1.25 Y 36:17	4425 Y	3284 Y	1.0760	n	
12	Unk	1, 2, 3, 6, 7, 8-HxCDF	50.00	5.42e+07	3.03e+07	2.39e+07	1.27 Y 36:23	4720 Y	3576 Y	1.1720	n	
13	Unk	2, 3, 4, 6, 7, 8-HxCDF	50.00	5.15e+07	2.88e+07	2.27e+07	1.26 Y 36:53	4490 Y	3360 Y	1.1128	n	
14	Unk	1, 2, 3, 7, 8, 9-HxCDF	50.00	4.42e+07	2.46e+07	1.96e+07	1.26 Y 37:41	3415 Y	2568 Y	0.9555	n	
15	Unk	1, 2, 3, 4, 6, 7, 8-HpCDF	50.00	4.84e+07	2.49e+07	2.36e+07	1.05 Y 39:12	2254 Y	2224 Y	1.4113	n	
16	Unk	1, 2, 3, 4, 7, 8, 9-HpCDF	50.00	3.78e+07	1.93e+07	1.85e+07	1.04 Y 41:11	1487 Y	1533 Y	1.1023	n	
17	Unk	OCDF	100.00	5.87e+07	2.80e+07	3.06e+07	0.91 Y 45:11	2452 Y	2619 Y	1.2961	n	
18	ES/RT	13C-2, 3, 7, 8-TCDD	100.00	8.10e+07	3.55e+07	4.56e+07	0.78 Y 31:34	7429 Y	8646 Y	1.0158	n	
19	ES	13C-1, 2, 3, 7, 8-PeCDF	100.00	6.59e+07	4.04e+07	2.55e+07	1.59 Y 34:21	7381 Y	6556 Y	0.8260	n	
20	ES	13C-1, 2, 3, 6, 7, 8-HxCDD	100.00	6.26e+07	3.80e+07	3.03e+07	1.26 Y 37:05	5328 Y	5455 Y	1.0341	n	
21	ES	13C-1, 2, 3, 4, 6, 7, 8-HpCDF	100.00	5.42e+07	2.79e+07	2.63e+07	1.06 Y 40:29	3758 Y	3758 Y	0.8232	n	
22	ES	13C-OCDD	200.00	9.05e+07	4.29e+07	4.76e+07	0.90 Y 44:51	6169 Y	6348 Y	0.6877	n	
23	ES/RT	13C-1, 2, 3, 7, 8-TCDF	100.00	1.10e+08	4.85e+07	6.10e+07	0.80 Y 31:01	10427 Y	11634 Y	1.3734	n	
24	ES	13C-1, 2, 3, 6, 7, 8-HxCDF	100.00	1.07e+08	6.53e+07	4.13e+07	1.58 Y 33:33	2475 Y	4397 Y	1.3373	n	
25	ES	13C-1, 2, 3, 4, 6, 7, 8-HpCDF	100.00	9.26e+07	3.21e+07	6.05e+07	0.53 Y 36:22	5723 Y	10972 Y	1.4067	n	
26	ES	13C-1, 2, 3, 4, 6, 7, 8-HpCDF	100.00	6.87e+07	2.12e+07	4.74e+07	0.45 Y 39:11	2444 Y	4497 Y	1.0434	n	
27	JS	13C-1, 2, 3, 4-TCDD	100.00	7.98e+07	3.52e+07	4.46e+07	0.79 Y 31:09	6536 Y	7344 Y	-	n	
28	JS	13C-1, 2, 3, 7, 8, 9-HxCDD	100.00	6.58e+07	3.66e+07	2.92e+07	1.25 Y 37:20	5176 Y	5449 Y	-	n	
29	CS	37Cl-1, 2, 3, 7, 8-TCDD	10.00	8.15e+06	8.15e+06	6.59e+07	1.59 Y 34:10	31:35	1730 Y	4447 Y	1.0220	n
30	CS	13C-2, 3, 4, 7, 8-PeCDF	100.00	1.07e+08	6.59e+07	4.15e+07	1.27 Y 37:00	5393 Y	5577 Y	1.3454	n	
31	CS	13C-1, 2, 3, 4, 7, 8-HxCDD	100.00	6.57e+07	3.68e+07	2.89e+07	0.52 Y 36:16	5003 Y	9603 Y	0.9990	n	
32	CS	13C-1, 2, 3, 4, 7, 8-HxCDF	100.00	8.16e+07	2.80e+07	5.35e+07	0.45 Y 41:10	1801 Y	3296 Y	1.2397	n	
33	CS	13C-1, 2, 3, 4, 7, 8, 9-HpCDF	100.00	6.09e+07	1.89e+07	4.20e+07	-	-	-	0.9249	n	
34	SS	37Cl-1, 2, 3, 7, 8-TCDD	10.00	8.15e+06	8.15e+06	6.59e+07	1.59 Y 34:07	31:35	1730 Y	4447 Y	1.0061	n
35	SS	13C-2, 3, 4, 7, 8-PeCDF	100.00	1.07e+08	6.59e+07	4.15e+07	1.27 Y 37:00	5393 Y	5577 Y	1.0060	n	
36	SS	13C-1, 2, 3, 4, 7, 8-HxCDD	100.00	6.57e+07	3.68e+07	2.89e+07	0.52 Y 36:16	5003 Y	9603 Y	0.9661	n	
37	SS	13C-1, 2, 3, 4, 7, 8-HxCDF	100.00	8.16e+07	2.80e+07	5.35e+07	0.45 Y 41:10	1801 Y	3296 Y	0.8813	n	
38	SS	13C-1, 2, 3, 4, 7, 8, 9-HpCDF	100.00	6.09e+07	1.89e+07	4.20e+07	-	-	-	0.8864	n	
39	Total	Tetra-Furans	0.00	-	-	-	-	-	-	-	1.1056	n
40	Total	Total Tetra-Dioxins	0.00	-	-	-	-	-	-	-	0.9557	n
41	Total	Total Penta-Furans Fn1	0.00	-	-	-	-	-	-	-	1.0369	n
42	Total	Total Penta-Furans Fn2	0.00	-	-	-	-	-	-	-	1.0369	n
43	Total	Total Penta-Dioxins	0.00	-	-	-	-	-	-	-	1.0536	n
44	Total	Total Hexa-Furans	0.00	-	-	-	-	-	-	-	1.0791	n


File: A10JUL07A #1-399 Acq:10-JUL-2007 12:06:23 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#5 Text:CS3 S25-26C
 319.8965 S:5 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,1856.0,5.00%,F,T)
 100%
 0 50 100




File:A10JUL07A #1-184 Acq:10-JUL-2007 12:06:23 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#5 Text:CS3 S25-26C
 355.8546 S:5 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,2284.0,5.00%,F,T)
 100%



File: A10JUL07A #1-252 Acq:10-JUL-2007 12:06:23 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#5 Text:CS3 S25-26C Exp:EXP_DB5MS
 389.8156 S:5 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.018,2024.0,5.00%,F,T)
 100% 37:01 37:21



File:A10JUL07A #1-292 Accq:10-JUL-2007 12:06:23 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#5 Text:CS3 S25-26C Exp:EXP_DB5MS
 423.7767 S:5 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,1944.0,5.00%,F,T)
 100% 40:30




File: A03307A #1-363 Acc#: 10-101-2007 13:06:23 GC EI+ Voltage SIR Autospec-UltimaE


```

file#A15 Text:CS3 S25-26C Exp:EXP DB5MS
457.737 S:5 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,1476.0,5.00%,F,T)

```



File:A10JUL07A #1-399 Acq:10-JUL-2007 12:06:23 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#5 Text:CS3 S25-26C
 303.9016 S:5 BSUB (256,15,-3.0) PKD(3,2,1,0.01%,2064.0,5.00%,F,T)
 100%
 0 50 100




File: A10JUL07A #1-184 Acq:10-JUL-2007 12:06:23 GC EI+ Voltage SIR Autospec-UltimaE

Sampole#5 Text:CS3 S25-26C

339.8597 S:5 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,6600.0,5.00%,F,T)

100%




341.8568 S:5 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4788.0,5.00%,F,T)

100%



351.9000 S:5 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,11444.0,5.00%,F,T)

100%



353.8970 S:5 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4088.0,5.00%,F,T)

100%




409.7974 S:5 F:2 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,1992.0,5.00%,F,T)

100%




366.9792 S:5 F:2 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)

100%





File: A100JUT07A #1-252 Acq: 10-JUL-2007 12:06:23 GC EII+ Voltage SIR Autospec-Ultimate

Sample# 5 Text:CS3 S25-26C EXP:EXP_DB5MS
373.8207 S:5 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.018,2176.0,5.00%,F,T)
100% 36:23 36:53



File:A10JUL07A #1-292 Accq:10-JUL-2007 12:06:23 GC EI+ Voltage SIR Autospec-Ultimae
 Sample#5 Text:CS3 S25-26C
 407.7818 S:5 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3456.0,5.00%,F,T)
 100%
 39:12






Filename: a10jul07a - 6
 Analyte: m8290-07007a Call: m8290-071007a
 Sample text: CS4 S25-26D


TYP	Name	Amount	Resp	Ion1	Ion2	RA	RT	S/N1?	S/N2?	RRF	Mod?	
1	Unk	2,3,7,8-TCDD	40.00	3.45e+07	1.52e+07	1.93e+07	0.79 Y 31:35	2786 Y	3422 Y	0.9955	n	
2	Unk	1,2,3,7,8-PeCDD	200.00	1.49e+08	9.09e+07	5.79e+07	1.57 Y 34:22	16046 Y	10200 Y	1.0924	n	
3	Unk	1,2,3,4,7,8-HxCDD	200.00	1.48e+08	8.27e+07	6.35e+07	1.26 Y 37:01	12435 Y	11562 Y	1.0388	n	
4	Unk	1,2,3,6,7,8-HxCDD	200.00	1.41e+08	7.87e+07	6.22e+07	1.27 Y 37:06	12650 Y	11637 Y	0.9874	n	
5	Unk	1,2,3,7,8-HxCDD	200.00	1.41e+08	7.87e+07	6.26e+07	1.26 Y 37:21	11709 Y	10698 Y	0.9904	n	
6	Unk	1,2,3,4,6,7,8-HpCDD	200.00	1.21e+08	6.18e+07	5.37e+07	1.05 Y 40:30	8414 Y	7855 Y	1.0925	n	
7	Unk	OCDD	400.00	2.09e+08	9.89e+07	1.10e+08	0.90 Y 44:52	12286 Y	12189 Y	1.1241	n	
8	Unk	2,3,7,8-TCDF	40.00	5.40e+07	2.39e+07	3.02e+07	0.79 Y 31:02	3336 Y	4311 Y	1.1806	n	
9	Unk	1,2,3,7,8-PeCDF	200.00	2.31e+08	1.41e+08	9.02e+07	1.56 Y 33:34	2853 Y	2298 Y	1.0091	n	
10	Unk	1,2,3,4,7,8-PeCDF	200.00	2.16e+08	1.46e+08	9.32e+07	1.56 Y 34:10	2849 Y	2332 Y	1.0452	n	
11	Unk	1,2,3,6,7,8-HxCDF	200.00	2.16e+08	9.60e+07	9.60e+07	1.25 Y 36:17	22334 Y	17124 Y	1.1041	n	
12	Unk	1,2,3,4,6,7-HxCDF	200.00	2.34e+08	1.31e+08	1.03e+08	1.26 Y 36:23	21552 Y	17322 Y	1.1952	n	
13	Unk	2,3,4,6,7,8-HxCDF	200.00	2.19e+08	1.22e+08	9.71e+07	1.25 Y 36:53	20627 Y	16789 Y	1.1173	n	
14	Unk	1,2,3,7,8,9-HxCDF	200.00	1.89e+08	1.06e+08	8.33e+07	1.27 Y 37:41	16265 Y	12834 Y	0.9646	n	
15	Unk	1,2,3,4,6,7,8-HpCDF	200.00	2.05e+08	1.05e+08	9.99e+07	1.05 Y 39:12	5861 Y	7840 Y	1.4133	n	
16	Unk	1,2,3,4,7,8,9-HpCDF	200.00	1.62e+08	8.33e+07	7.88e+07	1.06 Y 41:11	3773 Y	4991 Y	1.1183	n	
17	Unk	OCDF	400.00	2.61e+08	1.24e+08	1.36e+08	0.91 Y 45:11	13016 Y	12237 Y	1.3988	n	
18	ES/RT	13C-2,3,7,8-TCDD	100.00	8.67e+07	3.79e+07	4.88e+07	0.78 Y 31:34	6373 Y	9300 Y	1.0625	n	
19	ES	13C-1,2,3,7,8-PeCDD	100.00	6.81e+07	4.18e+07	6.23e+07	1.59 Y 34:21	9561 Y	5609 Y	0.8352	n	
20	ES	13C-1,2,3,6,7,8-HxCDD	100.00	7.97e+07	3.16e+07	3.16e+07	1.26 Y 37:05	6146 Y	5455 Y	1.0415	n	
21	ES	13C-1,2,3,4,6,7,8-HpCDD	100.00	5.52e+07	2.83e+07	2.68e+07	1.06 Y 40:29	3843 Y	3518 Y	0.8056	n	
22	ES	13C-OCDD	200.00	9.31e+07	4.41e+07	4.91e+07	0.90 Y 44:51	4258 Y	5110 Y	0.6800	n	
23	ES/RT	13C-2,3,7,8-TCDF	100.00	1.14e+08	5.08e+07	6.37e+07	0.80 Y 31:01	6656 Y	12119 Y	1.4032	n	
24	ES	13C-1,2,3,7,8-PeCDF	100.00	1.14e+08	7.01e+07	4.32e+07	1.58 Y 33:33	2748 Y	2736 Y	1.4016	n	
25	ES	13C-1,2,3,6,7,8-HxCDF	100.00	9.79e+07	3.39e+07	5.40e+07	0.53 Y 36:22	5372 Y	13629 Y	1.4302	n	
26	ES	13C-1,2,3,4,6,7,8-HpCDF	100.00	7.25e+07	2.24e+07	5.01e+07	0.45 Y 39:11	1998 Y	5599 Y	1.0589	n	
27	JS	13C-1,2,3,4-TCDD	100.00	8.16e+07	3.61e+07	4.54e+07	0.80 Y 31:09	5404 Y	7715 Y	-	n	
28	JS	13C-1,2,3,7,8-HxCDD	100.00	6.85e+07	3.81e+07	3.03e+07	1.26 Y 37:20	5783 Y	5067 Y	-	n	
29	CS	37Cl-2,3,7,8-TCDD	40.00	3.62e+07	3.62e+07	4.29e+07	1.59 Y 34:10	6634 Y	2617 Y	2597 Y	1.1097	n
30	CS	13C-2,3,4,7,8-PeCDD	100.00	1.11e+08	6.83e+07	3.03e+07	1.27 Y 37:00	5653 Y	4919 Y	1.0064	n	
31	CS	13C-1,2,3,4,7,8-HxCDD	100.00	6.89e+07	3.86e+07	5.74e+07	0.52 Y 36:16	5402 Y	13308 Y	1.2771	n	
32	CS	13C-1,2,3,4,7,8-HxCDF	100.00	8.74e+07	3.00e+07	4.42e+07	0.45 Y 41:10	1514 Y	4190 Y	0.9373	n	
33	CS	13C-1,2,3,4,7,8,9-HpCDF	100.00	6.42e+07	1.99e+07	4.42e+07	0.45 Y 41:07	-	-	-	n	
34	SS	37Cl-2,3,7,8-TCDD	40.00	3.62e+07	3.62e+07	4.29e+07	1.59 Y 34:10	6634 Y	2617 Y	2597 Y	1.0444	n
35	SS	13C-2,3,4,7,8-PeCDD	100.00	1.11e+08	6.83e+07	3.86e+07	1.27 Y 37:00	5653 Y	4919 Y	0.9663	n	
36	SS	13C-1,2,3,4,7,8-HxCDD	100.00	6.89e+07	3.00e+07	5.74e+07	0.52 Y 36:16	5402 Y	13308 Y	0.9299	n	
37	SS	13C-1,2,3,4,7,8-HpCDF	100.00	8.74e+07	3.00e+07	4.42e+07	0.45 Y 41:10	1514 Y	4190 Y	0.8852	n	
38	SS	13C-1,2,3,4,7,8,9-HpCDF	100.00	6.42e+07	1.99e+07	4.42e+07	0.45 Y 41:07	-	-	-	n	
39	Total	Tetra-Furans	0.00	-	-	-	-	-	-	-	n	
40	Total	Total Tetra-Dioxins	0.00	-	-	-	-	-	-	-	1.1806	
41	Total	Penta-Furans Fn1	0.00	-	-	-	-	-	-	-	0.9955	
42	Total	Total Penta-Furans Fn2	0.00	-	-	-	-	-	-	-	1.0271	
43	Total	Total Penta-Dioxins	0.00	-	-	-	-	-	-	-	1.0271	
44	Total	Total Hexa-Furans	0.00	-	-	-	-	-	-	-	1.0924	


Sample#6 Text:CS4 S25-26D Exp:EXP_DB5MS
S:6 BSUB(256,15,-3.0) PKD(3,2,1,0.018,1972.0,5.008,F,T)
1000




e: A10JII.07A #1- 84 Acq: 10-JUL-2007 12:54:41 GC E1+ Voltage SIR Autospec-UltimaE

Sample#6 Text:CS4 S:5-B2D S:6-F:2 BSUB1128,15,-3.0 PKD(3,2,1,0.01%,2312.0,5.00%,F,T) Exp:EXP_DB5MS






FILE:A10JUL07A #1-292 Acq:10-JUL-2007 12:54:41 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#6 Text:CS4 S25-26D Exp:EXP_DB5MS
 423.7767 S:6 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,1976.0,5.00%,F,T)
 100% 40:30



File:A10JUL07A #1-362 Acq:10-JUL-2007 12:54:41 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#6 Text:CS4 S25-26D Exp:EXP_DB5MS
 457.7377 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,1664.0,5.00%,F,T)
 100%
 459.7348 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,1844.0,5.00%,F,T)
 100%
 469.7780 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,2068.0,5.00%,F,T)
 100%
 471.7750 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,1936.0,5.00%,F,T)
 100%



File:A10JUL07A #1-399 Acq:10-JUL-2007 12:54:41 GC EI+ Voltage SIR Autospec-Ultimate

Sample#6 Text:CS4 S25-26D Exp:EXP_DB5MS

303.9016 S:6 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,2132.0,5.00%,F,T)

100%

7.1E6

3.6E6

0.0E0

Time

31:00

32:00

7.1E6

3.6E6

0.0E0

Time

375.8364 S:6 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,2056.0,5.00%,F,T)

100%

3.0E3

1.5E3

9.6E6

7.5E6

5.6E6

3.6E6


1.5E6

9.6E6

7.5E6

5.6E6

File:A10JUL07A #1-184 Accq:10-JUL-2007 12:54:41 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#6 Text:CS4 S25-26D Exp:EXP_DB5MS
 339.8597 S:6 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,22612.0,5.00%,F,T)
 100% 34:10



File:A10JUL07A #1-252 Acq:10-JUL-2007 12:54:41 GC EI+ Voltage SIR Autospec-Ultimate

Sample#6 Text:CS4 S25-26D Exp:EXP_DB5MS

373.8207 S:6 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,2052.0,5.00%,F,T)

100%

36:18 36:53


37:41

0.0E0

2.3E7

4.6E7

Time



375.8178 S:6 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,2064.0,5.00%,F,T)

100%

36:23

36:53


37:41

0.0E0

3.6E7

1.8E7

Time



383.8639 S:6 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,2184.0,5.00%,F,T)

100%

36:17

36:52

37:40

0.0E0


1.2E7

5.9E6

0.0E0

2.2E7

Time



385.8610 S:6 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,1636.0,5.00%,F,T)

100%

36:22

36:52

37:40


0.0E0

1.1E7

0.0E0

2.2E7

Time



445.7555 S:6 F:3 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,2628.0,5.00%,F,T)

100%

36:25

36:51

37:08

37:23

37:55


38:00

38:16

4.0E3

0.0E0

Time



380.9760 S:6 F:3 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)

100%

35:34

36:10

36:39

37:06

37:21

37:41

37:41

0.0E0

1.8E7

9.1E6

0.0E0

Time



File:A10JUL07A #1-292 Accq:10-JUL-2007 12:54:41 GC EI+ Voltage SIR Autospec-Ultimate

Sample#6 Text:CS4 S25-26D

Exp:EXP_DB5MS

407.7818 S:6 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,5456.0,5.00%,F,T)

100%

3.2E7

1.6E7

0.0E0

41:11

Time

409.7788 S:6 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,3876.0,5.00%,F,T)

100%

3.0E7

1.5E7

0.0E0

41:11

Time

417.8253 S:6 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,3356.0,5.00%,F,T)

100%

6.7E6

3.4E6

0.0E0

41:11

Time

419.8220 S:6 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,2644.0,5.00%,F,T)

100%

1.5E7

7.4E6

0.0E0

41:11

Time

479.7165 S:6 F:4 BSUB(128,15,-3.0) PKD(3,2,1,100.008,1888.0,5.00%,F,T)

100%

3.1E3

1.6E3

0.0E0

41:00

Time

430.9728 S:6 F:4 SMO(1,3) PKD(3,2,1,100.008,0.0,5.00%,F,T)

100%

1.1E7

5.3E6

0.0E0

41:00

Time

39:00 39:00 40:00 40:00 41:00 42:00

39:00

41:47 41:59

1.1E7

5.3E6

0.0E0

42:00

Time

39:00 39:00 40:00 40:00 41:00 42:00

39:00

41:00


42:00

Time

File:A10JUL07A #1-362 Acq:10-JUL-2007 12:54:41 GC EI+ Voltage SIR Autospec-Ultimate

Sample#6 Text:CS4 S25-26D


441.7427 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,1948.0,5.00%,F,T)




443.7398 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,2260.0,5.00%,F,T)




469.7780 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,2068.0,5.00%,F,T)





471.7750 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,1936.0,5.00%,F,T)



513.6775 S:6 F:5 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,2184.0,5.00%,F,T)



454.9728 S:6 F:5 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)



Filename: a10jul07a - 7
 Analyte: m8290-070507a cal: m8290-071007a
 Sample text: CS5 S25-26E

Acquired: 10-JUL-07 13:42:57 Processed: 10-JUL-07 14:31:03

Typ	Name	Amount	Resp	Ion1	Ion2	RA	RT	S/N1?	S/N2?	RRF	Mod2	
1	Unk	2,3,7,8-TCDD	200.00	1.78e+08	7.75e+07	1.00e+08	0.77 Y 31:35	13174 Y	16902 Y	1.0117	n	
2	Unk	1,2,3,7,8-PeCDD	1000.00	7.64e+08	4.67e+08	2.97e+08	1.57 Y 34:22	98056 Y	48706 Y	1.0653	n	
3	Unk	1,2,3,4,7,8-HxCDD	1000.00	7.51e+08	4.18e+08	3.33e+08	1.25 Y 37:01	56120 Y	57255 Y	1.0088	n	
4	Unk	1,2,3,6,7,8-HxCDD	1000.00	7.35e+08	4.09e+08	3.26e+08	1.26 Y 37:06	57894 Y	58518 Y	0.9866	n	
5	Unk	1,2,3,7,8,9-HxCDD	1000.00	7.24e+08	4.03e+08	3.21e+08	1.25 Y 37:21	52312 Y	52819 Y	0.9719	n	
6	Unk	1,2,3,4,6,7,8-HpCDD	1000.00	6.36e+08	3.26e+08	3.10e+08	1.05 Y 40:30	36731 Y	35299 Y	1.0930	n	
7	Unk	OCDD	2000.00	1.15e+09	5.41e+08	6.04e+08	0.90 Y 44:53	58457 Y	55088 Y	1.1278	n	
8	Unk	2,3,7,8-TCDF	200.00	2.67e+08	1.17e+08	1.50e+08	0.78 Y 31:02	13662 Y	17441 Y	1.1748	n	
9	Unk	1,2,3,7,8-PeCDF	1000.00	1.20e+09	7.32e+08	4.65e+08	1.57 Y 33:34	5655 Y	5579 Y	1.0159	n	
10	Unk	2,3,4,7,8-PeCDF	1000.00	1.24e+09	7.58e+08	4.85e+08	1.56 Y 34:11	5688 Y	5680 Y	1.0544	n	
11	Unk	1,2,3,4,7,8-HxCDF	1000.00	6.14e+09	6.14e+08	4.88e+08	1.26 Y 36:17	66612 Y	65789 Y	1.1234	n	
12	Unk	1,2,3,6,7,8-HxCDF	1000.00	1.15e+09	6.43e+08	5.09e+08	1.26 Y 36:24	66643 Y	64771 Y	1.1745	n	
13	Unk	2,3,4,6,7,8-HxCDF	1000.00	1.11e+09	6.19e+08	4.92e+08	1.26 Y 36:53	65282 Y	64812 Y	1.1325	n	
14	Unk	1,2,3,7,8,9-HxCDF	1000.00	9.12e+08	5.26e+08	4.16e+08	1.26 Y 37:41	49271 Y	50237 Y	0.9602	n	
15	Unk	1,2,3,4,6,7,8-HpCDF	1000.00	1.07e+09	5.47e+08	5.21e+08	1.05 Y 39:12	25854 Y	15160 Y	1.4380	n	
16	Unk	1,2,3,4,7,8,9-HpCDF	1000.00	8.38e+08	4.31e+08	4.08e+08	1.06 Y 41:11	18194 Y	10477 Y	1.1294	n	
17	Unk	OCDF	2000.00	1.45e+09	6.93e+08	7.59e+08	0.91 Y 45:11	79875 Y	93001 Y	1.4294	n	
18	ES/RT	13C-2,3,7,8-TCDD	100.00	8.79e+07	3.85e+07	4.94e+07	0.78 Y 31:34	5386 Y	7452 Y	1.0654	n	
19	ES	13C-1,2,3,7,8-PeCDD	100.00	7.17e+07	4.39e+07	2.78e+07	1.58 Y 34:21	13131 Y	5491 Y	0.8697	n	
20	ES	13C-1,2,3,6,7,8-HxCDD	100.00	7.45e+07	4.15e+07	3.30e+07	1.26 Y 37:05	5712 Y	5276 Y	1.0581	n	
21	ES	13C-1,2,3,4,6,7,8-HpCDD	100.00	5.82e+07	2.99e+07	2.83e+07	1.06 Y 40:29	3457 Y	4148 Y	0.9266	n	
22	ES	13C-OCDD	200.00	1.02e+08	4.79e+07	5.36e+07	0.89 Y 44:52	4433 Y	5122 Y	0.7215	n	
23	ES/RT	13C-2,3,7,8-TCDF	100.00	1.14e+08	5.03e+07	6.34e+07	0.79 Y 31:01	7109 Y	7796 Y	1.3785	n	
24	ES	13C-1,2,3,7,8-PeCDF	100.00	1.18e+08	7.21e+07	4.57e+07	1.58 Y 33:33	5578 Y	3692 Y	1.4287	n	
25	ES	13C-1,2,3,6,7,8-HxCDF	100.00	9.81e+07	3.40e+07	6.41e+07	0.53 Y 36:23	6378 Y	10176 Y	1.3940	n	
26	ES	13C-1,2,3,4,6,7,8-HpCDF	100.00	7.42e+07	2.30e+07	5.12e+07	0.45 Y 39:12	3527 Y	3043 Y	1.0547	n	
27	JS	13C-1,2,3,4-TCDD	100.00	8.25e+07	3.63e+07	4.62e+07	0.79 Y 31:10	4357 Y	5873 Y	-	n	
28	JS	13C-1,2,3,7,8,9-HxCDD	100.00	7.04e+07	3.92e+07	3.12e+07	1.26 Y 37:20	5189 Y	4771 Y	-	n	
29	CS	37Cl-2,3,7,8-TCDD	200.00	1.86e+08	1.86e+08	7.10e+08	4.47e+07	31:35	33281 Y	3414 Y	1.1264	n
30	CS	13C-2,3,4,7,8-PeCDF	100.00	1.16e+08	7.10e+07	3.92e+07	3.10e+07	1.26 Y 37:00	5500 Y	5182 Y	1.4027	n
31	CS	13C-1,2,3,4,7,8-HxCDD	100.00	7.02e+07	3.92e+07	3.09e+07	5.89e+07	0.52 Y 36:17	5977 Y	4637 Y	0.9968	n
32	CS	13C-1,2,3,4,7,8-HxCDF	100.00	8.98e+07	3.09e+07	5.89e+07	4.57e+07	0.45 Y 41:11	2799 Y	9813 Y	1.2753	n
33	CS	13C-1,2,3,4,7,8,9-HpCDF	100.00	6.64e+07	2.07e+07	4.57e+07	-	-	2394 Y	0.9433	n	
34	SS	37Cl-2,3,7,8-TCDF	200.00	1.86e+08	1.86e+08	7.10e+07	4.47e+07	31:35	33281 Y	3414 Y	1.0573	n
35	SS	13C-2,3,4,7,8-PeCDF	100.00	1.16e+08	7.10e+07	3.92e+07	3.10e+07	1.26 Y 37:00	5500 Y	5182 Y	0.9818	n
36	SS	13C-1,2,3,4,7,8-HxCDD	100.00	7.02e+07	3.92e+07	3.09e+07	5.89e+07	0.52 Y 36:17	5977 Y	4637 Y	0.9421	n
37	SS	13C-1,2,3,4,7,8-HxCDF	100.00	8.18e+07	3.09e+07	5.89e+07	4.57e+07	0.45 Y 41:11	2799 Y	9813 Y	0.9149	n
38	SS	13C-1,2,3,4,7,8,9-HpCDF	100.00	6.64e+07	2.07e+07	4.57e+07	-	-	2394 Y	0.9433	n	
39	Tot	Total Tetra-Furans	0.00	-	-	-	-	-	-	-	n	
40	Tot	Total Tetra-Dioxins	0.00	-	-	-	-	-	-	-	n	
41	Tot	Total Penta-Furans Fn1	0.00	-	-	-	-	-	-	-	n	
42	Tot	Total Penta-Furans Fn2	0.00	-	-	-	-	-	-	-	n	
43	Tot	Total Penta-Dioxins	0.00	-	-	-	-	-	-	-	n	
44	Tot	Total Hexa-Furans	0.00	-	-	-	-	-	-	-	n	

File:A10JUL07A #1-399 Accq:10-JUL-2007 13:42:57 GC EI+ Voltage SIR Autospec-Ultimaee


Sample#7 Text:CS5 S25-26E

Exp:EXP_DB5MS

319.8965 S:7 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,2332.0,5.00%,F,T)


100%
50
0

3.1E7
1.5E7
0.E0




100%
50
0

4.0E7
2.0E7
0.E0




100%
50
0

1.4E7
7.2E6
0.E0




100%
50
0

1.9E7
9.3E6
0.E0



100%
50
0



7.4E7
3.7E7
0.E0



100%
50
0


4.8E6
0.E0

File:A10JUL07A #1-184 Accq:10-JUL-2007 13:42:57 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#7 Text:CS5 S25-26E Exp:EXP_DB5MS
 355.8546 S:7 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,2192.0,5.00%,F,T)
 100%
 357.8517 S:7 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,2824.0,5.00%,F,T)



File: A10JUL07A ##-252 Acq: 10-JUL-2007 13:42:57 CC EII+ VoEage SIR Autospec-Ultimate

Sample#7 Text:CS5 S25-26E
Exp: EXP DB5MS



File:AI0JUL07A #1-292 Acq:10-JUL-2007 13:42:57 GC EI+ Voltage SIR Autospec-Ultimae

Sample#7 Text:CS5 S25-26E Exp:EXP DE5MS

423.7767 S:7 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.018,2476.0,5.00%,F,T)
100% 40:30

9.1E7

4.5E7

0.0E0

Time

42:00

41:00

40:00

39:00

38:00

37:00

36:00

35:00

34:00

33:00

32:00

31:00

30:00

29:00

28:00

27:00

26:00

25:00

24:00

23:00

22:00

21:00

20:00

19:00

18:00

17:00

16:00

15:00

14:00

13:00

12:00

11:00

10:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

Time

42:00

41:00

40:00

39:00

38:00

37:00

36:00

35:00

34:00

33:00

32:00

31:00

30:00

29:00

28:00

27:00

26:00

25:00

24:00

23:00

22:00

21:00

20:00

19:00

18:00

17:00

16:00

15:00

14:00

13:00

12:00

11:00

10:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

Time

9.1E7

4.5E7

0.0E0

Time

42:00

41:00

40:00

39:00

38:00

37:00

36:00

35:00

34:00

33:00

32:00

31:00

30:00

29:00

28:00

27:00

26:00

25:00

24:00

23:00

22:00

21:00

20:00

19:00

18:00

17:00

16:00

15:00

14:00

13:00

12:00

11:00

10:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

Time

42:00

41:00

40:00

39:00

38:00

37:00

36:00

35:00

34:00

33:00

32:00

31:00

30:00

29:00

28:00

27:00

26:00

25:00

24:00

23:00

22:00

21:00

20:00

19:00

18:00

17:00

16:00

15:00

14:00

13:00

12:00

11:00

10:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

Time

9.1E7

4.5E7

0.0E0

Time

42:00

41:00

40:00

39:00

38:00

37:00

36:00

35:00

34:00

33:00

32:00

31:00

30:00

29:00

28:00

27:00

26:00

25:00

24:00

23:00

22:00

21:00

20:00

19:00

18:00

17:00

16:00

15:00

14:00

13:00

12:00

11:00

10:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

Time

42:00

41:00

40:00

39:00

38:00

37:00

36:00

35:00

34:00

33:00

32:00

31:00

30:00

29:00

28:00

27:00

26:00

25:00

24:00

23:00

22:00

21:00

20:00

19:00

18:00

17:00

16:00

15:00

14:00

13:00

12:00

11:00

10:00

09:00

08:00

07:00

06:00

05:00

04:00

03:00

02:00

01:00

00:00

Time

9.1E7

4.5E7

0.0E0

Time

42:00

41:00

40:00

39:00

38:00

37:00

36:00

35:00

34:00

33:00


32:00

31:00


30:00

29:00

File:A10JUL07A #1-362 Acc:10-JUL-2007 13:42:57 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#7 Text:CS5 S25-26E Exp:EXP_DB5MS
 457.7377 S:7 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,1928.0,5.00%,F,T)
 100%
 0 50 100%



File:A10JUL07A #1-399 Acq:10-JUL-2007 13:42:57 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#7 Text:CS5 S25-26E
 303.9016 S:7 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,2456.0,5.00%,F,T)
 100%
 0 50 100



File:AI0JUL07A #1-T184 Acc:10-JUL-2007 13:42:57 GC EI+ Voltage SIR Autospec-Ultimate

Sample#7 Text:CS5 S25-26E

Exp:EXP_D5MS

339.8597 S:7 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,60468.0,5.00%,F,T)

100%

34:11

3.4E8

1.7E8

50

0

0.0E0

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

341.8568 S:7 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,39264.0,5.00%,F,T)

100%

34:11

2.2E8

1.1E8

50

0

0.0E0

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

351.9000 S:7 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5596.0,5.00%,F,T)

100%

34:11

3.1E7

1.6E7

50

0

0.0E0

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

353.8970 S:7 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5528.0,5.00%,F,T)

100%

34:11

2.0E7

1.0E7

50

0

0.0E0

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

409.7974 S:7 F:2 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,2732.0,5.00%,F,T)

100%

34:48

2.7E5

1.3E5

50

0

0.0E0

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

366.9792 S:7 F:2 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)

100%

34:07

5.4E6

2.7E6

50

0

0.0E0

32:48 33:00 33:12 33:24 33:36 33:48 34:00 34:12 34:24 34:36 34:48 35:00 Time

File:AI0JUL07A #1-252 Acq:10-JUL-2007 13:42:57 GC EI+ Voltage SIR Autospec-Ultimate

Sample#7 Text:CS5 S25-26E Exp:EXP_DB5MS

373.8207 S:7 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,34480.0,5.00%,F,T)
100%

36:54 37:41
2.3E8
1.2E8
0.0E0

35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time
375.8178 S:7 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,2768.0,5.00%,F,T)
100%

36:54 37:41
1.8E8
9.1E7
0.0E0

35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time
383.8639 S:7 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,1944.0,5.00%,F,T)
100%

36:23 36:53 37:41
1.2E7
6.2E6
0.0E0

35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time
385.8610 S:7 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,2256.0,5.00%,F,T)
100%

36:23 36:53 37:40
2.3E7
1.1E7
0.0E0

35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time
445.7555 S:7 F:3 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,2808.0,5.00%,F,T)
100%

37:07 37:40
5.4E3
2.7E3
0.0E0

35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time
380.9760 S:7 F:3 SMO(1,3) PKD(3,2,1,100.00%,0.5,0.00%,F,T)
100%
35:09 35:32 35:42
1.7E7
8.6E6
0.0E0

35:12 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time
0.0E0

File:A10JUL07A #1-292 Acq:10-JUL-2007 13:42:57 GC EI+ Voltage SIR Autospec-Ultimate

Sample#7 Text:CS5 S25-26E

407.7818 S:7 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,6192.0,5.00%,F,T)

100%

41.11 39:00 40:00 41:00 42:00 Time

1.6E8
8.0E7
0.0E0

41.11 39:00 40:00 41:00 42:00 Time

1.5E8
7.7E7
0.0E0

41.11 39:00 40:00 41:00 42:00 Time

1.5E8
7.7E7
0.0E0

409.7788 S:7 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,10184.0,5.00%,F,T)

100%

41.11 39:00 40:00 41:00 42:00 Time

1.5E8
8.0E7
0.0E0

41.11 39:00 40:00 41:00 42:00 Time

1.5E8
7.7E7
0.0E0

417.8253 S:7 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,1904.0,5.00%,F,T)

100%

41.11 39:00 40:00 41:00 42:00 Time

6.7E6
3.4E6
0.0E0

41.11 39:00 40:00 41:00 42:00 Time

6.7E6
3.4E6
0.0E0

419.8220 S:7 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4912.0,5.00%,F,T)

100%

41.11 39:00 40:00 41:00 42:00 Time

1.5E7
7.5E6
0.0E0

41.11 39:00 40:00 41:00 42:00 Time

1.5E7
7.5E6
0.0E0

479.7165 S:7 F:4 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,2484.0,5.00%,F,T)

100%

41.12 40:01 40:46 41:12 41:22 41:38 41:54 41:00 42:00 Time

3.9E3
2.0E3
0.0E0

41.12 40:01 40:46 41:12 41:22 41:38 41:54 41:00 42:00 Time

3.9E3
2.0E3
0.0E0

430.9728 S:7 F:4 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)

100%

41.11 40:00 41:00 42:00 Time

5.2E6
0.0E0

41.11 40:00 41:00 42:00 Time

5.2E6
0.0E0

1.0E7

41:50

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00

42:00

41:00


42:00

41:00

42:00

41:00</p

File:A10JUL07A #1-362 Acq:10-JUL-2007 13:42:57 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#7 Text:CS5 S25-26E Exp:EXP_DB5MS
 441.7427 S:7 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,1840.0,5.00%,F,T)
 100%



Paradigm Sample Log


Data File	S	Sample ID	Analyst	Acq.	Date	Time
a24jul07a;1		✓RETCON S27-120F	:JWP	24-JUL-07	16:06:26	
a24jul07a;2		:OPR14370	;JWP	24-JUL-07	16:54:46	
a24jul07a;3		:OPRD14370	;JWP	24-JUL-07	17:43:07	
a24jul07a;4		;LMB14370	;JWP	24-JUL-07	18:31:27	
a24jul07a;5		;G431-15-5B	;JWP	24-JUL-07	19:19:49	
a24jul07a;6		;G431-15-10B	;JWP	24-JUL-07	20:08:10	
a24jul07a;7		;G431-15-15B	;JWP	24-JUL-07	20:56:31	
a24jul07a;8		;G431-15-20B	;JWP	24-JUL-07	21:44:52	
a24jul07a;9		;G371-161-9B	;JWP	24-JUL-07	22:33:13	
a24jul07a;10		;S100-P50-3B	;JWP	24-JUL-07	23:21:34	
a24jul07a;11		✓RETCON S27-120F	;JWP	25-JUL-07	00:09:55	

① 12/8/07


Paradigm Sample Log

Data File S	Sample ID	Analyst	Acq. Date	Time
a24jul07a_2;1	:OPRD14371	;JWP	25-JUL-07	01:02:41
a24jul07a_2;2	:OPRD14371	;JWP	25-JUL-07	01:51:02
a24jul07a_2;3	:LMB14371	;JWP	25-JUL-07	02:39:24
a24jul07a_2;4	:G676-33-5B	;JWP	25-JUL-07	03:27:47
a24jul07a_2;5	:G676-33-10B	;JWP	25-JUL-07	04:16:10
a24jul07a_2;6	:G676-33-15B	;JWP	25-JUL-07	05:04:33
a24jul07a_2;7	:G676-33-20B	;JWP	25-JUL-07	05:52:54
a24jul07a_2;8	:BLK070207A	;JWP	25-JUL-07	06:41:17
a24jul07a_2;9	✓RETCON S27-120F	;JWP	25-JUL-07	07:29:38


Peak Locate Examination:24-JUL-2007:16:04 File:A24JUL07A_LL
Experiment:EXP_DB5MS Function:1 Reference:PFK




Peak Locate Examination: 24-JUL-2007:16:04 File:A24JUL07A.L
Experiment: EXP_DB5MS Function:2 Reference: PFK




Peak Locate Examination:24-JUL-2007:16:05 File:A24JUL07A_L
 Experiment:EXP_DB5MS Function:3 Reference:PFK




Peak Locate Examination:24-JUL-2007:16:05 File:A24JUL07A_L
Experiment:EXP_DB5MS Function:4 Reference:PFK




Peak Locate Examination:24-JUL-2007:16:05 File:A24JUL07A.L
Experiment:EXP_DB5MS Function:5 Reference:PFK




Peak Locate Examination:25-JUL-2007:00:58 File:A24JUL07A_RES_CHECK
 Experiment:EXP_DB5MS Function:1 Reference:PFK




Peak Locate Examination:25-JUL-2007:00:59 File:A24JUL07A_RES_CHECK
 Experiment:EXP_DB5MS Function:2 Reference:PFK




Peak Locate Examination:25-JUL-2007:01:00 File:A24JUL07A_RES_CHECK
 Experiment:EXP_DB5MS Function:3 Reference:PFK




Peak Locate Examination:25-JUL-2007:01:01 File:A24JUL07A_RES_CHECK
Experiment:EXP_DB5MS Function:4 Reference:PFK




Peak Locate Examination:25-JUL-2007:01:02 File:A24JUL07A_RES_CHECK
Experiment:EXP_DB5MS Function:5 Reference:PFK




Peak Locate Examination:25-JUL-2007:08:18 File:A24JUL07A_2_RES_CHECK
Experiment:EXP DB5MS Function:1 Reference:PFK




Peak Locate Examination:25-JUL-2007:08:19 File:A24JUL07A_2_RES_CHECK
Experiment :EXP_DB5MS Function:2 Reference:PFK




Peak Locate Examination:25-JUL-2007:08:20 File:A24JUL07A_2_RES CHECK
Experiment:EXP_DB5MS Function:3 Reference:PFK



Peak Locate Examination:25-JUL-2007:08:21 File:A24JUL07A_2_RES_CHECK
 Experiment:EXP_DB5MS Function:4 Reference:PFK



Peak Locate Examination:25-JUL-2007:08:22 File:A24JUL07A_2_RES_CHECK
Experiment:EXP_DB5MS Function:5 Reference:PFK



Filename : a24jul07a
Sample : 1
Acquired : 24-JUL-07 16:06:26
Processed : 25-JUL-07 15:50:11
Sample ID : RETCON S27-120F

Name	First Eluter RT	Last Eluter RT
TCDD	28:40	32:10
PeCDD	33:05	34:43
RxCDD	35:51	37:28
HxCDD	39:41	40:39
OCDD	45:07	
TCDF	26:56	32:15
PeCDF	32:14	34:54
RxCDF	35:25	37:48
HxCDF	39:21	41:21
OCDF	45:25	

File:A24JUL07A #1-399 Acq:24-JUL-2007 16:06:26 GC EI+ Voltage SIR Autospec-Ultimate

Sample#1 Text: RETCON S27-120F

303,9016,319.8965,339.8597

100%

80

60

40

20

0

26:56

28:40

31:08

31:41

32:15

30:22

31:00

32:00

29:00

28:00

30:00

27:00

31:22

Time

F:2 339.8597,355.8546

33:05

33:39

34:16

34:43

34:54

34:27

34:48

35:00

Time

F:3 373.8207,389.8156

35:51

35:25

36:23

36:00

36:12

36:24

36:36

36:48

37:00

37:12

37:24

37:36

37:48

37:50

38:00

38:12

38:24

38:36

38:48

38:50

39:00

39:12

39:24

39:36

39:48

39:50

40:00

40:12

40:24

40:36

40:48

40:50

41:00

41:12

41:24

41:36

41:48

41:50

42:00

43:00

44:00

45:00

46:00

47:00

Time

F:4 407.7818,423.7767

39:21

39:41

40:39

41:21

41:43

42:25

43:07

44:50

45:07

45:25

46:00

47:00

Time

F:5 443.7398,459.7348

40:00

40:40

41:20

42:00

42:40

43:20

44:00

45:00

46:00

47:00



Time

File:A24JUL07A #1-399 Acq:24-JUL-2007 16:06:26 GC EI+ Voltage SIR Autospec-Ultimate

Sample#1 Test:RETCON S27-120F

303.9016,315.9419

100 95 90 85 80 75 70 65 60 55 50 45 40 35 30 25 20 15 10 5 0



Filename : a24jul07a
Sample : 11
Acquired : 25-JUL-07 00:09:55
Processed : 25-JUL-07 15:50:22
Sample ID : RETCON S27-120F

Name	First Eluter RT	Last Eluter RT
TCDD	28:41	32:10
PeCDD	33:05	34:43
HxCDD	35:50	37:27
HpCDD	39:40	40:38
OCD	45:06	
TCDF	26:57	32:14
PeCDF	32:13	34:54
HxCDF	35:25	37:48
HpCDF	39:21	41:21
OCDF	45:25	

File:A24JUL07A #1-399 Acq:25-JUL-2007 00:09:55 GC EI+ Voltage SIR Autospec-Ultimate

Exp:EXP_DB5MS

Sample#11 Text:RETCON S27-120F

S:11 303.9016,319.8965,339.8597

100%

26:57


80

60

40

20

0



File:A24JUL07A #1-399 Acq:25-JUL-2007 00:09:55 GC EI+ Voltage SIR Autospec-Ultimae

Exp:EXP_DB5MS

Sample#11 Text:RETCON S27-120F

S:11 303.9016,315.9419

100%

95

90

85

80

75

70

65

60

55

50

45

40

35

30

25

20

15

10

5

0

31:09 30:42 30:48 30:54 31:00 31:06 31:12 31:18 31:24 31:30 31:36 31:42 31:48 31:54 32:00 32:06 Time

S:11 321.8936,333.9339

100%

95

90

85

80

75

70

65

60

55

50

45

40

35

30

25

20

15

10

5

0

31:40 30:42 30:48 30:54 31:00 31:06 31:12 31:18 31:24 31:30 31:36 31:42 31:48 31:54 32:00 32:06 Time

Filename : a24jul107a_2
Sample : 9
Acquired : 25-JUL-07 07:29:38
Processed : 25-JUL-07 15:50:45
Sample ID : RETCON S27-120F


Name	First Eluter RT	Last Eluter RT
TCDD	28:40	32:10
PeCDD	33:05	34:33
HxCDD	35:50	37:27
HpCDD	39:41	40:38
OCDD	45:06	
TCDF	26:56	32:14
PeCDF	32:13	34:54
HxCDF	35:24	37:48
HpCDF	39:20	41:20
OCDF	45:25	

File:A24JUL07A_2 #1-399 Acq:25-JUL-2007 07:29:38 GC EI+ Voltage SIR Autospec-UltimaE



Sample#9 Text:RETCON S27-120F

S:9 303.9016,319.8965,339.8597

Exp:EXP_DB5MS



File:A24JUL07A_2 #1-399 Acq:25-JUL-2007 07:29:38 GC EI+ Voltage SIR Autospec-UltimaE
Sample#9 Text:RETCON S27-120F
S:9 303.9016,315.9419
100%



Filename : a24jul07a

Sample : 1

Acquired : 24-JUL-07 16:06:26

Processed : 25-JUL-07 15:20:52

Sample ID : RETCON S27-120F

Cal Table : ml613-071007a

Results Table ;


Comments ;

TYP	Name;	Resp;	RA;?;	RT;	S/N1;?;	S/N1;?;	Limits	Conc	;	mod?
Unk	; 2,3,7,8-TCDD;	3.33e+06;	0.75;Y;	31:40;	94;Y;	14;Y;	10.254	; 7.8 - 12.9	;	no
Unk	; 1,2,3,7,8-PeCDD;	2.08e+07;	1.27;Y;	37:07;	83;Y;	37;Y;	49.380	; 39 - 65	;	no
Unk	; 1,2,3,4,7,8-HxCDD;	1.17e+07;	1.27;Y;	37:07;	352;Y;	38;Y;	49.124	; 39 - 64	;	no
Unk	; 1,2,3,6,7,8-HxCDD;	1.31e+07;	1.26;Y;	37:13;	351;Y;	37;Y;	51.434	; 39 - 64	;	no
Unk	; 1,2,3,7,8,9-HxCDD;	1.17e+07;	1.21;Y;	37:28;	300;Y;	33;Y;	48.795	; 41 - 61	;	no
Unk	; 1,2,3,4,6,7,8-HpCDD;	9.59e+06;	1.04;Y;	40:39;	248;Y;	20;Y;	50.054	; 43 - 58	;	no
Unk	; OCDD;	1.52e+07;	0.89;Y;	45:08;	298;Y;	32;Y;	101.718	; 79 - 126	;	no
Unk	; 2,3,7,8-TCDF;	4.92e+06;	0.78;Y;	31:08;	129;Y;	17;Y;	9.882	; 8.4 - 12.0	;	no
Unk	; 1,2,3,7,8-PeCDF;	2.03e+07;	1.59;Y;	33:39;	572;Y;	55;Y;	49.233	; 41 - 60	;	no
Unk	; 2,3,4,7,8-PeCDF;	1.98e+07;	1.61;Y;	34:15;	616;Y;	60;Y;	48.055	; 41 - 61	;	no
Unk	; 1,2,3,4,7,8-HxCDF;	1.71e+07;	1.26;Y;	36:23;	306;Y;	34;Y;	48.722	; 45 - 56	;	no
Unk	; 1,2,3,6,7,8-HxCDF;	1.94e+07;	1.25;Y;	36:30;	299;Y;	33;Y;	49.114	; 44 - 57	;	no
Unk	; 2,3,4,6,7,8-HxCDF;	1.76e+07;	1.25;Y;	36:60;	275;Y;	31;Y;	49.605	; 45 - 56	;	no
Unk	; 1,2,3,7,8,9-HxCDF;	1.42e+07;	1.25;Y;	37:48;	208;Y;	22;Y;	49.469	; 44 - 57	;	no
Unk	; 1,2,3,4,6,7,8-HpCDF;	1.57e+07;	1.05;Y;	39:21;	431;Y;	35;Y;	49.227	; 45 - 55	;	no
Unk	; 1,2,3,4,7,8,9-HpCDF;	1.17e+07;	1.04;Y;	41:21;	268;Y;	22;Y;	48.706	; 43 - 58	;	no
Unk	; OCDF;	1.81e+07;	0.91;Y;	45:26;	316;Y;	39;Y;	99.392	; 63 - 159	;	no
ES/RT;	13C-2,3,7,8-TCDD;	3.35e+07;	0.78;Y;	31:40;	1201;Y;	122;Y;	92.931	; 82 - 121	;	no
ES	; 13C-1,2,3,7,8-PeCDD;	2.48e+07;	1.58;Y;	34:26;	1157;Y;	74;Y;	83.194	; 62 - 160	;	no
ES	; 13C-1,2,3,4,7,8-HxCDD;	2.30e+07;	1.36;Y;	37:06;	892;Y;	64;Y;	98.733	; 85 - 117	;	no
ES	; 13C-1,2,3,6,7,8-HxCDF;	2.63e+07;	1.19;Y;	37:12;	973;Y;	72;Y;	107.174	; 85 - 118	;	no
ES	; 13C-1,2,3,4,6,7,8-HpCDD;	2.81e+07;	1.06;Y;	40:38;	496;Y;	46;Y;	94.950	; 72 - 138	;	no
ES	; 13C-1,2,3,4,7,8,9-OCTD;	2.78e+07;	0.90;Y;	45:07;	456;Y;	66;Y;	174.868	; 96 - 415	;	no
ES/RT;	13C-2,3,7,8-TCDF;	4.45e+07;	0.79;Y;	31:07;	1230;Y;	140;Y;	94.686	; 71 - 140	;	no
ES	; 13C-1,2,3,7,8-PeCDF;	4.13e+07;	1.58;Y;	33:38;	1078;Y;	92;Y;	84.435	; 76 - 130	;	no
ES	; 13C-2,3,7,8-PeCDF;	3.90e+07;	1.58;Y;	34:15;	1060;Y;	92;Y;	81.270	; 77 - 130	;	no
ES	; 13C-1,2,3,4,7,8-HxCDF;	2.88e+07;	0.52;Y;	36:23;	753;Y;	140;Y;	97.711	; 76 - 131	;	no
ES	; 13C-1,2,3,6,7,8-HxCDF;	3.35e+07;	0.52;Y;	36:29;	809;Y;	145;Y;	102.125	; 70 - 143	;	no
ES	; 13C-2,3,4,6,7,8-HxCDF;	3.07e+07;	0.52;Y;	36:59;	742;Y;	137;Y;	98.376	; 73 - 137	;	no
ES	; 13C-1,2,3,7,8,9-HxCDF;	2.49e+07;	0.52;Y;	37:47;	531;Y;	96;Y;	92.401	; 74 - 135	;	no
ES	; 13C-1,2,3,4,6,7,8-HpCDF;	2.30e+07;	0.45;Y;	39:21;	405;Y;	91;Y;	94.383	; 78 - 129	;	no
ES	; 13C-1,2,3,4,7,8,9-HpCDF;	1.96e+07;	0.45;Y;	41:20;	276;Y;	62;Y;	90.127	; 77 - 129	;	no
JS	; 13C-1,2,3,4,7,8,9-HxCDD;	3.41e+07;	0.79;Y;	31:15;	1202;Y;	122;Y;	41.857	;	no	
JS	; 13C-1,2,3,7,8,9-HxCDD;	2.35e+07;	1.25;Y;	37:27;	799;Y;	59;Y;	33.100	;	no	
CS	; 37Cl-2,3,7,8-TCDD;	3.48e+06	; 31:40;		219;Y	;	9.465	; 7.9 - 12.7	;	no
Tot	; Total Tetra-Furans;	1.44e+07;	0.78;Y;	26:55;	96;Y;	12;Y;	28.926	;	no	
Tot	; Total Penta-Furans Fn1;	1.74e+07;	0.80;Y;	28:40;	63;Y;	9;Y;	53.706	;	no	
Tot	; Total Penta-Furans Fn2;	6.02e+07;	0.64;Y;	32:13;	623;Y;	135;Y;	50.618	;	no	
Tot	; Total Penta-Furans Fn3;	7.57e+07;	0.57;Y;	33:02;	74;Y;	7;Y;	146.064	;	no	
Tot	; Total Hexa-Furans;	4.42e+07;	1.57;Y;	33:25;	1014;Y;	45;Y;	170.947	;	no	
Tot	; Total Hexa-Furans;	8.66e+07;	1.25;Y;	35:51;	390;Y;	44;Y;	257.132	;	no	
Tot	; Total Hexa-Dioxins;	5.22e+07;	1.25;Y;	35:51;	482;Y;	52;Y;	213.662	;	no	


Sample text; RETCON S27-120F
 Filename: a24ju07a -1
 ICAL; m8290-071007a
 Acquired: 24-JUL-07 16:06:26 Processed: 24-JUL-07 16:58:09
 Results:

Name;	Resp;	Ion 1;	Ion 2 ;	RA ;?	RT ;	Conc ;	Dev'n;CCAL RRF;ICAL RRF	Mod
2,3,7,8-TCDD;3.3e+06; 1.43e+06; 1.90e+06; 1.90e+06 ;	1,2,3,7,8-PecDF;1.3e+07; 7.80e+06; 4.96e+06 ;	/ 0.75 ;Y ; 31:40 ;	/ 10.25 ;	/ 2.5;	/ 0.9949;	/ 0.9703	/n	
1,2,3,4,7,8-HxCDD;1.2e+07; 6.53e+06; 5.16e+06 ;	1,2,3,4,7,8-HxCDD;1.3e+07; 7.28e+06; 5.78e+06 ;	/ 1.57 ;Y ; 34:27 ;	/ 49.38 ;	/ -1.2;	/ 1.0302;	/ 1.0431	/n	
1,2,3,6,7,8-HxCDD;1.3e+07; 6.43e+07; 6.43e+07 ;	1,2,3,7,8,9-HxCDD;9.6e+06; 4.88e+06; 4.71e+06 ;	/ 1.27 ;Y ; 37:07 ;	/ 45.24 ;	/ -9.5;	/ 0.8902;	/ 0.9838	/n	
1,2,3,4,6,7,8-HpCDF;2.0e+07; 7.19e+06; 8.04e+06 ;	2,3,7,8-TCDF;4.9e+06; 2.16e+06; 2.77e+06 ;	/ 1.26 ;Y ; 37:13 ;	/ 51.43 ;	/ 2.9;	/ 0.9944;	/ 0.9667	/n	
1,2,3,4,7,8-PecDF;2.0e+07; 1.22e+07; 7.58e+06 ;	1,2,3,4,7,8-HxCDF;1.7e+07; 9.51e+06; 7.54e+06 ;	/ 1.61 ;Y ; 34:15 ;	/ 46.23 ;	/ -7.5;	/ 0.9831;	/ 0.9985	/n	
1,2,3,6,7,8-HxCDF;1.9e+07; 1.06e+07; 8.48e+06 ;	1,2,3,4,6,7,8-HxCDF;1.8e+07; 9.77e+06; 7.82e+06 ;	/ 1.25 ;Y ; 36:23 ;	/ 46.60 ;	/ -6.8;	/ 1.0185;	/ 1.0927	/n	
1,2,3,4,6,7,8-HxCDF;1.4e+07; 6.28e+06; 6.28e+06 ;	1,2,3,4,6,7,8-HpCDF;1.6e+07; 8.07e+06; 7.67e+06 ;	/ 1.25 ;Y ; 36:60 ;	/ 49.11 ;	/ -1.8;	/ 1.1392;	/ 1.1598	/n	
1,2,3,4,7,8,9-HxCDF;9.6e+06; 4.71e+06; 4.71e+06 ;	1,2,3,4,6,7,8-HxCDF;1.6e+07; 8.07e+06; 7.67e+06 ;	/ 1.25 ;Y ; 37:48 ;	/ 47.78 ;	/ -4.4;	/ 1.0510;	/ 1.0999	/n	
1,2,3,4,7,8,9-HpCDF;1.6e+07; 8.07e+06; 7.67e+06 ;	1,2,3,4,7,8-TCDF;3.3e+07; 1.46e+07; 1.88e+07 ;	/ 1.04 ;Y ; 39:21 ;	/ 44.75 ;	/ -10.5;	/ 0.8453;	/ 0.9444	/n	
1,2,3,4,7,8,9-HpCDF;1.2e+07; 5.99e+06; 5.73e+06 ;	1,2,3,4,7,8-TCDF;3.3e+07; 1.46e+07; 1.88e+07 ;	/ 1.04 ;Y ; 41:21 ;	/ 46.52 ;	/ -1.5;	/ 0.3692;	/ 1.3907	/n	
1,2,3,4,7,8,9-HpCDF;1.2e+07; 8.61e+06; 9.46e+06 ;	1,2,3,4,7,8-TCDF;3.3e+07; 1.46e+07; 1.88e+07 ;	/ 0.91 ;Y ; 45:26 ;	/ 99.39 ;	/ -7.0;	/ 1.0198;	/ 1.0961	/n	
OCDF;1.8e+07; 8.61e+06; 9.46e+06 ;	OCDF;1.8e+07; 8.61e+06; 9.46e+06 ;	/ 0.91 ;Y ; 45:08 ;	/ 101.7 ;	/ 1.7;	/ 1.0969;	/ 1.0783	/n	
Extraction Standards								
13C-2,3,7,8-TCDD;3.3e+07; 1.46e+07; 1.88e+07 ;	13C-1,2,3,7,8-PecDF;2.5e+07; 9.60e+06; 1.96e+07 ;	/ 0.78 ;Y ; 31:08 ;	/ 9.882 ;	/ -1.2;	/ 1.1068;	/ 1.1201	/n	
13C-1,2,3,6,7,8-HxCDD;2.6e+07; 1.43e+07; 1.20e+07 ;	13C-1,2,3,4,6,7,8-HxCDF;3.3e+07; 1.15e+07; 2.20e+07 ;	/ 1.58 ;Y ; 34:26 ;	/ 49.23 ;	/ -1.5;	/ 0.9831;	/ 0.9985	/n	
13C-1,2,3,4,6,7,8-HpCDF;2.3e+07; 7.14e+06; 1.58e+07 ;	13C-1,2,3,4,6,7,8-HpCDF;2.0e+07; 6.10e+06; 1.35e+07 ;	/ 1.06 ;Y ; 36:29 ;	/ 46.60 ;	/ -6.8;	/ 1.0185;	/ 1.0927	/n	
Cleanup Standards								
37Cl-2,3,7,8-TCDD;3.5e+06; 3.48e+06; 3.48e+06 ;	13C-1,2,3,7,8-PecDF;4.4e+07; 1.96e+07; 2.49e+07 ;	/ 0.79 ;Y ; 31:07 ;	/ 94.69 ;	/ -5.3;	/ 1.3055;	/ 1.3787	/n	
13C-1,2,3,7,8-PecDF;3.9e+07; 2.39e+07; 1.51e+07 ;	13C-1,2,3,6,7,8-HxCDD;2.3e+07; 1.32e+07; 9.75e+06 ;	/ 1.58 ;Y ; 34:15 ;	/ 84.44 ;	/ -15.6;	/ 1.2113;	/ 1.4346	/n	
13C-1,2,3,4,6,7,8-HxCDF;2.9e+07; 9.86e+06; 1.90e+07 ;	13C-1,2,3,4,6,7,8-HxCDF;2.9e+07; 9.86e+06; 1.90e+07 ;	/ 0.52 ;Y ; 36:23 ;	/ 102.1 ;	/ 2.1;	/ 1.4237;	/ 1.3941	/n	
13C-1,2,3,4,7,8,9-HpCDF;2.0e+07; 6.10e+06; 1.35e+07 ;	13C-1,2,3,4,7,8,9-HpCDF;2.0e+07; 6.10e+06; 1.35e+07 ;	/ 0.45 ;Y ; 39:21 ;	/ 94.38 ;	/ -5.6;	/ 0.7696;	/ 0.8106	/n	
Injection Standards								
13C-1,2,3,4,7,8-TCDF;3.4e+07; 1.51e+07; 1.90e+07 ;	13C-1,2,3,7,8-TCDF;4.4e+07; 1.96e+07; 2.49e+07 ;	/ 0.79 ;Y ; 31:15 ;	/ 41.86 ;	/ -;	/ -;	/ -;	-	
13C-1,2,3,7,8-HxCDD;2.4e+07; 1.31e+07; 1.04e+07 ;	13C-1,2,3,7,8-PecDF;4.1e+07; 1.60e+07; 1.60e+07 ;	/ 1.25 ;Y ; 37:27 ;	/ 33.10 ;	/ -;	/ -;	/ -;	-	
Cleanup Standards								
37Cl-2,3,7,8-TCDD;3.5e+06; 3.48e+06; 3.48e+06 ;	13C-2,3,4,7,8-PecDF;3.9e+07; 1.51e+07; 2.39e+07 ;	/ - ;	/ 31:40 ;	/ 10.19 ;	/ 1.9;	/ 1.0399;	/ 1.0210	/n
13C-1,2,3,4,7,8-HxCDD;2.3e+07; 1.32e+07; 9.75e+06 ;	13C-1,2,3,4,7,8-HxCDF;2.9e+07; 9.86e+06; 1.90e+07 ;	/ 1.58 ;Y ; 34:15 ;	/ 96.20 ;	/ -3.8;	/ 0.9448;	/ 0.9821	/n	
13C-1,2,3,4,7,8-HxCDF;2.9e+07; 9.86e+06; 1.90e+07 ;	13C-1,2,3,4,7,8-HpCDF;2.0e+07; 6.10e+06; 1.35e+07 ;	/ 1.36 ;Y ; 37:06 ;	/ 92.12 ;	/ -7.9;	/ 0.8753;	/ 0.9501	/n	
13C-1,2,3,4,7,8,9-HpCDF;2.0e+07; 6.10e+06; 1.35e+07 ;	13C-1,2,3,4,7,8,9-HpCDF;2.0e+07; 6.10e+06; 1.35e+07 ;	/ 0.52 ;Y ; 36:23 ;	/ 95.63 ;	/ -4.4;	/ 0.8606;	/ 0.8999	/n	
Sampling Standards								
37Cl-2,3,7,8-TCDD;3.5e+06; 3.48e+06; 3.48e+06 ;	13C-2,3,4,7,8-PecDF;3.9e+07; 1.51e+07; 2.39e+07 ;	/ - ;	/ 31:40 ;	/ 95.49 ;	/ -4.5;	/ 0.8518;	/ 0.8920	/n






Page 1 of 1
 8290 CCAL




FILE:A24JUL07A #1-184 Acq:24-JUL-2007 16:06:26 GC EI+ Voltage SIR Autospec-Ultimae
 Sample#1 Text:RETCON S27-120F
 355.8546 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3732.0,5.00%,F,T)
 33.05 100%
 357.8517 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5432.0,5.00%,F,T)
 33.05 100%
 367.8949 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5168.0,5.00%,F,T)
 33.05 100%
 369.8919 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5144.0,5.00%,F,T)
 33.05 100%



File:A24.JUL07A #1-251 Acc:24-JUL-2007 16:06:26 GC EI+ Voltage SIR Autospec-Ultimae
 Sample#1 Text:RETCON S27-120F Exp:EXP_DB5MS
 389.8156 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,6580.0,5.00%,F,T)
 35:51 100%
 391.8127 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4856.0,5.00%,F,T)
 35:51 100%




File:A24JUL07A #1-293 Acq:24-JUL-2007 16:06:26 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#1 Text:RETCON S27-120F Exp:EXP DB5MS
 423.7767 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4800.0,5.00%,F,T)
 100% 39:41



File:A24JUL07A #1-368 Acq:24-JUL-2007 16:06:26 GC EI+ Voltage SIR Autospec-Ultimate

Sample#1 Text:RETCON S27-120F
457.7377 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4124.0,5.00%,F,T)
100%




459.7348 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4196.0,5.00%,F,T)
100%

469.7780 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4756.0,5.00%,F,T)
100%

471.7750 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3676.0,5.00%,F,T)
100%

454.9728 F:5 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)
100% 42.30 43:00 43:14 42:57 43:33 43:46 44:10 44.42 45:02 45:14 45:32 45:57 4.8E6
0 43:00 43:00 44:00 44:00 45:00 45:00 46:00 46:00 46:00 46:00 46:00 46:00

File:A24JUL07A #1-399 Accq:24-JUL-2007 16:06:26 GC EI+ Voltage SIR Autospec-Ultimae
 Sample#1 Text:RETCON S27-120F
 303.9016 BSUB(256,15,-3.0) PKD(3,2,1,0,0.01%,5204.0,5.00%,F,T)
 100%
 0



File:A24JUL07A #1-184 Acq:24-JUL-2007 16:06:26 GC EI+ Voltage SIR Autospec-Ultimae

Sample#1 Text:RETCON S27-120F Exp:EXP_DB5MS

339.8597 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,8872.0,5.00%,F,T)

100%

341.8568 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5540.0,5.00%,F,T)

100%

34:16

34:54

5.5E6

33:39

2.7E6

33:02

0.0E0

33:00

Time

33:12

34:00

33:24

34:12

33:36

34:24

33:48

34:36

34:54

35:00

34:16

34:54

34:16

34:54

33:38

34:16

33:38

0.0E0

33:02

Time

33:12

34:00

33:24

34:12

33:36

34:24

33:48

34:36

34:54

35:00

34:16

34:54

33:38

34:16

33:38

0.0E0

33:02

Time

33:12

34:00

33:24

34:12

33:36

34:24

33:48

34:36

34:54

35:00

34:16

34:54

33:38

34:16

33:38

0.0E0

33:02

Time

33:12

34:00

33:24

34:12

33:36

34:24

33:48

34:36

34:54

35:00

34:16

34:54

33:38

34:16

33:38

0.0E0

33:02

Time

33:12

34:00

33:24

34:12

33:36

34:24

33:48

34:36

34:54

35:00

34:16

34:54

33:38

34:16

33:38

0.0E0

33:02

Time

33:12

34:00

33:24

34:12

33:36

34:24

33:48

34:36

34:54

35:00

34:16

34:54

33:38

34:16

33:38

0.0E0

33:02

Time

33:12

34:00

33:24

34:12

33:36

34:24

33:48

34:36

34:54

35:00

34:16


34:54

33:38

34:16

33:38

0.0E0



File:A24JUL07A #1-293 Acq:24-JUL-2007 16:06:26 GC EI+ Voltage SIR Autospec-UltimaE

Sample#1 Text:REFCON S27-120F
407.7818 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5124.0,5.00%,F,T)
100% 39:21

2.2E6

1.1E6

0.0E0

Time

41:21

42:00

0.0E0

Time

41:21

4

File:A24JUL07A #1-368 Acq:24-JUL-2007 16:06:26 GC EI+ Voltage SIR Autospec-Ultimae

Sample#1 Text:RETCQN S27-120F Exp:EXP DB5MS


441.7427 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4792.0,5.00%,F,T)

100%




443.7398 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4112.0,5.00%,F,T)

100%




469.7780 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4756.0,5.00%,F,T)

100%





471.7750 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3676.0,5.00%,F,T)

100%




513.6775 F:5 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,5456.0,5.00%,F,T)

100%



File:A24JUL07A #1-399 Acq:24-JUL-2007 16:06:26 GC EI+ Voltage SIR Autospec-Ultimae
 Sample#1 Text:RETCON S27-120F
 Exp:EXP_DB5MS
 341.8568 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5340.0,5.00%,F,T)




Sample text; RETCON S27-120F
 Filename: a24ju07a -11
 ICAL: m8290-071007a

Acquired: 25-JUL-07 00:09:55 Processed: 25-JUL-07 08:00:04
 Results:

Page 2 of 2
 8290 CCAL

Name;	Resp;	Ion 1;	Ion 2 ;	RA ;?	RT ;	Conc ;	Dev'n;CCAL RRF;ICAL RRF	;Mod
2,3,7,8-TCDD;4,2e+06; 1.84e+06; 2.35e+06 ;	1.0 79 ;Y ;	31:40 ;	/	9.963 ;	/	-0.4;	0.9667;	0.9703
1,2,3,7,8-PeCDF;1.6e+07; 1.01e+07; 6.35e+06 ;	1.158 ;Y ;	34:27 ;	48.43 ;	/	-3.1;	1.0103;	1.0431	/n
1,2,3,4,7,8-HxCDD;1.6e+07; 8.80e+06; 7.07e+06 ;	1.124 ;Y ;	37:07 ;	50.44 ;	/	0.9;	0.9925;	0.9838	/n
1,2,3,6,7,8-HxCDD;1.5e+07; 8.44e+06; 6.68e+06 ;	1.126 ;Y ;	37:12 ;	48.92 ;	/	-2.2;	0.9458;	0.9667	/n
1,2,3,7,8,9-HxCDD;1.5e+07; 8.26e+06; 6.62e+06 ;	1.125 ;Y ;	37:28 ;	48.84 ;	/	-2.3;	0.9305;	0.9525	/n
1,2,3,4,6,7,8-HpCDF;1.2e+07; 6.37e+06; 6.09e+06 ;	1.105 ;Y ;	40:39 ;	49.09 ;	/	-1.8;	1.0391;	1.0583	/n
OCDD;1.9e+07; 9.04e+06; 1.01e+07 ;	0.89 ;Y ;	45:07 ;	99.66 ;	/	-0.3;	1.0746;	1.0783	/n
2,3,7,8-TCDF;5.8e+06; 2.55e+06; 3.26e+06 ;	0.78 ;Y ;	31:08 ;	/	9.664 ;	/	-3.4;	1.0824;	1.1201
1,2,3,7,8-PeCDF;2.4e+07; 1.48e+07; 9.34e+06 ;	1.58 ;Y ;	33:38 ;	47.98 ;	/	-4.0;	0.9580;	0.9985	/n
2,3,4,7,8-PeCDF;2.4e+07; 1.48e+07; 9.34e+06 ;	1.58 ;Y ;	34:15 ;	46.13 ;	/	-7.7;	0.9556;	1.0357	/n
1,2,3,4,7,8-HxCDF;2.1e+07; 1.18e+07; 9.39e+06 ;	1.25 ;Y ;	36:23 ;	48.71 ;	/	-2.6;	1.0646;	1.0927	/n
1,2,3,6,7,8-HxCDF;2.3e+07; 1.25e+07; 1.01e+07 ;	1.24 ;Y ;	36:29 ;	49.11 ;	/	-1.8;	1.1392;	1.1598	/n
2,3,4,6,7,8-HxCDF;2.2e+07; 1.19e+07; 9.59e+06 ;	1.24 ;Y ;	36:60 ;	49.20 ;	/	-1.6;	1.0822;	1.0999	/n
1,2,3,7,8,9-HxCDF;1.8e+07; 9.91e+06; 7.81e+06 ;	1.27 ;Y ;	37:48 ;	47.15 ;	/	-5.7;	0.8906;	0.9444	/n
1,2,3,4,6,7,8-HpCDF;1.9e+07; 9.74e+06; 9.39e+06 ;	1.04 ;Y ;	39:21 ;	47.98 ;	/	-4.0;	1.3347;	1.3907	/n
1,2,3,4,7,8,9-HpCDF;1.4e+07; 7.35e+06; 6.97e+06 ;	1.05 ;Y ;	41:21 ;	45.55 ;	/	-8.9;	0.9986;	1.0961	/n
1,2,3,4,7,8,9-HpCDF;1.2e+07; 1.05e+07; 1.15e+07 ;	0.91 ;Y ;	45:21 ;	94.55 ;	/	-5.4;	1.2375;	1.3088	/n
Extraction Standards								
13C-2,3,7,8-TCDD;4,3e+07; 1.89e+07; 2.44e+07 ;	0.77 ;Y ;	31:39 ;	/	96.59 ;	/	-3.4;	1.0212;	1.0572
13C-1,2,3,7,8-PeCDF;3.3e+07; 1.26e+07; 1.26e+07 ;	1.58 ;Y ;	34:26 ;	87.72 ;	/	-12.3;	0.7666;	0.8739	/n
13C-1,2,3,6,7,8-HxCDD;3.2e+07; 1.77e+07; 1.43e+07 ;	1.24 ;Y ;	37:11 ;	100.9 ;	/	0.9;	1.0515;	1.0423	/n
13C-1,2,3,4,6,7,8-HpCDF;2.4e+07; 1.23e+07; 1.17e+07 ;	1.05 ;Y ;	40:38 ;	97.30 ;	/	-2.7;	0.7887;	0.8106	/n
13C-OCDD;3.6e+07; 1.68e+07; 1.89e+07 ;	0.89 ;Y ;	45:06 ;	173.5 ;	/	-13.3;	0.5858;	0.6753	/n
13C-2,3,7,8-TCDF;5.4e+07; 2.37e+07; 3.00e+07 ;	0.79 ;Y ;	31:07 ;	/	91.88 ;	/	-8.1;	1.2667;	1.3378
13C-1,2,3,7,8-PeCDF;5.0e+07; 3.09e+07; 1.96e+07 ;	1.58 ;Y ;	33:38 ;	83.00 ;	/	-17.0;	1.1906;	1.4346	/n
13C-1,2,3,4,6,7,8-HpCDF;2.9e+07; 8.89e+06; 1.98e+07 ;	0.53 ;Y ;	36:28 ;	93.84 ;	/	-6.2;	1.3082;	1.3941	/n
Injection Standards								
13C-1,2,3,7,8-TCDD;4,2e+07; 1.87e+07; 2.37e+07 ;	0.79 ;Y ;	31:15 ;	/	52.08 ;	/	-7;	-7;	-
13C-1,2,3,7,8,9-HxCDD;3.0e+07; 1.69e+07; 1.36e+07 ;	1.24 ;Y ;	37:27 ;	42.80 ;	/	-7;	-7;	-7;	-
Cleanup Standards								
37Cl-2,3,7,8-TCDF;4,4e+06; 4.43e+06; -	1.58 ;Y ;	31:40 ;	/	9.674 ;	/	-3.3;	1.0442;	1.0795
13C-2,3,4,7,8-PeCDF;4.9e+07; 2.99e+07; 1.89e+07 ;	1.35e+07 ;	34:14 ;	81.62 ;	/	-18.4;	1.1494;	1.4082	/n
13C-1,2,3,4,7,8-HxCDF;3.1e+07; 1.71e+07; 1.35e+07 ;	1.27 ;Y ;	37:06 ;	101.8 ;	/	1.8;	1.0081;	0.9902	/n
13C-1,2,3,4,7,8-HxCDF;3.6e+07; 1.22e+07; 2.34e+07 ;	0.52 ;Y ;	36:22 ;	93.28 ;	/	-6.7;	1.1697;	1.2540	/n
Sampling Standards								
37Cl-2,3,7,8-TCDF;4,4e+06; 4.43e+06; -	1.58 ;Y ;	34:14 ;	/	98.30 ;	/	-1.7;	0.9654;	0.9821
13C-2,3,4,7,8-HxCDD;3.1e+07; 1.71e+07; 1.35e+07 ;	1.27 ;Y ;	37:06 ;	100.9 ;	/	0.9;	0.9567;	0.9501	/n
13C-1,2,3,4,7,8-HpCDF;3.6e+07; 1.22e+07; 2.34e+07 ;	0.52 ;Y ;	36:22 ;	99.35 ;	/	-0.6;	0.8941;	0.8999	/n
13C-1,2,3,4,7,8,9-HpCDF;2.4e+07; 7.59e+06; 1.68e+07 ;	0.45 ;Y ;	41:20 ;	95.35 ;	/	-4.6;	0.8505;	0.8920	/n






File:A24JUL07A #1-399 Acq:25-JUL-2007 00:09:55 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#11 Text:RETCON S27-120F
 Exp:EXP DB5MS
 319.8965 S:11 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,5156.0,5.00%,F,T)
 100%
 50
 0




File:A24JUL07A #1-184 Acc:25-JUL-2007 00:09:55 GC EI+ Voltage SIR Autospec-Ultimae


Sample#11 Text:RETCON S27-120F Exp:EXP_DB5MS

355.8546 S:11 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.018,4640.0,5.00%,F,T)








File:A24JUL07A #1-293 Acq:25-JUL-2007 00:09:55 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#11 Text:RETCON S27-120F
 423.7737 S:11 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4924.0,5.00%,F,T)
 100%
 39:40




File:A24JUL07A #1-367 Acq:25-JUL-2007 00:09:55 GC EI+ Voltage SIR Autospec-Ultimae
 Sample#11 Text:RETCON S27-120F Exp:EXP_DB5MS
 457.7377 S:11 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4532.0,5.00%,F,T)
 100%











File:A24JUL07A #1-293 Acq:25-JUL-2007 00:09:55 GC EI+ Voltage SIR Autospec-Ultimae

Sample#11 Text:RETCON S27-120F Exp:EXP DB5MS


409.7818 S:11 F:4 ESUB(128,15,-3.0) PKD(3,2,1,0.01%,5308.0,5.00%,F,T)
39:21 100%



File:A24JUL07A #1-367 Acq:25-JUL-2007 06:09:55 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#11 Text:RETCON S27-120F EXP:EXP_DB2MS
 441.7427 S:11 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4692.0,5.00%,F,T)
 100% 45:25



File:A24JUL07A #1-399 Acc:25-JUL-2007 00:09:55 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#11 Text:RETCON S27-120F Exp:EXP_DB5MS
 341.8568 S:11 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4924.0,5.00%,F,T)
 100%



Sample text; RETCON S27-120F
 Filename: a24jul07a.2 -9
 ICAL; m8290-071007a


Page 1 of 1

8290 CCAL


Acquired: 25-JUL-07 07:29:38 Processed: 25-JUL-07 15:11:34
 Results:

Name:	Resp:	Ion 1;	Ion 2 ;	RA ;?	RT ;	Conc ;	Dev'n;CCAL RRF;TICAL RRF	:Mod	
2,3,7,8-TCDD;5.3e+06; 2.27e+06; 2.99e+06 ;	1.2,3,7,8-PecDF;2.2e+07; 1.35e+07; 8.62e+06 ;	1.0 .76 ;Y ;	31:40 ;	/	10.11 ;	1.1;	0.9807;	0.9703	
1,2,3,4,7,8-HxCDD;2.0e+07; 1.13e+07; 8.92e+06 ;	1.2,3,6,7,8-HxCDD;2.1e+07; 1.15e+07; 9.14e+06 ;	1.56 ;Y ;	34:27 ;	49.23 ;	-1.5;	1.0271;	1.0431	;in	
1,2,3,4,6,7,8-HxCDD;2.0e+07; 1.10e+07; 8.82e+06 ;	1,2,3,4,6,7,8-HxCDD;2.0e+07; 1.8e+07; 9.08e+06 ;	1.26 ;Y ;	37:07 ;	47.20 ;	-5.6;	0.9287;	0.9838	;in	
1,2,3,4,6,7,8-HxCDD;2.0e+07; 1.8e+07; 9.08e+06 ;	1,2,3,4,6,7,8-HxCDD;2.0e+07; 1.8e+07; 9.08e+06 ;	1.25 ;Y ;	37:12 ;	49.16 ;	-1.7;	0.9504;	0.9667	;in	
1,2,3,4,6,7,8-HxCDD;2.0e+07; 1.8e+07; 9.08e+06 ;	1,2,3,4,6,7,8-HxCDD;2.0e+07; 1.8e+07; 9.08e+06 ;	1.04 ;Y ;	40:38 ;	47.77 ;	-4.5;	0.9100;	0.9525	;in	
OCDD;2.6e+07; 1.24e+07; 1.39e+07 ;	OCDD;2.6e+07; 1.24e+07; 1.39e+07 ;	0.89 ;Y ;	45:07 ;	99.46 ;	-1.5;	1.0426;	1.0583	;in	
2,3,7,8-TCDF;7.9e+06; 3.49e+06; 4.43e+06 ;	2,3,7,8-PecDF;3.3e+07; 2.07e+07; 1.32e+07 ;	0.79 ;Y ;	31:08 ;	10.22 ;	2.2;	1.1450;	1.1201	;in	
2,3,4,7,8-PecDF;3.4e+07; 2.07e+07; 1.32e+07 ;	2,3,4,7,8-PecDF;3.4e+07; 2.07e+07; 1.32e+07 ;	1.57 ;Y ;	33:38 ;	49.41 ;	-1.2;	0.9886;	0.9985	;in	
1,2,3,4,7,8-HxCDF;2.9e+07; 1.62e+07; 1.29e+07 ;	1,2,3,6,7,8-HxCDF;3.0e+07; 1.66e+07; 1.34e+07 ;	1.25 ;Y ;	36:23 ;	49.38 ;	-3.4;	1.0006;	1.0357	;in	
1,2,3,4,6,7,8-HxCDF;3.0e+07; 1.66e+07; 1.34e+07 ;	1,2,3,4,6,7,8-HxCDF;2.9e+07; 1.62e+07; 1.29e+07 ;	1.25 ;Y ;	36:29 ;	48.33 ;	-1.2;	0.9793;	1.0927	;in	
1,2,3,4,6,7,8-HxCDF;2.9e+07; 1.62e+07; 1.29e+07 ;	1,2,3,4,6,7,8-HxCDF;2.9e+07; 1.62e+07; 1.29e+07 ;	1.25 ;Y ;	36:59 ;	49.02 ;	-3.3;	1.1211;	1.1598	;in	
1,2,3,4,6,7,8-HxCDF;2.4e+07; 1.34e+07; 1.27e+07 ;	1,2,3,4,6,7,8-HxCDF;2.4e+07; 1.34e+07; 1.27e+07 ;	1.27 ;Y ;	37:47 ;	47.86 ;	-2.0;	1.0783;	1.0999	;in	
1,2,3,4,6,7,8-HxCDF;2.4e+07; 1.34e+07; 1.27e+07 ;	1,2,3,4,6,7,8-HxCDF;2.4e+07; 1.34e+07; 1.27e+07 ;	1.05 ;Y ;	39:20 ;	49.03 ;	-4.3;	0.9040;	0.9444	;in	
1,2,3,4,7,8-HxCDF;2.1e+07; 1.09e+07; 1.05e+07 ;	1,2,3,4,7,8-HxCDF;2.1e+07; 1.09e+07; 1.05e+07 ;	1.04 ;Y ;	41:20 ;	48.41 ;	-1.9;	1.0612;	1.3907	;in	
1,2,3,4,6,7,8-HxCDF;2.1e+07; 1.09e+07; 1.05e+07 ;	1,2,3,4,6,7,8-HxCDF;2.1e+07; 1.09e+07; 1.05e+07 ;	0.92 ;Y ;	45:25 ;	93.59 ;	-3.2;	1.0612;	1.0961	;in	
Extraction Standards					-6.4;	1.2249;	1.3088	;in	
13C-2,3,7,8-TCDD;5.4e+07; 2.34e+07; 3.03e+07 ;	13C-1,2,3,7,8-PecDF;4.5e+07; 2.63e+07; 1.67e+07 ;	0.77 ;Y ;	31:39 ;	94.05 ;	-5.9;	0.9943;	1.0572	;in	
13C-1,2,3,7,8-PecDF;4.5e+07; 2.63e+07; 1.67e+07 ;	13C-1,2,3,6,7,8-HxCDD;4.4e+07; 2.43e+07; 1.93e+07 ;	1.52 ;Y ;	34:26 ;	91.20 ;	-8.8;	0.9700;	0.8739	;in	
13C-1,2,3,6,7,8-HxCDD;4.4e+07; 2.43e+07; 1.93e+07 ;	13C-1,2,3,4,6,7,8-HpcDF;3.4e+07; 1.74e+07; 1.67e+07 ;	1.26 ;Y ;	37:11 ;	103.1 ;	3.1;	1.0423;	1.0423	;in	
13C-1,2,3,4,6,7,8-HpcDF;4.9e+07; 2.32e+07; 2.59e+07 ;	13C-1,2,3,4,6,7,8-HpcDF;4.9e+07; 2.32e+07; 2.59e+07 ;	1.04 ;Y ;	40:37 ;	104.0 ;	4.0;	0.8429;	0.8106	;in	
Injection Standards					-10.3;	0.6058;	0.6753	;in	
13C-2,3,7,8-TCDF;6.9e+07; 3.05e+07; 3.86e+07 ;	13C-1,2,3,7,8-PecDF;6.8e+07; 4.16e+07; 2.62e+07 ;	0.79 ;Y ;	31:07 ;	92.92 ;	-7.1;	1.2812;	1.3787	;in	
13C-1,2,3,7,8-PecDF;6.8e+07; 4.16e+07; 2.62e+07 ;	13C-1,2,3,6,7,8-HxCDD;5.4e+07; 1.86e+07; 3.54e+07 ;	1.59 ;Y ;	33:38 ;	87.52 ;	-12.5;	1.2555;	1.4346	;in	
13C-1,2,3,6,7,8-HxCDD;5.4e+07; 1.86e+07; 3.54e+07 ;	13C-1,2,3,4,6,7,8-HpcDF;4.0e+07; 1.25e+07; 2.78e+07 ;	0.53 ;Y ;	36:28 ;	95.64 ;	-4.4;	1.3334;	1.3941	;in	
Sampling Standards					-3.9;	0.9954;	1.0354	;in	
13C-1,2,3,7,8-TCDD;5.4e+07; 2.35e+07; 3.05e+07 ;	13C-1,2,3,7,8-PecDF;4.0e+07; 2.25e+07; 1.80e+07 ;	0.77 ;Y ;	31:15 ;	66.28 ;	-i;	-i;	-i;	-in	
Cleanup Standards					56.96 ;	-i;	-i;	-in	
37Cl-2,3,7,8-TCDD;5.5e+06; 5.47e+06; -	13C-2,3,4,7,8-PecDF;6.7e+07; 4.09e+07; 2.57e+07 ;	i .	31:40 ;	9.395 ;	-6.0;	1.0142;	1.0795	;in	
13C-2,3,4,7,8-PecDF;6.7e+07; 4.09e+07; 2.57e+07 ;	13C-1,2,3,4,7,8-HxCDD;3.9e+07; 2.21e+07; 1.74e+07 ;	1.59 ;Y ;	34:14 ;	87.63 ;	-12.4;	1.2341;	1.4082	;in	
13C-1,2,3,4,7,8-HxCDD;3.9e+07; 2.21e+07; 1.74e+07 ;	13C-1,2,3,4,6,7,8-HpcDF;4.9e+07; 1.69e+07; 3.22e+07 ;	1.26 ;Y ;	37:06 ;	98.51 ;	-1.5;	0.9755;	0.9902	;in	
13C-1,2,3,4,6,7,8-HpcDF;4.9e+07; 1.69e+07; 3.22e+07 ;	13C-1,2,3,4,7,8,9-HpcDF;3.58e+07; 1.11e+07; 2.46e+07 ;	0.53 ;Y ;	36:22 ;	96.84 ;	-3.2;	1.2144;	1.2540	;in	
Sampling Standards					95.41 ;	-4.6;	0.8812;	0.9236	;in
37Cl-2,3,7,8-TCDF;5.5e+06; 5.47e+06; -	13C-2,3,4,7,8-PecDF;6.7e+07; 4.09e+07; 2.57e+07 ;	i .	31:40 ;	9.991 ;	-0.1;	1.0200;	1.0210	;in	
13C-2,3,4,7,8-PecDF;6.7e+07; 4.09e+07; 2.57e+07 ;	13C-1,2,3,4,7,8-HxCDD;3.9e+07; 2.21e+07; 1.74e+07 ;	1.59 ;Y ;	34:14 ;	100.1 ;	0.1;	0.9829;	0.9821	;in	
13C-1,2,3,4,7,8-HxCDD;3.9e+07; 2.21e+07; 1.74e+07 ;	13C-1,2,3,4,7,8-HpcDF;4.9e+07; 1.69e+07; 3.22e+07 ;	1.26 ;Y ;	37:06 ;	95.53 ;	-4.5;	0.9076;	0.9501	;in	
13C-1,2,3,4,7,8-HpcDF;4.9e+07; 1.69e+07; 3.22e+07 ;	13C-1,2,3,4,7,8,9-HpcDF;3.68e+07; 1.11e+07; 2.46e+07 ;	0.53 ;Y ;	36:22 ;	101.2 ;	1.2;	0.9108;	0.8999	;in	
Sampling Standards					99.24 ;	-0.8;	0.8852;	0.8920	;in


File:A24JUL07A_2 #1-399 Acc:25-JUL-2007 07:29:38 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#9 Text: RETCON S27-120F
 319.8965 S:9 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,4464.0,5.00%,F,T)
 100%
 100%




File:A24JUL07A_2 #1-184 ACG:25-JUL-2007 07:29:38 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#9 Text:RETC0N S27-120F EXP:EXP DB5MS
 355.8546 S:9 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5060.0,5.00%,F,T)
 100%
 33:05




File: A24JUL07A_2 #1-252 Acq:25-JUL-2007 07:29:38 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#9 Text: RETCON S27-120F Exp: EXP DB5MS
 389.8156 S:9 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.018,6476.0,5.00%,F,T)
 100% 35:50



File:A24JUL07A_2 #1-292 Acq:25-JUL-2007 07:29:38 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#9 Text:RETCON S27-120F
 Exp:EXP_DBMS
 423.7767 S:9 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5428.0,5.00%,F,T)
 100% 39:41



425.7737 S:9 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5240.0,5.00%,F,T)
 100% 39:41




435.8169 S:9 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5012.0,5.00%,F,T)
 100% 40:37




437.8140 S:9 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4584.0,5.00%,F,T)
 100% 40:37




430.9728 S:9 F:4 SMO(1,3) PKD(3,2,1,100.00%,0.0,5.00%,F,T)
 100% 38:31 38:43 39:13 39:30 39:45 39:59 40:25 40:42 40:57 41:13 41:28 41:40



File:A24JUL07A_2 #1-368 Acq:25-JUL-2007 07:29:38 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#9 Text:RETCON S27-120F Exp:EXP DB5MS
 457.7377 S:9 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4356.0,5.00%,F,T)
 100% 50% 0%



File:A24JUL07A_2 #1-399 Acq:25-JUL-2007 07:29:38 GC EI+ Voltage SIR Autospec-Ultimate
 Sample#9 Text:RETCON S27-120F
 Exp:EXP_DB5MS
 303.9015 S:9 BSUB(256,15,-3.0) PKD(3,2,1,0.01%,4976.0,5.00%,F,T)
 100% 100% 100%



File:A24JUL07A_2 #1-184 Acq:25-JUL-2007 07:29:38 GC EI+ Voltage SIR Autospec-UI time

Sample#9 Text:RETC0N S27-120F Exp:EXP DB5MS

339.8597 S:9 F:2 BSUB(128,15,-3.0) PKD(3,2,1,0.018,8948.0,5.00%,F,T)

100%

34:54

1.0E7

5.0E6

0.0E0

Time

34:15

0.0E0

Time

33:38

0.0E0

Time

33:02

50

0

Time

32:48

0

Time

33:00

50

0

Time

33:12

0

Time

33:15

50

0

Time

33:18

0

Time

33:24

50

0

Time

33:27

0

Time

33:30

50

0

Time

33:36

0

Time

33:40

50

0

Time

33:43

0

Time

33:48

50

0

Time

33:51

0

Time

34:00

50

0

Time

34:03

0

Time

34:08

50

0

Time

34:12

0

Time

34:15

50

0

Time

34:18

0

Time

34:21

50

0

Time

34:24

0

Time

34:27

50

0

Time

34:30

0

Time

34:33

50

0

Time

34:36

0

Time

34:39

50

0

Time

34:42

0

Time

34:45

50

0

Time

34:48

0

Time

34:51

50

0

Time

35:04

0

Time

35:07

50

0

Time

35:10

0

Time

35:13

50

0

Time

35:16

0

Time

35:19

50

0

Time

35:22

0

Time

35:25

50

0

Time

35:28

0

Time

35:31

50

0

Time

35:34

0

Time

35:37

50

0

Time

35:40

0

Time

35:43

50

0

Time

35:46

0

Time

35:49

50

0

Time

35:52

0

Time

35:55

50

0

Time

35:58

0

Time

36:01

50

0

Time

36:04

0

Time

36:07

50

0

Time

36:10

0

Time

36:13

50

0

Time

36:16

0

Time

36:19

50

0

Time

36:22

0

Time

36:25

50

0

Time

36:28

0

Time

36:31

50

0

Time

36:34

0

Time

36:37

50

0

Time

36:40

0

Time

36:43

50

0

Time

36:46

0

Time

36:49

50

0

Time

36:52

0

Time

36:55

50

0

Time

36:58

0

Time

37:01

50

0

Time

37:04

0

Time

37:07

50

0

Time

37:10

0

Time

37:13

50

0

Time

37:16

0

Time

37:19

50

0

Time

37:22

0

Time

37:25

50

0

Time

37:28

0

Time

37:31

50

0

Time

37:34

0

Time

37:37

50

0

Time

37:40

0

Time

37:43

50

0

Time

37:46

0

Time

37:49

50

0

File: A24JUL07A_2 #1-252 Acq:25-JUL-2007 07:29:38 GC EI+ Voltage SIR Autospec-UltimaE

Sample#9 Text: RETCON S27-120F Exp: EXP_DBSMS

373.8207 S:9 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,7504.0,5.00%,F,T)

100% 35:24 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time

375.8178 S:9 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,6440.0,5.00%,F,T)

100% 35:24 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time

383.8639 S:9 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4524.0,5.00%,F,T)

100% 35:24 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time

385.8610 S:9 F:3 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4200.0,5.00%,F,T)

100% 35:24 35:24 35:36 35:48 36:00 36:12 36:24 36:36 36:48 37:00 37:12 37:24 37:36 37:48 38:00 38:12 Time


445.7555 S:9 F:3 BSUB(128,15,-3.0) PKD(3,2,1,100.00%,5696.0,5.00%,F,T)

100% 35:15 35:30 35:36 35:48 36:03 36:25 36:48 36:59 37:23 37:39 37:46 38:03 38:03 38:03 38:03 38:03 Time

380.9760 S:9 F:3 SMO(1,3) PKD(3,2,1,100.00%,0,0,5.00%,F,T)

100% 35:16 35:31 35:45 35:58 36:16 36:40 37:00 37:26 37:41 37:41 37:41 37:41 37:41 37:41 37:41 Time


File:A24JUL07A_2 #1-292 Acq:25-JUL-2007 07:29:38 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#9 Text:RETCON S27-120F
 Exp:EXP_DB5MS
 407.7818 S:9 F:4 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,4684.0,5.00%,F,T)
 100% 39:20




File:A24JUL07A_2 #1-368 Acq:25-JUL-2007 07:29:38 GC EI+ Voltage SIR Autospec-UltimaE

Sample#9 Text:RETCON S27-120F

441.7427 S:9 F:5 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,3856.0,5.00%,F,T)



File:A24JUL07A_2 #1-399 Acq:25-JUL-2007 07:29:38 GC EI+ Voltage SIR Autospec-UltimaE
 Sample#9 Text:RETCON S27-120F Exp:EXP_DB5MS
 341.8568 S:9 BSUB(128,15,-3.0) PKD(3,2,1,0.01%,5128.0,5.00%,F,T)
 100% 100%



Injection Prep Log

Sample ID	IJ STD Lot#	IJ Amt (μ L)	IJ Conc. (ng/ μ L)	Final Vol.* (μ L)	Analyst (initials)	Date	Comments
1 OP24360	S27-331	20	0.1	20	JW	07.16.06	
2 OPROM40			1				
3 LM01760			1				
4 67540-10-4C			1				
5 67540-05-05			1				
6 68952-2-10			1				
7 6579-252-28			1				
8 6579-254-18			1				
9 6383-576-18			1				
10 6399-2-16-21C			1				
11 6399-226-21D			1				
12 6399-218-22D			1				
13 6399-218-22D			1				
14 6579-253-1C	S27-331	20	0.1	20	JW	07.16.06	
15 6579-254-1C			1				
16 6908-2-4C			1				
17 6371-559-1C			1				
18 6552-434-1C			1				
19							07.16.06
20							

DC17.021800.1

* = to be entered in the Prep table.

Logbook: 12 _____ Page: 206 _____

Injection Prep Log

Sample ID	IJ STD Lot#	IJ Amt (μ l)	IJ Conc. (μ g/ μ l)	Final Vol.* (μ l)	Analyst (initials)	Date	Comments
1 6616-33-10B	521-341	2.0	0.1	2.0	✓	6/24/07	
2 6616-32-15B							
3 6626-33-10B							
4 NRP-A372	S21-353	100	0.5	100	HMP	25/6/07	
5 OPRD4372							
6 LMBK372							
7 G291-92-1B							
8 G291-92-2B							
9 G291-92-3B							
10 G291-92-4B							
11 G291-92-5B							
12 G291-92-6B							
13 G657-49-1C							
14 G657-49-2C							
15 G657-49-3C							
16 G657-49-4C							
17							
18							
19							
20							

DC17.021800.1

* = to be entered in the Prep table.

Logbook: 12 Page: 213

Injection Prep Log

Sample ID	IJ STD Lot#	IJ Amt (μ L)	IJ Conc. (μ M)	Final Vol.* (μ L)	Analyst (initials)	Date	Comments
1 0P2114365	S21-219	20	6.1	20	✓✓✓	01-24-07	
2 0P2114365							
3 LM84565							
4 6371-157.1C							
5 6371-157-2C							
6 6371-157-1C							
7 6371-158-2C							
8 6371-160-1B							
9 6371-160-2B							
10 0P2114367	S21-313	100	0.5	100	✓✓✓	01-24-07	
11 0P2114367							
12 LM84567							
13 6371-159-3C							
14 6371-229-1B							
15 6371-229-1C	227-355						
16 6371-229-1D							
17 0P2114371	S21-219	20	0.1	20	✓✓✓	01-24-07	
18 0P2114371							
19 LM84561							
20 6371-33-5B							

DC17.021800.1

* = to be entered in the Prep table.

Logbook: 12 _____ Page: 2,2 _____

Injection Prep Log

Sample ID	IJ STD Lot#	IJ Amt (μ L)	IJ Conc. (μ g/ μ L)	Final Vol.* (μ L)	Analyst (initials)	Date	Comments
1 6100-939-10	511-13	10.0	0.5	100	JKW	07-19-07	
2 6100-939-15							
3 6100-939-36							
4 6100-939-45							
5 6100-115-03	527-279	1.0	2.0	3.00	JKW	07-19-07	
6 6100-115-03							
7 6100-115-03							
8 6220-61-20							
9 6220-61-20							
10 6220-61-20							
11 6220-61-20							
12 6220-61-20							
13 6100-939-10							
14 6100-939-10	511-13	0.1	2.0	JKW	07-19-07		
15 6100-939-10							
16 6100-939-10							
17 6100-939-10							
18 6351-148-95							
19 6100-939-10							
20 6100-939-10							

DC17.021800.1

* = to be entered in the Prep table.

Logbook: 12 Page: 210 Page: 268

Injection Prep Log

Sample ID	IJ STD Lot#	IJ Amt (μ L)	IJ Conc. (mg/L)	Final Vol.* (μ L)	Analyst (initials)	Date	Comments
1 6431-150	521-3411	2.0	0.1	2.0	320	07.10.07	
2 6430-931-3C							
3 6430-931-3C							
4 OP11346	521-3411	2.0	0.1	2.0	320	07.10.07	
5 OP11346							
6 LM014366							
7 6349-248-15C							
8 OP11346							
9 OP2014366							
10 LM014366							
11 6185-281-1B							
12 6185-282-1C							
13 OP2014370	521-3411	2.0	0.1	2.0	320	07.10.07	
14 OP2014370							
15 LM014370							
16 6431-15-08							
17 6431-15-08							
18 6431-15-08							
19 6431-15-08							
20							

DC17.021800.1

* = to be entered in the Prep table.

Logbook: 12 Page: 211

TEST RESULTS AND CALCULATIONS

Inlet Hg Emissions Data

ONTARIO HYDRO - RESULTS

Plant Name	Fibrominn Biomass Power Plant	Date	07/05/07
Sampling Location	SDA Inlet	Project #	snc-07-benson.mn-comp#1
Operator	TP	Stack Type	Circular

Historical Data						
Run Number		IN-OHM-1	IN-OHM-2	IN-OHM-3	Average	
Run Start Time		18:02	21:12	0:43		hh:mm
Run Stop Time		20:20	23:30	3:00		hh:mm
Meter Calibration Factor (Y)	1.007	1.007	1.007			
Pitot Tube Coefficient (C_p)	0.840	0.840	0.840			
Average Nozzle Diameter (D_{na})	0.251	0.232	0.222			in
Stack Test Data						
Initial Meter Volume (V_m) _i	109.850	149.015	184.550			ft3
Final Meter Volume (V_m) _f	148.836	182.820	210.595			ft3
Total Meter Volume (V_m)	38.986	33.805	26.045	32.945		ft3
Total Sampling Time (Θ)	120.0	120.0	120.0	120.0		min
Average Meter Temperature (t_m) _{avg}	104.5	104.0	99.5	102.7		oF
Average Stack Temperature (t_s) _{avg}	338.5	348.2	341.3	342.7		oF
Barometric Pressure (P_b)	29.53	29.52	29.57	29.54		in Hg
Stack Static Pressure (P_{static})	-0.23	-0.23	-0.23	-0.23		in H2O
Absolute Stack Pressure (P_s)	29.51	29.50	29.55	29.52		in Hg
Average Orifice Pressure Drop (ΔH) _{avg}	2.09	0.96	1.36	1.47		in H2O
Absolute Meter Pressure (P_m)	29.65	29.64	29.69	29.66		in Hg
Avg Square Root Pitot Pressure ($\Delta p^{1/2}$) _{avg}	0.91	0.86	1.05	0.94		(in H2O) ^{1/2}
Moisture Content Data						
Impingers 1-3 Water Volume Gain (V_n)	157.3	192.9	119.3	156.5		ml
Impinger 4 Silica Gel Weight Gain (W_n)	10.1	12.7	18.4	13.7		g
Total Water Volume Collected (V_c)	167.4	205.7	137.7	170.3		ml
Standard Water Vapor Volume (V_w) _{std}	7.880	9.681	6.484	8.015		scf
Standard Meter Volume (V_m) _{std}	36.322	31.476	24.484	30.761		dscf
Calculated Stack Moisture ($B_{ws(cal)}$)	17.78	23.50	20.90	20.72		%
Saturated Stack Moisture ($B_{ws(svp)}$)	100.0	100.0	100.0	100.0		%
Reported Stack Moisture Content (B_{ws})	17.78	23.50	20.90	20.72		%
Gas Analysis Data						
Carbon Dioxide Percentage (%CO ₂)	14.0	14.0	14.0	14.0		%
Oxygen Percentage (%O ₂)	5.0	5.0	5.0	5.0		%
Carbon Monoxide Percentage (%CO)	0.0	0.0	0.0	0.0		%
Nitrogen Percentage (%N ₂)	81.0	81.0	81.0	81.0		%
Dry Gas Molecular Weight (M_d)	30.44	30.44	30.44	30.44		lb/lb-mole
Wet Stack Gas Molecular Weight (M_s)	28.23	27.52	27.84	27.86		lb/lb-mole
Calculated Fuel Factor (F_o)	1.135	1.135	1.135	1.135		
Fuel F-Factor (F_c)	1890	1890	1890	1890		dscf/MMBtu
Percent Excess Air (%EA)	30.5	30.5	30.5	30.5		%
Volumetric Flow Rate Data						
Average Stack Gas Velocity (v_s)	65.38	61.68	75.04	67.37		ft/sec
Stack Cross-Sectional Area (A_s)	90.76	90.76	90.76	90.76		ft ²
Actual Stack Flow Rate (Q_{aw})	356,041	335,878	408,658	366,859		acfm
Wet Standard Stack Flow Rate (Q_{sw})	13,934	12,983	15,958	14,291		wkscfh
Dry Standard Stack Flow Rate (Q_{sd})	190,931	165,540	210,390	188,954		dscfm
Percent of Isokinetic Rate (I)	100.5	103.7	95.6	99.9		%
Emission Rate Data						
Total Mass of Hg	(part. bound)	0.00001	0.00000	0.00000	0.00000	mg
	(oxidized)	0.00000	0.00000	0.00000	0.00000	mg
	(elemental)	0.000050	0.00000	0.00000	0.000017	mg
	(all forms)	0.000052	0.00000	0.00000	0.000017	mg
Emission Rate of Hg	(part. bound)	0.00001	0.00000	0.00000	0.00000	lbs/hr
	(oxidized)	0.00000	0.00000	0.00000	0.00000	lbs/hr
	(elemental)	0.000035	0.00000	0.00000	0.000012	lbs/hr
	(all forms)	0.000036	0.00000	0.00000	0.000012	lbs/hr
Emission Rate of Hg	(part. bound)	0.00004	0.00000	0.00000	0.00001	tons/yr
	(oxidized)	0.00000	0.00000	0.00000	0.00000	tons/yr
	(elemental)	0.00153	0.00000	0.00000	0.00051	tons/yr
	(all forms)	0.00156	0.00000	0.00000	0.00052	tons/yr
Emission Rate of Hg	(part. bound)	9.83E-09	0.00E+00	0.00E+00	3.28E-09	lbs/MMBtu
	(oxidized)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	lbs/MMBtu
	(elemental)	4.13E-07	0.00E+00	0.00E+00	1.38E-07	lbs/MMBtu
	(all forms)	4.23E-07	0.00E+00	0.00E+00	1.41E-07	lbs/MMBtu

Note: Results reported below practical quantitation limit (BPQL) set to non-detect (ND) for calculations.



Air Hygiene International, Inc.
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
(888) 461-8778
www.airhygiene.com

MERCURY ANALYSIS DATASHEET

Paramter	Units	Run 1				
		Particle Bound Hg		Oxidized Hg	Elemental Hg	
		Filter	Probe Wash	KCl (Imp 1-3)	HNO ₃ -H ₂ O ₂ (Imp 4)	KMNO ₄ (Imp 5-7)
Sample		IN-OHM-1-CON1	IN-OHM-1-CON2	IN-OHM-1-CON3	IN-OHM-1-CON4	IN-OHM-1-CON5
Log Number		20073701	20073708	20073709	20073710	20073711
Solids PQL	µg	0.007				
Ash Hg Content Weight	µg	0.012				
Liquid Results	mg/L		0.000000	0.000000	0.000000	0.000770
Liquids PQL	mg/L		0.00140	0.00014	0.00140	0.00014
Sample Volume	mL		430	510	120	535
Dry Std. Stack Flow Rate (Q _{sd})	dscfm			190,931		
DGM Volume	dscf			36.322		
DGM Volume	dscm			1.03		
Carbon Dioxide Concentration	%			14.00		
Total Hg (ea. form)	mg		0.0000	0.0000	0.0005	0.0005
Total Hg						
Hg (ea. form)	lb/MMBtu		9.83E-09	0.00E+00	4.13E-07	
Hg				4.23E-07		
Hg (ea. form)	lb/hr		0.0000	0.0000	0.0004	
Hg					0.0004	
Hg (ea. form)	ton/yr		0.0000	0.0000	0.0015	
Hg					0.0016	

Paramter	Units	Run 2				
		Particle Bound Hg		Oxidized Hg	Elemental Hg	
		Filter	Probe Wash	KCl (Imp 1-3)	HNO ₃ -H ₂ O ₂ (Imp 4)	KMNO ₄ (Imp 5-7)
Sample		IN-OHM-2-CON1	IN-OHM-2-CON2	IN-OHM-2-CON3	IN-OHM-2-CON4	IN-OHM-2-CON5
Log Number		20073702	20073712	20073713	20073714	20073715
Solids PQL	µg	0.007				
Ash Sample Weight	µg	0.000				
Liquid Results	mg/L		0.000000	0.000000	0.000000	0.000000
Liquids PQL	mg/L		0.00140	0.00014	0.00140	0.00014
Sample Volume	mL		415	280	430	510
Dry Std. Stack Flow Rate (Q _{sd})	dscfm			165,540		
DGM Volume	dscf			31.476		
DGM Volume	dscm			0.89		
Carbon Dioxide Concentration	%			14.00		
Total Hg (ea. form)	mg		0.0000	0.0000	0.0000	0.0000
Total Hg				0.0000		
Hg (ea. form)	lb/MMBtu		0.00E+00	0.00E+00	0.00E+00	
Hg				0.00E+00		
Hg (ea. form)	lb/hr		0.0000	0.0000	0.0000	
Hg				0.0000		
Hg (ea. form)	ton/yr		0.0000	0.0000	0.0000	
Hg				0.0000		

Paramter	Units	Run 3				
		Particle Bound Hg		Oxidized Hg	Elemental Hg	
		Filter	Probe Wash	KCl (Imp 1-3)	HNO ₃ -H ₂ O ₂ (Imp 4)	KMNO ₄ (Imp 5-7)
Sample		IN-OHM-3-CON1	IN-OHM-3-CON2	IN-OHM-3-CON3	IN-OHM-3-CON4	IN-OHM-3-CON5
Log Number		20073703	20073716	20073717	20073718	20073719
Solids PQL	µg	0.007				
Ash Sample Weight	µg	0.000				
Liquid Results	mg/L		0.000000	0.000000	0.000000	0.000000
Liquids PQL	mg/L		0.00140	0.00014	0.00140	0.00014
Sample Volume	mL		440	465	140	510
Dry Std. Stack Flow Rate (Q _{sd})	dscfm			210,390		
DGM Volume	dscf			24.484		
DGM Volume	dscm			0.69		
Carbon Dioxide Concentration	%			14.00		
Total Hg (ea. form)	mg		0.0000	0.0000	0.0000	0.0000
Total Hg				0.0000		
Hg (ea. form)	lb/MMBtu		0.00E+00	0.00E+00	0.00E+00	
Hg				0.00E+00		
Hg (ea. form)	lb/hr		0.0000	0.0000	0.0000	
Hg				0.0000		
Hg (ea. form)	ton/yr		0.0000	0.0000	0.0000	
Hg				0.0000		

ONTARIO HYDRO SOURCE SAMPLING TITLE PAGE

Source Information				
Plant Name	Fibrominn Biomass Power Plant			
Sampling Location	SDA Inlet			
Fuel or Source Type	Biomass			
Fuel F-Factor	1890	1890	1890	

Test Information				
Starting Test Date	07/05/07			
Project #	snc-07-benson.mn-comp#1			
Operator	TP			
Standard Temperature	68		oF	
Standard Pressure	29.92		in Hg	
Minimum Required Sample Vol.	Sec 10.1.5	35.3	scf	
Run Duration	Sec 10.1.5	120	minutes	
Unit Number	IN-OHM			
Load	% or w/DB	100%		
Base Run Number	IN-OHM			
Number of Ports Available	2			
Number of Ports Used	2			
Port Inside Diameter	5.00		in	
Circular Stack				

Test Equipment Information				
Run		1	2	3
Meter Box Number	from ACS	SAMP-CP-0002	SAMP-CP-0002	SAMP-CP-0002
Meter Calibration Factor	(Y)	1.007	1.007	1.007
Orifice Meter Coefficient	(ΔH@)	1.667	1.667	1.667
Pitot Identification	from ACS	SAMP-HP-0021	SAMP-HP-0021	SAMP-HP-0036
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840
Orsat Identification	from ACS	N/A	N/A	N/A
Nozzle Number	from ACS	D4	D7	A7
Nozzle Diameter	(D _n)	0.251	0.232	0.222
Probe Number	from ACS	SAMP-HP-0021	SAMP-HP-0021	SAMP-HP-0036
Probe Length		96.00	96.00	96.00
(SS, Glass) Liner Material	from list	glass	glass	glass
Sample Case / Oven Number	from ACS	SAMP-BH-0009	SAMP-BH-0009	SAMP-BH-0009
Impinger Case Number	from ACS	SAMP-BC-0015	SAMP-BC-0021	SAMP-BC-0015
Acetone Lot Number	from bottle	C38B11	C38B11	C38B11

Testing Company Information				
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)			
Address	5634 S. 122nd East Ave., Suite F			
City, State Country Zip	Tulsa, Oklahoma 74146			
Project Manager	Thomas K. Graham			
Phone Number	(918) 307-8865			
Fax Number	(918) 307-9131			

METHOD 1 - SAMPLE AND VELOCITY TRAVERSSES FOR CIRCULAR SOURCES

Plant Name	Fibrominn Biomass Power Plant		Date	07/05/07
Sampling Location	SDA Inlet		Project #	snc-07-benson.mn-comp#1
Operator	TP		# of Ports Available	2
Stack Type	Circular		# of Ports Used	2
Stack Size	Large		Port Inside Diameter	5.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	136.00	in
Distance to Near Wall of Stack	(L _{nw})	7.00	in
Diameter of Stack	(D)	129.00	in
Area of Stack	(A _s)	90.76	ft ²


Distance from Port to Disturbances			
Distance Upstream	(A)	350.00	in
Diameters Upstream	(A _D)	2.71	diameters
Distance Downstream	(B)	1222.00	in
Diameters Downstream	(B _D)	9.47	diameters

Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of Traverse Points	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²
Upstream Spec		12	12
Downstream Spec		12	12
Traverse Pts Required		12	12

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

² 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

Location of Traverse Points in Circular Stacks									
(Fraction of Stack Dimension from Inside Wall to Traverse Point)									
Traverse Point	Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6				.956	.806	.658	.356	.269	.220
7					.895	.774	.644	.366	.283
8						.968	.854	.750	.634
9							.918	.823	.731
10								.625	.382
11								.717	.618
12								.780	.704
								.831	.764



Number of Traverse Points Used			
2	Ports by	6	Across
12	Pts Used	12	Required
			Particulate Traverse

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
		in	in
1	0.04	5 5/8	12 5/8
2	0.15	18 7/8	25 7/8
3	0.30	38 1/8	45 1/8
4	0.70	90 7/8	97 7/8
5	0.85	110 1/8	117 1/8
6	0.96	123 3/8	130 3/8
7			
8			
9			
10			
11			
12			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE				
--	--	--	--	--

Plant Name	Fibrominn Biomass Power Plant			Date	06/30/07	
Sampling Location	SDA Inlet			Project #	snc-07-benson.mn-comp#1	
Operator	TP			# of Ports Used	2	
Stack Type	Circular			Pitot Identification	SAMP-HP-0021	
Pitot Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Pitot Coefficient (C_p)	0.84

Stack Dimensions				Velocity Traverse Data									
Diameter or Length of Stack (D)		129.00	in	Run Number		IN-OHM-V1							
Width of Stack (W)			in	Run Time		Start	12:10	End					
Area of Stack (A _s)		90.76	ft ²	Traverse Point	Velocity Head (Δp)	Null Angle (N_a)	Stack Temp (t_s)	Local Velocity (v_{s(l)})					
Pressures													
Barometric Pressure (P _b)		29.92	in Hg		in H ₂ O	deg	oF	ft/sec					
Static Pressure (P _{static})		-0.23	in H ₂ O	A-1	2.10	-5	219	95.9					
Absolute Stack Pressure (P _s)		29.90	in Hg	A-2	2.10	5	219	95.9					
Stack Gas Composition													
Composition Data:				A-3	1.70	5	192	84.5					
Carbon Dioxide Concentration (%CO ₂)		14.4	%	A-4	2.30	0	207	99.5					
Oxygen Concentration (%O ₂)		4.8	%	A-5	2.20	0	215	97.9					
Carbon Monoxide Concentration (%CO)		0.0	%	A-6	1.90	0	197	89.7					
Nitrogen Concentration (%N ₂)		80.8	%	B-1	2.30	-5	196	98.6					
Stack Moisture Content (B _{ws})		30.000	%	B-2	2.40	5	202	101.2					
Stack Dry Molecular Weight (M _d)		30.50	lb/lb-mole	B-3	2.10	0	200	94.5					
Stack Wet Molecular Weight (M _s)		26.75	lb/lb-mole	B-4	1.90	0	183	88.8					
Results													
Avg Stack Gas Velocity (v _s)		94.8	ft/sec										
Avg Stack Dry Std Flow Rate (Q _{sd})		17,271,132	dscf/hr										
Avg Stack Dry Std Flow Rate (Q _{sd})		287,852	dscf/min										
Avg Stack Wet Flow Rate (Q _{aw})		516,261	acf/min										
Avg Stack Wet Std Flow Rate (Q _{sw})		24,673,046	ascf/hr										
Stack Cross Section Schematic													

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER								
---	--	--	--	--	--	--	--	--

Plant Name	Fibrominn Biomass Power Plant				Date	07/05/07		
Sampling Location	SDA Inlet				Project #	snc-07-benson.mn-comp#1		
Operator	TP				# of Ports Used	2		
Fuel Type	Biomass		Minimum Fuel Factor		1.000	Maximum Fuel Factor		1.120
Orsat Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Orsat Identification	N/A		

Gas Analysis Data									
Run Number		IN-OHM-1		Run Start Time		18:02	Run Stop Time		20:20
Sample Analysis Time	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N2)	Dry Molecular Weight (M_d)	Molecular Weight Deviation (ΔM_d)
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole
2:18	14.0	5.0	100.0	14.0	5.0	0.0	81.0	30.44	0.00
Results		Averages	14.0	5.0	0.0	81.0	30.44		
Average Calculated Fuel Factor		(F_o)avg	1.135			Molecular Wt Deviation < 0.3?		<input checked="" type="checkbox"/>	
Average Excess Air		(%EA)avg	30.5	percent	Fuel Factor in Handbook Range?			<input checked="" type="checkbox"/>	

Gas Analysis Data									
Run Number		IN-OHM-2		Run Start Time		21:12	Run Stop Time		23:30
Sample Analysis Time	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N2)	Dry Molecular Weight (M_d)	Molecular Weight Deviation (ΔM_d)
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole
2:18	14.0	5.0	100.0	14.0	5.0	0.0	81.0	30.44	0.00
Results		Averages	14.0	5.0	0.0	81.0	30.44		
Average Calculated Fuel Factor		(F_o)avg	1.135			Molecular Wt Deviation < 0.3?		<input checked="" type="checkbox"/>	
Average Excess Air		(%EA)avg	30.5	percent	Fuel Factor in Handbook Range?			<input checked="" type="checkbox"/>	

Gas Analysis Data									
Run Number		IN-OHM-3		Run Start Time		0:43	Run Stop Time		3:00
Sample Analysis Time	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N2)	Dry Molecular Weight (M_d)	Molecular Weight Deviation (ΔM_d)
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole
2:17	14.0	5.0	100.0	14.0	5.0	0.0	81.0	30.44	0.00
Results		Averages	14.0	5.0	0.0	81.0	30.44		
Average Calculated Fuel Factor		(F_o)avg	1.135			Molecular Wt Deviation < 0.3?		<input checked="" type="checkbox"/>	
Average Excess Air		(%EA)avg	30.5	percent	Fuel Factor in Handbook Range?			<input checked="" type="checkbox"/>	

Fuel Factor Fo		
Fuel Type	Minimum	Maximum
Coal, Anthracite	1.016	1.130
Coal, Lignite	1.016	1.130
Coal, Bituminous	1.083	1.230
Oil, Distillate	1.260	1.413
Oil, Residual	1.210	1.370
Gas, Natural	1.600	1.836
Gas, Propane	1.434	1.586
Gas, Butane	1.405	1.553
Biomass	1.000	1.120
Wood Bark	1.003	1.130

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Fibrominn Biomass Power Plant			Date	07/05/07	
Sampling Location	SDA Inlet			Project #	snc-07-benson.mn-comp#1	
Operator	TP			# of Ports Used	2	
Stack Type	Circular			Meter Box Number	SAMP-CP-0002	
Train Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Meter Cal Factor (Y)	1.007

Moisture Content Data							
Run Number	IN-OHM-1		Run Start Time	18:02	Run Stop Time		20:20
Total Meter Volume	(V _m)	38.986	dcf	Barometric Press.	(P _b)	29.53	in Hg
Avg Stack Temp	(t _s) _{avg}	339	oF	Stack Static Press.	(P _{static})	-0.23	in H ₂ O
Avg Meter Temp	(t _m) _{avg}	105	oF	Avg Orifice Press.	(ΔH) _{avg}	2.09	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents	KCl	KCl	KCl	HNO ₃ -H ₂ O ₂	H ₂ SO ₄ -KMnO ₄	H ₂ SO ₄ -KMnO ₄	H ₂ SO ₄ -KMnO ₄
Final Value	(V _t),(W _f)	846.90	800.50	739.90	718.30	748.10	778.30
Initial Value	(V _i),(W _i)	729.30	770.40	733.90	716.60	747.40	778.00
Net Value	(V _n),(W _n)	117.6	30.1	6.0	1.7	0.7	0.3
Results							
Total Weight	(W _t)	167.10	g	Water Vol Weighed	(V _{wsg(std)})	7.879	scf
Std Meter Volume	(V _{m(std)})	36.428	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws(calc)})	17.8	%	Final Moisture Content	(B _{ws})	17.8	%

Moisture Content Data							
Run Number	IN-OHM-2		Run Start Time	21:12	Run Stop Time		23:30
Total Meter Volume	(V _m)	33.805	dcf	Barometric Press.	(P _b)	29.52	in Hg
Avg Stack Temp	(t _s) _{avg}	348	oF	Stack Static Press.	(P _{static})	-0.23	in H ₂ O
Avg Meter Temp	(t _m) _{avg}	104	oF	Avg Orifice Press.	(ΔH) _{avg}	0.96	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents	KCl	KCl	KCl	HNO ₃ -H ₂ O ₂	H ₂ SO ₄ -KMnO ₄	H ₂ SO ₄ -KMnO ₄	H ₂ SO ₄ -KMnO ₄
Final Value	(V _t),(W _f)	776.50	731.30	742.10	759.20	795.80	783.10
Initial Value	(V _i),(W _i)	742.30	711.50	727.40	756.70	731.40	775.50
Net Value	(V _n),(W _n)	34.2	19.8	14.7	2.5	64.4	7.6
Results							
Total Weight	(W _t)	205.30	g	Water Vol Weighed	(V _{wsg(std)})	9.680	scf
Std Meter Volume	(V _{m(std)})	31.518	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	23.5	%	Final Moisture Content	(B _{ws})	23.5	%

Moisture Content Data							
Run Number	IN-OHM-3		Run Start Time	0:43	Run Stop Time		3:00
Total Meter Volume	(V _m)	26.045	dcf	Barometric Press.	(P _b)	29.57	in Hg
Avg Stack Temp	(t _s) _{avg}	341	oF	Stack Static Press.	(P _{static})	-0.23	in H ₂ O
Avg Meter Temp	(t _m) _{avg}	100	oF	Avg Orifice Press.	(ΔH) _{avg}	1.36	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents	KCl	KCl	KCl	HNO ₃ -H ₂ O ₂	H ₂ SO ₄ -KMnO ₄	H ₂ SO ₄ -KMnO ₄	H ₂ SO ₄ -KMnO ₄
Final Value	(V _t),(W _f)	828.60	799.10	746.50	723.30	762.00	781.10
Initial Value	(V _i),(W _i)	729.30	781.30	744.20	723.20	762.30	781.30
Net Value	(V _n),(W _n)	99.3	17.8	2.3	0.1	-0.3	-0.2
Results							
Total Weight	(W _t)	137.50	g	Water Vol Weighed	(V _{wsg(std)})	6.483	scf
Std Meter Volume	(V _{m(std)})	24.544	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	20.9	%	Final Moisture Content	(B _{ws})	20.9	%

ONTARIO HYDRO ISOKINETIC SAMPLING DATA

Plant Name	Fibrominn Biomass Power Plant				Date	7/5/2007				Ideal Nozzle Diameter and IsoKinetic Factor Setup									
Sampling Location	SDA Inlet				Project #	snc-07-benson.mn-comp#1				Pitot Tube Coefficient	(C _p)	0.84							
Operator	TP				Run #	IN-OHM-1				Avg Stack Temp	(t _s)	203	oF						
# of Points Across	6				# of Ports Used	2				Avg Gas Meter Temp	(t _m)	81							
Leak Checks								Sampling Equipment								Pressures			
Train	Pre	0	ft3/min @	15	in Hg	Meter #	SAMP-CP-0002				Barometric Pressure	(P _b)	29.53	in Hg					
OK?	<input checked="" type="checkbox"/>	Post	0	ft3/min @	15	in Hg	Meterbox Cal. Factor	(Y)	1.007	Nozzle #	Stack Static Pressure	(P _{static})	-0.23	in H2O					
Pitot	Pre	6.7/5.4	in. H ₂ O for	15	sec	Average Nozzle Diameter	(D _{na})	0.2513	in	Estimated Orifice Flow Rate	(Q _m)	0.750	acfm						
OK?	<input checked="" type="checkbox"/>	Post	7.3/5.6	in. H ₂ O for	15	sec	Rec. Nozzle Diameter	(D _{ri})	0.2190	in	DP to DH Isokinetic Factor	(K)	2.03						
Orsat	OK?	<input checked="" type="checkbox"/>				Probe # / Length	SAMP-HP-0021	/ 96	in										
Nozzle Measurements								Liner Material								Pressures			
Pre	0.250	0.252	0.252	PASS	Sample Case / Oven #	SAMP-BH-0009				Absolute Stack Pressure	(P _s)	29.51	in Hg						
Post	0.250	0.252	0.252	PASS	Impinger Case #	SAMP-BC-0015				Absolute Meter Pressure	(P _m)	29.65	in Hg						
Run Time								Weights								Pressures			
Start	18:02	End	20:20		Pre	729.30	770.40	733.90	716.60	747.40	778.00	731.30	933.80	Wash	H ₂ O	50.0	ml		
					Post	846.90	800.50	739.90	718.30	748.10	778.30	731.90	943.90	Volume	MeCl		ml	Filter #	
																	M-1976		
Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (Δp ^{1/2})	Local Stack Velocity (v _s)	Cumulative Meter Volume (V _m) _{std}	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}
		min	hh:mm:ss	ft3	in H ₂ O	in H ₂ O	in H ₂ O	oF	oF	oF	oF	oF	oF	in Hg	(in H ₂ O) ^{1/2}	ft/sec	scf	%	scf
A-1	0.0	0:00:00	109.850	0.760	1.544	1.500	336	223	256	68	223	104	104	4.0	0.87	62.19	4.894	77.6	58.724
A-2	10.0	0:10:00	115.090	0.800	1.625	1.600	340	224	246	52	225	104	104	7.5	0.89	63.97	10.368	81.4	62.207
A-3	20.0	0:20:00	120.950	0.790	1.604	1.600	340	236	241	48	228	105	105	9.5	0.89	63.57	15.552	81.2	62.210
A-4	30.0	0:30:00	126.510	0.300	0.609	0.600	336	238	238	47	229	105	105	11.5	0.55	39.07	20.222	89.7	60.666
A-5	40.0	0:40:00	131.530	0.530	1.076	1.100	335	240	237	46	226	105	106	14.0	0.73	51.90	25.582	92.2	61.396
A-6	50.0	0:50:00	137.290	0.140	0.284	0.280	338	230	235	47	224	106	106	14.0	0.37	26.73	30.276	104.9	60.553
B-1	60.0	1:00:00	142.350	0.130	0.264	0.260	338	240	235	48	226	105	105	15.0	0.36	25.75	33.617	107.2	57.630
B-2	70.0	1:10:00	145.945	0.350	0.711	0.710	339	235	234	53	223	104	104	17.5	0.59	42.28	34.815	104.5	52.223
B-3	80.0	1:20:00	147.230	0.930	1.889	1.900	338	230	234	60	225	104	104	18.0	0.96	68.88	35.717	102.1	47.623
B-4	90.0	1:30:00	148.195	1.900	3.859	3.900	339	225	235	68	224	104	104	18.5	1.38	98.52	35.865	101.7	43.038
B-5	100.0	1:40:00	148.352	2.800	5.687	5.700	340	229	237	67	226	104	104	19.0	1.67	119.67	36.020	101.3	39.295
B-6	110.0	1:50:00	148.517	2.900	5.890	5.900	343	225	237	67	223	104	104	20.0	1.70	122.02	36.322	100.5	36.322
Last Pt	120.0	2:00:00	148.836																
Final Val	120.0	2:00:00	148.836											Max Vac	20.0	Final Values	36.322	100.5	
Average Values				1.03		2.09	339	231	239	56	225	105	105		0.91	65.38			
														105					

ONTARIO HYDRO ISOKINETIC SAMPLING DATA

Plant Name	Fibrominn Biomass Power Plant				Date	7/5/2007				Ideal Nozzle Diameter and IsoKinetic Factor Setup																
Sampling Location	SDA Inlet				Project #	snc-07-benson.mn-comp#1				Pitot Tube Coefficient	(C _p)	0.84														
Operator	TP				Run #	IN-OHM-2				Avg Stack Temp	(t _s)	339	oF													
# of Points Across	6				# of Ports Used	2				Avg Gas Meter Temp	(t _m)	105														
Leak Checks								Sampling Equipment								DH @ 0.75 SCFM										
Train	Pre	0	ft3/min @	15	in Hg	Meter #	SAMP-CP-0002				(ΔH@)	1.67	in H ₂ O				Avg Pitot Tube Diff. Pressure	(ΔP _{avg})	0.91	in H ₂ O						
OK?	<input checked="" type="checkbox"/>	Post	0	ft3/min @	15	in Hg	Meterbox Cal. Factor	(Y)	1.007	Nozzle #	D7					Stack Moisture Content	(B _{ws})	25.00	%							
Pitot	Pre	5.9/6.1	in. H ₂ O for	15	sec	Average Nozzle Diameter	(D _{na})	0.2317	in	Stack Dry Molecular Weight	(M _d)	30.44	lb/lb-mole			Estimated Orifice Flow Rate	(Q _m)	0.325	acfm							
OK?	<input checked="" type="checkbox"/>	Post	6.6/7	in. H ₂ O for	15	sec	Rec. Nozzle Diameter	(D _{ri})	0.1659	in	DP to DH Isokinetic Factor	(K)	1.27			Orsat	OK?	<input checked="" type="checkbox"/>								
Nozzle Measurements								Probe # / Length								SAMP-HP-0021										
Pre	0.231	0.232	0.232	PASS	Liner Material	glass				Sample Case / Oven #	SAMP-BH-0009				Pressures		Barometric Pressure		(P _b)	29.52	in Hg					
Post	0.231	0.232	0.232	PASS	Impinger Case #	SAMP-BC-0021				Wash								Stack Static Pressure		(P _{static})	-0.23	in H ₂ O				
Run Time								Weights								Absolute Stack Pressure		(P _s)	29.50	in Hg						
Start	21:12	End	23:30		Pre	742.30	711.50	727.40	756.70	731.40	775.50	740.30	909.20	Wash	H ₂ O	50.0	ml	Absolute Meter Pressure		(P _m)	29.64	in Hg				
					Post	776.50	731.30	742.10	759.20	795.80	783.10	789.70	921.90	Volume	MeCl	ml		Filter #		M-1915						
Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumulative Meter Volume (V _m) _{std}	Cumulative Percent IsoKinetic (I)	Cumulative Est-Run Meter Volume (V _m) _{std}							
	min	hh:mm:ss	ft3	in H ₂ O	in H ₂ O	in H ₂ O	oF	oF	oF	oF	oF	oF	oF	in Hg	(in H ₂ O) ^{1/2}	ft/sec	scf	%	scf							
A-1	0.0	0:00:00	149.015	0.900	1.142	1.100	352	223	256	63	224	104	104	5.5	0.95	68.37	7.037	121.9	84.444							
A-2	10.0	0:10:00	156.560	0.920	1.168	1.200	353	229	254	52	226	105	105	8.0	0.96	69.16	10.674	101.6	64.041							
A-3	20.0	0:20:00	160.465	0.930	1.180	1.200	351	235	254	51	229	105	105	12.0	0.96	69.45	16.703	102.0	66.813							
A-4	30.0	0:30:00	166.940	0.680	0.863	0.860	351	241	256	52	230	105	105	16.0	0.82	59.39	22.547	105.8	67.640							
A-5	40.0	0:40:00	173.220	0.540	0.685	0.690	349	244	251	56	228	105	105	16.0	0.73	52.86	27.569	106.9	66.166							
A-6	50.0	0:50:00	178.620	0.510	0.647	0.650	348	252	256	59	227	105	105	18.0	0.71	51.34	31.280	104.3	62.559							
B-1	60.0	1:00:00	182.610	0.480	0.609	0.610	347	248	261	62	224	104	104	20.0	0.69	49.77	31.363	104.1	53.766							
B-2	70.0	1:10:00	182.700	0.680	0.863	0.860	349	240	266	63	223	103	103	20.0	0.82	59.32	31.386	104.0	47.079							
B-3	80.0	1:20:00	182.724	0.840	1.066	1.100	349	339	261	62	224	103	103	20.0	0.92	65.93	31.410	103.9	41.880							
B-4	90.0	1:30:00	182.750	0.860	1.092	1.100	348	235	261	62	226	103	103	20.0	0.93	66.66	31.443	103.8	37.731							
B-5	100.0	1:40:00	182.785	0.620	0.787	0.790	342	243	263	63	225	103	103	20.0	0.79	56.39	31.462	103.8	34.322							
B-6	110.0	1:50:00	182.805	1.000	1.269	1.300	339	246	263	65	227	103	103	20.0	1.00	71.48	31.476	103.7	31.476							
Last Pt	120.0	2:00:00	182.820																							
Final Val	120.0	2:00:00	182.820											Max Vac	20.0	Final Values	31.476	103.7								
Average Values				0.75	0.96	348	248	259	59	226	104	104	104	0.86	61.68											

ONTARIO HYDRO ISOKINETIC SAMPLING DATA

Plant Name	Fibrominn Biomass Power Plant				Date	7/6/2007				Ideal Nozzle Diameter and IsoKinetic Factor Setup											
Sampling Location	SDA Inlet				Project #	snc-07-benson.mn-comp#1				Pitot Tube Coefficient	(C _p)	0.84									
Operator	TP				Run #	IN-OHM-3				Avg Stack Temp	(t _s)	348	oF								
# of Points Across	6				# of Ports Used	2				Avg Gas Meter Temp	(t _m)	104									
Leak Checks					Sampling Equipment																
Train	Pre	0	ft3/min @	15	in Hg	Meter #	SAMP-CP-0002														
OK?	<input checked="" type="checkbox"/>	Post	0	ft3/min @	15	in Hg	Meterbox Cal. Factor	(Y)	1.007												
Pitot	Pre	5.3/7.6	in. H ₂ O for	15	sec	Nozzle #	A7														
OK?	<input checked="" type="checkbox"/>	Post	7.2/6.9	in. H ₂ O for	15	sec	Average Nozzle Diameter	(D _{na})	0.2223	in											
Orsat	OK?	<input checked="" type="checkbox"/>				Rec. Nozzle Diameter	(D _{ri})	0.1576	in												
						Probe # / Length	SAMP-HP-0036	/ 96	in												
Nozzle Measurements					Liner Material	glass															
Pre	0.222	0.223	0.222	PASS	Sample Case / Oven #	SAMP-BH-0009															
Post	0.222	0.223	0.222	PASS	Impinger Case #	SAMP-BC-0015															
Run Time					Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8				Pressures				
Start	0:43	End	3:00		Pre	729.30	781.30	744.20	723.20	762.30	781.30	730.20	963.90	Wash	H ₂ O	50.0	ml	Barometric Pressure	(P _b)	29.57	in Hg
					Post	828.60	799.10	746.50	723.30	762.00	781.10	730.30	982.30	Volume	MeCl	ml		Stack Static Pressure	(P _{static})	-0.23	in H ₂ O
																	Absolute Stack Pressure	(P _s)	29.55	in Hg	
																	Absolute Meter Pressure	(P _m)	29.69	in Hg	
																	Filter #	M-1954			
Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (Δp ^{1/2})	Local Stack Velocity (v _s)	Cumulative Meter Volume (V _m) _{std}	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}		
	min	hh:mm:ss	ft3	in H ₂ O	in H ₂ O	in H ₂ O	oF	oF	oF	oF	oF	oF	oF	in Hg	(in H ₂ O) ^{1/2}	ft/sec	scf	%	scf		
A-1	0.0	0:00:00	184.550	0.720	0.765	0.770	337	232	263	60	224	99	99	5.0	0.85	60.53	5.693	118.5	68.320		
A-2	10.0	0:10:00	190.595	0.690	0.733	0.730	338	255	254	43	227	100	100	7.5	0.83	59.29	10.929	115.1	65.577		
A-3	20.0	0:20:00	196.165	0.760	0.808	0.810	338	255	252	45	229	101	101	12.5	0.87	62.23	15.815	110.2	63.259		
A-4	30.0	0:30:00	201.370	0.610	0.648	0.650	339	257	247	51	226	101	101	16.5	0.78	55.78	20.135	107.5	60.405		
A-5	40.0	0:40:00	205.975	0.510	0.542	0.540	340	264	249	54	225	100	100	18.0	0.71	51.04	22.724	102.6	54.537		
A-6	50.0	0:50:00	208.730	0.510	0.542	0.540	342	253	253	58	223	99	99	22.0	0.71	51.10	23.110	101.0	46.219		
B-1	60.0	1:00:00	209.140	0.510	0.542	0.540	342	249	247	59	224	99	99	22.0	0.71	51.10	23.445	99.7	40.191		
B-2	70.0	1:10:00	209.496	0.710	0.755	0.750	346	237	251	61	227	99	99	22.0	0.84	60.45	23.480	99.6	35.219		
B-3	80.0	1:20:00	209.533	1.000	1.063	1.100	344	225	252	61	229	99	99	22.0	1.00	71.65	23.755	98.5	31.673		
B-4	90.0	1:30:00	209.825	2.500	2.657	2.700	343	239	255	61	228	99	99	22.0	1.58	113.21	24.029	97.4	28.835		
B-5	100.0	1:40:00	210.115	3.500	3.720	3.700	343	242	254	63	227	99	99	22.0	1.87	133.96	24.214	96.7	26.416		
B-6	110.0	1:50:00	210.310	3.300	3.508	3.500	344	243	256	65	224	99	99	22.0	1.82	130.15	24.484	95.6	24.484		
Last Pt	120.0	2:00:00	210.595																		
Final Val	120.0	2:00:00	210.595											Max Vac	22.0	Final Values	24.484	95.6			
Average Values				1.277		1.361	341	246	253	57	226	100	100		1.05	75.04					
														100							

ONTARIO HYDRO - SAMPLE RECOVERY AND INTEGRITY DATA SHEET					
--	--	--	--	--	--

Plant Name	Fibrominn Biomass Power Plant			Date	07/05/07
Sampling Location	SDA Inlet			Project #	snc-07-benson.mn-comp#1
Operator	TP			Acetone Lot Number	C38B11

Run History Data				
Run Number	IN-OHM-1	IN-OHM-2	IN-OHM-3	
Run Start Time	18:02	21:12	0:43	(hh:mm)
Run Stop Time	20:20	23:30	3:00	(hh:mm)
Train Prepared By	KV/SK	KV/SK	KV/SK	
Train Recovered By	KV/SK	KV/SK	KV/SK	
Recovery Date	7/5/2007	7/5/2007	7/5/2007	(mm/dd/yy)
Relinquished By	TG	TG	TG	
Received By	PS	PS	PS	
Relinquished Date	7/6/2007	7/6/2007	7/6/2007	(mm/dd/yy)
Relinquished Time	12:00	12:00	12:00	(hh:mm)

Equipment Identification Numbers			
Filter	M-1976	M-1915	M-1954
Acetone Wash	ok	ok	ok
Silica Gel	ok	ok	ok
Impinger Case	SAMP-BC-0015	SAMP-BC-0021	SAMP-BC-0015
Sample Box	SAMP-BH-0009	SAMP-BH-0009	SAMP-BH-0009
Oven	ok	ok	ok

Sample Blank Taken YES

Moisture Content Data					
Impingers 1, 2, 3, 4, 5, 6 and 7 - Liquid Volume					
Final Volume	(V _f)	5373.6	5387.4	5380.6	ml
Initial Volume	(V _i)	5216.3	5194.5	5261.3	ml
Net Volume	(V _n)	157.3	192.9	119.3	ml
Comments					
Impinger 8 - Silica Gel Weight					
Final Weight	(W _f)	943.9	921.9	982.3	g
Initial Weight	(W _i)	933.8	909.2	963.9	g
Net Weight	(W _n)	10.1	12.7	18.4	g
Comments					
Total Water Collected					
Total Volume	(V _{tc})	167.4	205.7	137.7	ml

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

L_{fw} = distance to far wall of stack (in.)

L_{nw} = distance to near wall of stack (in.) [reference]

D = diameter of stack (in.)

A_s = area of stack (ft^2)

B = distance downstream (in.)

B_D = stack diameters downstream (dia.)

A = distance upstream (in.)

A_D = stack diameters upstream (dia.)

Area of Stack (ft^2)

$$A_s (\text{ft}^2) = \pi \times \left(\frac{D}{2 \times 12} \right)^2$$

$$A_s (\text{ft}^2) = 3.14 \times \left(\frac{129.0 \text{ in.}}{2 \times 12 \text{ in./ft}} \right)^2 = 90.76 \text{ ft}^2$$

Diameter of Stack (in.)

$$D (\text{in.}) = L_{fw} - L_{nw}$$

$$D (\text{in.}) = 136 \text{ in.} - 7 \text{ in.} = 129 \text{ in.}$$

Stack Diameters Downstream

$$B_D (\text{dia.}) = \frac{B}{D}$$

$$B_D (\text{dia.}) = \frac{1222 \text{ in.}}{129 \text{ in.}} = 9.47 \text{ diameters}$$



Stack Diameters Upstream

$$A_D (\text{dia.}) = \frac{A}{D}$$

$$A_D (\text{dia.}) = \frac{350 \text{ in.}}{129 \text{ in.}} = 2.71 \text{ diameters}$$

Number of Traverse Points

Based on 40 CFR Part 60, Appendix A, Method 1, Section 2.2



Traverse Point Locations

Based on 40 CFR Part 60, Appendix A, Method 1, Section 2.3

Traverse Point	Location of Traverse Points in Circular Stacks (Fraction of Stack Dimension from Inside Wall to Traverse Point)											
	2	4	6	8	10	12	14	16	18	20	22	24
1	.146	.067	.044	.032	.026	.021	.018	.016	.014	.013	.011	.011
2	.854	.250	.146	.105	.082	.067	.057	.049	.044	.039	.035	.032
3	.750	.296	.194	.146	.118	.098	.085	.075	.067	.060	.056	.055
4	.933	.704	.323	.226	.177	.146	.125	.109	.097	.087	.079	.079
5	.854	.677	.342	.250	.201	.169	.146	.129	.116	.116	.105	.105
6	.956	.806	.658	.566	.466	.366	.283	.236	.204	.180	.161	.132
7	.896	.774	.644	.566	.486	.406	.326	.256	.204	.180	.161	.132
8	.968	.854	.750	.634	.535	.436	.336	.250	.218	.194	.174	.144
9	.918	.823	.731	.625	.532	.432	.332	.250	.218	.194	.174	.144
10	.974	.882	.799	.717	.618	.518	.418	.318	.288	.251	.227	.197
11	.933	.854	.760	.674	.574	.474	.374	.274	.241	.209	.183	.153
12	.979	.901	.831	.764	.694	.624	.554	.484	.451	.417	.383	.323
13	.943	.875	.812	.750	.685	.620	.550	.480	.447	.412	.377	.323
14	.962	.915	.854	.796	.736	.677	.617	.557	.524	.491	.452	.393
15	.951	.891	.835	.782	.728	.670	.610	.550	.517	.484	.445	.385
16	.964	.925	.871	.820	.770	.710	.650	.590	.557	.524	.484	.445
17	.956	.903	.854	.804	.754	.704	.644	.584	.551	.517	.484	.445
18	.968	.933	.884	.834	.784	.734	.674	.614	.581	.547	.514	.474
19	.961	.918	.868	.818	.768	.718	.658	.608	.575	.541	.508	.468
20	.987	.940	.895	.845	.795	.745	.685	.635	.602	.568	.535	.495
21	.965	.921	.871	.821	.771	.721	.661	.611	.578	.544	.511	.471
22	.969	.945	.895	.845	.795	.745	.685	.635	.602	.568	.535	.495
23	.968	.968	.928	.878	.828	.778	.718	.668	.635	.592	.559	.519
24	.969	.969	.929	.879	.829	.779	.719	.669	.636	.593	.560	.520

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2)

P_b = barometric pressure (in. Hg)
 P_{static} = static pressure (in. H₂O)
 P_s = absolute stack pressure (in. Hg)
%N₂ = nitrogen concentration (%)
%CO₂ = carbon dioxide concentration (%)
%O₂ = oxygen concentration (%)
%CO = carbon monoxide concentration (%)
MW = molecular weight (lb/lb-mole)
B_{ws} = stack moisture content (%)
M_d = stack dry molecular weight (lb/lb-mole)
M_s = stack wet molecular weight (lb/lb-mole)
T_{std} = standard temperature, 68°F, 528°R
P_{std} = standard pressure, 29.92 in. Hg
v_{sl} = local velocity (ft/sec)
v_s = average stack gas velocity (ft/sec)
Q_{sd} = average stack dry standard flow rate (dscf/hr)
Q_{aw} = average stack wet flow rate (ascf/min)

C_p = pitot tube coefficient
Δp = velocity head (in. H₂O)
A_s = area of stack (ft²)
N_a = null angle (deg.)
t_s = stack temperature (°F)
T_u = temperature offset, 460°R
K_p = pitot tube constant,
85.49 (ft/sec)((lb/lb-mole)(in. Hg)/(°R)(in. Hg))^{1/2}

Absolute Stack Pressure (in. Hg)

$$P_s (\text{in. Hg}) = P_b + \frac{P_{\text{static}}}{13.6}$$

$$P_s (\text{in. Hg}) = 29.92 \text{ in. Hg} + \frac{-0.23 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 29.90 \text{ in. Hg}$$

Nitrogen Concentration (%)

$$\% N_2 = 100 - \% CO_2 - \% O_2 - \% CO$$

$$\% N_2 (\%) = 100 - 14.39 \% - 4.83 \% - 0 \% = 80.78 \%$$

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d (\text{lb / lb - mol}) = \sum \left(\frac{MW_{\text{comp}}}{100} \times \% \text{ component} \right)$$

$$M_d (\text{lb/lb-mol}) = \left[\frac{44 \text{ lb/lb-mol}}{100} \times 14.39 \% \right] + \left[\frac{32 \text{ lb/lb-mol}}{100} \times 4.83 \% \right] + \text{etc.} = \frac{30.5 \text{ lb}}{\text{lb-mol}}$$

Stack Wet Molecular Weight (lb/lb-mole)

$$M_s (\text{lb / lb - mol}) = \left[M_d \times \left(1 - \frac{B_{ws}}{100} \right) \right] + \left[MW_{H_2O} \times \frac{B_{ws}}{100} \right]$$

$$M_s (\text{lb/lb-mol}) = \left[\frac{30.5 \text{ lb}}{\text{lb-mol}} \times \left(1 - \frac{30 \%}{100} \right) \right] + \left[\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{30 \%}{100} \right] = \frac{26.75 \text{ lb}}{\text{lb-mol}}$$

Local Velocity (ft/sec)

$$v_{sl(l)} (\text{ft / sec}) = K_p \times C_p \times \sqrt{\Delta p} \times \sqrt{\frac{t_s + T_u}{P_s \times M_s}}$$

$$v_{sl} (\text{ft/sec}) = \frac{85.49 \text{ ft}}{\text{sec}} \left[\frac{(\text{lb/lb-mol})(\text{in. Hg})}{(\text{°R})(\text{in. H}_2\text{O})} \right]^{1/2} \times 0.84 \times \sqrt{2.10 \text{ in. H}_2\text{O}} \times \sqrt{\frac{219 + 460 \text{ °R}}{29.9 \text{ in. Hg} \times 26.75 \text{ lb/lb-mol}}} = \frac{95.88 \text{ ft}}{\text{sec}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2)

P_b = barometric pressure (in. Hg)
 P_{static} = static pressure (in. H₂O)
 P_s = absolute stack pressure (in. Hg)
%N₂ = nitrogen concentration (%)
%CO₂ = carbon dioxide concentration (%)
%O₂ = oxygen concentration (%)
%CO = carbon monoxide concentration (%)
MW = molecular weight (lb/lb-mole)
B_{ws} = stack moisture content (%)
M_d = stack dry molecular weight (lb/lb-mole)
M_s = stack wet molecular weight (lb/lb-mole)
K_p = pitot tube constant,

$$85.49 \text{ (ft/sec)}(((\text{lb/lb-mole})(\text{in. Hg}))(({}^{\circ}\text{R})(\text{in. Hg})))^{1/2}$$

T_{STD} = standard temperature, 68°F

P_{STD} = standard pressure, 29.92 in. Hg

v_{sl} = local velocity (ft/sec)

v_s = average stack gas velocity (ft/sec)

Q_{SD} = average stack dry standard flow rate (dscfh)

Q_{AW} = average stack wet flow rate (ascf/min)

C_p = pitot tube coefficient

Δp = velocity head (in. H₂O)

A_s = area of stack (ft²)

N_A = null angle (deg.)

t_s = stack temperature (°F)

T_u = temperature offset, 460°R

Average Stack Gas Velocity (ft/sec)

$$v_s (\text{ft/sec}) = K_p \times C_p \times \left(\sqrt{\Delta p} \right)_{\text{avg}} \times \sqrt{\frac{(t_s)_{\text{avg}} + T_u}{P_s \times M_s}}$$

$$v_{\text{sl}} (\text{ft/sec}) = \frac{85.49 \text{ ft}}{\text{sec}} \left[\frac{(\text{lb/lb-mol})(\text{in. Hg})}{({}^{\circ}\text{R})(\text{in. H}_2\text{O})} \right] \times 0.84 \times 1.45 \text{ in. H}_2\text{O}^{1/2} \times \sqrt{\frac{203 + 460 {}^{\circ}\text{R}}{29.9 \text{ in. Hg} \times 26.75 \text{ lb/lb-mol}}} = \frac{94.8 \text{ ft}}{\text{sec}}$$

Average Stack Dry Standard Flow Rate (dscfh)

$$Q_{\text{sd}} (\text{dscfh}) = \frac{60 \times 60 \times \left(1 - \frac{B_{\text{ws}}}{100} \right) \times v_s \times A_s \times T_{\text{std}} \times P_s}{(t_s + T_u) \times P_{\text{std}}}$$

$$Q_{\text{sd}} (\text{dscfh}) = \frac{3600 \text{ sec}}{\text{hr}} \times \left[1 - \frac{30.0 \%}{100} \right] \times \frac{94.80 \text{ ft}}{\text{sec}} \times 90.76 \text{ ft}^2 \times \frac{68 + 460 {}^{\circ}\text{R}}{203 + 460 {}^{\circ}\text{R}} \times \frac{29.90 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{17,271,132 \text{ dscf}}{\text{hr}}$$

Average Stack Wet Flow Rate (acf m)

$$Q_{\text{aw}} (\text{acf m}) = 60 \times v_s \times A_s$$

$$Q_{\text{aw}} (\text{acf/min}) = \frac{60 \text{ sec}}{\text{min}} \times \frac{94.80 \text{ ft}}{\text{sec}} \times 90.76 \text{ ft}^2 = \frac{516,261 \text{ acf}}{\text{min}}$$

Average Stack Wet Standard Flow Rate (ascfh)

$$Q_{\text{sw}} (\text{ascfh}) = \frac{60 \times Q_{\text{aw}} \times T_{\text{std}} \times P_s}{(t_s + T_u) \times P_{\text{std}}}$$

$$Q_{\text{sw}} (\text{ascf/hr}) = \frac{60 \text{ min}}{\text{hr}} \times \frac{516,261 \text{ acf}}{\text{min}} \times \frac{68 + 460 {}^{\circ}\text{R}}{203 + 460 {}^{\circ}\text{R}} \times \frac{29.90 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{24,673,046 \text{ ascf}}{\text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 3a)

$\%N_2$ = nitrogen concentration (%)
 $\%CO_2$ = carbon dioxide concentration (%)
 $\%O_2$ = oxygen concentration (%)
 $ppmCO$ = carbon monoxide concentration (ppm)
 $\%CO$ = carbon monoxide concentration (%)
 M_d = stack dry molecular weight (lb/lb-mole)
 $(F_o)_{avg}$ = average calculated fuel factor
 $(\%EA)_{avg}$ = average excess air (%)

Carbon Monoxide Concentration (%)

$$\% CO = \frac{ppmCO}{10,000}$$

$$\% CO (\%) = \frac{100.00 \text{ ppm}}{10,000 \text{ ppm/\%}} = 1.0E-02 \text{ \%}$$

Nitrogen Concentration (%)

$$\% N_2 = 100 - \% CO_2 - \% O_2 - \% CO$$

$$\% N_2 (\%) = 100 - 14 \% - 5 \% - 0.01 \% = 80.99 \%$$

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d (\text{lb / lb - mol}) = \sum \left(\frac{MW_{comp}}{100} \times \% \text{ component} \right)$$

$$M_d (\text{lb/lb-mol}) = \left[\frac{44 \text{ lb/lb-mol}}{100} \times 14 \% \right] + \left[\frac{32 \text{ lb/lb-mol}}{100} \times 5 \% \right] + \text{etc.} = \frac{30.44 \text{ lb}}{\text{lb-mol}}$$

Average Calculated Fuel Factor

$$F_{o(avg)} = \frac{|20.9 - (\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})|}{(\% CO_2)_{avg} + (\% CO)_{avg}}$$

$$F_{o(avg)} = \frac{20.9 \% - 5 \% - [0.5 \times 0.01 \%]}{14 \% + 0.01 \%} = 1.135$$

Average Excess Air (%)

$$\% EA_{avg} (\%) = \frac{100 \times [(\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})]}{(0.264 \times (N_2)_{avg}) - [(\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})]}$$

$$(\% EA)_{AVG} = \frac{100 \times \{ 5 \% - [0.5 \times 0.01 \%] \}}{\{ 0.264 \times 80.99 \% \} - \{ 5 \% - [0.5 \times 0.01 \%] \}} = 30.5 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4)

V_{mf} = final dry gas meter reading (dcf)

V_{mi} = initial dry gas meter reading (dcf)

V_m = total meter volume (dcf)

$t_{m(\text{avg})}$ = average meter temp. ($^{\circ}\text{F}$)

$t_{s(\text{avg})}$ = average stack temp. ($^{\circ}\text{F}$)

P_b = barometric pressure (in. Hg)

P_{static} = static pressure (in. H_2O)

ΔH_{avg} = average orifice pressure (in. H_2O)

V_i = initial impinger volume (ml)

V_f = final impinger volume (ml)

W_i = initial impinger weight (g)

W_f = final impinger weight (g)

V_t = total impinger volume (ml) = $\Sigma(V_f - V_i)$

W_t = total impinger weight (g) = $\Sigma(W_f - W_i)$

K_5 = water mass to std water vapor, 0.04715 ft^3/g

K_1 = standard volume correction, 17.65 $^{\circ}\text{R}/\text{in. Hg}$

Y = meter calibration factor

T_u = absolute temperature offset, 460 $^{\circ}\text{R}$

B_{ws} = final moisture content (%) = min of $B_{ws(\text{calc})}$ and $B_{ws(\text{svp})}$

Water Volume Weighed (dscf)

$$V_{wsg(\text{std})} (\text{dscf}) = W_t \times K_5$$

$$V_{wsg(\text{std})} = 167.10 \text{ g} \times 0.04715 \text{ ft}^3/\text{g} = 7.879 \text{ dscf}$$

Standard Meter Volume (dscf)

$$V_{m(\text{std})} (\text{dscf}) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{\text{avg}}}{13.6} \right)}{(t_{m(\text{avg})} + T_u)}$$

$$V_{m(\text{std})} = \frac{\frac{17.65 \text{ } ^{\circ}\text{R}}{\text{in. Hg}} \times 1.01 \times 38.986 \text{ dcf} \times \left[29.53 \text{ in. Hg} + \frac{2.09 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O / in. Hg}} \right]}{105 \text{ } ^{\circ}\text{F} + 460 \text{ } ^{\circ}\text{R}} = 36.43 \text{ dscf}$$

Calculated Moisture Content (%)

$$B_{ws(\text{calc})} (\%) = 100 \times \frac{V_{wsg(\text{std})}}{V_{wsg(\text{std})} + V_{m(\text{std})}}$$

$$B_{ws(\text{calc})} = 100 \times \frac{7.878765 \text{ dscf}}{7.878765 \text{ dscf} + 36.42751 \text{ dscf}} = 17.7825 \%$$

Saturated Moisture Content (%)

$$B_{ws(\text{svp})} (\%) = 100 \times \frac{10 \frac{3144}{t_{s(\text{avg})} + 390.86}}{P_b + \frac{P_{\text{static}}}{13.6}} \leq 100$$

$$B_{ws(\text{svp})} = 100 \times \frac{10 \left[\frac{3144}{339 \text{ } ^{\circ}\text{F} + 390.86} - \frac{6.691}{29.53 \text{ in. Hg} + \frac{-0.23 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O / in. Hg}}} \right]}{\leq 100 = 100 \%}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling)

C_n = nozzle diameter constant, 0.03575

Q_m = estimated orifice flow rate, 0.750 acfm

else V_m/Θ from previous run

V_m = total meter volume (acf)

Θ = total sampling time (min)

t_m = average gas meter temperature ($^{\circ}$ F)

T_u = absolute temperature offset, 460 $^{\circ}$ R

C_p = pitot tube coefficient

B_{wm} = meter moisture content (%)

B_{ws} = stack moisture content (%)

t_s = average stack temperature ($^{\circ}$ F)

M_d = stack dry molecular weight (lb/lb-mole)

P_s = absolute stack pressure (in. Hg)

C_k = K Factor Constant, 849.8

Δp_{avg} = average pitot tube differential pressure (in. H₂O)

$\Delta H@ = DH @ 0.75 \text{ SCFM (in. H}_2\text{O)}$

D_{na} = actual nozzle diameter (in.)

Δp = velocity head (in. H₂O)

Desired Orifice (in. H₂O)

$$\Delta H_d (\text{in. H}_2\text{O}) = K \times \Delta p$$

$$\Delta H_d (\text{in. H}_2\text{O}) = 2.03 \times 0.76 \text{ in. H}_2\text{O} = 1.544 \text{ in. H}_2\text{O}$$

Absolute Meter Pressure (in. Hg)

$$P_m (\text{in. Hg}) = P_b + \frac{\Delta H @}{13.6}$$

$$P_m (\text{in. Hg}) = 29.53 \text{ in. Hg} + \frac{1.67 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 29.65 \text{ in. Hg}$$

Recommended Nozzle Diameter (in.)

$$D_{ni} (\text{in.}) = \sqrt{\frac{C_n \times Q_m \times P_m}{(t_m + T_u) \times C_p} \times \left(\frac{1 - \frac{B_{wm}}{100}}{1 - \frac{B_{ws}}{100}} \right) \times \sqrt{(t_s + T_u) \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + (18 \times B_{ws})}{P_s \times \Delta p_{avg}} \right]}}$$

$$D_{ni} (\text{in.}) = \frac{0.03575 \text{ (lb-mole}^{\circ}\text{R} \cdot \text{in. H}_2\text{O})^{1/2} \cdot \text{min} \cdot \text{in.}^2}{\text{acf} \cdot \text{in. Hg}^{3/4} \cdot \text{lb}^{1/2}} \times 0.75 \text{ acf} \times 29.65 \text{ in. Hg} \times \frac{0.0}{\left(81 \text{ }^{\circ}\text{F} + 460 \text{ }^{\circ}\text{R} \right) \times 0.84} \times \frac{0.0}{\left(1 - \frac{0.0}{100} \right)} \times \frac{0.0}{\left(1 - \frac{25.0}{100} \right)}$$

$$D_{ni} (\text{in.}) = \frac{0.0}{\left(203 \text{ }^{\circ}\text{F} + 460 \text{ }^{\circ}\text{R} \right) \times \frac{30.44 \text{ lb}}{\text{lb-mole}} \times \frac{0.0}{29.51 \text{ in. Hg}} \times \frac{0.0}{1.45} \times \frac{0.0}{\left(1 - \frac{25.0}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{25.0}{100} \right)}} = 0.219 \text{ in.}$$

DP to DH Isokinetic Factor

$$K = C_k \times C_p^2 \times \Delta H @ \times D_{na}^4 \times \left[\frac{M_d \times \left(1 - \frac{B_{wm}}{100} \right) + (18 \times \frac{B_{wm}}{100})}{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + (18 \times \frac{B_{ws}}{100})} \right] \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{wm}}{100}} \right)^2 \times \left(\frac{t_m + T_u}{t_s + T_u} \right) \times \frac{P_s}{P_m}$$

$$K = \frac{849.8}{\text{in. H}_2\text{O} \cdot \text{in.}^4} \times 0.84^2 \times 1.67 \text{ in. H}_2\text{O} \times 0.251333^4 \times \frac{0.0}{\left(1 - \frac{25.0}{100} \right)^2} \times \frac{0.0}{\left(1 - \frac{0.0}{100} \right)} \times \frac{0.0}{\left(\frac{81 \text{ }^{\circ}\text{F} + 460 \text{ }^{\circ}\text{R}}{203 \text{ }^{\circ}\text{F} + 460 \text{ }^{\circ}\text{R}} \right)} \times$$

$$\left(\frac{30.44 \text{ lb}}{\text{lb/mole}} \times \frac{0.0}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0.0}{100} \right) \times \frac{0.0}{\left(1 - \frac{0.0}{100} \right)} \times \frac{0.0}{\left(1 - \frac{25.0}{100} \right)} \times \frac{0.0}{\left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{25.0}{100} \right)} \times \frac{29.51 \text{ in. Hg}}{29.65 \text{ in. Hg}} = 2.03$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 29, Run 1)

Mercury Emissions Rate (lb/hr)

$$E' \text{ (lb / hr)} = \frac{M_n \times Q_{sd}}{V_{m(std)}} \times \frac{60}{453.592 \times 1000}$$

$$E' \text{ (lb/hr)} = \frac{\text{g}}{1000 \text{ mg}} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{\text{lb}}{453.592 \text{ g}} \times \frac{0.00052 \text{ mg}}{36.32 \text{ dscf}} \times \frac{190,931 \text{ dscf}}{\text{min}} = \frac{0.00036 \text{ lb}}{\text{hr}}$$

Mercury Emissions Rate (ton/yr)

$$E'' \text{ (ton / yr)} = E' \times \frac{8760}{2000}$$

$$E'' \text{ (ton/yr)} = \frac{\text{ton}}{2000 \text{ lb}} \times \frac{8760 \text{ hr}}{\text{yr}} \times \frac{0.00036 \text{ lb}}{\text{hr}} = \frac{0.00157 \text{ ton}}{\text{yr}}$$

Mercury Emissions Rate (lb/MMBtu)

$$E''' \text{ (lb / MMBtu)} = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{100}{\% CO_2} \right)$$

$$E''' \text{ (lb/MMBtu)} = \frac{\text{g}}{1000 \text{ mg}} \times \frac{\text{lb}}{453.592 \text{ g}} \times \frac{0.00052 \text{ mg}}{36.32 \text{ dscf}} \times \frac{1,890 \text{ dscf (CO}_2\text{)}}{\text{MMBtu}} \times \left(\frac{100\%}{14.0 \%} \right) = \frac{4.23E-07 \text{ lb}}{\text{MMBtu}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Outlet Hg Emissions Data

ONTARIO HYDRO - RESULTS

Plant Name	Fibrominn Biomass Power Plant	Date	07/05/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TP	Stack Type	Circular

Historical Data						
Run Number		OUT-OHM-1	OUT-OHM-2	OUT-OHM-3	Average	
Run Start Time		18:02	21:12	0:43		hh:mm
Run Stop Time		22:10	23:22	2:55		hh:mm
Meter Calibration Factor (Y)	1.005	1.005	1.005			
Pitot Tube Coefficient (C_p)	0.840	0.840	0.840			
Average Nozzle Diameter (D_{na})	0.174	0.176	0.174			in
Stack Test Data						
Initial Meter Volume (V_m) _i	707.020	757.850	813.500			ft3
Final Meter Volume (V_m) _f	757.110	812.030	863.450			ft3
Total Meter Volume (V_m)	50.090	54.180	49.950	51.407		ft3
Total Sampling Time (Θ)	120.0	120.0	120.0	120.0		min
Average Meter Temperature (t_m) _{avg}	82.0	81.1	77.4	80.2		oF
Average Stack Temperature (t_s) _{avg}	297.8	302.2	297.6	299.2		oF
Barometric Pressure (P_b)	29.53	29.52	29.57	29.54		in Hg
Stack Static Pressure (P_{static})	-0.23	-0.23	-0.23	-0.23		in H2O
Absolute Stack Pressure (P_s)	29.51	29.50	29.55	29.52		in Hg
Average Orifice Pressure Drop (ΔH) _{avg}	0.58	0.67	0.58	0.61		in H2O
Absolute Meter Pressure (P_m)	29.66	29.65	29.70	29.67		in Hg
Avg Square Root Pitot Pressure ($\Delta p^{1/2}$) _{avg}	1.13	1.19	1.13	1.15		(in H2O) ^{1/2}
Moisture Content Data						
Impingers 1-3 Water Volume Gain (V_n)	299.9	374.2	329.3	334.5		ml
Impinger 4 Silica Gel Weight Gain (W_n)	11.9	14.8	9.3	12.0		g
Total Water Volume Collected (V_c)	311.9	389.0	338.6	346.5		ml
Standard Water Vapor Volume (V_w) _{std}	14.679	18.310	15.938	16.309		scf
Standard Meter Volume (V_m) _{std}	48.469	52.518	48.814	49.933		dscf
Calculated Stack Moisture ($B_{ws(cal)}$)	23.24	25.85	24.61	24.57		%
Saturated Stack Moisture ($B_{ws(svp)}$)	100.0	100.0	100.0	100.0		%
Reported Stack Moisture Content (B_{ws})	23.24	25.85	24.61	24.57		%
Gas Analysis Data						
Carbon Dioxide Percentage (%CO ₂)	14.0	14.0	14.0	14.0		%
Oxygen Percentage (%O ₂)	5.0	5.0	5.0	5.0		%
Carbon Monoxide Percentage (%CO)	0.0	0.0	0.0	0.0		%
Nitrogen Percentage (%N ₂)	81.0	81.0	81.0	81.0		%
Dry Gas Molecular Weight (M_d)	30.44	30.44	30.44	30.44		lb/lb-mole
Wet Stack Gas Molecular Weight (M_s)	27.55	27.22	27.38	27.38		lb/lb-mole
Calculated Fuel Factor (F_o)	1.135	1.135	1.135	1.135		
Fuel F-Factor (F_c)	1890	1890	1890	1890		dscf/MMBtu
Percent Excess Air (%EA)	30.5	30.5	30.5	30.5		%
Volumetric Flow Rate Data						
Average Stack Gas Velocity (v_s)	78.83	83.31	78.89	80.34		ft/sec
Stack Cross-Sectional Area (A_s)	63.62	63.62	63.62	63.62		ft ²
Actual Stack Flow Rate (Q_{aw})	300,898	317,986	301,116	306,667		acfm
Wet Standard Stack Flow Rate (Q_{sw})	12,407	13,033	12,437	12,626		wkscfh
Dry Standard Stack Flow Rate (Q_{sd})	158,727	161,063	156,271	158,687		dscfm
Percent of Isokinetic Rate (I)	100.3	101.3	100.7	100.8		%
Emission Rate Data						
Total Mass of Hg	(part. bound)	0.00000	0.00000	0.00000	0.00000	mg
	(oxidized)	0.00000	0.00000	0.00000	0.00000	mg
	(elemental)	0.00000	0.00000	0.00000	0.00000	mg
	(all forms)	0.00000	0.00000	0.00000	0.00000	mg
Emission Rate of Hg	(part. bound)	0.00000	0.00000	0.00000	0.00000	lbs/hr
	(oxidized)	0.00000	0.00000	0.00000	0.00000	lbs/hr
	(elemental)	0.00000	0.00000	0.00000	0.00000	lbs/hr
	(all forms)	0.00000	0.00000	0.00000	0.00000	lbs/hr
Emission Rate of Hg	(part. bound)	0.00000	0.00000	0.00000	0.00000	tons/yr
	(oxidized)	0.00000	0.00000	0.00000	0.00000	tons/yr
	(elemental)	0.00000	0.00000	0.00000	0.00000	tons/yr
	(all forms)	0.00000	0.00000	0.00000	0.00000	tons/yr
Emission Rate of Hg	(part. bound)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	lbs/MMBtu
	(oxidized)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	lbs/MMBtu
	(elemental)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	lbs/MMBtu
	(all forms)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	lbs/MMBtu

Note: Results reported below practical quantitation limit (BPQL) set to non-detect (ND) for calculations.



Air Hygiene International, Inc.
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
(888) 461-8778
www.airhygiene.com

MERCURY ANALYSIS DATASHEET

Paramter	Units	Run 1				
		Particle Bound Hg		Oxidized Hg	Elemental Hg	
		Filter	Probe Wash	KCl (Imp 1-3)	HNO ₃ -H ₂ O ₂ (Imp 4)	KMNO ₄ (Imp 5-7)
Sample		OUT-OHM-1-CON1	OUT-OHM-1-CON2	OUT-OHM-1-CON3	OUT-OHM-1-CON4	OUT-OHM-1-CON5
Log Number		20073704	20073720	20073721	20073722	20073723
Solids PQL	µg	0.007				
Ash Hg Content Weight	µg	0.000				
Liquid Results	mg/L		0.000000	0.000000	0.000000	0.000000
Liquids PQL	mg/L		0.00140	0.00014	0.00140	0.00014
Sample Volume	mL		235	645	145	380
Dry Std. Stack Flow Rate (Q _{sd})	dscfm			158,727		
DGM Volume	dscf			48.469		
DGM Volume	dscm			1.37		
Carbon Dioxide Concentration	%			14.00		
Total Hg (ea. form)	mg		0.0000	0.0000	0.0000	
Total Hg				0.0000		
Hg (ea. form)	lb/MMBtu		0.00E+00	0.00E+00	0.00E+00	
Hg				0.00E+00		
Hg (ea. form)	lb/hr		0.0000	0.0000	0.0000	
Hg				0.0000		
Hg (ea. form)	ton/yr		0.0000	0.0000	0.0000	
Hg				0.0000		

Paramter	Units	Run 2				
		Particle Bound Hg		Oxidized Hg	Elemental Hg	
		Filter	Probe Wash	KCl (Imp 1-3)	HNO ₃ -H ₂ O ₂ (Imp 4)	KMNO ₄ (Imp 5-7)
Sample		OUT-OHM-2-CON1	OUT-OHM-2-CON2	OUT-OHM-2-CON3	OUT-OHM-2-CON4	OUT-OHM-2-CON5
Log Number		20073705	20073724	20073725	20073726	20073727
Solids PQL	µg	0.007				
Ash Sample Weight	µg	0.000				
Liquid Results	mg/L		0.000000	0.000000	0.000000	0.000000
Liquids PQL	mg/L		0.00140	0.00014	0.00140	0.00014
Sample Volume	mL		150	645	130	380
Dry Std. Stack Flow Rate (Q _{sd})	dscfm			161,063		
DGM Volume	dscf			52.518		
DGM Volume	dscm			1.49		
Carbon Dioxide Concentration	%			14.00		
Total Hg (ea. form)	mg		0.0000	0.0000	0.0000	
Total Hg				0.0000		
Hg (ea. form)	lb/MMBtu		0.00E+00	0.00E+00	0.00E+00	
Hg				0.00E+00		
Hg (ea. form)	lb/hr		0.0000	0.0000	0.0000	
Hg				0.0000		
Hg (ea. form)	ton/yr		0.0000	0.0000	0.0000	
Hg				0.0000		

Paramter	Units	Run 3				
		Particle Bound Hg		Oxidized Hg	Elemental Hg	
		Filter	Probe Wash	KCl (Imp 1-3)	HNO ₃ -H ₂ O ₂ (Imp 4)	KMNO ₄ (Imp 5-7)
Sample		OUT-OHM-3-CON1	OUT-OHM-3-CON2	OUT-OHM-3-CON3	OUT-OHM-3-CON4	OUT-OHM-3-CON5
Log Number		20073706	20073728	20073729	20073730	20073731
Solids PQL	µg	0.007				
Ash Sample Weight	µg	0.000				
Liquid Results	mg/L		0.000000	0.000000	0.000000	0.000000
Liquids PQL	mg/L		0.00140	0.00014	0.00140	0.00014
Sample Volume	mL		190	645	160	380
Dry Std. Stack Flow Rate (Q _{sd})	dscfm			156,271		
DGM Volume	dscf			48.814		
DGM Volume	dscm			1.38		
Carbon Dioxide Concentration	%			14.00		
Total Hg (ea. form)	mg		0.0000	0.0000	0.0000	
Total Hg				0.0000		
Hg (ea. form)	lb/MMBtu		0.00E+00	0.00E+00	0.00E+00	
Hg				0.00E+00		
Hg (ea. form)	lb/hr		0.0000	0.0000	0.0000	
Hg				0.0000		
Hg (ea. form)	ton/yr		0.0000	0.0000	0.0000	
Hg				0.0000		

ONTARIO HYDRO SOURCE SAMPLING TITLE PAGE

Source Information				
Plant Name	Fibrominn Biomass Power Plant			
Sampling Location	Stack Outlet			
Fuel or Source Type	Biomass			
Fuel F-Factor	1890	1890	1890	

Test Information						
Starting Test Date	07/05/07					
Project #	snc-07-benson.mn-comp#1					
Operator	TP					
Standard Temperature	68		oF			
Standard Pressure	29.92		in Hg			
Minimum Required Sample Vol.	Sec 10.1.5	35.3	scf			
Run Duration	Sec 10.1.5	120	minutes			
Unit Number	OUT-OHM					
Load	% or w/DB	100%				
Base Run Number	OUT-OHM					
Number of Ports Available	4					
Number of Ports Used	4					
Port Inside Diameter	5.00		in			
Circular Stack						

Test Equipment Information				
Run		1	2	3
Meter Box Number	from ACS	SAMP-CP-0017	SAMP-CP-0017	SAMP-CP-0017
Meter Calibration Factor	(Y)	1.005	1.005	1.005
Orifice Meter Coefficient	(ΔH@)	1.814	1.814	1.814
Pitot Identification	from ACS	SAMP-HP-0011	SAMP-HP-0034	SAMP-HP-0011
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840
Orsat Identification	from ACS	N/A	N/A	N/A
Nozzle Number	from ACS	#6B-3	#A-1	#6B-3
Nozzle Diameter	(D _n)	0.174	0.176	0.174
Probe Number	from ACS	SAMP-HP-0011	SAMP-HP-0034	SAMP-HP-0011
Probe Length		60.00	60.00	60.00
(SS, Glass) Liner Material	from list	glass	glass	glass
Sample Case / Oven Number	from ACS	SAMP-BH-0013	SAMP-BH-0023	SAMP-BH-0013
Impinger Case Number	from ACS	SAMP-BC-0019	SAMP-BC-0015	SAMP-BC-0019
Acetone Lot Number	from bottle	C38B11	C38B11	C38B11

Testing Company Information				
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)			
Address	5634 S. 122nd East Ave., Suite F			
City, State Country Zip	Tulsa, Oklahoma 74146			
Project Manager	Thomas K. Graham			
Phone Number	(918) 307-8865			
Fax Number	(918) 307-9131			

METHOD 1 - SAMPLE AND VELOCITY TRAVERSSES FOR CIRCULAR SOURCES

Plant Name	Fibrominn Biomass Power Plant		Date	07/05/07
Sampling Location	Stack Outlet		Project #	snc-07-benson.mn-comp#1
Operator	TP		# of Ports Available	4
Stack Type	Circular		# of Ports Used	4
Stack Size	Large		Port Inside Diameter	5.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	129.00	in
Distance to Near Wall of Stack	(L _{nw})	21.00	in
Diameter of Stack	(D)	108.00	in
Area of Stack	(A _s)	63.62	ft ²


Distance from Port to Disturbances			
Distance Upstream	(A)	2358.00	in
Diameters Upstream	(A _D)	21.83	diameters
Distance Downstream	(B)	910.00	in
Diameters Downstream	(B _D)	8.43	diameters

Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of Traverse Points	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²
Upstream Spec		12	12
Downstream Spec		12	12
Traverse Pts Required		12	12

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

² 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

Location of Traverse Points in Circular Stacks										
Traverse		(Fraction of Stack Dimension from Inside Wall to Traverse Point)								
Point		Number of Traverse Points Across the Stack								
Number		2	4	6	8	10	12	14	16	18
1		.146	.067	.044	.032	.026	.021	.018	.016	.014
2		.854	.250	.146	.105	.082	.067	.057	.049	.044
3			.750	.296	.194	.146	.118	.099	.085	.075
4				.933	.704	.323	.226	.177	.146	.125
5					.854	.677	.342	.250	.201	.169
6						.956	.806	.658	.356	.269
7							.895	.774	.644	.366
8								.968	.854	.750
9									.918	.823
10										.731
11										.625
12										.382



Number of Traverse Points Used			
4	Ports by	3	Across
12	Pts Used	12	Required
			Particulate Traverse

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
		in	in
1	0.04	4 6/8	25 6/8
2	0.15	15 6/8	36 6/8
3	0.30	32	53
4			
5			
6			
7			
8			
9			
10			
11			
12			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant Name	Fibrominn Biomass Power Plant			Date	06/30/07	
Sampling Location	Stack Outlet			Project #	snc-07-benson.mn-comp#1	
Operator	TP			# of Ports Used	4	
Stack Type	Circular			Pitot Identification	SAMP-HP-0011	
Pitot Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Pitot Coefficient (C_p)	0.84

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER								
---	--	--	--	--	--	--	--	--

Plant Name	Fibrominn Biomass Power Plant				Date	07/05/07		
Sampling Location	Stack Outlet				Project #	snc-07-benson.mn-comp#1		
Operator	TP				# of Ports Used	4		
Fuel Type	Biomass		Minimum Fuel Factor	1.000		Maximum Fuel Factor	1.120	
Orsat Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Orsat Identification	N/A		

Gas Analysis Data									
Run Number		OUT-OHM-1		Run Start Time		18:02	Run Stop Time		22:10
Sample Analysis Time	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N2)	Dry Molecular Weight (M_d)	Molecular Weight Deviation (ΔM_d)
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole
4:08	14.0	5.0	100.0	14.0	5.0	0.0	81.0	30.44	0.00
Results		Averages	14.0	5.0	0.0	81.0	30.44		
Average Calculated Fuel Factor		(F_o)avg	1.135			Molecular Wt Deviation < 0.3?			<input checked="" type="checkbox"/>
Average Excess Air		(%EA)avg	30.5	percent		Fuel Factor in Handbook Range?			<input checked="" type="checkbox"/>

Gas Analysis Data									
Run Number		OUT-OHM-2		Run Start Time		21:12	Run Stop Time		23:22
Sample Analysis Time	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N2)	Dry Molecular Weight (M_d)	Molecular Weight Deviation (ΔM_d)
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole
2:10	14.0	5.0	100.0	14.0	5.0	0.0	81.0	30.44	0.00
Results		Averages	14.0	5.0	0.0	81.0	30.44		
Average Calculated Fuel Factor		(F_o)avg	1.135			Molecular Wt Deviation < 0.3?			<input checked="" type="checkbox"/>
Average Excess Air		(%EA)avg	30.5	percent		Fuel Factor in Handbook Range?			<input checked="" type="checkbox"/>

Gas Analysis Data									
Run Number		OUT-OHM-3		Run Start Time		0:43	Run Stop Time		2:55
Sample Analysis Time	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO2)	Oxygen Conc. (%O2)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N2)	Dry Molecular Weight (M_d)	Molecular Weight Deviation (ΔM_d)
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole
2:12	14.0	5.0	100.0	14.0	5.0	0.0	81.0	30.44	0.00
Results		Averages	14.0	5.0	0.0	81.0	30.44		
Average Calculated Fuel Factor		(F_o)avg	1.135			Molecular Wt Deviation < 0.3?			<input checked="" type="checkbox"/>
Average Excess Air		(%EA)avg	30.5	percent		Fuel Factor in Handbook Range?			<input checked="" type="checkbox"/>

Fuel Factor Fo		
Fuel Type	Minimum	Maximum
Coal, Anthracite	1.016	1.130
Coal, Lignite	1.016	1.130
Coal, Bituminous	1.083	1.230
Oil, Distillate	1.260	1.413
Oil, Residual	1.210	1.370
Gas, Natural	1.600	1.836
Gas, Propane	1.434	1.586
Gas, Butane	1.405	1.553
Biomass	1.000	1.120
Wood Bark	1.003	1.130

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES							
---	--	--	--	--	--	--	--

Plant Name	Fibrominn Biomass Power Plant				Date	07/05/07	
Sampling Location	Stack Outlet				Project #	snc-07-benson.mn-comp#1	
Operator	TP				# of Ports Used	4	
Stack Type	Circular				Meter Box Number	SAMP-CP-0017	
Train Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Meter Cal Factor (Y)	1.005	

Moisture Content Data							
Run Number	OUT-OHM-1		Run Start Time	18:02		Run Stop Time	
Total Meter Volume	(V _m)	50.090	dcf	Barometric Press.	(P _b)	29.53	in Hg
Avg Stack Temp	(t _s) _{avg}	298	oF	Stack Static Press.	(P _{static})	-0.23	in H ₂ O
Avg Meter Temp	(t _m) _{avg}	82	oF	Avg Orifice Press.	(ΔH) _{avg}	0.58	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents	KCl	KCl	KCl	HNO ₃ -H ₂ O ₂	H ₂ SO ₄ -KMnO ₄	H ₂ SO ₄ -KMnO ₄	H ₂ SO ₄ -KMnO ₄
Final Value	(V _t),(W _t)	961.80	801.70	748.50	696.10	735.20	733.20
Initial Value	(V _i),(W _i)	737.00	732.90	744.10	696.30	734.00	733.40
Net Value	(V _n),(W _n)	224.8	68.8	4.4	-0.2	1.2	-0.2
	Results						
Total Weight	(W _t)	311.30	g	Water Vol Weighed	(V _{wsg(std)})	14.678	scf
Std Meter Volume	(V _{m(std)})	48.471	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws(calc)})	23.2	%	Final Moisture Content	(B _{ws})	23.2	%

Moisture Content Data							
Run Number	OUT-OHM-2		Run Start Time	21:12		Run Stop Time	
Total Meter Volume	(V _m)	54.180	dcf	Barometric Press.	(P _b)	29.52	in Hg
Avg Stack Temp	(t _s) _{avg}	302	oF	Stack Static Press.	(P _{static})	-0.23	in H ₂ O
Avg Meter Temp	(t _m) _{avg}	81	oF	Avg Orifice Press.	(ΔH) _{avg}	0.67	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents	KCl	KCl	KCl	HNO ₃ -H ₂ O ₂	H ₂ SO ₄ -KMnO ₄	H ₂ SO ₄ -KMnO ₄	H ₂ SO ₄ -KMnO ₄
Final Value	(V _t),(W _t)	988.50	867.20	754.70	741.10	765.60	730.40
Initial Value	(V _i),(W _i)	739.80	753.70	750.40	737.80	764.10	729.60
Net Value	(V _n),(W _n)	248.7	113.5	4.3	3.3	1.5	0.8
	Results						
Total Weight	(W _t)	388.30	g	Water Vol Weighed	(V _{wsg(std)})	18.308	scf
Std Meter Volume	(V _{m(std)})	52.511	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	25.9	%	Final Moisture Content	(B _{ws})	25.9	%

Moisture Content Data							
Run Number	OUT-OHM-3		Run Start Time	0:43		Run Stop Time	
Total Meter Volume	(V _m)	49.950	dcf	Barometric Press.	(P _b)	29.57	in Hg
Avg Stack Temp	(t _s) _{avg}	298	oF	Stack Static Press.	(P _{static})	-0.23	in H ₂ O
Avg Meter Temp	(t _m) _{avg}	77	oF	Avg Orifice Press.	(ΔH) _{avg}	0.58	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents	KCl	KCl	KCl	HNO ₃ -H ₂ O ₂	H ₂ SO ₄ -KMnO ₄	H ₂ SO ₄ -KMnO ₄	H ₂ SO ₄ -KMnO ₄
Final Value	(V _t),(W _t)	965.00	831.60	739.00	697.30	739.60	750.40
Initial Value	(V _i),(W _i)	738.50	739.80	733.30	695.20	738.10	750.30
Net Value	(V _n),(W _n)	226.5	91.8	5.7	2.1	1.5	0.1
	Results						
Total Weight	(W _t)	338.00	g	Water Vol Weighed	(V _{wsg(std)})	15.937	scf
Std Meter Volume	(V _{m(std)})	48.813	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	24.6	%	Final Moisture Content	(B _{ws})	24.6	%

ONTARIO HYDRO ISOKINETIC SAMPLING DATA

Plant Name	Fibrominn Biomass Power Plant				Date	7/5/2007				Ideal Nozzle Diameter and IsoKinetic Factor Setup									
Sampling Location	Stack Outlet				Project #	snc-07-benson.mn-comp#1				Pitot Tube Coefficient	(C _p)	0.84							
Operator	TP				Run #	OUT-OHM-1				Avg Stack Temp	(t _s)	291	oF						
# of Points Across	3				# of Ports Used	4				Avg Gas Meter Temp	(t _m)	81							
Leak Checks					Sampling Equipment														
Train	Pre	0.0175	ft3/min @	15	in Hg	Meter #	SAMP-CP-0017												
OK?	<input checked="" type="checkbox"/>	Post	0	ft3/min @	15	in Hg	Meterbox Cal. Factor	(Y)	1.005										
Pitot	Pre	3/4	in. H ₂ O for	15	sec	Nozzle #	#6B-3												
OK?	<input checked="" type="checkbox"/>	Post	4/5	in. H ₂ O for	15	sec	Average Nozzle Diameter	(D _{na})	0.1743	in									
Orsat	OK?	<input checked="" type="checkbox"/>				Rec. Nozzle Diameter	(D _{ri})	0.2454											
Nozzle Measurements					Probe # / Length	SAMP-HP-0011 / 60				Liner Material	glass				Pressures				
Pre	0.174	0.174	0.175	PASS						Sample Case / Oven #	SAMP-BH-0013				Barometric Pressure	(P _b)	29.53	in Hg	
Post	0.174	0.174	0.175	PASS						Impinger Case #	SAMP-BC-0019				Stack Static Pressure	(P _{static})	-0.23	in H ₂ O	
Run Time					Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8		Absolute Stack Pressure	(P _s)	29.51	in Hg	
Start	18:02	End	22:10		Pre	737.00	732.90	744.10	696.30	734.00	733.40	747.30	916.30		Wash	H ₂ O	50.0	ml	
					Post	961.80	801.70	748.50	696.10	735.20	733.20	747.90	928.20		Volume	MeCl		ml	
															Filter #				
																M-1986			
Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (Δp ^{1/2})	Local Stack Velocity (v _s)	Cumulative Meter Volume (V _m) _{std}	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}
		min	hh:mm:ss	ft3	in H ₂ O	in H ₂ O	in H ₂ O	oF	oF	oF	oF	oF	oF	in Hg	(in H ₂ O) ^{1/2}	ft/sec	scf	%	scf
A-1	0.0	0:00:00	707.020	1.000	0.451	0.450	296	241	258	68		80	80	2.0	1.00	69.52	3.592	100.6	43.110
A-2	10.0	0:10:00	710.720	1.000	0.451	0.450	297	249	256	63		80	80	3.0	1.00	69.57	6.534	92.4	39.207
A-3	20.0	0:20:00	713.750	1.500	0.677	0.680	297	249	256	63		80	80	3.0	1.22	85.20	11.042	96.8	44.169
B-1	30.0	0:30:00	718.390	1.500	0.677	0.680	296	245	246	57		80	80	4.0	1.22	85.15	15.356	97.3	46.067
B-2	40.0	0:40:00	722.830	1.500	0.677	0.680	296	251	263	58		82	82	4.0	1.22	85.15	19.721	97.9	47.330
B-3	50.0	0:50:00	727.340	1.400	0.631	0.630	297	248	260	57		83	83	4.0	1.18	82.32	24.029	98.6	48.059
C-1	60.0	1:00:00	731.800	1.300	0.586	0.590	298	256	260	52		83	83	4.0	1.14	79.37	28.241	99.4	48.413
C-2	70.0	1:10:00	736.160	1.200	0.541	0.540	300	255	259	50		83	83	4.0	1.10	76.36	32.133	99.4	48.199
C-3	80.0	1:20:00	740.190	1.000	0.451	0.450	298	258	261	62		83	83	4.0	1.00	69.61	35.870	100.0	47.826
D-1	90.0	1:30:00	744.060	1.400	0.631	0.630	298	249	257	60		83	83	4.0	1.18	82.37	40.130	100.1	48.156
D-2	100.0	1:40:00	748.470	1.600	0.722	0.720	301	252	261	62		83	83	4.0	1.26	88.23	44.613	100.0	48.669
D-3	110.0	1:50:00	753.110	1.100	0.496	0.500	300	256	256	64		84	84	4.0	1.05	73.11	48.469	100.3	48.469
Last Pt	120.0	2:00:00	757.110																
Final Val	120.0	2:00:00	757.110												Max Vac	4.0	Final Values	48.469	100.3
Average Values				1.29		0.58	298	251	258	60		82	82			1.13	78.83		
														82					

ONTARIO HYDRO ISOKINETIC SAMPLING DATA

Plant Name	Fibrominn Biomass Power Plant				Date	7/5/2007				Ideal Nozzle Diameter and IsoKinetic Factor Setup									
Sampling Location	Stack Outlet				Project #	snc-07-benson.mn-comp#1				Pitot Tube Coefficient	(C _p)	0.84							
Operator	TP				Run #	OUT-OHM-2				Avg Stack Temp	(t _s)	298	oF						
# of Points Across	3				# of Ports Used	4				Avg Gas Meter Temp	(t _m)	82							
Leak Checks					Sampling Equipment														
Train	Pre	0	ft3/min @	15	in Hg	Meter #	SAMP-CP-0017												
OK?	<input checked="" type="checkbox"/>	Post	0	ft3/min @	15	in Hg	Meterbox Cal. Factor	(Y)	1.005										
Pitot	Pre	3/4	in. H ₂ O for	15	sec	Nozzle #	#A-1												
OK?	<input checked="" type="checkbox"/>	Post	4/5	in. H ₂ O for	15	sec	Average Nozzle Diameter	(D _{na})	0.1760	in									
Orsat	OK?	<input checked="" type="checkbox"/>				Rec. Nozzle Diameter	(D _{ri})	0.1796	in										
Nozzle Measurements					Probe # / Length	SAMP-HP-0034	/ 60	in											
Pre	0.176	0.176	0.176	PASS	Liner Material	glass													
Post	0.176	0.176	0.176	PASS	Sample Case / Oven #	SAMP-BH-0023													
Run Time					Impinger Case #	SAMP-BC-0015													
Start	21:12	End	23:22		Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8	Wash	H ₂ O	50.0	ml		
					Pre	739.80	753.70	750.40	737.80	764.10	729.60	763.80	893.20	Volume	MeCl	ml			
					Post	988.50	867.20	754.70	741.10	765.60	730.40	765.20	908.00				Filter #		
																	M-1937		
Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (Δp ^{1/2})	Local Stack Velocity (v _s)	Cumulative Meter Volume (V _m) _{std}	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}
	min	hh:mm:ss	ft3	in H ₂ O	in H ₂ O	in H ₂ O	oF	oF	oF	oF	oF	oF	oF	in Hg	(in H ₂ O) ^{1/2}	ft/sec	scf	%	scf
A-1	0.0	0:00:00	757.850	1.700	0.791	0.790	302	255	242	68		79	79	4.0	1.30	91.02	4.837	102.4	58.044
A-2	10.0	0:10:00	762.820	1.900	0.884	0.880	304	254	249	66		79	79	4.0	1.38	96.35	9.987	102.8	59.920
A-3	20.0	0:20:00	768.110	1.300	0.605	0.600	304	253	252	63		80	80	3.0	1.14	79.70	14.172	102.4	56.686
B-1	30.0	0:30:00	772.420	1.600	0.744	0.740	303	254	252	66		81	81	4.0	1.26	88.36	18.699	101.5	56.098
B-2	40.0	0:40:00	777.090	1.500	0.698	0.700	304	250	251	65		81	81	4.0	1.22	85.61	23.159	101.3	55.580
B-3	50.0	0:50:00	781.690	1.100	0.512	0.510	304	250	248	65		81	81	3.0	1.05	73.31	27.005	101.3	54.011
C-1	60.0	1:00:00	785.660	1.600	0.744	0.740	303	248	247	68		82	82	4.0	1.26	88.36	31.902	102.2	54.689
C-2	70.0	1:10:00	790.720	1.400	0.651	0.650	303	254	248	63		82	82	3.0	1.18	82.65	36.246	102.1	54.369
C-3	80.0	1:20:00	795.210	1.200	0.558	0.560	303	256	248	65		82	82	3.0	1.10	76.52	40.267	102.0	53.690
D-1	90.0	1:30:00	799.367	1.500	0.698	0.700	298	260	251	63		82	82	4.0	1.22	85.27	44.591	101.6	53.509
D-2	100.0	1:40:00	803.835	1.300	0.605	0.600	298	261	251	60		82	82	3.5	1.14	79.39	48.804	101.6	53.240
D-3	110.0	1:50:00	808.190	1.100	0.512	0.510	300	260	253	60		82	82	3.0	1.05	73.12	52.518	101.3	52.518
Last Pt	120.0	2:00:00	812.030																
Final Val	120.0	2:00:00	812.030											Max Vac	4.0	Final Values	52.518	101.3	
Average Values				1.43		0.67	302	255	249	64		81	81		1.19	83.31			
												81							

ONTARIO HYDRO ISOKINETIC SAMPLING DATA

Plant Name	Fibrominn Biomass Power Plant				Date	7/6/2007				Ideal Nozzle Diameter and IsoKinetic Factor Setup											
Sampling Location	Stack Outlet				Project #	snc-07-benson.mn-comp#1				Pitot Tube Coefficient	(C _p)	0.84									
Operator	TP				Run #	OUT-OHM-3				Avg Stack Temp	(t _s)	302	oF								
# of Points Across	3				# of Ports Used	4				Avg Gas Meter Temp	(t _m)	81									
Leak Checks					Sampling Equipment																
Train	Pre	0	ft3/min @	15	in Hg	Meter #	SAMP-CP-0017														
OK?	<input checked="" type="checkbox"/>	Post	0	ft3/min @	15	in Hg	Meterbox Cal. Factor	(Y)	1.005												
Pitot	Pre	3/4	in. H ₂ O for	15	sec	Nozzle #	#6B-3														
OK?	<input checked="" type="checkbox"/>	Post	4/5	in. H ₂ O for	15	sec	Average Nozzle Diameter	(D _{na})	0.1743	in											
Orsat	OK?	<input checked="" type="checkbox"/>				Rec. Nozzle Diameter	(D _{ri})	0.1849	in												
						Probe # / Length	SAMP-HP-0011	/ 60	in												
Nozzle Measurements					Liner Material	glass															
Pre	0.174	0.174	0.175	PASS	Sample Case / Oven #	SAMP-BH-0013															
Post	0.174	0.174	0.175	PASS	Impinger Case #	SAMP-BC-0019															
Run Time					Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8				Pressures				
Start	0:43	End	2:55		Pre	738.50	739.80	733.30	695.20	738.10	750.30	734.50	928.20	Wash	H ₂ O	50.0	ml	Barometric Pressure	(P _b)	29.57	in Hg
					Post	965.00	831.60	739.00	697.30	739.60	750.40	735.50	937.50	Volume	MeCl	ml		Stack Static Pressure	(P _{static})	-0.23	in H ₂ O
																	Absolute Stack Pressure	(P _s)	29.55	in Hg	
																	Absolute Meter Pressure	(P _m)	29.70	in Hg	
																	Filter #	M-1936			
Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (Δp ^{1/2})	Local Stack Velocity (v _s)	Cumulative Meter Volume (V _m) _{std}	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}		
	min	hh:mm:ss	ft3	in H ₂ O	in H ₂ O	in H ₂ O	oF	oF	oF	oF	oF	oF	oF	in Hg	(in H ₂ O) ^{1/2}	ft/sec	scf	%	scf		
A-1	0.0	0:00:00	813.500	1.500	0.667	0.670	303	254	223	64		75	75	2.5	1.22	85.48	3.839	88.1	46.070		
A-2	10.0	0:10:00	817.410	1.300	0.578	0.580	304	254	257	62		75	75	2.5	1.14	79.63	8.188	98.3	49.127		
A-3	20.0	0:20:00	821.840	1.400	0.622	0.620	296	256	259	63		76	76	2.5	1.18	82.21	12.411	98.9	49.646		
B-1	30.0	0:30:00	826.150	0.850	0.378	0.380	295	256	257	66		77	77	2.5	0.92	64.01	15.901	100.4	47.703		
B-2	40.0	0:40:00	829.720	0.980	0.436	0.440	295	256	257	65		77	77	2.5	0.99	68.73	19.548	100.9	46.915		
B-3	50.0	0:50:00	833.450	1.200	0.534	0.530	297	256	258	66		78	78	3.0	1.10	76.16	23.530	101.0	47.060		
C-1	60.0	1:00:00	837.530	1.500	0.667	0.670	297	261	255	65		78	78	3.0	1.22	85.15	28.002	101.2	48.004		
C-2	70.0	1:10:00	842.110	1.500	0.667	0.670	297	262	262	57		78	78	3.0	1.22	85.15	32.376	101.1	48.565		
C-3	80.0	1:20:00	846.590	1.500	0.667	0.670	296	262	260	55		79	79	3.0	1.22	85.09	36.752	100.9	49.003		
D-1	90.0	1:30:00	851.080	1.600	0.711	0.710	297	262	259	57		78	78	3.0	1.26	87.94	41.225	100.7	49.470		
D-2	100.0	1:40:00	855.660	1.400	0.622	0.620	297	263	259	51		79	79	3.0	1.18	82.26	45.425	100.6	49.554		
D-3	110.0	1:50:00	859.970	0.870	0.387	0.390	297	263	259	53		79	79	3.0	0.93	64.85	48.814	100.7	48.814		
Last Pt	120.0	2:00:00	863.450																		
Final Val	120.0	2:00:00	863.450											Max Vac	3.0	Final Values	48.814	100.7			
Average Values				1.300		0.579	298	259	255	60		77	77		1.13	78.89					
													77								

ONTARIO HYDRO - SAMPLE RECOVERY AND INTEGRITY DATA SHEET					
--	--	--	--	--	--

Plant Name	Fibrominn Biomass Power Plant			Date	07/05/07
Sampling Location	Stack Outlet			Project #	snc-07-benson.mn-comp#1
Operator	TP			Acetone Lot Number	C38B11

Run History Data				
Run Number	OUT-OHM-1	OUT-OHM-2	OUT-OHM-3	
Run Start Time	18:02	21:12	0:43	(hh:mm)
Run Stop Time	22:10	23:22	2:55	(hh:mm)
Train Prepared By	KV/SK	KV/SK	KV/SK	
Train Recovered By	KV/SK	KV/SK	KV/SK	
Recovery Date	7/5/2007	7/5/2007	7/6/2007	(mm/dd/yy)
Relinquished By	TG	TG	TG	
Received By	PS	PS	PS	
Relinquished Date	7/7/2007	7/7/2007	7/7/2007	(mm/dd/yy)
Relinquished Time	19:00	19:00	19:00	(hh:mm)

Equipment Identification Numbers			
Filter	M-1986	M-1937	M-1936
Acetone Wash	ok	ok	ok
Silica Gel	ok	ok	ok
Impinger Case	SAMP-BC-0019	SAMP-BC-0015	SAMP-BC-0019
Sample Box	SAMP-BH-0013	SAMP-BH-0023	SAMP-BH-0013
Oven	ok	ok	ok

Sample Blank Taken YES

Moisture Content Data					
Impingers 1, 2, 3, 4, 5, 6 and 7 - Liquid Volume					
Final Volume	(V _f)	5434.2	5622.8	5468.2	ml
Initial Volume	(V _i)	5134.2	5248.6	5139.0	ml
Net Volume	(V _n)	299.9	374.2	329.3	ml
Comments					
Impinger 8 - Silica Gel Weight					
Final Weight	(W _f)	928.2	908.0	937.5	g
Initial Weight	(W _i)	916.3	893.2	928.2	g
Net Weight	(W _n)	11.9	14.8	9.3	g
Comments					
Total Water Collected					
Total Volume	(V _{tc})	311.9	389.0	338.6	ml

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

L_{fw} = distance to far wall of stack (in.)

L_{nw} = distance to near wall of stack (in.) [reference]

D = diameter of stack (in.)

A_s = area of stack (ft^2)

B = distance downstream (in.)

B_D = stack diameters downstream (dia.)

A = distance upstream (in.)

A_D = stack diameters upstream (dia.)

Area of Stack (ft^2)

$$A_s (\text{ft}^2) = \pi \times \left(\frac{D}{2 \times 12} \right)^2$$

$$A_s (\text{ft}^2) = 3.14 \times \left(\frac{108.0 \text{ in.}}{2 \times 12 \text{ in./ft}} \right)^2 = 63.62 \text{ ft}^2$$

Diameter of Stack (in.)

$$D (\text{in.}) = L_{fw} - L_{nw}$$

$$D (\text{in.}) = 129 \text{ in.} - 21 \text{ in.} = 108 \text{ in.}$$

Stack Diameters Downstream

$$B_D (\text{dia.}) = \frac{B}{D}$$

$$B_D (\text{dia.}) = \frac{910 \text{ in.}}{108 \text{ in.}} = 8.43 \text{ diameters}$$



Stack Diameters Upstream

$$A_D (\text{dia.}) = \frac{A}{D}$$

$$A_D (\text{dia.}) = \frac{2358 \text{ in.}}{108 \text{ in.}} = 21.83 \text{ diameters}$$

Number of Traverse Points

Based on 40 CFR Part 60, Appendix A, Method 1, Section 2.2



Traverse Point Locations

Based on 40 CFR Part 60, Appendix A, Method 1, Section 2.3

Traverse Point	Location of Traverse Points in Circular Stacks (Fraction of Stack Dimension from Inside Wall to Traverse Point)											
	2	4	6	8	10	12	14	16	18	20	22	24
1	.146	.067	.044	.032	.026	.021	.018	.016	.014	.013	.011	.011
2	.854	.250	.146	.105	.082	.067	.057	.049	.044	.039	.035	.032
3	.750	.296	.194	.146	.118	.098	.085	.075	.067	.060	.056	.055
4	.933	.704	.323	.226	.177	.146	.125	.109	.097	.087	.079	.079
5	.854	.677	.342	.250	.201	.169	.146	.129	.116	.116	.105	.105
6	.956	.806	.658	.366	.269	.220	.188	.165	.146	.146	.132	.132
7	.896	.774	.644	.366	.283	.236	.204	.180	.161	.161	.151	.151
8	.968	.854	.750	.634	.375	.296	.250	.218	.194	.194	.180	.180
9	.918	.823	.731	.625	.362	.306	.262	.230	.204	.180	.161	.161
10	.974	.882	.799	.717	.618	.588	.515	.472	.439	.406	.372	.372
11	.933	.854	.760	.704	.612	.593	.532	.491	.459	.432	.406	.406
12	.979	.901	.831	.764	.694	.607	.538	.491	.459	.432	.406	.406
13	.943	.875	.812	.750	.685	.602	.538	.491	.459	.432	.406	.406
14	.962	.915	.854	.796	.736	.677	.618	.571	.532	.491	.459	.459
15	.951	.891	.835	.782	.728	.677	.618	.571	.532	.491	.459	.459
16	.964	.925	.871	.820	.770	.728	.677	.618	.571	.532	.491	.491
17	.956	.903	.854	.806	.756	.714	.667	.618	.571	.532	.491	.491
18	.968	.933	.884	.839	.786	.747	.700	.652	.618	.571	.532	.532
19	.961	.918	.869	.825	.776	.737	.689	.641	.593	.555	.517	.517
20	.987	.940	.895	.850	.797	.758	.710	.662	.624	.586	.548	.548
21	.965	.921	.876	.830	.783	.744	.696	.648	.610	.572	.534	.534
22	.969	.945	.904	.858	.801	.762	.714	.666	.628	.590	.552	.552
23	.968	.968	.926	.880	.823	.784	.736	.688	.650	.612	.574	.574
24	.969	.969	.969	.969	.969	.969	.969	.969	.969	.969	.969	.969

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2)

P_b = barometric pressure (in. Hg)
 P_{static} = static pressure (in. H₂O)
 P_s = absolute stack pressure (in. Hg)
%N₂ = nitrogen concentration (%)
%CO₂ = carbon dioxide concentration (%)
%O₂ = oxygen concentration (%)
%CO = carbon monoxide concentration (%)
MW = molecular weight (lb/lb-mole)
B_{ws} = stack moisture content (%)
M_d = stack dry molecular weight (lb/lb-mole)
M_s = stack wet molecular weight (lb/lb-mole)
T_{std} = standard temperature, 68°F, 528°R
P_{std} = standard pressure, 29.92 in. Hg
v_{sl} = local velocity (ft/sec)
v_s = average stack gas velocity (ft/sec)
Q_{sd} = average stack dry standard flow rate (dscf/hr)
Q_{aw} = average stack wet flow rate (ascf/min)

C_p = pitot tube coefficient
Δp = velocity head (in. H₂O)
A_s = area of stack (ft²)
N_a = null angle (deg.)
t_s = stack temperature (°F)
T_u = temperature offset, 460°R
K_p = pitot tube constant,
85.49 (ft/sec)((lb/lb-mole)(in. Hg)/(°R)(in. Hg))^{1/2}

Absolute Stack Pressure (in. Hg)

$$P_s (\text{in. Hg}) = P_b + \frac{P_{\text{static}}}{13.6}$$

$$P_s (\text{in. Hg}) = 29.92 \text{ in. Hg} + \frac{-0.23 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 29.90 \text{ in. Hg}$$

Nitrogen Concentration (%)

$$\% N_2 = 100 - \% CO_2 - \% O_2 - \% CO$$

$$\% N_2 (\%) = 100 - 14.39 \% - 4.83 \% - 0 \% = 80.78 \%$$

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d (\text{lb / lb - mol}) = \sum \left(\frac{MW_{\text{comp}}}{100} \times \% \text{ component} \right)$$

$$M_d (\text{lb/lb-mol}) = \left[\frac{44 \text{ lb/lb-mol}}{100} \times 14.39 \% \right] + \left[\frac{32 \text{ lb/lb-mol}}{100} \times 4.83 \% \right] + \text{etc.} = \frac{30.5 \text{ lb}}{\text{lb-mol}}$$

Stack Wet Molecular Weight (lb/lb-mole)

$$M_s (\text{lb / lb - mol}) = \left[M_d \times \left(1 - \frac{B_{ws}}{100} \right) \right] + \left[MW_{H_2O} \times \frac{B_{ws}}{100} \right]$$

$$M_s (\text{lb/lb-mol}) = \left[\frac{30.5 \text{ lb}}{\text{lb-mol}} \times \left(1 - \frac{30 \%}{100} \right) \right] + \left[\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{30 \%}{100} \right] = \frac{26.75 \text{ lb}}{\text{lb-mol}}$$

Local Velocity (ft/sec)

$$v_{sl(l)} (\text{ft / sec}) = K_p \times C_p \times \sqrt{\Delta p} \times \sqrt{\frac{t_s + T_u}{P_s \times M_s}}$$

$$v_{sl} (\text{ft/sec}) = \frac{85.49 \text{ ft}}{\text{sec}} \left[\frac{(\text{lb/lb-mol})(\text{in. Hg})}{(\text{°R})(\text{in. H}_2\text{O})} \right]^{1/2} \times 0.84 \times \sqrt{1.00 \text{ in. H}_2\text{O}} \times \sqrt{\frac{291 + 460 \text{ °R}}{29.9 \text{ in. Hg} \times 26.75 \text{ lb/lb-mol}}} = \frac{69.59 \text{ ft}}{\text{sec}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2)

P_b = barometric pressure (in. Hg)
 P_{static} = static pressure (in. H₂O)
 P_s = absolute stack pressure (in. Hg)
%N₂ = nitrogen concentration (%)
%CO₂ = carbon dioxide concentration (%)
%O₂ = oxygen concentration (%)
%CO = carbon monoxide concentration (%)
MW = molecular weight (lb/lb-mole)
B_{ws} = stack moisture content (%)
M_d = stack dry molecular weight (lb/lb-mole)
M_s = stack wet molecular weight (lb/lb-mole)
K_p = pitot tube constant,

$$85.49 \text{ (ft/sec)}(((\text{lb/lb-mole})(\text{in. Hg}))(({}^{\circ}\text{R})(\text{in. Hg})))^{1/2}$$

T_{STD} = standard temperature, 68°F

P_{STD} = standard pressure, 29.92 in. Hg

v_{sl} = local velocity (ft/sec)

v_s = average stack gas velocity (ft/sec)

Q_{SD} = average stack dry standard flow rate (dscfh)

Q_{AW} = average stack wet flow rate (ascf/min)

C_p = pitot tube coefficient
Δp = velocity head (in. H₂O)
A_s = area of stack (ft²)
N_A = null angle (deg.)
t_s = stack temperature (°F)
T_u = temperature offset, 460°R

Average Stack Gas Velocity (ft/sec)

$$v_s (\text{ft/sec}) = K_p \times C_p \times \left(\sqrt{\Delta p} \right)_{\text{avg}} \times \sqrt{\frac{(t_s)_{\text{avg}} + T_u}{P_s \times M_s}}$$

$$v_{\text{sl}} (\text{ft/sec}) = \frac{85.49 \text{ ft}}{\text{sec}} \left[\frac{(\text{lb/lb-mol})(\text{in. Hg})}{({}^{\circ}\text{R})(\text{in. H}_2\text{O})} \right] \times 0.84 \times 1.05 \text{ in. H}_2\text{O}^{1/2} \times \sqrt{\frac{291 + 460 {}^{\circ}\text{R}}{29.9 \text{ in. Hg} \times 26.75 \text{ lb/lb-mol}}} = \frac{72.74 \text{ ft}}{\text{sec}}$$

Average Stack Dry Standard Flow Rate (dscfh)

$$Q_{sd} (\text{dscfh}) = \frac{60 \times 60 \times \left(1 - \frac{B_{ws}}{100} \right) \times v_s \times A_s \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sd} (\text{dscfh}) = \frac{3600 \text{ sec}}{\text{hr}} \times \left[1 - \frac{30.0 \%}{100} \right] \times \frac{72.74 \text{ ft}}{\text{sec}} \times 63.62 \text{ ft}^2 \times \frac{68 + 460 {}^{\circ}\text{R}}{291 + 460 {}^{\circ}\text{R}} \times \frac{29.90 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{8,192,279 \text{ dscf}}{\text{hr}}$$

Average Stack Wet Flow Rate (acf m)

$$Q_{aw} (\text{acf m}) = 60 \times v_s \times A_s$$

$$Q_{aw} (\text{acf/min}) = \frac{60 \text{ sec}}{\text{min}} \times \frac{72.74 \text{ ft}}{\text{sec}} \times 63.62 \text{ ft}^2 = \frac{277,654 \text{ acf}}{\text{min}}$$

Average Stack Wet Standard Flow Rate (ascfh)

$$Q_{sw} (\text{ascfh}) = \frac{60 \times Q_{aw} \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sw} (\text{ascf/hr}) = \frac{60 \text{ min}}{\text{hr}} \times \frac{277,654 \text{ acf}}{\text{min}} \times \frac{68 + 460 {}^{\circ}\text{R}}{291 + 460 {}^{\circ}\text{R}} \times \frac{29.90 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{11,703,256 \text{ ascf}}{\text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 3a)

%N₂ = nitrogen concentration (%)

%CO₂ = carbon dioxide concentration (%)

%O₂ = oxygen concentration (%)

ppmCO = carbon monoxide concentration (ppm)

%CO = carbon monoxide concentration (%)

M_d = stack dry molecular weight (lb/lb-mole)

(F_o)_{avg} = average calculated fuel factor

(%EA)_{avg} = average excess air (%)

Carbon Monoxide Concentration (%)

$$\% CO = \frac{ppmCO}{10,000}$$

$$\% CO (\%) = \frac{100.00 \text{ ppm}}{10,000 \text{ ppm/\%}} = 1.0E-02 \text{ \%}$$

Nitrogen Concentration (%)

$$\% N_2 = 100 - \% CO_2 - \% O_2 - \% CO$$

$$\% N_2 (\%) = 100 - 14 \% - 5 \% - 0.01 \% = 80.99 \%$$

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d (\text{lb / lb-mol}) = \sum \left(\frac{MW_{comp}}{100} \times \% \text{ component} \right)$$

$$M_d (\text{lb/lb-mol}) = \left[\frac{44 \text{ lb/lb-mol}}{100} \times 14 \% \right] + \left[\frac{32 \text{ lb/lb-mol}}{100} \times 5 \% \right] + \text{etc.} = \frac{30.44 \text{ lb}}{\text{lb-mol}}$$

Average Calculated Fuel Factor

$$F_{o(\text{avg})} = \frac{|20.9 - (\% O_2)_{\text{avg}} - (0.5 \times (\% CO)_{\text{avg}})|}{(\% CO_2)_{\text{avg}} + (\% CO)_{\text{avg}}}$$

$$F_{o(\text{avg})} = \frac{20.9 \% - 5 \% - [0.5 \times 0.01 \%]}{14 \% + 0.01 \%} = 1.135$$

Average Excess Air (%)

$$\% EA_{\text{avg}} (\%) = \frac{100 \times [(\% O_2)_{\text{avg}} - (0.5 \times (\% CO)_{\text{avg}})]}{(0.264 \times (N_2)_{\text{avg}}) - [(\% O_2)_{\text{avg}} - (0.5 \times (\% CO)_{\text{avg}})]}$$

$$(\% EA)_{\text{AVG}} = \frac{100 \times \{ 5 \% - [0.5 \times 0.01 \%] \}}{\{ 0.264 \times 80.99 \% \} - \{ 5 \% - [0.5 \times 0.01 \%] \}} = 30.5 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4)

V_{mf} = final dry gas meter reading (dcf)

V_{mi} = initial dry gas meter reading (dcf)

V_m = total meter volume (dcf)

$t_{m(\text{avg})}$ = average meter temp. ($^{\circ}\text{F}$)

$t_{s(\text{avg})}$ = average stack temp. ($^{\circ}\text{F}$)

P_b = barometric pressure (in. Hg)

P_{static} = static pressure (in. H_2O)

ΔH_{avg} = average orifice pressure (in. H_2O)

V_i = initial impinger volume (ml)

V_f = final impinger volume (ml)

W_i = initial impinger weight (g)

W_f = final impinger weight (g)

V_t = total impinger volume (ml) = $\Sigma(V_f - V_i)$

W_t = total impinger weight (g) = $\Sigma(W_f - W_i)$

K_5 = water mass to std water vapor, 0.04715 ft^3/g

K_1 = standard volume correction, 17.65 $^{\circ}\text{R}/\text{in. Hg}$

Y = meter calibration factor

T_u = absolute temperature offset, 460 $^{\circ}\text{R}$

B_{ws} = final moisture content (%) = min of $B_{ws(\text{calc})}$ and $B_{ws(\text{svp})}$

Water Volume Weighed (dscf)

$$V_{wsg(\text{std})} (\text{dscf}) = W_t \times K_5$$

$$V_{wsg(\text{std})} = 311.30 \text{ g} \times 0.04715 \text{ ft}^3/\text{g} = 14.678 \text{ dscf}$$

Standard Meter Volume (dscf)

$$V_{m(\text{std})} (\text{dscf}) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{\text{avg}}}{13.6} \right)}{(t_m)_{\text{avg}} + T_u}$$

$$V_{m(\text{std})} = \frac{\frac{17.65 \text{ } ^{\circ}\text{R}}{\text{in. Hg}} \times 1.01 \times 50.09 \text{ dcf} \times \left[29.53 \text{ in. Hg} + \frac{0.58 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O / in. Hg}} \right]}{82 \text{ } ^{\circ}\text{F} + 460 \text{ } ^{\circ}\text{R}} = 48.47 \text{ dscf}$$

Calculated Moisture Content (%)

$$B_{ws(\text{calc})} (\%) = 100 \times \frac{V_{wsg(\text{std})}}{V_{wsg(\text{std})} + V_{m(\text{std})}}$$

$$B_{ws(\text{calc})} = 100 \times \frac{14.6778 \text{ dscf}}{14.6778 \text{ dscf} + 48.47122 \text{ dscf}} = 23.24311 \%$$

Saturated Moisture Content (%)

$$B_{ws(\text{svp})} (\%) = 100 \times \frac{10 \frac{3144}{t_{s(\text{avg})} + 390.86}}{P_b + \frac{P_{\text{static}}}{13.6}} \leq 100$$

$$B_{ws(\text{svp})} = 100 \times \frac{10 \left[\frac{3144}{298 \text{ } ^{\circ}\text{F} + 390.86} - \frac{0.23 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O / in. Hg}} \right]}{29.53 \text{ in. Hg} + \frac{-0.23 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O / in. Hg}}} \leq 100 = 100 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling)

C_n = nozzle diameter constant, 0.03575

Q_m = estimated orifice flow rate, 0.750 acfm

else V_m/Θ from previous run

V_m = total meter volume (acf)

Θ = total sampling time (min)

t_m = average gas meter temperature ($^{\circ}$ F)

T_u = absolute temperature offset, 460 $^{\circ}$ R

C_p = pitot tube coefficient

B_{wm} = meter moisture content (%)

B_{ws} = stack moisture content (%)

t_s = average stack temperature ($^{\circ}$ F)

M_d = stack dry molecular weight (lb/lb-mole)

P_s = absolute stack pressure (in. Hg)

C_k = K Factor Constant, 849.8

Δp_{avg} = average pitot tube differential pressure (in. H₂O)

$\Delta H@ = DH @ 0.75 \text{ SCFM (in. H}_2\text{O)}$

D_{na} = actual nozzle diameter (in.)

Δp = velocity head (in. H₂O)

Desired Orifice (in. H₂O)

$$\Delta H_d \text{ (in. H}_2\text{O)} = K \times \Delta p$$

$$\Delta H_d \text{ (in. H}_2\text{O)} = 0.45 \times 1 \text{ in. H}_2\text{O} = 0.451 \text{ in. H}_2\text{O}$$

Absolute Meter Pressure (in. Hg)

$$P_m \text{ (in. Hg)} = P_b + \frac{\Delta H @}{13.6}$$

$$P_m \text{ (in. Hg)} = 29.53 \text{ in. Hg} + \frac{1.81 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 29.66 \text{ in. Hg}$$

Recommended Nozzle Diameter (in.)

$$D_{ni} \text{ (in.)} = \sqrt{\frac{C_n \times Q_m \times P_m}{(t_m + T_u) \times C_p} \times \left(\frac{1 - \frac{B_{wm}}{100}}{1 - \frac{B_{ws}}{100}} \right) \times \sqrt{(t_s + T_u) \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + (18 \times B_{ws})}{P_s \times \Delta p_{avg}} \right]}}$$

$$D_{ni} \text{ (in.)} = \frac{0.03575 \text{ (lb-mole}^{\circ}\text{R} \cdot \text{in. H}_2\text{O)}^{1/2} \cdot \text{min} \cdot \text{in.}^2}{\text{acf} \cdot \text{in. Hg}^{3/4} \cdot \text{lb}^{1/2}} \times 0.75 \text{ acf} \times 29.66 \text{ in. Hg} \times \frac{0.0}{\left(81 \text{ }^{\circ}\text{F} + 460 \text{ }^{\circ}\text{R} \right) \times 0.84} \times \frac{0.0}{\left(1 - \frac{0.0}{100} \right)} \times \frac{0.0}{\left(1 - \frac{25.0}{100} \right)}$$

$$D_{ni} \text{ (in.)} = \frac{\left(291 \text{ }^{\circ}\text{F} + 460 \text{ }^{\circ}\text{R} \right) \times \frac{30.44 \text{ lb}}{\text{lb-mole}} \times \left(1 - \frac{25.0}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times 25.0 \% \right)}{29.51 \text{ in. Hg} \times 1.05 \text{ in. H}_2\text{O}} = 0.245 \text{ in.}$$

DP to DH Isokinetic Factor

$$K = C_k \times C_p^2 \times \Delta H @ \times D_{na}^4 \times \left[\frac{M_d \times \left(1 - \frac{B_{wm}}{100} \right) + (18 \times \frac{B_{wm}}{100})}{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + (18 \times \frac{B_{ws}}{100})} \right] \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{wm}}{100}} \right)^2 \times \left(\frac{t_m + T_u}{t_s + T_u} \right) \times \frac{P_s}{P_m}$$

$$K = \frac{849.8}{\text{in. H}_2\text{O} \cdot \text{in.}^4} \times 0.84^2 \times 1.81 \text{ in. H}_2\text{O} \times 0.174333^4 \times \frac{25.0}{\left(1 - \frac{0.0}{100} \right)^2} \times \frac{0.0}{\left(1 - \frac{25.0}{100} \right)} \times \frac{81 \text{ }^{\circ}\text{F} + 460 \text{ }^{\circ}\text{R}}{\left(291 \text{ }^{\circ}\text{F} + 460 \text{ }^{\circ}\text{R} \right)} \times$$

$$\left(\frac{30.44 \text{ lb}}{\text{lb/mole}} \times \left(1 - \frac{0.0}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0.0}{100} \right) \right) \times \frac{29.51 \text{ in. Hg}}{29.66 \text{ in. Hg}} = 0.45$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 29, Run 1)

Mercury Emissions Rate (lb/hr)

$$E' \text{ (lb / hr)} = \frac{M_n \times Q_{sd}}{V_{m(std)}} \times \frac{60}{453.592 \times 1000}$$

$$E' \text{ (lb/hr)} = \frac{\text{g}}{1000 \text{ mg}} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{\text{lb}}{453.592 \text{ g}} \times \frac{0.00000 \text{ mg}}{48.47 \text{ dscf}} \times \frac{158,727 \text{ dscf}}{\text{min}} = \frac{0.00000 \text{ lb}}{\text{hr}}$$

Mercury Emissions Rate (ton/yr)

$$E'' \text{ (ton / yr)} = E' \times \frac{8760}{2000}$$

$$E'' \text{ (ton/yr)} = \frac{\text{ton}}{2000 \text{ lb}} \times \frac{8760 \text{ hr}}{\text{yr}} \times \frac{0.00000 \text{ lb}}{\text{hr}} = \frac{0.00000 \text{ ton}}{\text{yr}}$$

Mercury Emissions Rate (lb/MMBtu)

$$E''' \text{ (lb / MMBtu)} = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{100}{\% CO_2} \right)$$

$$E''' \text{ (lb/MMBtu)} = \frac{\text{g}}{1000 \text{ mg}} \times \frac{\text{lb}}{453.592 \text{ g}} \times \frac{0.00000 \text{ mg}}{48.47 \text{ dscf}} \times \frac{1,890 \text{ dscf (CO}_2\text{)}}{\text{MMBtu}} \times \left(\frac{100\%}{14.0 \%} \right) = \frac{0.00E+00 \text{ lb}}{\text{MMBtu}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.



Air Hygiene International

AHI Project: scn-07-benson.mn-comp#1

CONSOL Project: 1650-030-1

Date: 07/27/07

Results - Impingers, Rinses, Blanks

Lab No.	Description	Sample	Hg (µg/L)	Impinger Volume (L)	Hg (µg)
20073708	RUN 1 GLASS LINER & FRONT HALF 7/5/07	IN-OHM-1-CON2	<1.40	0.430	<0.602
20073709	RUN 1 IMPINGERS 1, 2, AND 3 7/5/07	IN-OHM-1-CON3	0.36	0.510	0.184
20073710	RUN 1 IMPINGER 4 7/5/07	IN-OHM-1-CON4	< 1.40	0.120	<0.168
20073711	RUN 1 IMPINGERS 5, 6, AND 7 7/5/07	IN-OHM-1-CON5	1.96	0.535	1.049
20073712	RUN 2 NOZZLE, GLASS LINER & FRONT HALF 7/5/07	IN-OHM-2-CON2	< 1.40	0.415	<0.581
20073713	RUN 2 IMPINGERS 1, 2, AND 3 7/5/07	IN-OHM-2-CON3	0.35	0.280	0.098
20073714	RUN 2 IMPINGER 4 7/5/07	IN-OHM-2-CON4	< 1.40	0.430	<0.602
20073715	RUN 2 IMPINGERS 5, 6, AND 7 7/5/07	IN-OHM-2-CON5	0.76	0.510	0.388
20073716	RUN 3 NOZZLE, GLASS LINER & FRONT HALF 7/5/07	IN-OHM-3-CON2	< 1.40	0.440	<0.616
20073717	RUN 3 IMPINGERS 1, 2, AND 3 7/5/07	IN-OHM-3-CON3	0.35	0.465	0.163
20073718	RUN 3 IMPINGER 4 7/5/07	IN-OHM-3-CON4	< 1.40	0.140	<0.196
20073719	RUN 3 IMPINGERS 5, 6, AND 7 7/5/07	IN-OHM-3-CON5	0.76	0.510	0.388
20073720	RUN 1 NOZZLE, GLASS LINER & FRONT HALF 7/5/07	OUT-OHM-1-CON2	< 1.40	0.235	<0.329
20073721	RUN 1 IMPINGERS 1, 2, AND 3 7/5/07	OUT-OHM-1-CON3	0.51	0.645	0.329
20073722	RUN 1 IMPINGER 4 7/5/07	OUT-OHM-1-CON4	< 1.40	0.145	<0.203
20073723	RUN 1 IMPINGERS 5, 6, AND 7 7/5/07	OUT-OHM-1-CON5	0.74	0.380	0.281
20073724	RUN 2 NOZZLE, GLASS LINER & FRONT HALF 7/5/07	OUT-OHM-2-CON2	< 1.40	0.150	<0.210
20073725	RUN 2 IMPINGERS 1, 2, AND 3 7/5/07	OUT-OHM-2-CON3	0.51	0.645	0.329
20073726	RUN 2 IMPINGER 4 7/5/07	OUT-OHM-2-CON4	< 1.40	0.130	<0.182
20073727	RUN 2 IMPINGERS 5, 6, AND 7 7/5/07	OUT-OHM-2-CON5	0.74	0.380	0.281
20073728	RUN 3 NOZZLE, GLASS LINER & FRONT HALF 7/5/07	OUT-OHM-3-CON2	< 1.40	0.190	<0.266
20073729	RUN 3 IMPINGERS 1, 2, AND 3 7/5/07	OUT-OHM-3-CON3	0.51	0.645	0.329
20073730	RUN 3 IMPINGER 4 7/5/07	OUT-OHM-3-CON4	< 1.40	0.160	<0.224
20073731	RUN 3 IMPINGERS 5, 6, AND 7 7/5/07	OUT-OHM-3-CON5	0.74	0.380	0.281
20073732	50 ML OF 0.1 N HNO3 BLANK 7/5/07	H-B-OHM-CON7	< 1.40	0.110	<0.154
20073733	50 ML OF 1 N KCL BLANK	K-B-OHM-CON8	1.82	0.095	0.173
20073734	50 ML OF HNO3-H2O2 BLANK	HH-B-OHM-CON9	< 1.40	0.085	< 0.119
20073735	50 ML OF H2SO4-KMNO4 BLANK	HK-B-OHM-CON10	0.33	0.065	0.021
20073736	100 ML OF HYDROXYLAMINE BLANK	HXM-B-OHM-CON11	0.86	0.150	0.129

Results - Filters

ANALNUM	DESCR	SAMPLE	Hg (ug/filter)	Filter	Hg (ug)
20073701	RUN 1 FILTER 7/5/07	IN-OHM-1-CON1	0.012	1	0.012
20073702	RUN 2 FILTER	IN-OHM-2-CON1	< 0.007	1	< 0.007
20073703	RUN 3 FILTER	IN-OHM-3-CON1	< 0.007	1	< 0.007
20073704	RUN 1 FILTER	OUT-OHM-1-CON1	< 0.007	1	< 0.007
20073705	RUN 2 FILTER	OUT-OHM-2-CON1	< 0.007	1	< 0.007
20073706	RUN 3 FILTER	OUT-OHM-3-CON1	< 0.007	1	< 0.007
20073707	SAMPLE BLANK FILTER	F-B-OHM-CON12	< 0.007	1	< 0.007



Air Hygiene International

AHI Project: scn-07-benson.mn-comp#1
 CONSOL Project: 1650-030-1
 Date: 7/27/2007

QAQC

Mercury Duplicate Analyses RPD (Limit of 10%)..Impingers, Rinses, Blanks

Lab No.	Description		Hg ($\mu\text{g/L}$)	Hg ($\mu\text{g/L}$)	Hg ave($\mu\text{g/L}$)	RPD, %
20073708	RUN 1 GLASS LINER & FRONT HALF 7/5/07	IN-OHM-1-CON2	<1.40	<1.40	<1.40	0.0
20073709	RUN 1 IMPINGERS 1, 2, AND 3 7/5/07	IN-OHM-1-CON3	0.37	0.35	0.36	5.6
20073710	RUN 1 IMPINGER 4 7/5/07	IN-OHM-1-CON4	< 1.40	< 1.40	< 1.40	0.0
20073711	RUN 1 IMPINGERS 5, 6, AND 7 7/5/07	IN-OHM-1-CON5	2.02	1.90	1.96	6.1
20073712	RUN 2 NOZZLE, GLASS LINER & FRONT HALF 7/5/07	IN-OHM-2-CON2	< 1.40	< 1.40	< 1.40	0.0
20073713	RUN 2 IMPINGERS 1, 2, AND 3 7/5/07	IN-OHM-2-CON3	0.33	0.37	0.35	11.4
20073714	RUN 2 IMPINGER 4 7/5/07	IN-OHM-2-CON4	< 1.40	< 1.40	< 1.40	0.0
20073715	RUN 2 IMPINGERS 5, 6, AND 7 7/5/07	IN-OHM-2-CON5	0.76	0.76	0.76	0.0
20073716	RUN 3 NOZZLE, GLASS LINER & FRONT HALF 7/5/07	IN-OHM-3-CON2	< 1.40	< 1.40	< 1.40	0.0
20073717	RUN 3 IMPINGERS 1, 2, AND 3 7/5/07	IN-OHM-3-CON3	0.33	0.37	0.35	11.4
20073718	RUN 3 IMPINGER 4 7/5/07	IN-OHM-3-CON4	< 1.40	< 1.40	< 1.40	0.0
20073719	RUN 3 IMPINGERS 5, 6, AND 7 7/5/07	IN-OHM-3-CON5	0.76	0.76	0.76	0.0
20073720	RUN 1 NOZZLE, GLASS LINER & FRONT HALF 7/5/07	OUT-OHM-1-CON2	< 1.40	< 1.40	< 1.40	0.0
20073721	RUN 1 IMPINGERS 1, 2, AND 3 7/5/07	OUT-OHM-1-CON3	0.49	0.52	0.51	5.6
20073722	RUN 1 IMPINGER 4 7/5/07	OUT-OHM-1-CON4	< 1.40	< 1.40	< 1.40	0.0
20073723	RUN 1 IMPINGERS 5, 6, AND 7 7/5/07	OUT-OHM-1-CON5	0.77	0.71	0.74	8.1
20073724	RUN 2 NOZZLE, GLASS LINER & FRONT HALF 7/5/07	OUT-OHM-2-CON2	< 1.40	< 1.40	< 1.40	0.0
20073725	RUN 2 IMPINGERS 1, 2, AND 3 7/5/07	OUT-OHM-2-CON3	0.49	0.52	0.51	5.6
20073726	RUN 2 IMPINGER 4 7/5/07	OUT-OHM-2-CON4	< 1.40	< 1.40	< 1.40	0.0
20073727	RUN 2 IMPINGERS 5, 6, AND 7 7/5/07	OUT-OHM-2-CON5	0.77	0.71	0.74	8.1
20073728	RUN 3 NOZZLE, GLASS LINER & FRONT HALF 7/5/07	OUT-OHM-3-CON2	< 1.40	< 1.40	< 1.40	0.0
20073729	RUN 3 IMPINGERS 1, 2, AND 3 7/5/07	OUT-OHM-3-CON3	0.49	0.52	0.51	5.6
20073730	RUN 3 IMPINGER 4 7/5/07	OUT-OHM-3-CON4	< 1.40	< 1.40	< 1.40	0.0
20073731	RUN 3 IMPINGERS 5, 6, AND 7 7/5/07	OUT-OHM-3-CON5	0.77	0.71	0.74	8.1
20073732	50 ML OF 0.1 N HNO3 BLANK 7/5/07	H-B-OHM-CON7	< 1.40	< 1.40	< 1.40	0.0
20073733	50 ML OF 1 N KCL BLANK	K-B-OHM-CON8	1.84	1.80	1.82	2.2
20073734	50 ML OF HNO3-H2O2 BLANK	HH-B-OHM-CON9	< 1.40	< 1.40	< 1.40	0.0
20073735	50 ML OF H2SO4-KMNO4 BLANK	HK-B-OHM-CON10	0.36	0.30	0.33	18.2
20073736	100 ML OF HYDROXYLAMINE BLANK	HXM-B-OHM-CON11	0.78	0.93	0.86	17.4

Mercury Duplicate Analyses RPD (Limit of 10%)..Filters

Lab No.	Description		Hg ($\mu\text{g/filter}$)	Hg ($\mu\text{g/filter}$)	Hg ave($\mu\text{g/L}$)	RPD, %
20073701	RUN 1 FILTER 7/5/07	IN-OHM-1-CON1	0.012	0.012	0.012	0.0
20073702	RUN 2 FILTER	IN-OHM-2-CON1	< 0.007	< 0.007	< 0.007	0.0
20073703	RUN 3 FILTER	IN-OHM-3-CON1	< 0.007	< 0.007	< 0.007	0.0
20073704	RUN 1 FILTER	OUT-OHM-1-CON1	< 0.007	< 0.007	< 0.007	0.0
20073705	RUN 2 FILTER	OUT-OHM-2-CON1	< 0.007	< 0.007	< 0.007	0.0
20073706	RUN 3 FILTER	OUT-OHM-3-CON1	< 0.007	< 0.007	< 0.007	0.0
20073707	SAMPLE BLANK FILTER	F-B-OHM-CON12	< 0.007	< 0.007	< 0.007	0.0

Mercury Triplicate Analyses - Filters..... RSD (Limit of 10%)

Lab No.	Description		Hg ($\mu\text{g/filter}$)	Hg ($\mu\text{g/filter}$)	Hg ($\mu\text{g/filter}$)	RSD, %
20073704	RUN 1 FILTER	OUT-OHM-1-CON1	< 0.007	< 0.007	< 0.007	0.0

Mercury Triplicate Analyses RSD (Limit of 10%)

Lab No.	Description		Hg ($\mu\text{g/L}$)	Hg ($\mu\text{g/L}$)	Hg ($\mu\text{g/L}$)	RSD, %
20073731	RUN 3 IMPINGERS 5, 6, AND 7 7/5/07	OUT-OHM-3-CON5	0.77	0.71	0.83	7.8
20073718	RUN 3 IMPINGER 4 7/5/07	IN-OHM-3-CON4	< 1.40	< 1.40	< 1.40	0.0
20073724	RUN 2 NOZZLE, GLASS LINER & FRONT HALF 7/5/07	OUT-OHM-2-CON2	< 1.40	< 1.40	< 1.40	0.0
20073732	50 ML OF 0.1 N HNO3 BLANK 7/5/07	H-B-OHM-CON7	< 1.40	< 1.40	< 1.40	0.0

Matrix (Standard Addition) Spikes (recovery of 90 - 110%)

The following samples were spiked with a standard solution of 2ppb.

Lab No.	Description	% Recovery
20073711	RUN 1 IMPINGERS 5, 6, AND 7 7/5/07	93.0%
20073710	RUN 1 IMPINGER 4 7/5/07	103.0%
20073716	RUN 3 NOZZLE, GLASS LINER & FRONT HALF 7/5/07	99.0%
20073705	RUN 2 FILTER	116.0%

NIST SRM 1633B Fly Ash...Digested/Analyzed with Filters (90 -110% of Certified Value)

NIST SRM has a certified value of 141 ng/g.

Lab No.	Description	Hg (ng/mg)	% RECOVERY
NIST SRM 1633B Fly Ash		135	95.7%

Digestion Duplicates and Digestion Spikes...Impingers

Digestion 1 and 2 results represent an average of duplicate analyses.

Lab No.	Description	Sample	Digestion 1	Digestion 2	RPD, %
20073715	RUN 2 IMPINGERS 5, 6, AND 7 7/5/07	IN-OHM-2-CON5	0.76	0.79	3.8
20073709	RUN 1 IMPINGERS 1, 2, AND 3 7/5/07	IN-OHM-1-CON3	0.31	0.36	15.2

The following samples were spiked with a standard solution of 2 ppb before digestion.

Lab No.	Description	% Recovery
20073715	RUN 2 IMPINGERS 5, 6, AND 7 7/5/07	92.5%
20073709	RUN 1 IMPINGERS 1, 2, AND 3 7/5/07	92.0%



Analytical Narrative

Summary

Samples were prepared and analyzed as outlined in ASTM D 6784-02 (Ontario Hydro Method).

Detection Limits

For samples determined to be less than the detection limit, results were reported as a less than value, based on the Thermo Unicam 969 detection limit of 0.14 µg/L multiplied with any sample dilution.

QAQC Summary

R₂ for all calibration curves were > 0.999. NIST SRM 1641D, prepared to a concentration of 4.0 µg/L, was analyzed immediately after calibration (independent calibration verification sample). The recovery criteria was 90-110% or the run was stopped and the analyzer was re-calibrated. NIST 1641D (4.0 µg/L), was also used as the continuing calibration verification sample and analyzed after every 10 samples. The recovery was 90 -110% or the run was stopped, the analyzer was recalibrated, and the affected samples were re-analyzed. All samples were analyzed in duplicate with a limit of a 10% (RPD). One in 10 samples were analyzed in triplicate with a criteria limit of 10% (RSD). Matrix spikes were included at a 1 in 10 sample frequency with a criteria of 90 - 110 % spike recovery. Although not required by D 6784-02, (1) digestion duplicates and (1) digestion spikes, were included to assess the efficiency of the digestions. NIST SRM1633B was digested and analyzed with the filters with a criteria of 90 - 110%. There were a few exceptions; samples 20073713, 20073717, 20073735, and 20073736 had RPD's slightly above 10%. However, these samples were determined to be slightly above detection limits. As such, the values were reported. Using the average should minimize any concerns. Sample 20073705 matrix spike was slightly above the 10% recovery criteria. All exceptions were noted in red font. Please refer to the QAQC worksheet for all QAQC data.

Disclaimer

In no event shall CONSOL Energy Inc. be liable for any direct, indirect, special, punitive, incidental, exemplary or consequential damages, or and damages what so ever, even if CONSOL Energy Inc. has been previously advised of the possibility of such damages, whether in an action under contract, negligence, or any other theory, arising out of or in connection with the use, inability to use, or performance of the information services, products, and materials provided in this data or this analysis. This is a comprehensive limitation of liability that applies to all damages of any kind, including (without limitation) compensatory, direct, indirect or consequential damages, loss of data, income or profit, loss of or damage to property and claims of third parties and resulting from any negligence of the CONSOL Energy Inc., except for gross negligence or willful misconduct.

APPENDIX B

UNIT OPERATION PARAMETERS

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FLOW (TPH)	PROPANE FUEL FLOW (SCFH)	FWP DISCH FLOW (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/4/07 14:00	62.78	489,145.91	368.82	502,439.19	73.18	0.00	272.41	542.17	970.96	1,501.12	863.38	807.00
7/4/07 14:01	62.65	488,163.09	368.66	502,047.31	73.84	0.00	272.48	542.37	971.12	1,500.36	861.48	805.42
7/4/07 14:02	62.34	486,790.41	368.49	501,655.41	74.41	0.00	272.57	542.12	970.38	1,497.16	860.47	804.34
7/4/07 14:03	62.31	486,211.19	368.35	501,263.50	74.13	0.00	272.68	541.82	969.86	1,498.21	860.38	804.16
7/4/07 14:04	62.19	485,853.41	368.18	500,871.69	75.43	0.00	272.74	541.49	969.37	1,497.67	860.75	803.91
7/4/07 14:05	62.06	484,247.09	367.96	500,479.81	75.58	0.00	272.76	541.33	969.51	1,495.76	861.30	803.79
7/4/07 14:06	62.00	484,535.31	367.74	500,087.91	74.21	0.00	272.73	541.39	970.01	1,496.43	862.04	804.29
7/4/07 14:07	62.14	486,740.69	367.51	500,110.69	73.75	0.00	272.72	541.72	971.04	1,500.13	863.03	804.83
7/4/07 14:08	62.23	487,253.00	367.24	500,635.41	74.16	0.00	272.72	542.10	972.91	1,501.64	864.22	805.69
7/4/07 14:09	62.22	486,457.81	366.84	500,448.81	78.60	0.00	272.67	542.06	973.41	1,502.33	865.14	806.02
7/4/07 14:10	62.37	488,654.19	366.51	500,262.19	79.78	0.00	272.66	541.93	974.41	1,508.24	866.05	806.40
7/4/07 14:11	62.56	491,341.31	366.01	500,075.59	79.52	0.00	272.57	542.18	975.50	1,511.44	866.91	807.09
7/4/07 14:12	61.96	486,055.31	365.58	499,889.00	77.09	0.00	272.58	542.06	973.14	1,499.44	867.20	806.84
7/4/07 14:13	62.01	488,325.81	364.99	499,702.41	76.19	0.00	272.53	541.99	971.29	1,502.83	867.10	806.59
7/4/07 14:14	61.94	487,674.91	364.42	499,515.81	77.62	0.00	272.43	542.41	971.45	1,501.83	867.71	807.28
7/4/07 14:15	62.09	490,114.91	363.76	499,329.09	79.56	0.00	272.41	542.52	969.10	1,506.46	867.94	807.40
7/4/07 14:16	61.85	489,138.09	363.24	499,142.50	79.96	0.00	272.38	542.56	966.96	1,503.16	868.14	807.44
7/4/07 14:17	61.51	487,789.09	362.84	498,955.91	81.51	0.00	272.37	542.66	966.94	1,498.55	869.07	808.52
7/4/07 14:18	61.38	488,479.19	362.61	498,819.59	80.18	0.00	272.35	542.70	965.55	1,498.50	868.71	809.06
7/4/07 14:19	61.58	487,085.09	362.46	499,097.50	80.39	0.00	272.37	543.25	967.35	1,502.48	866.92	807.98
7/4/07 14:20	61.39	485,830.69	362.46	499,375.31	78.63	0.00	272.32	543.79	970.08	1,497.22	867.55	809.68
7/4/07 14:21	60.98	482,591.50	362.42	499,653.19	77.27	0.00	272.32	543.65	969.71	1,490.77	867.91	809.94
7/4/07 14:22	61.26	485,604.19	362.37	499,931.00	77.16	0.00	272.34	543.60	970.05	1,498.96	868.39	810.24
7/4/07 14:23	60.82	481,911.41	362.27	500,208.91	77.42	0.00	272.33	543.72	971.34	1,492.75	868.84	810.71
7/4/07 14:24	61.17	485,229.59	362.13	500,486.69	78.72	0.00	272.30	543.61	970.73	1,499.23	868.58	810.33
7/4/07 14:25	60.83	481,636.69	361.92	500,764.59	78.63	0.00	272.31	543.79	971.42	1,495.59	868.80	810.60
7/4/07 14:26	60.59	480,039.19	361.77	501,042.41	80.46	0.00	272.36	543.92	971.04	1,493.83	868.93	810.46
7/4/07 14:27	60.52	479,593.00	361.53	501,320.31	81.93	0.00	272.36	543.80	969.53	1,498.52	868.62	809.92
7/4/07 14:28	60.82	482,839.91	361.33	501,598.09	85.43	0.00	272.32	543.91	970.34	1,502.50	868.80	810.20
7/4/07 14:29	60.88	480,974.31	361.12	501,876.00	84.15	0.00	272.21	544.03	971.10	1,500.42	869.16	810.45
7/4/07 14:30	60.97	483,346.00	360.92	502,153.81	82.88	0.00	272.16	544.00	971.43	1,502.09	869.64	810.64
7/4/07 14:31	61.39	488,103.69	360.70	502,431.69	86.17	0.00	272.12	544.05	972.08	1,508.73	870.02	810.74
7/4/07 14:32	61.05	484,237.91	360.51	501,678.00	80.68	0.00	272.19	544.22	972.60	1,502.72	870.57	811.14
7/4/07 14:33	61.31	487,092.59	360.22	500,759.91	79.11	0.00	272.22	544.30	972.64	1,505.87	870.85	811.70
7/4/07 14:34	61.36	487,530.41	359.97	499,841.81	79.56	0.00	272.23	544.26	971.44	1,506.61	871.07	811.89
7/4/07 14:35	61.38	488,583.19	359.73	498,923.69	79.55	0.00	272.27	544.08	970.22	1,506.31	871.05	811.97
7/4/07 14:36	61.21	486,957.69	359.54	498,005.59	76.31	0.00	272.32	544.01	968.39	1,502.65	870.86	812.35
7/4/07 14:37	61.87	493,062.31	359.47	497,087.50	76.37	0.00	272.42	544.00	967.19	1,513.86	870.71	812.25
7/4/07 14:38	61.57	491,064.00	359.38	496,169.41	73.20	0.00	272.44	544.16	966.41	1,508.77	870.95	812.90
7/4/07 14:39	61.11	487,819.59	359.43	495,251.31	70.88	0.00	272.56	544.21	963.93	1,498.61	871.00	813.00
7/4/07 14:40	60.92	487,533.19	359.46	494,406.91	71.80	0.00	272.64	544.08	960.25	1,498.19	870.61	812.72
7/4/07 14:41	61.12	491,134.09	359.51	493,724.69	72.30	0.00	272.69	544.28	958.63	1,504.17	870.35	812.67
7/4/07 14:42	61.35	492,658.81	359.60	493,042.50	74.10	0.00	272.70	544.63	958.99	1,507.55	870.60	812.71
7/4/07 14:43	61.03	490,152.31	359.78	492,360.31	76.17	0.00	272.76	544.94	961.03	1,503.28	871.64	813.76
7/4/07 14:44	60.78	487,502.50	359.97	491,678.00	76.64	0.00	272.80	545.00	962.05	1,496.51	872.37	814.95
7/4/07 14:45	61.08	489,841.31	360.14	490,995.81	78.59	0.00	272.86	544.97	963.13	1,502.21	872.78	815.83
7/4/07 14:46	61.05	489,222.91	360.28	490,313.59	73.72	0.00	272.91	544.98	964.85	1,501.64	872.74	815.64
7/4/07 14:47	60.66	485,055.69	360.33	489,631.31	75.95	0.00	272.96	544.68	964.22	1,493.61	871.74	814.79
7/4/07 14:48	60.84	485,220.91	360.28	488,949.09	75.08	0.00	273.02	544.55	963.93	1,497.62	870.72	813.89
7/4/07 14:49	60.76	486,383.19	360.25	488,266.91	73.95	0.00	273.01	544.57	964.80	1,496.28	870.17	814.39

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/4/07 14:50	60.47	482,487.19	360.21	487,584.69	71.55	0.00	273.00	544.51	964.33	1,491.40	869.55	813.97
7/4/07 14:51	60.19	482,032.00	360.14	487,088.41	72.31	0.00	273.04	544.19	962.77	1,493.55	868.50	812.74
7/4/07 14:52	60.70	482,881.31	360.08	487,845.69	71.33	0.00	272.97	544.20	964.14	1,499.02	868.15	812.31
7/4/07 14:53	60.83	485,801.50	360.06	488,603.00	73.46	0.00	272.82	544.11	965.22	1,503.48	868.05	812.24
7/4/07 14:54	61.02	487,219.31	360.08	489,360.31	71.25	0.00	272.77	544.12	966.64	1,503.95	868.32	812.73
7/4/07 14:55	60.91	486,026.91	360.01	490,117.69	70.78	0.00	272.76	543.87	966.97	1,502.91	868.03	812.27
7/4/07 14:56	61.11	487,196.59	359.99	490,875.00	73.27	0.00	272.76	543.60	967.34	1,505.21	867.75	812.26
7/4/07 14:57	61.58	491,887.91	359.95	491,632.31	71.54	0.00	272.74	543.50	967.64	1,512.86	867.63	811.94
7/4/07 14:58	61.16	487,569.31	359.91	492,389.59	73.91	0.00	272.79	543.24	966.43	1,504.61	867.22	811.55
7/4/07 14:59	61.17	489,610.09	359.87	493,146.91	74.50	0.00	272.87	543.04	966.17	1,503.80	866.84	810.95
7/4/07 15:00	61.51	492,102.91	359.84	493,904.19	74.15	0.00	272.91	542.94	965.60	1,509.53	866.69	810.64
7/4/07 15:01	61.16	488,448.91	359.74	494,661.50	76.32	0.00	272.95	542.67	965.24	1,502.21	866.41	809.90
7/4/07 15:02	60.79	487,400.19	359.66	495,418.81	80.38	0.00	272.98	542.30	964.88	1,496.47	865.85	809.85
7/4/07 15:03	61.19	489,247.50	359.62	496,008.09	81.76	0.00	272.94	542.21	966.68	1,503.07	865.77	810.23
7/4/07 15:04	60.91	486,203.00	359.55	496,388.50	81.76	0.00	272.87	542.02	967.87	1,500.80	865.60	809.85
7/4/07 15:05	60.43	482,023.81	359.55	496,769.00	81.50	0.00	272.86	541.90	968.55	1,492.56	865.29	809.85
7/4/07 15:06	59.77	478,129.81	359.39	497,149.41	81.37	0.00	272.80	541.32	966.47	1,487.99	864.34	808.64
7/4/07 15:07	60.56	483,896.81	359.35	497,529.81	80.55	0.00	272.74	541.01	965.62	1,500.11	863.39	807.51
7/4/07 15:08	60.64	484,267.81	359.25	497,910.31	82.78	0.00	272.54	541.01	966.72	1,498.93	863.22	807.15
7/4/07 15:09	59.72	475,710.00	359.18	498,290.69	81.35	0.00	272.42	540.70	966.04	1,492.80	862.75	806.29
7/4/07 15:10	60.28	479,886.09	359.08	498,671.09	78.55	0.00	272.36	540.18	965.66	1,498.88	861.90	805.01
7/4/07 15:11	61.16	487,732.09	358.93	499,051.50	80.80	0.00	272.30	539.99	968.60	1,507.70	861.40	804.25
7/4/07 15:12	60.85	484,772.09	358.78	498,283.00	82.59	0.00	272.20	539.56	970.46	1,501.08	860.78	803.21
7/4/07 15:13	60.73	482,274.19	358.63	497,356.69	87.09	0.00	272.26	538.81	970.21	1,501.97	859.47	802.57
7/4/07 15:14	61.06	486,555.59	358.39	496,430.31	88.74	0.00	272.27	538.38	971.33	1,506.16	858.93	802.46
7/4/07 15:15	61.19	486,426.19	358.27	495,503.91	94.82	0.00	272.29	538.12	972.70	1,507.57	858.99	802.79
7/4/07 15:16	61.31	486,981.81	358.25	494,577.50	93.02	0.00	272.35	537.85	972.91	1,506.46	859.38	803.54
7/4/07 15:17	60.43	482,367.59	358.21	493,651.09	94.99	0.00	272.45	537.26	970.87	1,495.97	859.35	803.41
7/4/07 15:18	60.58	482,673.09	358.09	492,724.69	95.86	0.00	272.53	536.66	969.24	1,499.59	858.84	802.90
7/4/07 15:19	60.21	479,483.50	357.95	491,798.31	92.61	0.00	272.47	536.43	968.78	1,494.68	858.57	802.51
7/4/07 15:20	59.41	473,648.59	357.82	490,871.91	89.35	0.00	272.42	536.16	967.12	1,491.06	858.16	802.55
7/4/07 15:21	58.95	471,852.81	357.69	489,322.00	89.64	0.00	272.34	535.80	965.40	1,492.30	857.33	801.46
7/4/07 15:22	59.23	474,418.50	357.56	487,595.41	90.15	0.00	272.17	535.72	966.64	1,495.62	856.98	801.72
7/4/07 15:23	58.53	467,840.19	357.44	485,868.81	93.90	0.00	271.93	535.53	966.31	1,492.15	856.63	801.27
7/4/07 15:24	58.33	467,743.00	357.29	484,142.19	93.20	0.00	271.79	535.25	965.80	1,496.60	855.78	800.77
7/4/07 15:25	58.82	470,640.19	357.19	482,415.50	90.54	0.00	271.53	535.35	967.11	1,501.84	855.59	800.60
7/4/07 15:26	58.00	463,844.00	357.15	482,264.69	86.90	0.00	271.25	535.64	969.80	1,492.77	856.38	801.40
7/4/07 15:27	58.29	465,920.31	357.13	482,204.09	84.14	0.00	270.99	535.62	969.68	1,499.05	856.74	801.54
7/4/07 15:28	57.85	463,640.41	357.10	482,143.50	82.54	0.00	270.84	535.41	969.48	1,498.93	856.66	801.19
7/4/07 15:29	58.76	469,439.31	357.06	481,819.59	82.48	0.00	270.62	535.79	971.77	1,503.01	857.04	802.19
7/4/07 15:30	58.09	465,798.41	357.08	480,916.59	81.08	0.00	270.55	535.91	971.42	1,497.72	857.53	802.36
7/4/07 15:31	57.38	459,719.41	357.10	480,013.69	79.95	0.00	270.61	535.95	969.77	1,492.31	857.48	802.71
7/4/07 15:32	57.40	459,621.69	357.15	479,110.69	78.67	0.00	270.64	536.02	967.98	1,496.21	857.45	802.62
7/4/07 15:33	57.57	460,186.50	357.14	478,207.69	74.77	0.00	270.59	536.43	968.23	1,496.08	857.74	802.71
7/4/07 15:34	58.10	465,306.19	357.22	477,304.69	73.07	0.00	270.47	536.70	968.00	1,504.40	857.96	802.39
7/4/07 15:35	57.95	462,978.50	357.18	476,401.69	74.90	0.00	270.37	536.73	968.70	1,500.33	857.91	802.08
7/4/07 15:36	59.19	473,245.41	357.14	478,646.19	76.86	0.00	270.35	536.76	970.07	1,510.81	857.63	801.80
7/4/07 15:37	59.68	477,969.59	357.07	481,698.31	74.12	0.00	270.38	536.86	973.05	1,511.25	857.89	802.03
7/4/07 15:38	59.66	477,315.91	356.99	484,750.31	74.79	0.00	270.54	536.93	975.25	1,507.21	858.21	802.13
7/4/07 15:39	59.97	479,360.91	356.91	487,708.50	79.06	0.00	270.73	536.64	974.63	1,509.35	858.07	801.91

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FLOW (TPH)	PROPANE FUEL FLOW (SCFH)	FWP DISCH FLOW (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/4/07 15:40	61.03	487,222.50	356.86	490,513.09	78.77	0.00	270.94	536.87	976.97	1,512.97	858.72	803.53
7/4/07 15:41	60.96	486,776.59	356.90	493,317.69	76.77	0.00	271.26	536.85	977.17	1,508.12	859.62	803.99
7/4/07 15:42	61.01	487,016.59	356.84	496,122.31	77.19	0.00	271.57	536.62	975.74	1,508.18	859.93	803.88
7/4/07 15:43	61.28	489,204.50	356.86	497,815.81	74.67	0.00	271.87	536.55	973.83	1,509.57	860.43	804.13
7/4/07 15:44	61.05	486,865.09	356.96	497,689.81	74.60	0.00	272.16	536.67	972.02	1,502.85	861.39	805.33
7/4/07 15:45	60.84	486,493.91	357.10	497,564.00	76.14	0.00	272.32	536.62	968.82	1,502.20	862.04	805.54
7/4/07 15:46	60.76	486,784.69	357.24	497,438.09	79.82	0.00	272.41	536.78	968.13	1,502.53	862.85	806.35
7/4/07 15:47	60.59	486,367.19	357.37	497,312.19	77.85	0.00	272.41	536.79	967.97	1,499.95	863.55	807.28
7/4/07 15:48	60.76	486,538.31	357.44	497,186.31	77.01	0.00	272.42	536.59	968.48	1,502.51	863.43	807.49
7/4/07 15:49	60.68	486,114.91	357.49	497,060.31	77.97	0.00	272.38	536.53	969.68	1,499.94	863.52	807.70
7/4/07 15:50	60.67	484,179.41	357.62	496,934.41	77.79	0.00	272.39	536.58	970.46	1,499.28	864.19	808.04
7/4/07 15:51	60.73	485,171.91	357.80	496,808.50	81.90	0.00	272.45	536.77	971.00	1,499.51	865.12	809.19
7/4/07 15:52	60.07	478,203.31	357.95	496,682.59	87.56	0.00	272.48	536.74	969.88	1,491.94	865.90	809.24
7/4/07 15:53	59.78	476,992.69	358.13	496,556.69	89.76	0.00	272.46	536.76	969.58	1,492.83	866.61	809.59
7/4/07 15:54	60.79	483,563.41	358.33	496,430.81	92.07	0.00	272.41	536.98	969.92	1,503.99	867.23	809.97
7/4/07 15:55	60.53	483,053.00	358.49	496,304.91	90.36	0.00	272.29	537.35	970.79	1,500.78	867.98	810.87
7/4/07 15:56	60.56	483,207.91	358.67	496,179.00	86.96	0.00	272.37	537.65	971.00	1,503.58	868.63	811.58
7/4/07 15:57	60.41	480,433.41	358.96	496,053.09	86.58	0.00	272.43	537.92	971.54	1,499.19	869.53	812.52
7/4/07 15:58	61.21	488,645.19	359.18	495,927.19	88.19	0.00	272.47	538.13	971.80	1,511.10	870.01	813.41
7/4/07 15:59	61.25	487,947.50	359.47	497,291.81	88.46	0.00	272.55	538.41	972.94	1,510.46	870.86	814.04
7/4/07 16:00	61.28	488,285.00	359.66	498,799.31	90.63	0.00	272.70	538.52	972.88	1,507.04	871.23	814.40
7/4/07 16:01	61.53	490,071.69	359.77	500,306.81	90.51	0.00	272.81	538.45	971.50	1,510.54	871.12	813.81
7/4/07 16:02	61.76	492,250.81	359.90	501,814.31	94.19	0.00	272.96	538.82	972.11	1,513.71	871.39	814.00
7/4/07 16:03	61.71	492,463.91	360.06	503,321.91	91.10	0.00	273.05	539.23	972.39	1,514.32	871.99	813.99
7/4/07 16:04	61.42	490,135.19	360.23	504,829.41	90.70	0.00	273.21	539.63	973.53	1,507.82	872.51	814.57
7/4/07 16:05	61.83	493,580.59	360.40	506,336.91	85.54	0.00	273.24	539.94	973.48	1,514.61	873.05	814.98
7/4/07 16:06	62.01	494,904.91	360.60	507,844.41	82.25	0.00	273.36	540.34	973.69	1,518.10	873.77	815.65
7/4/07 16:07	63.08	503,991.09	360.82	509,351.91	79.57	0.00	273.38	541.07	975.58	1,525.96	875.05	817.82
7/4/07 16:08	62.58	500,313.50	361.01	509,866.69	78.90	0.00	273.47	541.50	975.05	1,511.63	876.06	818.44
7/4/07 16:09	62.89	502,742.31	361.14	510,245.00	82.09	0.00	273.67	541.30	972.07	1,514.95	875.73	818.28
7/4/07 16:10	63.44	508,654.19	361.25	510,623.31	82.58	0.00	273.76	541.48	971.49	1,518.54	876.07	818.35
7/4/07 16:11	63.32	508,682.00	361.47	511,001.59	81.68	0.00	273.91	541.74	970.40	1,511.36	876.43	819.09
7/4/07 16:12	62.97	507,364.91	361.63	511,379.91	83.64	0.00	274.22	541.43	967.85	1,506.60	876.21	818.15
7/4/07 16:13	63.24	510,616.31	361.74	511,758.19	85.29	0.00	274.36	541.23	966.83	1,510.78	875.84	817.88
7/4/07 16:14	62.54	505,049.59	361.91	512,136.50	87.15	0.00	274.56	541.23	966.80	1,499.97	876.01	818.15
7/4/07 16:15	61.78	499,274.19	361.99	511,996.91	84.22	0.00	274.71	540.86	964.59	1,493.29	875.27	817.37
7/4/07 16:16	62.21	502,945.59	362.09	511,009.09	81.70	0.00	274.71	540.89	965.52	1,502.49	875.19	818.56
7/4/07 16:17	61.93	498,739.91	362.23	510,021.31	84.19	0.00	274.55	540.99	968.01	1,497.14	875.76	819.17
7/4/07 16:18	61.89	497,313.00	362.28	509,033.50	85.59	0.00	274.53	540.62	968.90	1,497.21	875.47	818.17
7/4/07 16:19	61.43	493,389.91	362.23	508,045.81	85.84	0.00	274.42	540.11	970.07	1,494.45	874.70	816.76
7/4/07 16:20	61.47	491,853.59	362.12	507,058.00	87.02	0.00	274.30	539.69	970.70	1,494.50	873.64	815.12
7/4/07 16:21	61.54	491,909.00	362.05	506,070.19	88.84	0.00	274.15	539.61	971.68	1,496.67	873.01	813.93
7/4/07 16:22	61.27	488,888.69	362.04	505,082.41	86.11	0.00	274.09	539.47	970.98	1,496.36	872.70	813.36
7/4/07 16:23	60.76	484,871.31	362.07	504,094.59	86.27	0.00	273.98	539.36	970.20	1,487.89	872.63	813.21
7/4/07 16:24	61.15	488,406.69	362.01	503,106.81	86.80	0.00	273.79	539.21	969.44	1,496.24	872.15	812.49
7/4/07 16:25	61.08	487,537.91	362.01	502,119.09	86.97	0.00	273.52	539.35	971.06	1,498.50	872.19	812.50
7/4/07 16:26	60.58	484,348.09	362.00	501,131.31	87.63	0.00	273.35	539.29	970.88	1,487.73	871.96	812.23
7/4/07 16:27	60.56	483,839.09	362.00	500,143.50	88.43	0.00	273.24	539.21	969.86	1,488.87	871.69	812.10
7/4/07 16:28	61.04	488,088.00	362.02	499,155.69	88.33	0.00	273.16	539.43	971.41	1,498.75	872.16	812.69
7/4/07 16:29	60.83	485,523.00	362.18	498,167.91	87.52	0.00	273.09	539.98	973.28	1,496.14	872.30	814.17

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/4/07 16:30	59.84	478,459.91	362.35	497,180.19	90.95	0.00	273.15	540.48	973.22	1,480.68	869.82	811.68
7/4/07 16:31	60.14	481,530.31	362.44	496,192.41	89.12	0.00	273.12	540.71	971.75	1,489.22	869.10	811.04
7/4/07 16:32	60.30	481,705.91	362.58	495,204.59	88.54	0.00	273.00	541.14	973.09	1,493.30	869.34	811.43
7/4/07 16:33	59.98	479,589.31	362.73	494,216.81	86.54	0.00	272.87	541.63	972.82	1,495.07	870.46	812.31
7/4/07 16:34	58.78	470,660.50	362.86	493,229.00	83.13	0.00	272.80	541.98	972.43	1,488.90	871.44	813.16
7/4/07 16:35	59.29	474,804.59	362.91	492,241.19	84.50	0.00	272.66	542.53	972.22	1,497.93	872.42	813.73
7/4/07 16:36	59.14	472,216.09	362.99	491,253.41	81.43	0.00	272.40	543.44	972.94	1,497.13	873.85	814.39
7/4/07 16:37	58.98	472,513.91	363.03	490,265.69	80.26	0.00	272.18	544.45	972.46	1,496.28	875.07	814.65
7/4/07 16:38	58.79	471,821.91	363.05	490,870.00	85.12	0.00	271.99	545.05	971.09	1,497.44	876.28	815.63
7/4/07 16:39	59.26	476,110.81	363.08	491,693.19	82.02	0.00	271.82	545.81	970.85	1,505.06	877.36	816.50
7/4/07 16:40	59.30	476,510.00	363.00	492,516.31	81.36	0.00	271.67	546.35	971.21	1,502.43	878.46	817.04
7/4/07 16:41	58.89	470,541.81	362.85	493,339.50	83.82	0.00	271.57	546.49	970.35	1,495.42	878.93	817.13
7/4/07 16:42	59.17	475,406.00	362.65	494,162.69	79.81	0.00	271.61	546.59	969.14	1,502.81	879.01	816.85
7/4/07 16:43	59.64	477,960.59	362.42	495,482.91	77.46	0.00	271.59	547.30	970.66	1,504.01	879.76	817.27
7/4/07 16:44	59.63	479,067.91	362.11	497,677.31	76.62	0.00	271.57	547.71	970.64	1,502.57	880.09	817.18
7/4/07 16:45	59.56	478,255.09	361.74	499,871.81	74.58	0.00	271.67	547.71	968.73	1,502.47	879.51	816.32
7/4/07 16:46	60.95	489,373.09	361.47	502,066.31	74.42	0.00	271.70	547.83	969.18	1,511.94	879.48	816.48
7/4/07 16:47	60.74	485,938.50	361.32	502,675.81	76.11	0.00	271.77	548.20	970.29	1,506.00	880.35	817.20
7/4/07 16:48	60.93	488,680.50	361.29	501,966.59	77.53	0.00	271.94	548.19	969.88	1,508.28	881.12	817.76
7/4/07 16:49	60.63	486,103.91	361.39	501,257.50	77.96	0.00	272.20	548.30	968.86	1,503.81	881.79	818.02
7/4/07 16:50	61.21	491,400.81	361.45	500,548.31	79.43	0.00	272.33	548.42	969.42	1,512.48	882.29	818.45
7/4/07 16:51	61.34	491,575.09	361.58	499,839.09	79.41	0.00	272.48	548.63	970.69	1,513.48	882.82	818.96
7/4/07 16:52	60.66	487,314.31	361.62	499,129.91	80.13	0.00	272.62	548.66	969.43	1,501.74	882.69	818.78
7/4/07 16:53	60.70	487,903.41	361.69	498,420.81	81.78	0.00	272.73	548.67	967.90	1,502.72	882.43	818.66
7/4/07 16:54	60.86	489,911.69	361.75	497,711.59	80.92	0.00	272.86	549.00	968.36	1,506.14	882.72	819.11
7/4/07 16:55	60.85	488,951.91	361.95	497,002.41	81.38	0.00	272.93	549.17	967.77	1,502.81	883.13	819.58
7/4/07 16:56	60.18	482,711.59	362.13	496,293.31	81.69	0.00	272.93	549.16	966.88	1,490.08	883.23	819.96
7/4/07 16:57	60.63	486,351.31	362.27	495,584.09	81.12	0.00	272.97	549.04	966.18	1,497.31	883.05	820.43
7/4/07 16:58	60.36	484,796.00	362.44	494,874.91	81.73	0.00	272.97	549.18	966.17	1,495.31	882.97	820.61
7/4/07 16:59	60.51	484,794.09	362.60	494,165.69	81.71	0.00	272.89	549.46	967.08	1,497.10	883.02	820.52
7/4/07 17:00	60.00	480,556.50	362.72	493,456.50	83.87	0.00	272.84	549.49	967.70	1,491.45	882.76	820.03
7/4/07 17:01	60.48	484,031.19	362.78	492,747.41	85.17	0.00	272.83	549.26	968.42	1,500.39	882.03	819.32
7/4/07 17:02	60.48	483,371.09	362.80	492,038.19	83.54	0.00	272.73	549.17	971.03	1,500.81	881.38	818.67
7/4/07 17:03	59.83	477,459.41	362.79	491,329.00	79.85	0.00	272.71	548.85	971.48	1,494.07	879.82	815.98
7/4/07 17:04	59.88	479,473.00	362.76	490,619.81	76.08	0.00	272.75	548.37	971.74	1,501.17	875.97	814.48
7/4/07 17:05	60.25	482,797.41	362.86	490,366.69	78.90	0.00	272.72	548.45	973.93	1,504.78	871.91	814.38
7/4/07 17:06	60.41	484,518.69	362.96	491,512.50	81.25	0.00	272.59	548.31	973.56	1,504.46	870.06	812.74
7/4/07 17:07	60.05	483,069.19	363.09	492,658.31	82.39	0.00	272.61	547.78	971.88	1,501.09	869.43	812.82
7/4/07 17:08	60.30	486,066.00	363.15	493,804.09	80.07	0.00	272.68	547.20	971.25	1,504.74	869.82	814.39
7/4/07 17:09	59.93	482,858.09	363.23	494,949.91	81.58	0.00	272.69	546.75	972.17	1,499.51	869.36	816.37
7/4/07 17:10	60.13	484,093.69	363.24	496,095.81	79.85	0.00	272.78	546.53	973.61	1,501.61	868.21	819.39
7/4/07 17:11	60.16	484,833.69	363.35	497,241.59	79.61	0.00	272.79	546.18	972.15	1,503.20	868.71	821.46
7/4/07 17:12	60.42	487,669.00	363.43	498,387.41	80.84	0.00	272.77	545.99	971.41	1,507.93	869.59	821.96
7/4/07 17:13	60.46	487,901.81	363.47	499,533.19	82.30	0.00	272.77	545.70	971.96	1,507.95	869.80	820.19
7/4/07 17:14	60.11	484,397.59	363.59	500,679.00	84.34	0.00	272.73	545.36	973.42	1,499.33	868.25	819.30
7/4/07 17:15	59.65	481,698.59	363.60	501,748.81	86.70	0.00	272.75	544.69	970.69	1,495.81	865.37	816.96
7/4/07 17:16	59.94	484,901.19	363.62	501,934.59	84.65	0.00	272.69	544.53	969.76	1,502.66	864.13	814.53
7/4/07 17:17	60.41	487,466.31	363.73	502,120.31	82.58	0.00	272.56	544.56	969.85	1,506.51	865.31	815.17
7/4/07 17:18	58.91	476,144.09	363.73	502,301.00	81.81	0.00	272.45	544.09	968.31	1,489.97	866.40	815.96
7/4/07 17:19	59.37	479,215.19	363.71	502,310.91	79.41	0.00	272.40	543.52	969.13	1,499.52	865.70	817.28

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/4/07 17:20	58.97	473,922.59	363.76	502,320.81	80.49	0.00	272.20	543.45	971.49	1,493.87	865.87	819.43
7/4/07 17:21	59.46	478,726.59	363.72	502,330.59	77.45	0.00	272.07	543.31	971.25	1,501.32	866.98	820.47
7/4/07 17:22	58.74	472,935.81	363.80	502,340.50	77.78	0.00	271.90	543.17	970.59	1,494.20	867.83	820.18
7/4/07 17:23	58.39	469,868.00	363.82	502,350.41	77.30	0.00	271.79	542.90	970.59	1,491.84	867.77	819.27
7/4/07 17:24	58.78	474,147.69	363.80	502,360.31	74.07	0.00	271.67	542.59	970.57	1,500.25	866.56	818.17
7/4/07 17:25	58.67	472,044.81	363.86	502,370.19	74.42	0.00	271.53	542.63	972.61	1,498.81	865.89	817.03
7/4/07 17:26	58.53	471,859.50	363.86	502,380.09	78.44	0.00	271.37	542.57	972.54	1,498.17	865.79	815.23
7/4/07 17:27	58.88	474,626.31	363.90	502,390.00	80.99	0.00	271.29	542.37	971.88	1,503.03	866.58	814.97
7/4/07 17:28	59.77	480,318.69	363.95	502,399.81	79.23	0.00	271.22	542.50	971.98	1,509.25	867.81	816.57
7/4/07 17:29	59.42	477,406.31	364.05	502,370.41	77.26	0.00	271.21	542.61	972.89	1,501.69	868.50	818.50
7/4/07 17:30	60.09	484,093.19	364.19	502,325.09	76.79	0.00	271.37	542.70	972.96	1,507.18	869.87	820.24
7/4/07 17:31	59.58	478,225.91	364.52	502,279.81	78.31	0.00	271.49	543.09	972.70	1,499.48	872.44	822.12
7/4/07 17:32	59.22	476,480.91	364.84	502,234.50	77.67	0.00	271.64	543.47	972.11	1,498.34	874.23	823.16
7/4/07 17:33	59.23	476,760.41	365.13	502,189.19	74.43	0.00	271.75	543.81	970.82	1,497.71	874.80	823.33
7/4/07 17:34	59.42	477,044.41	365.34	502,143.81	78.90	0.00	271.70	544.03	969.74	1,502.89	873.81	823.15
7/4/07 17:35	60.03	483,056.19	365.51	502,098.50	78.64	0.00	271.68	544.45	970.62	1,505.94	873.61	822.93
7/4/07 17:36	59.80	481,965.41	365.65	500,064.19	79.65	0.00	271.68	544.81	971.77	1,501.35	874.47	823.55
7/4/07 17:37	59.82	480,683.69	365.80	497,798.50	76.42	0.00	271.81	544.80	970.14	1,500.46	874.60	823.56
7/4/07 17:38	59.74	481,889.91	365.82	495,532.91	76.26	0.00	271.87	544.79	967.71	1,501.60	874.34	823.26
7/4/07 17:39	59.70	483,051.31	365.95	493,267.19	76.99	0.00	271.89	545.00	966.62	1,503.23	874.00	823.44
7/4/07 17:40	59.67	481,107.50	366.00	491,001.59	78.98	0.00	271.94	545.20	966.42	1,499.43	874.17	823.54
7/4/07 17:41	58.57	474,923.09	366.05	488,735.91	80.87	0.00	271.98	545.26	965.85	1,494.74	874.38	822.36
7/4/07 17:42	58.51	472,520.81	366.12	486,809.91	79.44	0.00	271.97	545.32	966.89	1,495.31	874.46	819.06
7/4/07 17:43	58.35	468,576.59	366.15	487,173.41	78.56	0.00	271.91	545.61	971.44	1,494.57	872.78	818.70
7/4/07 17:44	57.89	464,748.41	366.25	487,537.00	76.74	0.00	271.70	546.03	974.45	1,491.54	870.44	818.20
7/4/07 17:45	57.74	463,084.09	366.31	487,900.59	80.30	0.00	271.51	546.10	973.03	1,495.72	869.21	815.36
7/4/07 17:46	58.23	467,014.09	366.35	488,264.09	79.87	0.00	271.25	546.43	973.68	1,501.61	870.06	815.14
7/4/07 17:47	58.83	470,995.50	366.44	488,241.59	79.38	0.00	270.94	546.91	975.43	1,502.66	872.22	817.32
7/4/07 17:48	58.94	470,692.09	366.55	487,974.81	78.94	0.00	270.88	547.11	977.11	1,501.34	872.50	818.64
7/4/07 17:49	59.16	473,085.59	366.63	487,707.91	77.01	0.00	270.89	547.12	977.30	1,505.27	872.13	820.24
7/4/07 17:50	59.15	473,491.81	366.71	487,441.09	79.98	0.00	270.97	547.26	976.51	1,502.01	873.34	821.42
7/4/07 17:51	59.27	475,180.41	366.78	487,174.31	80.62	0.00	271.04	547.41	974.73	1,503.04	874.67	820.95
7/4/07 17:52	59.08	473,408.09	366.77	486,907.41	80.19	0.00	271.17	547.24	971.93	1,502.13	874.75	819.26
7/4/07 17:53	58.70	470,985.91	366.83	486,640.59	79.45	0.00	271.29	547.26	971.60	1,498.25	872.61	818.53
7/4/07 17:54	58.92	473,328.31	366.82	486,600.09	79.49	0.00	271.32	547.57	970.55	1,500.77	870.27	816.96
7/4/07 17:55	58.53	470,086.00	366.85	487,596.19	79.61	0.00	271.30	547.79	969.78	1,496.51	869.86	814.68
7/4/07 17:56	58.63	471,773.00	366.79	488,592.31	76.73	0.00	271.27	547.71	967.72	1,500.07	870.33	814.01
7/4/07 17:57	58.80	471,522.50	366.83	489,588.50	75.34	0.00	271.24	547.85	968.76	1,497.32	871.34	814.68
7/4/07 17:58	58.69	472,081.31	366.83	490,584.59	77.13	0.00	271.19	547.80	969.45	1,501.66	870.57	815.19
7/4/07 17:59	58.04	467,234.59	366.80	491,580.81	81.50	0.00	271.14	547.70	969.71	1,496.34	869.91	815.89
7/4/07 18:00	58.39	470,444.59	366.79	492,576.91	85.35	0.00	271.10	547.72	969.53	1,501.08	870.80	816.82
7/4/07 18:01	59.64	479,580.91	366.77	493,573.00	83.02	0.00	270.97	547.91	970.81	1,511.07	872.12	816.53
7/4/07 18:02	59.31	476,134.31	366.83	493,683.91	80.05	0.00	270.83	548.18	973.30	1,503.58	873.18	816.53
7/4/07 18:03	58.26	467,610.69	366.85	495,311.59	79.70	0.00	270.94	547.78	971.96	1,494.11	871.08	815.71
7/4/07 18:04	59.01	471,665.91	366.79	497,363.41	80.48	0.00	271.06	547.48	971.73	1,501.55	869.07	814.02
7/4/07 18:05	59.96	479,809.41	366.76	499,415.19	81.86	0.00	271.03	547.76	973.09	1,507.69	869.97	813.87
7/4/07 18:06	58.43	469,949.41	366.78	496,624.50	79.32	0.00	271.06	547.81	971.12	1,494.85	871.33	814.66
7/4/07 18:07	58.49	469,980.69	366.75	493,464.59	76.51	0.00	271.16	547.30	967.84	1,497.98	871.25	814.97
7/4/07 18:08	58.85	473,275.59	366.68	490,489.91	72.68	0.00	271.17	547.14	968.46	1,499.93	870.52	815.97
7/4/07 18:09	58.75	471,809.91	366.60	488,763.19	76.26	0.00	271.13	546.93	968.37	1,499.77	870.53	816.84

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/4/07 18:10	58.90	475,630.59	366.60	487,036.41	73.55	0.00	271.10	546.82	968.91	1,501.02	871.65	817.28
7/4/07 18:11	58.20	468,205.81	366.57	485,309.69	71.99	0.00	271.13	546.51	967.84	1,495.75	872.34	814.39
7/4/07 18:12	58.60	471,941.81	366.56	483,583.00	76.44	0.00	271.18	546.28	967.90	1,500.80	870.74	811.56
7/4/07 18:13	58.29	469,272.09	366.66	481,856.19	75.13	0.00	271.11	546.21	968.72	1,498.56	867.52	810.56
7/4/07 18:14	57.12	460,681.41	366.76	480,129.50	79.74	0.00	271.05	546.21	967.58	1,490.15	866.08	808.82
7/4/07 18:15	57.52	463,413.41	366.84	479,664.59	77.35	0.00	270.96	546.29	966.85	1,496.58	866.22	807.07
7/4/07 18:16	57.68	464,571.09	366.93	482,203.19	74.96	0.00	270.75	546.57	968.19	1,497.22	867.63	808.73
7/4/07 18:17	57.10	459,821.00	366.98	484,741.81	74.73	0.00	270.63	546.50	968.43	1,493.21	867.33	809.76
7/4/07 18:18	57.77	465,017.81	366.99	487,280.41	74.94	0.00	270.51	546.46	969.48	1,503.01	865.37	810.28
7/4/07 18:19	58.85	470,950.09	367.04	489,294.59	75.48	0.00	270.34	546.76	973.23	1,503.99	866.36	812.64
7/4/07 18:20	58.09	465,366.09	367.03	490,155.31	75.57	0.00	270.34	546.46	971.90	1,500.87	867.26	812.09
7/4/07 18:21	58.02	465,762.50	366.92	491,015.81	73.30	0.00	270.38	546.07	971.13	1,502.45	867.24	808.75
7/4/07 18:22	58.57	470,240.09	366.81	491,876.41	71.03	0.00	270.42	546.06	972.58	1,505.39	865.69	807.66
7/4/07 18:23	59.01	471,821.00	366.82	493,332.81	70.50	0.00	270.42	546.03	973.01	1,504.80	863.38	806.97
7/4/07 18:24	58.93	471,891.91	366.80	494,926.81	72.16	0.00	270.47	545.87	971.94	1,501.56	862.99	805.07
7/4/07 18:25	58.67	470,513.81	366.71	496,520.69	78.03	0.00	270.58	545.47	970.32	1,498.57	863.40	803.78
7/4/07 18:26	59.49	477,855.00	366.61	498,114.59	78.14	0.00	270.70	544.99	969.68	1,506.72	863.85	804.37
7/4/07 18:27	59.78	478,536.41	366.48	499,150.31	79.88	0.00	270.78	544.71	971.34	1,505.99	863.26	806.09
7/4/07 18:28	59.26	475,288.81	366.38	499,048.31	82.60	0.00	270.91	544.26	970.77	1,499.00	861.96	807.27
7/4/07 18:29	59.48	479,007.81	366.31	498,946.31	85.57	0.00	271.10	544.00	969.35	1,504.03	862.51	808.69
7/4/07 18:30	59.36	477,221.69	366.29	498,844.31	81.74	0.00	271.21	543.91	969.60	1,501.21	864.08	808.72
7/4/07 18:31	58.90	472,745.91	366.17	498,742.31	84.90	0.00	271.31	543.38	968.37	1,496.47	864.17	805.70
7/4/07 18:32	59.38	476,531.69	366.05	498,640.31	85.49	0.00	271.31	542.92	968.61	1,504.05	861.46	804.12
7/4/07 18:33	59.44	477,048.00	366.11	498,604.91	83.12	0.00	271.26	542.84	971.00	1,501.52	859.22	803.63
7/4/07 18:34	59.60	477,074.59	366.02	498,705.41	83.67	0.00	271.31	542.64	970.35	1,503.21	859.68	800.72
7/4/07 18:35	58.89	472,769.91	366.05	498,806.00	81.73	0.00	271.26	542.39	969.66	1,497.76	860.72	800.46
7/4/07 18:36	60.02	483,291.91	366.03	498,906.50	84.85	0.00	271.21	542.08	970.24	1,507.45	861.73	801.77
7/4/07 18:37	59.64	477,848.91	365.96	499,500.69	84.33	0.00	271.15	541.78	971.98	1,500.04	861.36	803.72
7/4/07 18:38	59.98	479,615.81	365.85	500,142.19	85.43	0.00	271.24	541.26	971.64	1,503.66	860.74	805.09
7/4/07 18:39	60.39	483,743.91	365.77	500,783.69	82.40	0.00	271.29	540.91	971.03	1,506.47	861.88	806.89
7/4/07 18:40	60.47	481,174.81	365.72	501,425.19	79.38	0.00	271.36	540.88	973.10	1,502.16	863.86	805.70
7/4/07 18:41	60.46	483,798.59	365.73	502,066.69	79.95	0.00	271.56	540.24	973.26	1,504.18	863.32	801.33
7/4/07 18:42	59.89	475,491.19	365.79	502,670.00	81.46	0.00	271.70	539.63	973.22	1,495.93	859.54	800.02
7/4/07 18:43	60.26	482,632.41	365.77	503,087.91	81.86	0.00	271.80	539.03	972.20	1,505.17	856.33	797.34
7/4/07 18:44	59.88	477,661.00	365.74	503,309.69	85.01	0.00	271.77	538.80	972.68	1,497.44	856.13	795.02
7/4/07 18:45	59.63	476,608.41	365.61	502,519.81	88.13	0.00	271.79	538.44	971.38	1,497.80	856.69	792.88
7/4/07 18:46	59.34	474,966.69	365.45	501,730.00	90.31	0.00	271.83	537.96	969.27	1,498.72	855.57	789.65
7/4/07 18:47	60.27	481,039.09	365.41	500,437.81	89.08	0.00	271.78	537.98	970.66	1,504.67	852.74	790.42
7/4/07 18:48	59.20	474,830.91	365.42	497,604.69	84.30	0.00	271.70	537.83	968.76	1,496.11	851.54	790.09
7/4/07 18:49	59.40	475,674.81	365.50	494,771.59	81.49	0.00	271.68	537.91	967.72	1,498.59	852.87	789.26
7/4/07 18:50	59.61	476,592.91	365.58	495,214.81	79.95	0.00	271.53	538.14	968.43	1,503.33	854.91	792.15
7/4/07 18:51	58.73	470,638.31	365.67	493,409.00	79.21	0.00	271.42	538.31	969.42	1,492.25	856.34	795.55
7/4/07 18:52	59.19	474,848.81	365.67	490,366.19	79.13	0.00	271.40	538.14	968.58	1,500.79	855.37	797.47
7/4/07 18:53	58.89	471,348.81	365.71	489,142.81	80.84	0.00	271.28	538.26	968.26	1,498.85	855.78	799.73
7/4/07 18:54	59.34	478,452.69	365.71	491,972.41	81.58	0.00	271.20	538.79	969.82	1,505.82	857.69	801.76
7/4/07 18:55	58.49	467,314.19	365.75	489,215.19	81.20	0.00	271.11	538.83	970.73	1,492.37	859.50	797.15
7/4/07 18:56	58.50	468,534.81	365.72	485,516.19	80.15	0.00	271.12	538.50	970.76	1,497.86	856.69	793.88
7/4/07 18:57	58.87	470,559.50	365.61	488,061.50	78.37	0.00	271.03	538.38	971.52	1,503.52	852.14	792.73
7/4/07 18:58	58.89	469,627.00	365.62	491,536.59	79.21	0.00	270.91	538.75	974.20	1,498.40	850.70	789.96
7/4/07 18:59	59.03	470,532.69	365.60	489,695.91	76.19	0.00	270.84	538.71	973.70	1,499.55	851.70	788.82

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/4/07 19:00	59.32	472,737.81	365.59	489,426.91	78.64	0.00	270.88	538.65	973.20	1,501.84	853.18	790.90
7/4/07 19:01	59.75	475,501.19	365.50	491,007.50	79.23	0.00	270.95	538.42	972.81	1,505.57	852.79	792.64
7/4/07 19:02	59.48	472,902.09	365.49	491,303.59	78.87	0.00	270.97	538.18	971.95	1,500.39	851.33	793.84
7/4/07 19:03	59.28	474,385.59	365.41	491,054.41	79.99	0.00	271.00	538.05	970.89	1,501.10	851.53	795.45
7/4/07 19:04	59.15	473,128.31	365.33	491,076.19	79.37	0.00	271.11	538.18	969.25	1,501.15	852.44	795.78
7/4/07 19:05	59.58	474,903.81	365.30	491,790.00	81.10	0.00	271.11	538.35	970.93	1,501.88	853.26	792.47
7/4/07 19:06	59.39	473,792.41	365.23	492,503.91	83.36	0.00	271.12	538.18	970.76	1,499.31	851.61	791.54
7/4/07 19:07	60.05	479,490.69	365.17	493,929.00	79.36	0.00	271.17	538.08	970.64	1,507.68	849.18	790.69
7/4/07 19:08	60.80	484,009.81	365.16	496,591.31	75.09	0.00	271.19	538.27	973.51	1,508.07	850.19	788.74
7/4/07 19:09	60.58	482,684.69	365.14	499,253.59	77.81	0.00	271.29	538.24	973.29	1,504.06	851.74	790.24
7/4/07 19:10	61.08	487,192.31	365.17	502,621.31	77.27	0.00	271.41	538.03	973.08	1,509.94	852.67	792.43
7/4/07 19:11	61.58	490,414.09	365.16	506,551.19	78.35	0.00	271.56	537.91	973.93	1,514.61	852.26	794.44
7/4/07 19:12	61.34	488,002.69	365.14	508,945.19	79.16	0.00	271.71	537.80	974.42	1,507.74	852.15	796.01
7/4/07 19:13	61.81	492,106.69	365.08	509,437.69	81.18	0.00	271.90	537.46	974.20	1,514.52	852.91	797.44
7/4/07 19:14	61.57	490,091.00	364.96	509,930.19	79.66	0.00	272.07	537.01	972.64	1,509.09	852.49	795.39
7/4/07 19:15	61.88	491,448.81	364.82	510,422.69	77.43	0.00	272.29	536.59	972.40	1,513.96	850.94	791.98
7/4/07 19:16	61.62	490,793.81	364.73	510,133.59	76.85	0.00	272.41	536.32	972.44	1,508.29	849.85	790.62
7/4/07 19:17	61.26	488,481.41	364.64	508,246.09	78.26	0.00	272.55	535.84	970.81	1,500.74	848.58	788.75
7/4/07 19:18	61.79	493,333.91	364.62	508,840.59	81.83	0.00	272.65	535.43	969.93	1,512.37	848.19	787.87
7/4/07 19:19	61.41	490,468.69	364.58	509,053.81	82.25	0.00	272.69	535.42	970.70	1,504.73	849.67	790.33
7/4/07 19:20	61.33	489,108.19	364.75	509,266.91	78.60	0.00	272.68	535.21	969.65	1,502.53	850.32	791.81
7/4/07 19:21	61.12	487,890.81	364.86	509,480.00	79.55	0.00	272.68	534.98	968.45	1,496.83	850.46	792.48
7/4/07 19:22	61.19	487,550.91	364.96	509,693.19	76.79	0.00	272.61	534.84	968.35	1,498.33	850.67	794.07
7/4/07 19:23	61.05	486,257.19	365.02	509,906.31	73.90	0.00	272.58	534.71	967.70	1,495.94	851.89	795.32
7/4/07 19:24	61.11	487,683.59	365.11	510,119.41	78.20	0.00	272.55	534.65	967.99	1,498.17	853.10	794.21
7/4/07 19:25	61.18	487,714.69	365.17	510,332.50	76.09	0.00	272.53	534.81	970.30	1,498.64	854.29	795.29
7/4/07 19:26	60.99	485,082.19	365.23	510,545.69	72.31	0.00	272.51	534.80	970.92	1,495.54	855.24	795.31
7/4/07 19:27	61.23	487,307.09	365.29	510,758.81	72.81	0.00	272.52	534.85	971.96	1,501.92	855.90	794.24
7/4/07 19:28	61.55	489,288.09	365.39	510,971.91	74.66	0.00	272.54	535.16	974.22	1,506.11	857.57	795.31
7/4/07 19:29	61.71	489,069.59	365.48	511,185.09	81.92	0.00	272.55	535.36	975.98	1,507.91	859.01	797.50
7/4/07 19:30	61.87	489,495.59	365.51	511,398.19	82.89	0.00	272.61	535.39	975.38	1,510.18	859.29	798.12
7/4/07 19:31	61.73	489,070.00	365.63	511,611.31	84.53	0.00	272.72	535.43	974.46	1,506.43	859.33	798.86
7/4/07 19:32	62.08	492,464.91	365.69	511,824.50	84.54	0.00	272.84	535.47	973.16	1,512.40	859.55	800.22
7/4/07 19:33	62.16	494,005.81	365.73	512,037.59	84.76	0.00	272.83	535.85	972.19	1,514.65	860.49	801.52
7/4/07 19:34	61.66	490,302.50	365.76	512,250.81	88.04	0.00	272.99	536.00	968.28	1,505.32	860.51	801.68
7/4/07 19:35	62.23	497,056.59	365.83	512,463.91	86.78	0.00	273.07	536.20	964.58	1,515.60	860.08	802.43
7/4/07 19:36	61.81	493,286.31	365.97	512,341.00	83.05	0.00	273.12	536.69	964.26	1,504.88	860.02	804.10
7/4/07 19:37	61.76	494,583.50	366.02	511,739.41	80.14	0.00	273.22	536.61	961.27	1,504.39	859.10	803.37
7/4/07 19:38	61.70	494,031.31	366.04	511,137.81	81.93	0.00	273.41	536.73	962.62	1,504.44	858.99	804.73
7/4/07 19:39	61.94	496,131.69	366.12	510,536.31	85.46	0.00	273.41	537.07	965.70	1,504.82	859.78	808.40
7/4/07 19:40	61.55	491,474.69	366.14	509,934.81	83.34	0.00	273.44	537.18	965.15	1,499.39	859.98	810.76
7/4/07 19:41	61.99	496,351.31	366.20	509,333.19	80.46	0.00	273.44	537.18	965.79	1,505.82	859.85	812.82
7/4/07 19:42	61.22	488,656.19	366.19	508,731.69	80.88	0.00	273.38	537.28	966.53	1,496.21	860.11	815.48
7/4/07 19:43	61.07	487,603.09	366.11	508,130.09	80.04	0.00	273.36	537.13	965.41	1,493.07	860.18	815.53
7/4/07 19:44	61.14	488,238.50	366.03	507,528.59	76.22	0.00	273.29	537.05	964.73	1,494.32	860.16	814.71
7/4/07 19:45	60.87	486,819.19	365.87	506,927.00	75.58	0.00	273.18	537.03	964.26	1,490.85	860.26	813.78
7/4/07 19:46	61.41	491,787.09	365.74	506,325.50	79.54	0.00	273.07	537.03	964.81	1,502.04	860.52	812.74
7/4/07 19:47	60.88	485,933.91	365.67	505,723.91	79.61	0.00	272.92	537.05	966.27	1,490.37	861.03	812.21
7/4/07 19:48	61.16	487,810.91	365.57	505,122.41	79.75	0.00	272.92	536.79	966.09	1,495.86	860.92	810.78
7/4/07 19:49	61.21	488,000.81	365.45	504,520.81	82.20	0.00	272.87	536.71	967.58	1,497.06	861.10	810.07

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/4/07 19:50	61.42	490,140.00	365.34	503,919.31	79.53	0.00	272.84	536.85	969.33	1,503.54	861.61	809.65
7/4/07 19:51	61.26	487,624.81	365.30	503,317.69	77.61	0.00	272.85	536.83	969.80	1,497.98	861.88	808.80
7/4/07 19:52	61.47	489,033.09	365.16	502,716.19	75.78	0.00	272.93	536.81	970.01	1,500.90	861.95	808.11
7/4/07 19:53	61.49	487,742.69	365.10	502,114.59	76.55	0.00	272.94	536.86	970.27	1,500.85	862.21	807.66
7/4/07 19:54	61.36	485,070.00	365.04	501,513.09	78.86	0.00	273.00	536.97	970.83	1,498.92	862.47	807.61
7/4/07 19:55	61.39	487,074.59	364.93	500,911.50	78.80	0.00	273.10	536.88	969.35	1,498.56	862.28	806.83
7/4/07 19:56	61.29	486,975.59	364.82	500,310.00	75.08	0.00	273.16	536.93	968.77	1,497.10	862.03	806.95
7/4/07 19:57	61.20	486,620.69	364.75	499,708.41	73.04	0.00	273.15	537.36	968.85	1,497.32	860.04	806.41
7/4/07 19:58	60.81	482,155.81	364.78	499,106.91	72.06	0.00	273.10	538.10	969.04	1,490.49	858.03	803.98
7/4/07 19:59	61.22	485,967.81	364.80	498,505.31	69.66	0.00	273.09	538.48	969.45	1,498.97	857.64	803.92
7/4/07 20:00	60.93	483,016.81	364.82	497,903.81	71.67	0.00	273.08	538.65	970.53	1,494.95	858.12	804.45
7/4/07 20:01	61.42	486,464.81	364.85	497,302.31	72.04	0.00	273.05	538.83	972.37	1,504.30	858.97	805.32
7/4/07 20:02	60.92	482,819.59	364.81	496,993.50	70.26	0.00	272.97	538.96	972.57	1,495.33	860.08	805.95
7/4/07 20:03	61.36	484,757.81	364.76	496,897.50	69.11	0.00	272.92	539.06	972.29	1,504.02	860.58	805.51
7/4/07 20:04	61.68	488,163.31	364.62	496,801.59	67.68	0.00	272.86	539.69	973.35	1,508.89	861.66	806.31
7/4/07 20:05	61.30	483,439.31	364.49	496,705.59	65.64	0.00	272.77	540.21	973.94	1,499.74	862.68	806.98
7/4/07 20:06	61.72	489,041.41	364.16	496,609.59	67.01	0.00	272.81	540.09	971.76	1,507.84	862.91	806.66
7/4/07 20:07	61.20	484,739.19	363.86	496,513.59	67.00	0.00	272.83	540.09	972.03	1,498.32	863.37	807.44
7/4/07 20:08	61.75	489,018.31	363.45	496,417.59	70.40	0.00	272.82	539.86	970.68	1,507.26	863.42	807.48
7/4/07 20:09	61.20	485,879.31	363.08	496,321.69	72.08	0.00	272.84	539.74	969.66	1,498.67	863.64	807.58
7/4/07 20:10	61.40	487,017.00	362.60	496,225.69	74.28	0.00	272.80	539.57	968.34	1,501.33	863.74	807.39
7/4/07 20:11	60.88	483,560.69	362.12	496,129.69	73.53	0.00	272.79	539.54	967.35	1,495.33	863.81	806.88
7/4/07 20:12	60.94	482,988.50	361.52	494,775.59	72.39	0.00	272.73	539.74	968.15	1,495.75	864.06	806.86
7/4/07 20:13	60.80	482,341.31	360.92	493,192.19	70.37	0.00	272.66	539.57	966.26	1,496.24	863.66	806.76
7/4/07 20:14	60.29	478,738.19	360.39	491,608.81	70.62	0.00	272.57	539.49	966.54	1,493.94	863.59	807.15
7/4/07 20:15	60.20	479,545.09	359.98	490,025.31	69.34	0.00	272.50	539.47	966.70	1,496.91	862.24	807.28
7/4/07 20:16	60.42	478,772.19	359.68	489,556.09	69.21	0.00	272.35	539.96	969.01	1,497.86	859.73	805.88
7/4/07 20:17	60.56	478,767.81	359.50	489,171.69	69.07	0.00	272.16	540.14	970.59	1,498.75	859.65	807.08
7/4/07 20:18	59.55	471,801.91	359.34	488,789.41	68.08	0.00	272.12	539.85	969.62	1,495.37	859.55	807.41
7/4/07 20:19	60.63	480,487.50	359.22	488,415.09	65.34	0.00	272.02	540.07	970.93	1,506.07	860.14	808.31
7/4/07 20:20	59.69	471,892.09	359.14	488,040.69	66.28	0.00	271.85	540.44	971.39	1,495.16	861.14	809.28
7/4/07 20:21	59.55	471,354.59	358.98	487,666.31	67.25	0.00	271.79	540.52	969.56	1,496.10	861.53	808.82
7/4/07 20:22	59.91	472,816.59	358.88	488,800.09	68.17	0.00	271.70	540.79	969.19	1,499.57	862.01	809.42
7/4/07 20:23	58.86	466,654.81	358.72	490,281.91	66.09	0.00	271.59	541.16	969.27	1,493.12	862.65	809.74
7/4/07 20:24	59.24	470,485.09	358.56	491,763.81	66.10	0.00	271.47	541.11	968.31	1,499.38	862.88	810.07
7/4/07 20:25	59.32	469,960.41	358.33	493,245.59	67.70	0.00	271.34	541.29	969.63	1,499.39	863.58	811.13
7/4/07 20:26	59.68	472,670.69	358.13	494,727.41	69.43	0.00	271.27	541.25	969.81	1,503.82	863.89	811.36
7/4/07 20:27	60.28	475,905.50	357.94	496,209.31	70.02	0.00	271.19	541.40	970.97	1,507.43	864.33	811.58
7/4/07 20:28	59.85	473,426.41	357.73	497,691.09	73.25	0.00	271.19	541.50	971.46	1,499.99	864.82	812.55
7/4/07 20:29	60.18	475,348.31	357.49	499,172.91	71.06	0.00	271.16	541.47	970.28	1,505.05	864.59	812.40
7/4/07 20:30	61.20	485,378.69	357.21	500,654.81	72.46	0.00	271.25	541.82	971.72	1,510.88	865.17	812.68
7/4/07 20:31	60.94	481,831.91	356.95	499,171.00	71.95	0.00	271.30	541.86	971.19	1,503.93	865.78	813.59
7/4/07 20:32	61.02	482,043.50	356.72	497,402.81	73.64	0.00	271.46	541.50	969.19	1,505.45	865.72	813.76
7/4/07 20:33	61.66	487,920.41	356.51	495,634.69	74.22	0.00	271.60	541.40	969.34	1,511.01	865.93	814.09
7/4/07 20:34	61.38	485,614.81	356.34	493,866.50	78.49	0.00	271.71	541.31	969.48	1,504.42	866.31	814.34
7/4/07 20:35	60.49	476,110.09	356.15	492,098.41	81.01	0.00	271.85	540.93	967.48	1,491.21	865.96	813.78
7/4/07 20:36	60.48	479,211.00	355.98	490,284.41	82.55	0.00	272.00	540.46	964.35	1,497.62	864.98	813.35
7/4/07 20:37	59.90	475,521.81	355.80	488,453.31	80.02	0.00	272.01	540.41	963.66	1,494.30	864.66	813.37
7/4/07 20:38	59.43	471,458.09	355.66	486,622.31	78.13	0.00	271.90	540.48	963.19	1,492.33	864.41	813.50
7/4/07 20:39	58.62	464,335.00	355.53	484,791.31	79.11	0.00	271.78	540.49	962.91	1,489.55	864.06	814.26

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/4/07 20:40	58.83	466,654.41	355.38	482,960.31	77.55	0.00	271.60	540.42	962.82	1,494.81	863.49	814.06
7/4/07 20:41	59.02	467,792.41	355.28	481,129.19	83.00	0.00	271.43	540.44	964.26	1,499.43	862.94	814.19
7/4/07 20:42	58.94	465,174.91	355.20	480,774.09	83.83	0.00	271.14	540.58	966.03	1,495.64	862.86	814.17
7/4/07 20:43	60.35	477,154.69	355.15	484,565.81	86.80	0.00	270.88	540.52	966.97	1,509.73	862.50	813.69
7/4/07 20:44	61.73	487,206.81	355.07	487,766.91	89.52	0.00	270.77	540.69	969.61	1,515.95	862.95	814.01
7/4/07 20:45	61.90	487,551.31	355.03	489,669.00	86.47	0.00	270.92	540.56	971.02	1,511.09	863.50	814.48
7/4/07 20:46	61.86	487,497.50	355.02	491,571.09	82.39	0.00	271.26	540.01	969.20	1,509.56	863.29	813.91
7/4/07 20:47	62.86	496,086.31	354.91	493,473.19	80.19	0.00	271.64	539.63	968.97	1,523.46	863.21	815.36
7/4/07 20:48	62.65	493,953.50	354.85	495,375.31	79.46	0.00	272.01	539.50	970.22	1,518.11	863.63	817.02
7/4/07 20:49	62.59	494,399.59	354.81	497,277.41	83.76	0.00	272.43	538.98	968.84	1,515.53	863.47	817.58
7/4/07 20:50	62.86	496,090.69	354.75	499,179.50	89.51	0.00	272.81	538.53	968.22	1,520.62	863.44	818.15
7/4/07 20:51	63.68	504,862.50	354.68	501,677.19	88.93	0.00	273.07	538.14	968.25	1,529.33	863.62	818.49
7/4/07 20:52	63.66	504,162.19	354.67	505,485.31	87.20	0.00	273.33	537.88	968.97	1,523.28	864.23	819.81
7/4/07 20:53	63.82	506,957.41	354.65	509,293.41	86.08	0.00	273.62	537.29	968.00	1,517.89	864.48	820.28
7/4/07 20:54	64.31	511,293.00	354.57	513,101.41	83.71	0.00	273.89	536.68	967.07	1,521.31	864.62	820.20
7/4/07 20:55	65.13	518,925.00	354.63	516,909.50	84.24	0.00	274.09	536.38	968.85	1,524.04	865.36	820.79
7/4/07 20:56	64.82	516,920.31	354.66	520,717.59	81.87	0.00	274.36	535.79	968.53	1,514.53	865.76	821.37
7/4/07 20:57	64.33	512,839.31	354.58	524,249.91	81.33	0.00	274.69	534.85	965.95	1,506.48	865.09	820.55
7/4/07 20:58	64.79	517,726.81	354.43	522,040.91	86.84	0.00	274.95	533.96	965.18	1,513.46	864.05	819.44
7/4/07 20:59	64.11	511,784.00	354.34	519,831.81	89.38	0.00	275.06	533.55	965.16	1,501.46	863.43	818.99
7/4/07 21:00	64.28	513,433.31	354.31	517,622.81	89.48	0.00	275.23	532.97	963.62	1,505.27	862.88	818.64
7/4/07 21:01	63.54	507,959.19	354.39	515,413.81	91.17	0.00	275.25	532.71	963.77	1,496.01	863.35	819.24
7/4/07 21:02	63.69	508,373.50	354.52	513,204.81	89.63	0.00	275.24	532.46	964.56	1,500.14	864.30	819.71
7/4/07 21:03	62.69	498,616.19	354.70	510,995.81	86.61	0.00	275.14	532.06	964.62	1,489.79	865.08	819.38
7/4/07 21:04	62.72	499,041.81	354.79	510,178.41	85.31	0.00	275.02	531.53	965.26	1,492.40	865.11	818.42
7/4/07 21:05	62.91	499,007.00	354.86	512,197.09	85.69	0.00	274.79	531.16	968.41	1,498.44	865.02	818.98
7/4/07 21:06	62.84	497,042.59	354.86	514,215.91	86.60	0.00	274.46	530.99	972.12	1,497.47	865.16	819.17
7/4/07 21:07	62.78	495,135.81	354.78	516,234.59	88.77	0.00	274.21	530.36	973.34	1,497.93	864.40	817.91
7/4/07 21:08	63.36	499,921.00	354.69	518,253.31	88.21	0.00	274.08	530.12	975.86	1,506.37	863.82	817.75
7/4/07 21:09	64.81	510,332.59	354.76	520,272.09	89.20	0.00	273.98	530.22	978.23	1,519.12	863.80	818.19
7/4/07 21:10	64.77	510,009.59	354.79	520,526.50	85.15	0.00	273.96	530.44	979.26	1,514.33	864.20	819.03
7/4/07 21:11	64.59	509,102.50	354.83	520,231.50	80.58	0.00	274.21	530.06	976.13	1,510.59	863.82	818.28
7/4/07 21:12	64.64	510,566.19	354.81	519,936.50	77.97	0.00	274.46	529.94	973.71	1,509.73	863.58	817.51
7/4/07 21:13	64.74	511,696.19	354.84	519,641.50	77.35	0.00	274.75	529.96	972.40	1,506.67	863.76	817.75
7/4/07 21:14	64.15	506,456.09	354.86	519,346.41	80.16	0.00	275.02	529.81	969.89	1,500.64	863.53	817.53
7/4/07 21:15	64.10	506,516.59	354.87	519,051.41	80.25	0.00	275.26	529.62	967.94	1,501.57	863.39	817.32
7/4/07 21:16	64.44	512,042.09	354.99	518,756.41	77.57	0.00	275.32	529.86	969.06	1,508.47	863.85	818.16
7/4/07 21:17	64.69	513,569.50	355.14	518,461.31	79.83	0.00	275.40	530.20	970.79	1,507.18	864.96	818.92
7/4/07 21:18	64.24	510,072.81	355.25	518,166.31	79.43	0.00	275.47	530.32	971.04	1,500.79	865.38	819.24
7/4/07 21:19	64.08	508,204.50	355.33	517,871.31	78.65	0.00	275.48	530.34	970.06	1,500.62	865.48	819.03
7/4/07 21:20	64.59	511,400.09	355.50	517,576.31	76.80	0.00	275.42	530.80	971.03	1,507.75	866.10	819.97
7/4/07 21:21	64.27	509,003.19	355.65	517,281.31	77.74	0.00	275.33	531.25	971.25	1,502.71	866.87	820.65
7/4/07 21:22	64.02	507,066.41	355.80	516,986.19	77.93	0.00	275.21	531.56	970.64	1,501.68	867.29	820.80
7/4/07 21:23	64.59	510,949.19	356.01	516,691.19	79.66	0.00	275.11	531.96	971.00	1,507.71	867.96	821.26
7/4/07 21:24	64.69	511,949.00	356.21	516,396.19	79.90	0.00	274.98	532.26	971.67	1,507.47	868.85	822.11
7/4/07 21:25	64.51	510,564.69	356.43	516,101.09	77.52	0.00	274.92	532.59	971.37	1,504.53	869.51	823.05
7/4/07 21:26	64.30	508,399.59	356.57	515,806.09	76.76	0.00	274.94	532.59	969.69	1,501.77	869.76	822.85
7/4/07 21:27	64.84	513,271.81	356.80	515,511.09	78.10	0.00	274.94	532.69	968.71	1,508.12	870.06	822.95
7/4/07 21:28	64.62	512,167.81	356.98	515,216.00	79.10	0.00	274.93	532.91	968.89	1,505.98	870.87	823.79
7/4/07 21:29	63.77	503,593.69	357.22	514,921.00	82.08	0.00	275.00	532.88	968.11	1,496.01	871.49	824.05

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/4/07 21:30	64.09	507,579.81	357.41	513,941.81	81.11	0.00	275.10	532.90	967.26	1,502.59	872.12	824.67
7/4/07 21:31	63.29	499,251.81	357.70	511,988.00	80.41	0.00	275.09	533.43	968.59	1,491.84	873.30	826.67
7/4/07 21:32	62.84	496,841.09	358.02	510,034.31	80.02	0.00	275.07	533.87	967.56	1,490.57	874.13	827.77
7/4/07 21:33	62.58	492,831.31	358.33	508,080.59	78.13	0.00	274.91	534.37	966.75	1,490.33	874.70	828.32
7/4/07 21:34	62.57	493,177.19	358.60	506,126.81	77.81	0.00	274.68	535.20	966.88	1,494.19	875.06	829.24
7/4/07 21:35	62.15	487,648.31	358.82	504,173.09	78.40	0.00	274.53	535.96	966.36	1,490.79	875.26	829.13
7/4/07 21:36	62.71	492,246.19	359.08	502,219.31	78.91	0.00	274.33	536.93	967.68	1,499.53	875.53	829.51
7/4/07 21:37	62.08	486,931.59	359.27	502,767.41	78.47	0.00	274.00	537.63	967.44	1,492.98	875.68	830.23
7/4/07 21:38	62.24	488,931.69	359.44	503,555.31	78.73	0.00	273.86	538.23	967.09	1,496.24	875.29	830.01
7/4/07 21:39	62.41	489,787.59	359.63	504,343.19	75.34	0.00	273.71	539.04	969.32	1,499.81	875.70	830.91
7/4/07 21:40	62.19	486,540.09	359.81	505,131.19	78.69	0.00	273.56	539.76	971.03	1,494.44	876.17	831.24
7/4/07 21:41	62.72	491,440.50	360.01	505,919.09	79.65	0.00	273.57	540.22	970.71	1,505.83	876.01	830.35
7/4/07 21:42	62.66	489,807.69	360.15	506,707.00	81.44	0.00	273.54	540.84	971.85	1,504.39	876.51	830.80
7/4/07 21:43	62.86	492,456.41	360.36	507,494.91	85.20	0.00	273.50	541.35	971.68	1,506.81	876.96	832.19
7/4/07 21:44	62.89	493,630.19	360.47	508,282.81	87.34	0.00	273.51	541.65	970.81	1,506.26	877.20	832.04
7/4/07 21:45	63.32	497,119.09	360.62	509,070.81	91.89	0.00	273.57	542.05	970.24	1,509.44	877.40	831.78
7/4/07 21:46	62.88	494,085.19	360.78	509,858.69	90.49	0.00	273.57	542.25	968.28	1,504.41	877.25	831.18
7/4/07 21:47	63.34	497,648.69	360.88	510,646.59	92.10	0.00	273.61	542.62	968.72	1,508.19	877.60	831.75
7/4/07 21:48	63.33	497,723.81	361.03	511,434.50	91.65	0.00	273.60	542.92	968.08	1,507.26	877.99	831.59
7/4/07 21:49	63.22	496,761.31	361.18	512,222.50	87.97	0.00	273.64	543.08	967.71	1,503.86	878.06	831.78
7/4/07 21:50	63.95	503,252.81	361.32	513,010.41	88.74	0.00	273.66	543.33	968.74	1,513.80	878.14	832.02
7/4/07 21:51	64.10	502,177.50	361.50	513,207.09	89.54	0.00	273.64	543.83	971.50	1,510.03	878.64	833.11
7/4/07 21:52	64.19	504,279.59	361.72	512,841.41	92.88	0.00	273.79	543.90	970.61	1,509.95	878.95	832.96
7/4/07 21:53	64.33	505,984.19	361.92	512,475.69	90.78	0.00	273.92	543.99	970.14	1,511.59	879.44	833.00
7/4/07 21:54	64.39	508,040.09	362.17	512,110.00	86.47	0.00	274.02	544.33	970.19	1,510.12	880.34	833.82
7/4/07 21:55	63.74	501,833.31	362.52	511,744.31	84.43	0.00	274.10	544.35	968.95	1,499.94	881.19	833.64
7/4/07 21:56	63.64	502,054.00	362.76	511,378.59	87.56	0.00	274.28	544.30	967.81	1,499.69	881.84	833.80
7/4/07 21:57	63.13	495,199.41	362.98	511,012.91	86.71	0.00	274.29	544.22	967.34	1,492.75	882.33	833.92
7/4/07 21:58	62.97	495,871.31	363.23	510,405.81	85.26	0.00	274.29	544.15	966.76	1,493.99	882.29	834.43
7/4/07 21:59	63.22	498,248.09	363.44	509,775.59	85.85	0.00	274.18	544.19	967.67	1,498.46	882.73	834.67
7/4/07 22:00	62.21	489,334.41	363.64	509,145.31	88.59	0.00	274.09	543.91	967.27	1,488.81	882.38	834.60
7/4/07 22:01	62.30	490,926.50	363.79	508,515.09	86.80	0.00	274.00	543.65	965.91	1,494.30	881.39	833.58
7/4/07 22:02	63.01	495,753.00	363.96	507,884.91	83.55	0.00	273.74	543.89	967.99	1,504.91	881.27	834.43
7/4/07 22:03	62.41	490,561.19	364.15	508,376.59	83.93	0.00	273.50	543.89	968.23	1,496.90	881.20	833.92
7/4/07 22:04	62.31	489,651.09	364.32	509,285.09	84.25	0.00	273.39	543.77	968.94	1,497.46	881.01	833.52
7/4/07 22:05	63.04	493,225.91	364.50	510,193.59	81.13	0.00	273.32	543.93	970.44	1,505.86	881.02	833.53
7/4/07 22:06	63.39	497,372.91	364.69	511,102.00	81.76	0.00	273.24	544.19	973.70	1,508.26	881.82	833.98
7/4/07 22:07	63.45	496,357.81	364.96	512,010.50	79.56	0.00	273.28	544.31	975.06	1,508.81	882.26	834.44
7/4/07 22:08	63.50	496,504.19	365.19	511,727.69	79.57	0.00	273.38	544.56	975.56	1,504.71	883.18	835.10
7/4/07 22:09	63.37	495,729.09	365.48	510,636.69	78.83	0.00	273.50	544.50	973.77	1,502.69	883.53	835.54
7/4/07 22:10	63.20	493,984.19	365.74	509,545.69	77.17	0.00	273.63	544.57	972.50	1,500.31	883.96	836.10
7/4/07 22:11	62.25	486,458.00	365.91	508,454.69	80.64	0.00	273.73	544.46	969.00	1,491.47	883.52	835.31
7/4/07 22:12	62.03	487,524.31	366.03	507,363.69	81.02	0.00	273.72	544.31	965.62	1,489.90	882.38	834.23
7/4/07 22:13	62.28	488,835.09	366.09	506,272.69	78.15	0.00	273.59	544.52	964.92	1,496.91	881.87	834.09
7/4/07 22:14	62.06	487,978.31	366.22	505,181.81	81.37	0.00	273.35	544.83	965.76	1,492.55	881.77	834.53
7/4/07 22:15	62.08	487,303.91	366.35	504,090.81	79.65	0.00	273.17	544.86	966.07	1,493.78	881.44	834.10
7/4/07 22:16	62.03	486,893.91	366.45	502,999.81	78.31	0.00	272.98	544.92	966.61	1,492.31	880.93	833.62
7/4/07 22:17	62.04	485,846.31	366.52	501,908.81	81.24	0.00	272.87	545.01	967.79	1,491.83	880.62	832.47
7/4/07 22:18	61.39	481,258.19	366.62	500,817.81	80.78	0.00	272.75	545.09	968.08	1,482.88	879.95	832.24
7/4/07 22:19	61.68	483,952.19	366.67	499,726.81	83.22	0.00	272.61	545.24	968.82	1,489.09	879.66	832.20

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FLOW (TPH)	PROPANE FUEL FLOW (SCFH)	FWP DISCH FLOW (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/4/07 22:20	61.44	479,371.19	366.76	498,635.81	83.64	0.00	272.50	545.38	970.13	1,488.24	879.75	832.24
7/4/07 22:21	61.67	482,160.91	366.79	497,527.81	82.23	0.00	272.32	545.55	971.78	1,494.69	880.04	832.15
7/4/07 22:22	61.19	479,126.19	366.88	495,853.50	79.91	0.00	272.19	545.56	972.19	1,494.30	880.25	831.72
7/4/07 22:23	60.97	477,367.69	366.90	494,179.19	78.91	0.00	272.12	545.60	972.43	1,497.69	880.25	831.31
7/4/07 22:24	61.65	480,166.59	366.90	492,504.81	81.88	0.00	271.93	545.75	972.24	1,503.39	880.26	830.71
7/4/07 22:25	62.08	480,685.19	366.99	491,811.41	83.92	0.00	271.77	546.07	973.77	1,501.26	880.96	830.56
7/4/07 22:26	62.15	486,347.31	366.99	491,830.91	85.51	0.00	271.72	546.05	973.46	1,508.79	881.35	830.37
7/4/07 22:27	62.49	485,104.19	367.07	491,850.31	86.94	0.00	271.77	546.20	975.14	1,507.08	882.18	831.02
7/4/07 22:28	62.76	487,661.31	367.16	491,869.81	84.55	0.00	271.89	546.12	974.82	1,510.55	882.61	831.36
7/4/07 22:29	62.38	484,477.91	367.22	491,889.19	82.90	0.00	272.07	546.13	975.24	1,500.87	883.16	831.69
7/4/07 22:30	62.70	488,203.91	367.27	491,908.59	82.35	0.00	272.25	545.83	972.09	1,508.04	882.98	831.48
7/4/07 22:31	62.91	489,457.19	367.35	491,928.00	82.50	0.00	272.36	546.12	971.89	1,510.28	883.28	831.50
7/4/07 22:32	62.67	488,446.31	367.43	491,947.50	85.66	0.00	272.52	546.36	971.66	1,505.32	883.83	832.09
7/4/07 22:33	62.32	486,486.31	367.44	491,966.91	86.55	0.00	272.61	546.24	969.78	1,498.62	883.70	831.93
7/4/07 22:34	62.45	487,126.31	367.48	491,986.31	85.42	0.00	272.64	546.17	968.85	1,501.50	883.19	833.09
7/4/07 22:35	62.11	483,952.00	367.52	492,011.00	87.94	0.00	272.67	546.66	969.84	1,495.95	881.12	832.86
7/4/07 22:36	62.06	483,416.59	367.67	492,037.91	87.43	0.00	272.64	547.31	970.70	1,494.49	879.42	831.31
7/4/07 22:37	61.57	479,222.09	367.76	492,064.91	82.97	0.00	272.58	547.29	969.99	1,491.28	878.95	831.93
7/4/07 22:38	61.52	477,307.31	367.80	492,091.91	78.69	0.00	272.46	547.25	970.53	1,493.57	879.15	832.44
7/4/07 22:39	61.84	482,905.00	367.85	492,118.81	76.52	0.00	272.27	547.37	972.04	1,501.41	879.97	832.72
7/4/07 22:40	61.53	478,390.91	367.91	492,145.81	77.77	0.00	272.09	547.51	973.81	1,496.55	881.15	833.15
7/4/07 22:41	60.75	473,585.31	367.94	492,713.31	80.82	0.00	272.01	547.49	972.41	1,495.03	881.60	832.53
7/4/07 22:42	61.34	476,991.81	367.87	493,828.19	80.47	0.00	271.90	547.90	972.78	1,500.22	882.09	833.27
7/4/07 22:43	61.48	481,760.19	367.80	494,942.91	81.87	0.00	271.71	548.50	973.74	1,505.36	882.89	834.12
7/4/07 22:44	61.53	479,113.41	367.66	496,057.81	79.73	0.00	271.60	548.53	973.57	1,499.58	883.54	834.76
7/4/07 22:45	61.45	473,653.31	367.43	497,172.50	78.40	0.00	271.63	548.29	972.58	1,494.26	883.61	834.91
7/4/07 22:46	61.46	478,860.91	367.14	498,287.31	75.71	0.00	271.68	547.96	971.04	1,502.90	883.24	834.64
7/4/07 22:47	61.72	482,532.69	366.83	499,509.41	77.46	0.00	271.69	548.09	972.05	1,505.10	883.66	835.35
7/4/07 22:48	61.25	476,497.31	366.52	501,032.69	81.28	0.00	271.64	548.10	972.06	1,497.72	883.92	835.47
7/4/07 22:49	61.93	480,324.19	366.14	502,556.00	81.46	0.00	271.71	547.96	970.82	1,503.93	883.89	835.06
7/4/07 22:50	62.78	488,695.09	365.68	503,933.00	79.72	0.00	271.70	548.16	972.63	1,511.38	884.57	835.55
7/4/07 22:51	62.54	487,622.09	365.27	504,155.81	77.06	0.00	271.68	548.04	972.15	1,507.24	884.80	835.21
7/4/07 22:52	62.80	488,613.31	364.85	504,378.69	77.01	0.00	271.78	547.58	971.46	1,509.55	884.26	834.24
7/4/07 22:53	63.08	490,694.31	364.39	505,133.09	78.01	0.00	271.88	546.93	970.91	1,513.81	883.20	832.95
7/4/07 22:54	62.77	488,953.31	363.96	504,521.41	79.57	0.00	271.97	546.33	971.00	1,505.67	881.04	831.81
7/4/07 22:55	62.75	489,238.31	363.51	502,851.59	80.73	0.00	272.07	546.04	970.14	1,506.39	876.67	828.59
7/4/07 22:56	62.21	483,588.09	363.16	505,084.59	77.67	0.00	272.18	545.82	969.98	1,495.02	874.98	828.21
7/4/07 22:57	62.01	484,589.81	362.94	499,405.31	78.53	0.00	272.23	545.39	967.71	1,494.72	874.32	828.11
7/4/07 22:58	61.92	483,687.09	362.80	500,636.50	79.37	0.00	272.20	545.31	967.54	1,495.30	875.06	828.99
7/4/07 22:59	61.67	478,530.50	362.72	500,101.81	82.20	0.00	272.03	545.31	968.42	1,491.74	876.34	829.82
7/4/07 23:00	61.54	479,786.59	362.62	497,409.31	82.71	0.00	271.88	545.11	968.02	1,495.15	877.24	830.00
7/4/07 23:01	61.80	480,401.19	362.48	497,597.59	78.34	0.00	271.72	545.14	969.74	1,499.75	878.42	831.22
7/4/07 23:02	62.06	479,300.19	362.36	497,202.00	79.26	0.00	271.53	545.20	970.78	1,498.24	879.48	831.57
7/4/07 23:03	62.32	484,352.09	362.21	497,177.19	75.86	0.00	271.43	545.13	971.84	1,506.01	880.24	831.71
7/4/07 23:04	62.22	482,860.50	362.04	497,183.91	74.38	0.00	271.37	545.19	974.33	1,500.73	881.47	832.67
7/4/07 23:05	62.06	478,260.19	361.80	497,190.59	74.99	0.00	271.40	544.75	973.50	1,498.30	882.03	832.43
7/4/07 23:06	62.43	483,720.31	361.61	497,197.19	77.93	0.00	271.48	544.54	973.14	1,503.15	882.31	832.40
7/4/07 23:07	62.45	483,835.69	361.37	497,203.91	80.34	0.00	271.53	544.58	973.12	1,503.21	883.05	832.88
7/4/07 23:08	62.20	482,298.19	361.11	497,210.59	80.91	0.00	271.62	544.56	972.39	1,498.10	883.51	832.59
7/4/07 23:09	62.28	484,076.69	360.77	497,217.19	81.51	0.00	271.76	544.38	970.58	1,503.88	883.49	832.91

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/4/07 23:10	62.31	483,974.91	360.49	497,223.91	81.98	0.00	271.76	544.35	970.50	1,501.15	883.87	834.02
7/4/07 23:11	62.65	487,150.81	360.16	497,230.59	82.04	0.00	271.76	544.08	968.78	1,507.54	884.02	834.33
7/4/07 23:12	62.61	486,728.09	360.00	497,237.19	83.14	0.00	271.76	544.20	970.34	1,504.55	884.71	835.30
7/4/07 23:13	62.58	486,323.00	359.84	497,243.91	79.55	0.00	271.78	543.87	969.67	1,503.35	884.51	835.20
7/4/07 23:14	62.77	487,004.50	359.60	497,250.59	82.01	0.00	271.81	543.49	970.10	1,505.38	883.95	835.05
7/4/07 23:15	63.04	489,412.69	359.35	497,257.19	80.60	0.00	271.86	543.17	970.67	1,508.37	883.23	834.93
7/4/07 23:16	62.46	483,873.69	359.12	497,263.91	75.94	0.00	271.96	543.03	971.10	1,496.14	882.62	834.23
7/4/07 23:17	62.80	487,368.09	358.90	495,927.69	74.59	0.00	272.06	542.78	969.56	1,503.30	881.61	833.14
7/4/07 23:18	62.73	487,685.59	358.76	493,474.31	74.71	0.00	272.14	542.83	968.56	1,503.20	881.37	832.98
7/4/07 23:19	62.75	487,340.00	358.73	491,020.81	80.85	0.00	272.18	543.26	968.98	1,504.97	882.17	833.74
7/4/07 23:20	61.77	480,690.41	358.68	488,567.31	78.93	0.00	272.20	543.37	968.15	1,489.86	882.74	834.90
7/4/07 23:21	62.09	483,783.41	358.69	486,113.81	77.84	0.00	272.19	543.34	966.54	1,497.64	882.83	835.29
7/4/07 23:22	61.79	475,704.59	358.69	483,660.41	80.42	0.00	272.06	543.57	966.33	1,492.15	882.82	834.79
7/4/07 23:23	60.86	473,633.09	358.75	483,427.81	78.09	0.00	271.98	543.94	966.66	1,491.28	882.17	832.26
7/4/07 23:24	60.43	470,406.19	358.85	483,500.59	71.93	0.00	271.88	544.11	967.03	1,491.23	879.22	830.98
7/4/07 23:25	60.52	470,559.59	358.96	483,573.31	70.06	0.00	271.72	544.48	968.03	1,495.84	875.72	830.68
7/4/07 23:26	60.52	470,297.50	359.13	483,646.00	68.94	0.00	271.51	544.55	966.78	1,499.83	873.94	828.02
7/4/07 23:27	60.44	469,450.81	359.20	483,718.69	68.34	0.00	271.22	544.75	966.39	1,498.86	873.74	828.19
7/4/07 23:28	60.01	463,901.91	359.28	483,791.41	67.49	0.00	271.09	544.65	965.32	1,495.42	874.06	829.16
7/4/07 23:29	60.54	470,707.41	359.33	483,864.19	67.75	0.00	270.92	544.89	968.98	1,503.60	873.10	831.91
7/4/07 23:30	61.63	476,988.81	359.44	484,869.31	66.98	0.00	270.70	545.41	973.61	1,509.84	872.59	836.06
7/4/07 23:31	61.09	471,600.69	359.56	486,385.81	64.63	0.00	270.65	545.63	974.19	1,500.72	873.82	838.26
7/4/07 23:32	61.57	473,435.81	359.59	488,187.81	66.15	0.00	270.71	545.35	972.03	1,503.08	874.10	837.16
7/4/07 23:33	61.58	476,352.59	359.71	490,280.41	65.16	0.00	270.81	545.42	973.16	1,502.71	874.22	835.35
7/4/07 23:34	61.79	478,448.19	359.79	492,372.91	64.81	0.00	270.88	545.37	973.18	1,506.54	872.63	834.07
7/4/07 23:35	62.58	484,378.59	359.90	494,465.41	69.15	0.00	270.92	545.58	974.22	1,510.03	871.60	832.97
7/4/07 23:36	62.51	481,943.41	359.97	496,558.00	69.27	0.00	271.02	545.42	972.55	1,504.89	871.48	830.96
7/4/07 23:37	62.54	483,736.59	359.97	498,650.50	68.48	0.00	271.13	545.05	970.56	1,505.73	872.15	831.24
7/4/07 23:38	63.04	488,457.81	359.94	500,743.00	70.91	0.00	271.19	544.62	970.96	1,512.72	872.72	832.87
7/4/07 23:39	62.62	485,450.81	359.93	502,835.59	70.52	0.00	271.27	544.32	972.68	1,502.72	871.71	834.95
7/4/07 23:40	62.60	486,045.19	359.82	504,152.31	70.89	0.00	271.40	543.99	972.32	1,503.28	870.97	836.54
7/4/07 23:41	62.54	485,310.81	359.77	503,887.91	69.82	0.00	271.45	543.77	970.91	1,502.53	871.64	837.24
7/4/07 23:42	62.35	485,071.09	359.70	503,623.59	71.25	0.00	271.47	543.52	968.88	1,501.37	871.81	835.77
7/4/07 23:43	62.35	484,741.31	359.66	503,359.31	75.53	0.00	271.42	543.14	967.05	1,502.09	871.17	833.73
7/4/07 23:44	61.80	483,826.59	359.65	503,094.91	74.73	0.00	271.39	542.89	967.19	1,500.22	870.14	832.70
7/4/07 23:45	61.65	476,088.69	359.62	502,830.59	72.46	0.00	271.31	542.47	967.08	1,493.73	868.84	830.75
7/4/07 23:46	61.81	481,949.31	359.62	502,566.19	71.25	0.00	271.21	542.40	968.43	1,501.65	869.06	829.67
7/4/07 23:47	61.68	479,521.91	359.72	504,247.81	73.11	0.00	271.04	542.66	970.05	1,497.03	871.01	831.34
7/4/07 23:48	61.50	473,801.31	359.85	500,799.41	73.34	0.00	270.92	542.56	969.96	1,494.76	872.23	833.20
7/4/07 23:49	61.58	479,668.91	359.98	497,762.41	76.56	0.00	270.87	542.29	970.52	1,501.60	872.51	834.47
7/4/07 23:50	61.83	479,221.31	360.08	500,488.09	78.34	0.00	270.80	542.29	972.63	1,500.19	873.97	836.49
7/4/07 23:51	62.08	481,752.50	360.23	501,654.09	75.69	0.00	270.82	542.27	973.46	1,503.50	875.85	837.71
7/4/07 23:52	62.62	485,404.19	360.24	502,820.09	74.51	0.00	270.84	541.98	973.31	1,506.99	876.40	837.96
7/4/07 23:53	62.99	486,740.19	360.35	503,896.69	75.41	0.00	270.99	541.87	972.39	1,508.23	876.39	838.63
7/4/07 23:54	62.58	484,431.41	360.46	504,781.09	79.44	0.00	271.20	541.46	969.86	1,502.22	875.17	838.18
7/4/07 23:55	62.24	482,524.59	360.47	503,991.41	78.26	0.00	271.41	541.07	968.06	1,497.58	874.27	837.20
7/4/07 23:56	61.73	477,597.69	360.50	501,414.91	78.22	0.00	271.57	540.78	966.49	1,495.60	873.89	836.93
7/4/07 23:57	61.06	474,178.50	360.55	498,838.41	82.12	0.00	271.64	540.80	964.83	1,493.13	873.70	835.94
7/4/07 23:58	61.53	479,323.31	360.64	496,261.91	79.01	0.00	271.64	541.19	964.37	1,499.85	874.12	835.86
7/4/07 23:59	60.63	471,278.91	360.82	493,685.41	76.19	0.00	271.51	541.39	964.94	1,493.11	874.44	836.65

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 0:00	60.18	471,285.41	360.95	491,108.91	78.54	0.00	271.36	541.51	965.63	1,496.61	874.93	836.98
7/5/07 0:01	59.72	464,522.91	361.08	488,532.31	79.31	0.00	271.12	541.79	967.12	1,491.55	875.85	835.74
7/5/07 0:02	59.53	463,848.69	361.18	485,955.81	79.80	0.00	270.91	542.17	970.27	1,492.24	876.28	832.34
7/5/07 0:03	59.39	457,583.50	361.30	483,379.31	82.83	0.00	270.50	542.61	973.37	1,492.27	874.31	830.93
7/5/07 0:04	59.71	458,163.19	361.49	480,802.81	87.39	0.00	270.06	543.40	977.98	1,496.59	872.48	831.17
7/5/07 0:05	60.08	463,669.09	361.58	480,397.19	84.45	0.00	269.67	544.04	978.39	1,503.64	872.28	828.48
7/5/07 0:06	61.12	470,208.41	361.66	482,878.91	82.46	0.00	269.44	544.42	978.86	1,508.35	873.60	828.42
7/5/07 0:07	61.48	473,236.41	361.70	485,360.69	82.34	0.00	269.24	544.48	978.76	1,509.58	875.00	829.95
7/5/07 0:08	61.87	475,932.81	361.72	487,842.41	85.13	0.00	269.36	544.47	979.41	1,509.46	874.31	831.73
7/5/07 0:09	62.04	479,753.59	361.69	490,324.19	82.86	0.00	269.61	544.48	978.28	1,509.91	873.47	833.17
7/5/07 0:10	62.27	479,012.91	361.67	492,805.91	85.76	0.00	269.82	544.40	974.93	1,507.70	874.18	834.12
7/5/07 0:11	62.98	486,604.69	361.68	495,287.69	86.06	0.00	270.08	544.33	972.07	1,510.69	875.31	833.19
7/5/07 0:12	62.59	483,544.50	361.69	497,769.41	83.74	0.00	270.42	544.01	970.53	1,504.20	875.41	830.77
7/5/07 0:13	62.48	482,486.09	361.65	499,843.81	84.49	0.00	270.71	543.51	969.97	1,501.74	873.02	829.87
7/5/07 0:14	62.23	482,390.81	361.67	500,051.81	83.19	0.00	271.00	543.35	971.36	1,499.60	870.95	828.57
7/5/07 0:15	62.80	486,155.59	361.72	500,259.91	80.40	0.00	271.17	543.23	971.37	1,506.61	871.02	826.55
7/5/07 0:16	63.22	488,890.59	361.80	500,468.00	80.54	0.00	271.28	543.22	972.46	1,510.46	872.77	827.70
7/5/07 0:17	62.41	483,546.19	361.87	500,676.09	82.84	0.00	271.37	542.83	971.20	1,498.42	873.85	828.71
7/5/07 0:18	62.60	483,797.50	361.97	500,462.09	82.13	0.00	271.50	542.56	971.92	1,500.82	873.20	830.25
7/5/07 0:19	62.79	485,612.31	362.13	500,150.59	85.27	0.00	271.47	542.70	972.72	1,504.65	873.72	832.85
7/5/07 0:20	62.84	485,971.31	362.28	499,839.19	85.47	0.00	271.47	543.04	972.12	1,504.29	875.79	835.19
7/5/07 0:21	62.76	487,411.81	362.56	499,527.81	86.38	0.00	271.43	543.15	971.24	1,505.02	877.41	834.87
7/5/07 0:22	62.81	486,762.59	362.79	499,216.31	85.32	0.00	271.44	543.01	971.48	1,500.98	877.36	834.03
7/5/07 0:23	63.09	487,813.91	362.91	498,904.91	85.79	0.00	271.44	542.66	971.88	1,506.03	875.15	833.33
7/5/07 0:24	62.80	484,954.91	363.01	498,593.50	86.64	0.00	271.47	542.34	971.71	1,502.45	873.54	831.81
7/5/07 0:25	62.80	485,909.09	363.09	498,282.00	87.20	0.00	271.44	542.14	971.76	1,502.01	873.91	830.45
7/5/07 0:26	62.89	486,478.41	363.15	497,970.59	84.05	0.00	271.49	541.89	970.57	1,502.05	874.99	831.33
7/5/07 0:27	62.35	481,891.00	363.28	497,659.19	82.14	0.00	271.52	541.49	969.78	1,494.49	875.26	832.53
7/5/07 0:28	62.01	476,084.59	363.33	497,354.69	80.64	0.00	271.57	540.93	968.42	1,493.07	874.00	833.56
7/5/07 0:29	62.48	483,569.69	363.40	497,131.31	79.54	0.00	271.52	540.79	969.89	1,499.17	874.41	834.68
7/5/07 0:30	61.77	478,749.81	363.52	496,907.91	80.81	0.00	271.45	540.61	969.14	1,497.22	875.65	834.77
7/5/07 0:31	62.30	476,819.41	363.66	496,684.59	79.33	0.00	271.43	540.66	969.17	1,498.18	876.71	832.80
7/5/07 0:32	62.71	479,671.50	363.83	496,461.19	81.37	0.00	271.37	540.73	970.22	1,502.13	875.07	830.48
7/5/07 0:33	62.88	483,217.09	364.04	496,237.81	78.14	0.00	271.31	540.97	973.18	1,503.78	872.41	829.64
7/5/07 0:34	62.22	479,814.31	364.28	496,014.41	79.39	0.00	271.33	541.20	973.87	1,498.87	871.76	828.03
7/5/07 0:35	62.55	477,805.81	364.43	495,791.00	83.44	0.00	271.41	541.13	971.76	1,497.87	872.40	826.78
7/5/07 0:36	62.90	486,100.91	364.59	495,787.50	84.50	0.00	271.43	541.50	971.42	1,506.77	874.01	828.81
7/5/07 0:37	62.42	477,909.81	364.76	495,840.50	84.84	0.00	271.42	541.86	972.53	1,496.58	874.43	831.28
7/5/07 0:38	61.82	477,945.91	364.94	495,661.31	85.84	0.00	271.45	541.90	971.24	1,499.72	873.18	832.41
7/5/07 0:39	62.05	480,594.19	365.08	495,102.31	86.96	0.00	271.43	542.22	970.81	1,503.36	874.06	833.92
7/5/07 0:40	62.44	482,393.69	365.23	494,543.19	86.61	0.00	271.30	542.83	972.76	1,503.40	876.35	834.83
7/5/07 0:41	61.43	474,635.41	365.37	493,984.09	88.28	0.00	271.27	542.82	972.15	1,495.40	877.01	831.81
7/5/07 0:42	61.92	478,935.31	365.50	495,529.59	88.27	0.00	271.21	542.81	972.06	1,501.95	874.88	830.28
7/5/07 0:43	61.94	477,709.19	365.64	497,924.31	88.27	0.00	271.13	543.04	972.15	1,500.59	872.30	829.08
7/5/07 0:44	61.96	479,597.41	365.81	500,319.00	86.37	0.00	271.06	543.37	971.45	1,501.24	872.12	826.13
7/5/07 0:45	61.98	479,281.91	365.91	502,713.69	87.24	0.00	270.98	543.46	969.58	1,502.15	873.05	824.56
7/5/07 0:46	62.26	480,882.09	366.01	505,108.31	89.01	0.00	270.99	543.65	969.28	1,503.61	874.46	825.70
7/5/07 0:47	63.34	489,369.59	366.13	507,503.00	87.20	0.00	270.98	543.97	971.63	1,513.08	874.59	827.68
7/5/07 0:48	63.07	486,561.31	366.33	507,979.09	87.20	0.00	271.03	544.11	973.27	1,505.35	874.66	830.30
7/5/07 0:49	62.94	486,480.00	366.51	506,963.09	82.53	0.00	271.21	543.99	971.61	1,504.36	875.77	832.05

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FLOW (LB/HR)	PROPANE FUEL FLOW (TPH)	FWP DISCH FLOW (SCFH)	ECONOMIZER TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 0:50	63.20	487,718.31	366.58	505,947.00	78.76	0.00	271.31	544.03	971.37	1,507.66	877.18	831.75
7/5/07 0:51	63.40	489,613.19	366.66	504,930.91	77.52	0.00	271.45	544.31	973.18	1,512.54	878.14	830.75
7/5/07 0:52	62.90	485,048.19	366.82	503,914.81	81.36	0.00	271.60	544.17	972.71	1,499.77	875.48	830.09
7/5/07 0:53	63.21	487,629.31	366.92	502,898.69	81.32	0.00	271.72	543.94	970.54	1,505.77	872.67	828.63
7/5/07 0:54	63.49	489,332.91	367.07	501,882.59	82.42	0.00	271.80	544.19	971.06	1,508.15	873.76	827.00
7/5/07 0:55	62.82	483,024.69	367.17	500,866.50	81.58	0.00	271.82	544.04	968.18	1,497.43	875.21	827.21
7/5/07 0:56	62.91	486,794.31	367.22	500,508.19	81.38	0.00	271.92	543.84	965.71	1,499.97	875.89	827.54
7/5/07 0:57	63.17	488,743.69	367.28	501,490.19	77.58	0.00	271.90	543.77	967.12	1,504.81	874.97	829.13
7/5/07 0:58	63.29	489,335.59	367.27	502,472.19	74.21	0.00	271.89	543.66	968.50	1,505.78	874.88	830.67
7/5/07 0:59	63.24	487,360.00	367.21	503,454.19	77.66	0.00	271.85	543.61	969.02	1,504.84	876.36	832.09
7/5/07 1:00	63.24	485,799.00	367.25	504,436.31	79.29	0.00	271.88	543.60	970.27	1,497.39	877.82	828.79
7/5/07 1:01	63.12	486,690.09	367.25	505,418.31	77.91	0.00	271.88	543.26	971.43	1,501.04	876.20	824.10
7/5/07 1:02	63.19	488,787.00	367.26	506,400.31	75.56	0.00	271.88	542.87	972.82	1,504.98	871.57	822.21
7/5/07 1:03	62.96	484,341.41	367.19	507,382.31	79.72	0.00	271.83	542.45	972.46	1,497.08	868.05	818.25
7/5/07 1:04	63.32	488,144.31	367.08	508,364.31	83.49	0.00	271.84	542.09	971.27	1,504.79	867.28	815.09
7/5/07 1:05	63.59	490,350.31	366.98	509,346.41	81.65	0.00	271.78	542.22	972.93	1,509.79	868.57	812.72
7/5/07 1:06	63.47	489,480.91	366.95	510,328.41	82.08	0.00	271.83	541.91	971.70	1,505.94	867.55	810.43
7/5/07 1:07	63.59	489,469.31	366.94	511,310.41	80.22	0.00	271.96	541.49	971.19	1,508.05	864.02	810.56
7/5/07 1:08	63.85	493,225.59	366.89	512,292.41	81.60	0.00	271.91	541.28	972.03	1,512.94	862.98	809.38
7/5/07 1:09	63.97	492,447.09	366.89	512,215.41	80.96	0.00	272.00	541.33	972.71	1,514.70	864.69	809.12
7/5/07 1:10	63.63	489,934.31	366.99	512,351.91	77.23	0.00	272.05	541.39	972.93	1,506.63	867.00	812.25
7/5/07 1:11	63.96	493,222.41	367.13	512,109.69	77.65	0.00	272.11	541.27	972.98	1,513.77	868.09	815.85
7/5/07 1:12	63.79	490,814.81	367.27	512,889.69	76.51	0.00	272.18	541.23	973.71	1,510.16	868.08	819.36
7/5/07 1:13	63.85	492,363.69	367.42	509,715.50	76.42	0.00	272.23	541.16	971.61	1,509.59	869.19	821.66
7/5/07 1:14	63.40	488,336.31	367.44	507,223.00	81.42	0.00	272.30	541.30	970.14	1,500.32	871.11	822.70
7/5/07 1:15	63.57	490,826.81	367.51	508,270.81	78.84	0.00	272.29	541.15	969.77	1,502.73	872.46	816.78
7/5/07 1:16	63.48	489,186.19	367.61	508,619.09	76.94	0.00	272.27	540.98	970.63	1,500.70	869.69	814.01
7/5/07 1:17	63.46	489,187.91	367.69	508,967.41	75.21	0.00	272.22	540.91	971.75	1,501.11	865.53	813.25
7/5/07 1:18	63.76	490,894.31	367.77	509,315.59	75.92	0.00	272.13	540.87	972.82	1,506.44	864.22	809.59
7/5/07 1:19	63.82	490,011.09	367.85	509,663.91	80.42	0.00	272.07	541.10	976.09	1,506.26	866.28	809.73
7/5/07 1:20	63.69	489,921.91	367.90	510,012.19	82.03	0.00	272.05	540.98	976.19	1,505.65	868.12	812.58
7/5/07 1:21	63.80	489,342.41	368.00	510,360.41	85.38	0.00	272.04	540.71	976.15	1,503.03	867.76	814.89
7/5/07 1:22	64.68	498,967.41	368.04	510,708.69	89.65	0.00	272.08	540.58	975.47	1,514.91	866.79	817.06
7/5/07 1:23	64.49	496,630.69	368.17	511,056.91	89.54	0.00	272.11	540.80	976.61	1,506.75	868.45	819.89
7/5/07 1:24	64.51	498,008.69	368.31	511,405.19	84.94	0.00	272.33	540.80	973.94	1,508.01	870.29	820.13
7/5/07 1:25	64.45	496,123.41	368.53	511,753.50	79.73	0.00	272.47	540.80	973.43	1,503.76	871.52	817.90
7/5/07 1:26	64.57	497,969.69	368.67	512,101.69	80.61	0.00	272.58	540.79	972.55	1,504.99	870.00	818.13
7/5/07 1:27	64.38	496,157.81	368.87	512,450.00	79.02	0.00	272.72	540.75	970.88	1,501.79	868.35	818.16
7/5/07 1:28	63.85	492,388.09	368.95	512,454.31	80.31	0.00	272.77	540.72	968.49	1,497.51	868.91	815.62
7/5/07 1:29	63.96	492,883.91	369.09	511,701.69	79.86	0.00	272.72	540.96	967.21	1,499.55	870.34	817.45
7/5/07 1:30	63.82	492,061.59	369.13	510,949.19	77.32	0.00	272.59	541.22	967.79	1,497.85	871.55	820.21
7/5/07 1:31	63.39	489,579.91	369.27	510,196.69	74.95	0.00	272.52	541.17	966.42	1,495.18	870.56	821.72
7/5/07 1:32	63.49	491,309.50	369.28	509,444.19	75.37	0.00	272.47	541.15	965.40	1,499.83	870.23	823.55
7/5/07 1:33	63.28	489,096.41	369.32	508,691.69	76.12	0.00	272.32	541.49	966.12	1,496.97	871.45	825.87
7/5/07 1:34	63.28	489,997.41	369.27	507,939.19	74.00	0.00	272.19	541.73	965.23	1,499.29	871.64	823.60
7/5/07 1:35	63.02	487,556.19	369.34	507,186.69	75.81	0.00	272.05	541.94	965.74	1,494.78	870.80	820.09
7/5/07 1:36	63.24	489,188.19	369.47	506,434.09	78.14	0.00	271.93	542.13	966.68	1,498.46	869.75	817.80
7/5/07 1:37	62.97	485,286.00	369.54	505,681.59	79.97	0.00	271.83	542.40	967.89	1,492.29	868.79	815.33
7/5/07 1:38	62.99	484,612.69	369.59	504,929.09	82.07	0.00	271.82	542.53	967.84	1,491.74	868.40	814.31
7/5/07 1:39	62.77	484,155.00	369.62	504,176.59	80.63	0.00	271.77	542.49	967.42	1,488.88	868.36	815.25

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 1:40	63.22	488,453.09	369.59	503,424.09	80.10	0.00	271.72	542.80	969.27	1,501.11	868.15	816.68
7/5/07 1:41	63.01	486,037.50	369.60	503,654.19	79.82	0.00	271.63	542.81	969.43	1,493.73	867.66	817.03
7/5/07 1:42	63.00	486,170.91	369.72	503,998.50	77.70	0.00	271.67	542.71	968.93	1,496.96	866.96	819.02
7/5/07 1:43	63.24	486,890.41	369.69	504,342.81	77.98	0.00	271.71	542.83	969.43	1,500.87	867.54	821.07
7/5/07 1:44	63.12	486,149.31	369.66	504,687.19	76.01	0.00	271.69	542.96	970.94	1,499.07	868.48	821.24
7/5/07 1:45	63.19	487,428.81	369.70	505,031.50	76.20	0.00	271.69	542.90	969.65	1,500.89	868.48	820.21
7/5/07 1:46	63.06	484,445.09	369.64	505,375.81	75.92	0.00	271.66	542.89	969.49	1,495.34	868.64	818.48
7/5/07 1:47	63.49	490,164.09	369.57	505,720.19	76.78	0.00	271.65	542.87	968.87	1,507.10	868.58	815.67
7/5/07 1:48	63.27	487,968.91	369.51	506,064.50	75.76	0.00	271.69	542.92	969.69	1,502.69	868.99	815.34
7/5/07 1:49	63.26	488,077.81	369.38	506,408.81	74.75	0.00	271.67	542.80	969.26	1,502.41	868.70	815.64
7/5/07 1:50	63.34	488,339.09	369.26	506,753.19	75.64	0.00	271.67	542.79	968.97	1,504.14	868.23	814.96
7/5/07 1:51	63.36	488,082.19	369.15	507,097.50	78.77	0.00	271.68	542.75	969.55	1,505.21	867.80	815.47
7/5/07 1:52	63.16	487,181.91	369.09	507,441.91	80.24	0.00	271.66	542.57	968.55	1,500.28	867.44	816.55
7/5/07 1:53	63.17	487,805.19	368.86	507,786.19	78.86	0.00	271.67	542.39	967.50	1,502.17	866.99	815.66
7/5/07 1:54	63.93	493,174.50	368.79	508,130.50	76.90	0.00	271.62	542.41	966.96	1,516.01	866.23	814.88
7/5/07 1:55	63.74	492,268.69	368.68	508,474.81	76.14	0.00	271.54	542.52	967.03	1,510.80	865.76	815.06
7/5/07 1:56	63.58	491,812.59	368.63	508,818.81	80.18	0.00	271.60	542.25	964.96	1,507.29	864.49	814.51
7/5/07 1:57	63.47	491,928.81	368.52	509,162.81	81.53	0.00	271.73	541.77	963.11	1,506.67	863.02	812.72
7/5/07 1:58	63.60	492,506.09	368.44	509,506.81	80.96	0.00	271.77	541.51	964.40	1,507.31	862.81	813.58
7/5/07 1:59	63.23	490,403.81	368.30	509,850.69	80.49	0.00	271.83	541.01	963.25	1,500.36	862.12	815.20
7/5/07 2:00	63.08	489,808.00	368.03	510,194.69	80.66	0.00	271.84	540.37	961.44	1,497.87	860.64	816.02
7/5/07 2:01	63.47	493,176.31	367.81	510,538.69	80.56	0.00	271.80	539.89	961.60	1,506.48	859.39	817.06
7/5/07 2:02	63.09	489,151.09	367.57	510,573.69	78.92	0.00	271.78	539.48	963.94	1,498.83	859.02	818.86
7/5/07 2:03	63.18	489,850.81	367.26	507,014.69	78.30	0.00	271.79	538.69	964.00	1,499.02	858.74	818.75
7/5/07 2:04	62.87	486,160.91	367.00	503,455.81	79.63	0.00	271.75	538.19	966.67	1,492.74	858.96	818.37
7/5/07 2:05	63.05	488,638.69	366.66	499,896.81	82.22	0.00	271.70	537.50	967.20	1,498.15	859.00	817.93
7/5/07 2:06	62.84	485,018.09	366.40	496,337.81	80.28	0.00	271.61	537.22	969.63	1,493.18	859.62	817.28
7/5/07 2:07	62.33	480,718.19	366.08	492,778.91	78.40	0.00	271.51	536.62	968.09	1,486.28	859.55	816.56
7/5/07 2:08	62.35	481,053.69	365.79	489,219.91	77.46	0.00	271.39	536.17	967.23	1,488.84	859.54	816.69
7/5/07 2:09	61.54	475,213.81	365.52	485,661.00	79.85	0.00	271.22	536.04	967.52	1,487.28	859.97	816.32
7/5/07 2:10	60.61	464,965.41	365.27	482,126.00	80.52	0.00	271.08	535.82	966.50	1,477.84	859.82	814.55
7/5/07 2:11	59.75	461,347.69	364.91	479,390.31	80.41	0.00	270.91	535.55	965.25	1,485.25	859.20	812.61
7/5/07 2:12	60.08	464,064.81	364.57	476,654.69	76.65	0.00	270.46	535.67	965.85	1,493.39	858.90	811.40
7/5/07 2:13	59.81	461,429.91	364.31	473,919.00	73.59	0.00	270.10	535.99	967.51	1,491.84	858.91	810.40
7/5/07 2:14	59.00	454,989.81	364.00	471,183.31	75.06	0.00	269.80	536.03	967.86	1,486.89	858.72	809.60
7/5/07 2:15	58.91	454,726.81	363.72	468,447.59	74.18	0.00	269.52	536.12	968.02	1,491.22	857.41	808.68
7/5/07 2:16	58.80	452,911.91	363.47	465,711.91	74.38	0.00	269.19	536.95	969.82	1,493.21	854.52	806.20
7/5/07 2:17	59.10	453,951.81	363.38	462,976.19	79.35	0.00	268.92	538.09	972.11	1,496.61	854.34	806.35
7/5/07 2:18	58.32	446,567.41	363.35	462,681.00	79.04	0.00	268.72	538.80	972.85	1,490.78	854.94	806.70
7/5/07 2:19	58.49	449,695.59	363.31	463,217.41	82.57	0.00	268.64	539.16	972.08	1,496.58	855.79	806.87
7/5/07 2:20	58.68	450,354.59	363.20	463,753.81	81.50	0.00	268.51	539.51	971.93	1,498.80	856.41	807.02
7/5/07 2:21	58.83	452,664.09	362.98	464,290.19	78.56	0.00	268.36	539.94	972.44	1,499.86	857.21	807.35
7/5/07 2:22	58.23	448,977.31	362.64	464,826.59	76.61	0.00	268.29	540.18	970.23	1,495.64	857.24	806.88
7/5/07 2:23	58.55	450,313.59	362.29	465,363.00	77.06	0.00	268.22	540.90	969.90	1,500.67	857.68	807.01
7/5/07 2:24	58.67	450,881.09	361.91	465,703.81	75.32	0.00	268.10	541.81	970.85	1,497.95	858.52	807.34
7/5/07 2:25	58.62	451,123.59	361.46	465,320.09	72.47	0.00	268.00	542.05	970.06	1,497.95	858.83	807.14
7/5/07 2:26	59.17	456,029.81	360.98	464,936.31	76.61	0.00	267.95	542.21	970.03	1,504.29	859.29	807.56
7/5/07 2:27	58.41	449,413.31	360.54	464,552.50	74.59	0.00	267.84	542.54	969.96	1,493.78	860.31	808.28
7/5/07 2:28	58.32	449,305.50	360.11	464,168.69	76.60	0.00	267.78	542.76	968.38	1,496.28	861.02	808.76
7/5/07 2:29	58.18	448,142.31	359.67	463,784.91	75.92	0.00	267.63	543.38	968.51	1,494.61	862.02	810.01

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG)	SH OUTLET FLUE GAS TEMP (DEG)
7/5/07 2:30	58.32	449,171.81	359.09	463,401.09	74.95	0.00	267.49	543.92	967.98	1,495.39	862.71	810.61
7/5/07 2:31	57.88	446,448.09	358.45	463,017.31	73.13	0.00	267.35	544.36	967.00	1,494.36	863.12	810.91
7/5/07 2:32	58.15	448,450.91	357.94	462,633.59	70.41	0.00	267.25	544.91	966.78	1,498.39	863.65	811.99
7/5/07 2:33	57.72	445,063.69	357.51	462,249.81	71.10	0.00	267.11	545.40	966.09	1,493.31	864.27	812.37
7/5/07 2:34	58.12	447,690.31	357.21	461,866.00	71.46	0.00	267.04	545.96	965.96	1,498.81	864.45	812.98
7/5/07 2:35	57.82	445,376.09	357.02	461,482.19	73.06	0.00	266.96	546.75	967.01	1,495.15	862.28	811.46
7/5/07 2:36	57.92	448,434.81	356.90	461,098.41	74.92	0.00	266.88	547.23	968.43	1,499.80	861.31	810.92
7/5/07 2:37	58.00	446,321.19	356.77	460,714.59	78.33	0.00	266.85	547.32	969.31	1,498.57	860.94	810.40
7/5/07 2:38	58.20	447,839.69	356.65	460,330.81	77.12	0.00	266.84	547.37	970.71	1,501.09	860.99	810.40
7/5/07 2:39	58.63	452,203.00	356.53	460,602.81	73.52	0.00	266.83	547.53	972.17	1,504.57	861.26	810.03
7/5/07 2:40	58.89	451,766.09	356.44	463,879.00	72.30	0.00	266.91	547.63	972.99	1,503.80	861.80	810.27
7/5/07 2:41	59.83	461,013.69	356.30	467,155.31	73.08	0.00	267.03	547.64	973.33	1,512.10	862.09	809.88
7/5/07 2:42	60.09	461,400.31	356.19	470,431.50	74.14	0.00	267.19	547.54	974.00	1,509.34	862.23	809.48
7/5/07 2:43	61.20	469,395.00	355.98	473,707.69	74.05	0.00	267.34	547.29	974.77	1,512.57	862.38	809.17
7/5/07 2:44	61.19	469,868.69	355.72	476,983.91	76.87	0.00	267.58	546.64	973.79	1,508.75	862.38	808.89
7/5/07 2:45	60.84	466,733.69	355.49	480,005.31	73.48	0.00	267.94	545.95	972.35	1,502.75	862.10	808.60
7/5/07 2:46	61.49	471,289.41	355.14	481,015.41	72.02	0.00	268.26	545.35	970.93	1,506.87	861.56	807.91
7/5/07 2:47	61.94	475,951.91	354.95	482,025.69	71.44	0.00	268.53	545.07	971.29	1,508.34	861.77	808.32
7/5/07 2:48	61.80	473,701.31	354.67	483,035.91	70.49	0.00	268.75	544.55	970.99	1,503.30	861.80	808.21
7/5/07 2:49	61.86	476,805.69	354.39	484,046.09	68.78	0.00	268.95	544.06	970.62	1,504.24	861.91	807.93
7/5/07 2:50	61.94	478,153.09	354.09	485,056.31	68.77	0.00	269.09	543.74	970.87	1,502.88	862.18	807.71
7/5/07 2:51	61.89	476,601.00	353.81	486,066.50	66.25	0.00	269.20	543.16	969.48	1,501.99	861.92	807.05
7/5/07 2:52	61.30	471,538.69	353.56	486,294.50	66.85	0.00	269.32	542.59	968.41	1,495.96	861.53	806.43
7/5/07 2:53	61.27	472,030.91	353.32	485,146.81	69.50	0.00	269.37	542.11	967.01	1,498.34	860.82	804.07
7/5/07 2:54	60.94	468,911.31	353.19	483,999.19	68.46	0.00	269.35	541.76	967.26	1,494.79	859.64	802.67
7/5/07 2:55	60.03	462,306.91	353.15	482,851.50	65.87	0.00	269.31	541.25	967.12	1,491.01	856.11	802.59
7/5/07 2:56	60.38	465,718.00	353.16	481,703.81	65.71	0.00	269.24	540.85	966.60	1,498.12	853.20	801.23
7/5/07 2:57	59.68	460,351.19	353.17	481,765.50	67.74	0.00	269.07	540.56	965.81	1,493.17	852.09	800.04
7/5/07 2:58	60.36	465,044.41	353.17	482,903.19	69.23	0.00	268.90	540.28	966.29	1,500.82	852.48	801.91
7/5/07 2:59	60.43	463,904.31	353.16	484,040.81	69.14	0.00	268.70	540.09	968.80	1,499.56	853.47	804.52
7/5/07 3:00	60.78	466,681.09	353.20	485,178.41	71.05	0.00	268.66	539.72	972.09	1,502.75	852.69	808.10
7/5/07 3:01	61.11	468,080.09	353.22	486,316.09	72.12	0.00	268.70	539.39	973.90	1,504.38	853.05	811.32
7/5/07 3:02	60.71	465,144.69	353.18	486,417.59	71.86	0.00	268.77	538.94	972.82	1,497.39	854.25	813.04
7/5/07 3:03	60.80	465,488.41	353.19	486,225.50	70.96	0.00	268.88	538.32	970.60	1,500.54	854.62	811.18
7/5/07 3:04	61.46	473,280.50	353.25	486,033.41	69.84	0.00	269.02	538.06	971.92	1,507.39	854.34	809.89
7/5/07 3:05	61.21	469,815.91	353.31	485,841.31	69.52	0.00	269.08	538.04	974.46	1,499.76	853.35	809.74
7/5/07 3:06	61.20	469,215.31	353.36	485,649.19	69.51	0.00	269.23	537.66	973.80	1,499.24	852.28	807.67
7/5/07 3:07	61.46	471,574.19	353.39	485,457.09	70.86	0.00	269.32	537.38	972.36	1,502.78	852.69	806.65
7/5/07 3:08	61.29	470,436.50	353.47	485,265.00	73.11	0.00	269.36	537.48	971.11	1,499.82	854.78	807.91
7/5/07 3:09	61.36	472,093.41	353.61	485,072.91	75.68	0.00	269.40	537.64	970.58	1,501.87	856.28	810.61
7/5/07 3:10	61.26	470,305.31	353.83	484,880.81	75.06	0.00	269.37	537.94	971.68	1,499.91	856.99	814.46
7/5/07 3:11	61.39	475,884.19	353.97	484,688.69	74.21	0.00	269.34	538.27	971.84	1,506.56	858.36	817.97
7/5/07 3:12	61.82	475,932.69	354.10	484,496.59	76.51	0.00	269.26	538.58	971.56	1,504.54	860.55	819.43
7/5/07 3:13	61.69	473,515.41	354.24	484,304.50	74.98	0.00	269.26	538.92	971.92	1,498.31	861.99	819.10
7/5/07 3:14	61.13	470,519.91	354.33	484,301.81	72.74	0.00	269.28	538.85	968.89	1,499.00	861.56	817.52
7/5/07 3:15	61.25	473,561.59	354.41	484,609.41	75.66	0.00	269.31	539.20	969.26	1,500.91	860.70	816.95
7/5/07 3:16	61.28	470,958.50	354.49	484,917.09	77.81	0.00	269.25	539.62	969.52	1,501.10	860.67	815.64
7/5/07 3:17	61.76	473,817.91	354.61	485,224.69	79.74	0.00	269.19	540.04	971.05	1,503.05	861.93	816.03
7/5/07 3:18	62.08	475,235.50	354.71	485,532.31	79.53	0.00	269.23	540.29	971.33	1,502.46	863.57	817.12
7/5/07 3:19	62.23	475,991.00	354.78	485,839.91	80.70	0.00	269.30	540.23	970.72	1,502.26	864.08	817.73

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 3:20	62.61	480,398.31	354.90	486,147.50	82.70	0.00	269.43	540.30	971.19	1,506.66	864.15	818.92
7/5/07 3:21	62.53	478,676.50	354.98	486,455.19	82.39	0.00	269.61	540.40	971.89	1,501.75	865.20	820.10
7/5/07 3:22	61.83	473,755.81	355.01	486,758.50	86.91	0.00	269.79	540.18	970.75	1,495.05	865.57	819.51
7/5/07 3:23	61.86	473,851.50	355.03	486,972.69	86.86	0.00	270.02	539.91	968.69	1,499.91	864.78	818.81
7/5/07 3:24	61.82	476,852.59	355.06	487,186.91	87.02	0.00	270.09	539.88	967.25	1,500.07	863.67	818.63
7/5/07 3:25	62.10	479,759.31	355.14	487,401.09	88.50	0.00	270.13	539.85	966.55	1,506.15	862.36	818.03
7/5/07 3:26	62.25	479,776.81	355.24	487,615.31	87.65	0.00	270.10	539.95	968.77	1,501.96	862.43	817.95
7/5/07 3:27	62.03	476,570.50	355.30	487,829.50	86.56	0.00	270.15	539.70	969.00	1,501.79	862.45	817.99
7/5/07 3:28	62.02	477,216.50	355.30	488,043.69	86.47	0.00	270.21	539.57	969.08	1,498.63	862.41	817.35
7/5/07 3:29	61.94	476,676.31	355.29	488,257.81	84.35	0.00	270.22	539.43	966.86	1,500.65	861.92	816.77
7/5/07 3:30	61.88	479,026.50	355.30	487,413.69	81.04	0.00	270.25	539.41	966.49	1,502.03	861.85	816.89
7/5/07 3:31	62.06	478,914.50	355.31	486,546.91	83.74	0.00	270.24	539.36	966.14	1,501.94	862.31	816.49
7/5/07 3:32	61.16	469,129.09	355.28	485,680.19	84.10	0.00	270.28	539.28	967.68	1,491.80	863.10	814.39
7/5/07 3:33	60.67	466,078.00	355.27	484,813.50	81.25	0.00	270.24	539.12	970.00	1,491.84	862.40	811.56
7/5/07 3:34	60.56	465,051.00	355.31	483,946.69	78.92	0.00	270.14	539.20	973.06	1,495.79	859.87	810.66
7/5/07 3:35	59.98	460,012.09	355.37	483,080.00	77.02	0.00	269.94	539.56	974.96	1,492.43	858.73	809.49
7/5/07 3:36	59.63	457,341.81	355.51	482,213.31	77.14	0.00	269.56	539.81	974.13	1,492.40	859.27	808.12
7/5/07 3:37	59.80	458,508.59	355.66	481,346.59	77.54	0.00	269.23	540.18	974.08	1,496.42	861.51	810.13
7/5/07 3:38	60.44	463,451.31	355.83	480,479.81	77.58	0.00	268.93	540.74	976.23	1,502.76	863.54	813.53
7/5/07 3:39	60.13	460,318.41	356.03	481,455.91	79.98	0.00	268.63	541.10	977.81	1,498.43	863.57	815.98
7/5/07 3:40	60.94	466,205.41	356.18	483,965.31	83.48	0.00	268.49	541.32	977.90	1,504.43	864.47	818.28
7/5/07 3:41	62.12	473,922.50	356.32	486,474.81	76.56	0.00	268.46	541.62	978.13	1,510.76	866.45	819.70
7/5/07 3:42	62.50	477,436.50	356.40	488,984.19	73.74	0.00	268.50	541.55	978.27	1,510.26	867.82	818.26
7/5/07 3:43	62.47	476,854.19	356.42	491,493.59	72.86	0.00	268.80	541.37	978.75	1,505.37	867.02	816.31
7/5/07 3:44	62.69	477,980.31	356.43	493,821.00	75.82	0.00	269.05	541.12	977.88	1,505.16	864.37	815.30
7/5/07 3:45	62.73	482,037.09	356.53	493,417.81	76.29	0.00	269.39	540.96	976.53	1,508.19	862.98	812.90
7/5/07 3:46	62.92	482,923.19	356.60	493,014.69	75.48	0.00	269.63	540.88	973.15	1,505.90	863.48	811.26
7/5/07 3:47	63.00	483,751.09	356.75	492,611.59	74.48	0.00	269.90	540.93	971.65	1,505.06	865.08	813.21
7/5/07 3:48	62.71	480,338.69	356.82	492,208.41	74.22	0.00	270.12	540.77	970.78	1,498.48	865.62	815.06
7/5/07 3:49	62.13	478,616.81	356.95	491,647.81	78.08	0.00	270.23	540.40	969.55	1,499.60	864.42	816.02
7/5/07 3:50	62.08	477,415.31	357.07	490,644.69	79.73	0.00	270.28	540.34	969.67	1,498.57	865.00	817.49
7/5/07 3:51	61.52	472,697.19	357.13	489,641.50	82.43	0.00	270.21	540.35	967.74	1,493.55	865.98	817.82
7/5/07 3:52	61.15	472,171.81	357.18	488,638.41	81.67	0.00	270.16	540.16	966.24	1,495.02	866.15	816.51
7/5/07 3:53	61.05	474,684.09	357.27	487,635.31	81.11	0.00	270.04	540.15	967.81	1,498.95	865.09	815.72
7/5/07 3:54	60.80	469,124.31	357.37	486,632.19	77.90	0.00	269.81	540.07	968.59	1,494.95	862.93	814.67
7/5/07 3:55	61.27	472,221.31	357.48	485,629.09	75.48	0.00	269.59	540.12	969.69	1,502.45	862.39	812.82
7/5/07 3:56	60.32	464,397.31	357.60	484,625.91	70.10	0.00	269.36	540.23	970.21	1,494.02	863.06	812.08
7/5/07 3:57	60.49	464,515.00	357.65	483,622.81	75.46	0.00	269.24	540.25	969.46	1,497.50	863.75	811.96
7/5/07 3:58	60.42	464,354.09	357.65	482,619.69	75.95	0.00	269.09	540.28	970.12	1,496.67	863.40	812.89
7/5/07 3:59	60.06	462,059.41	357.67	481,616.59	79.37	0.00	268.98	540.07	969.27	1,494.54	862.28	813.76
7/5/07 4:00	59.99	461,496.69	357.61	480,613.41	83.68	0.00	268.96	539.84	968.06	1,494.78	862.44	814.09
7/5/07 4:01	59.89	460,947.69	357.55	479,610.31	80.88	0.00	268.91	539.97	967.62	1,496.35	863.48	813.53
7/5/07 4:02	59.61	458,863.31	357.67	478,607.19	78.47	0.00	268.85	539.99	967.05	1,494.62	863.84	810.97
7/5/07 4:03	59.86	460,849.41	357.73	477,604.09	80.08	0.00	268.86	539.92	968.49	1,499.65	861.19	809.50
7/5/07 4:04	59.79	459,694.19	357.87	476,601.00	80.84	0.00	268.77	539.86	970.36	1,498.31	858.74	807.92
7/5/07 4:05	59.85	459,273.09	357.95	477,375.09	83.91	0.00	268.71	539.70	970.01	1,499.22	857.97	805.39
7/5/07 4:06	60.83	466,558.41	357.93	478,515.31	89.39	0.00	268.72	539.79	971.45	1,507.87	858.81	805.37
7/5/07 4:07	61.25	469,751.19	357.98	479,655.59	87.18	0.00	268.67	540.00	973.98	1,508.19	860.25	807.60
7/5/07 4:08	61.42	469,789.31	358.07	480,795.91	85.62	0.00	268.71	540.09	975.50	1,503.54	859.20	808.73
7/5/07 4:09	61.52	472,431.91	358.06	481,936.19	84.36	0.00	268.87	539.75	973.72	1,505.24	858.20	809.86

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 4:10	61.23	469,161.50	358.04	483,076.41	81.31	0.00	268.99	540.00	973.29	1,500.46	859.36	811.94
7/5/07 4:11	61.46	473,348.59	358.07	482,536.31	81.79	0.00	269.11	540.15	971.06	1,503.88	860.41	809.49
7/5/07 4:12	61.33	470,789.81	358.06	480,287.50	83.40	0.00	269.13	540.35	970.43	1,499.98	860.39	807.02
7/5/07 4:13	60.23	463,074.09	358.13	478,038.69	83.75	0.00	269.20	540.18	968.16	1,491.95	857.58	805.85
7/5/07 4:14	60.18	464,973.09	358.06	475,179.19	81.54	0.00	269.19	540.03	965.46	1,495.60	855.07	803.15
7/5/07 4:15	59.86	462,300.91	358.04	471,776.31	82.00	0.00	269.00	540.24	964.51	1,493.09	855.14	800.04
7/5/07 4:16	59.23	457,935.19	358.05	468,373.41	83.59	0.00	268.82	540.31	962.39	1,492.66	856.03	800.21
7/5/07 4:17	58.99	456,858.41	358.10	467,362.91	84.53	0.00	268.63	540.58	962.64	1,494.10	856.91	801.90
7/5/07 4:18	58.89	456,301.41	358.21	467,865.91	84.23	0.00	268.33	540.87	964.60	1,494.78	856.35	803.76
7/5/07 4:19	58.19	449,016.50	358.33	468,369.00	83.10	0.00	268.02	541.17	965.93	1,489.34	857.05	805.88
7/5/07 4:20	58.53	451,890.09	358.40	468,872.00	84.52	0.00	267.87	541.50	966.70	1,495.27	858.97	807.83
7/5/07 4:21	58.44	450,281.09	358.50	469,375.00	84.44	0.00	267.59	541.85	968.09	1,494.94	860.93	806.47
7/5/07 4:22	58.89	452,946.09	358.72	469,878.00	81.73	0.00	267.42	542.28	969.43	1,502.68	861.07	805.10
7/5/07 4:23	58.44	449,676.41	358.80	470,381.00	80.53	0.00	267.36	542.55	970.89	1,495.56	858.71	805.26
7/5/07 4:24	58.75	451,392.00	358.85	470,884.09	79.55	0.00	267.38	542.69	970.36	1,498.50	857.51	803.00
7/5/07 4:25	58.84	453,262.00	358.92	471,387.09	76.98	0.00	267.37	542.89	969.53	1,501.06	858.25	800.23
7/5/07 4:26	58.57	449,610.31	358.93	471,890.09	79.88	0.00	267.40	543.24	969.19	1,494.84	860.01	801.30
7/5/07 4:27	59.21	454,996.59	358.92	472,393.09	78.44	0.00	267.47	543.38	969.05	1,505.19	860.74	803.28
7/5/07 4:28	59.73	459,284.59	358.98	472,896.19	76.64	0.00	267.48	543.63	970.55	1,507.63	860.12	805.21
7/5/07 4:29	60.11	464,134.31	359.00	473,120.81	81.21	0.00	267.56	543.73	970.57	1,510.24	861.25	807.03
7/5/07 4:30	59.88	460,298.50	359.05	471,714.81	77.56	0.00	267.67	543.82	970.00	1,502.89	863.17	808.06
7/5/07 4:31	59.73	459,826.31	359.05	470,308.81	76.11	0.00	267.83	543.58	969.86	1,499.52	864.01	803.74
7/5/07 4:32	61.21	470,754.41	359.05	473,625.19	78.80	0.00	267.94	543.51	972.07	1,511.94	861.23	801.42
7/5/07 4:33	60.23	463,011.41	359.09	480,771.69	79.89	0.00	268.01	543.43	972.90	1,500.07	857.57	800.87
7/5/07 4:34	60.59	464,902.91	359.14	484,620.69	82.62	0.00	268.15	543.27	971.88	1,503.20	856.00	797.52
7/5/07 4:35	61.49	473,530.81	359.19	488,469.69	81.76	0.00	268.25	543.49	971.84	1,509.73	856.91	796.99
7/5/07 4:36	61.64	473,042.91	359.21	491,238.50	79.96	0.00	268.26	543.76	972.15	1,505.10	858.59	794.98
7/5/07 4:37	61.56	473,590.69	359.27	492,664.50	75.77	0.00	268.35	543.54	971.20	1,503.32	856.98	795.16
7/5/07 4:38	61.91	475,993.50	359.36	494,090.59	68.91	0.00	268.55	543.43	970.56	1,503.85	854.44	796.30
7/5/07 4:39	61.64	474,551.81	359.41	495,516.69	76.68	0.00	268.71	543.38	969.15	1,501.28	854.43	794.38
7/5/07 4:40	61.89	477,092.00	359.47	496,942.69	79.81	0.00	268.88	543.31	968.34	1,504.43	855.77	795.25
7/5/07 4:41	62.58	481,047.19	359.51	498,368.81	84.68	0.00	268.99	543.27	969.52	1,507.36	857.59	799.12
7/5/07 4:42	62.39	479,886.09	359.59	499,794.81	84.60	0.00	269.13	543.00	970.91	1,502.78	857.80	802.72
7/5/07 4:43	62.80	482,572.50	359.62	501,220.91	86.09	0.00	269.30	542.53	971.21	1,506.94	857.52	806.37
7/5/07 4:44	62.70	481,203.31	359.68	502,646.91	86.11	0.00	269.45	542.20	971.98	1,501.85	859.16	809.69
7/5/07 4:45	62.73	482,496.50	359.75	504,073.00	87.34	0.00	269.60	541.79	972.37	1,503.03	860.88	808.07
7/5/07 4:46	63.69	489,699.69	359.81	505,499.00	87.99	0.00	269.79	541.32	974.36	1,513.90	861.38	803.73
7/5/07 4:47	63.49	485,846.50	359.95	506,925.09	85.80	0.00	269.90	540.96	978.24	1,506.36	858.34	803.66
7/5/07 4:48	64.07	489,810.91	360.09	508,351.19	83.19	0.00	270.13	540.35	978.72	1,514.78	855.39	802.76
7/5/07 4:49	64.23	489,041.59	360.20	509,777.19	79.25	0.00	270.33	539.95	977.77	1,515.15	856.08	799.78
7/5/07 4:50	64.48	492,860.59	360.36	511,203.31	81.66	0.00	270.54	539.68	980.43	1,519.43	858.45	802.60
7/5/07 4:51	64.47	492,089.19	360.46	512,629.31	82.24	0.00	270.81	539.20	979.70	1,517.69	860.14	805.48
7/5/07 4:52	64.52	493,827.91	360.58	514,055.41	82.36	0.00	271.06	538.76	979.00	1,518.12	859.65	808.92
7/5/07 4:53	65.29	500,833.19	360.72	515,481.41	81.92	0.00	271.21	538.40	977.35	1,522.12	859.66	811.24
7/5/07 4:54	65.75	506,158.00	360.85	519,159.31	81.97	0.00	271.37	538.24	976.56	1,521.68	861.58	814.32
7/5/07 4:55	65.46	503,724.31	360.98	518,288.00	81.77	0.00	271.66	537.84	974.80	1,513.03	863.31	811.97
7/5/07 4:56	65.82	507,757.59	361.10	516,580.91	82.71	0.00	271.93	537.38	973.61	1,515.27	862.95	809.47
7/5/07 4:57	65.65	505,941.91	361.27	524,596.19	83.17	0.00	272.18	537.10	973.81	1,508.45	860.60	809.59
7/5/07 4:58	65.52	505,797.41	361.38	521,965.81	82.68	0.00	272.41	536.66	972.44	1,505.89	859.75	807.64
7/5/07 4:59	65.60	507,537.59	361.51	520,961.00	86.04	0.00	272.57	536.35	971.17	1,507.70	860.82	807.05

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FLOW (TPH)	PROPANE FUEL FLOW (SCFH)	FWP DISCH FLOW (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 5:00	66.01	509,742.91	361.66	523,686.31	89.04	0.00	272.65	536.38	971.76	1,511.11	862.78	810.29
7/5/07 5:01	65.67	508,460.00	361.83	525,458.31	93.87	0.00	272.73	536.25	972.16	1,503.28	863.67	812.90
7/5/07 5:02	65.27	504,530.19	361.94	517,384.00	86.54	0.00	272.84	535.70	969.99	1,500.73	862.89	814.56
7/5/07 5:03	65.45	505,769.31	362.04	519,759.50	84.19	0.00	273.03	535.62	970.63	1,503.00	863.71	817.21
7/5/07 5:04	65.10	503,921.91	362.17	516,242.09	83.58	0.00	273.06	535.76	969.62	1,500.22	865.02	818.61
7/5/07 5:05	64.30	495,989.50	362.32	515,129.31	79.76	0.00	273.00	535.60	969.13	1,490.72	865.07	815.22
7/5/07 5:06	64.07	495,746.19	362.38	514,016.50	82.98	0.00	272.99	535.59	967.39	1,491.85	863.86	813.52
7/5/07 5:07	64.05	494,812.09	362.53	512,903.69	82.90	0.00	272.82	535.67	967.26	1,495.10	862.89	811.97
7/5/07 5:08	63.61	489,103.19	362.63	511,790.91	82.45	0.00	272.61	536.00	967.87	1,490.96	862.57	810.51
7/5/07 5:09	63.66	491,115.19	362.80	510,678.19	84.64	0.00	272.40	536.22	967.41	1,496.20	862.98	810.72
7/5/07 5:10	63.74	490,713.31	362.93	509,565.31	86.26	0.00	272.19	536.57	968.32	1,499.04	863.41	812.51
7/5/07 5:11	64.04	492,416.81	363.06	508,452.59	86.70	0.00	271.92	536.81	969.43	1,503.73	863.68	812.90
7/5/07 5:12	63.89	491,168.59	363.25	507,339.81	89.64	0.00	271.87	537.11	970.22	1,500.91	863.50	813.41
7/5/07 5:13	63.72	489,515.69	363.39	506,338.31	89.02	0.00	271.87	537.42	971.29	1,499.34	864.22	815.04
7/5/07 5:14	63.87	491,069.69	363.53	506,214.91	88.14	0.00	271.86	537.69	970.62	1,502.31	865.35	814.47
7/5/07 5:15	63.99	490,474.59	363.64	506,091.50	91.99	0.00	271.88	537.96	970.45	1,503.07	866.20	813.52
7/5/07 5:16	63.82	490,516.69	363.74	505,968.09	92.65	0.00	271.84	538.28	970.63	1,499.73	867.00	812.73
7/5/07 5:17	64.14	493,483.91	363.83	505,844.69	91.93	0.00	271.89	538.50	969.50	1,505.54	867.44	811.85
7/5/07 5:18	64.44	496,104.00	363.99	505,721.31	90.53	0.00	271.92	539.00	971.16	1,507.67	868.76	811.90
7/5/07 5:19	64.25	494,475.69	364.13	505,597.91	92.21	0.00	271.98	539.25	971.01	1,504.59	870.05	813.46
7/5/07 5:20	64.47	496,242.91	364.25	505,474.50	90.72	0.00	272.01	539.54	971.28	1,507.07	870.18	814.86
7/5/07 5:21	64.29	494,525.69	364.36	505,351.09	89.84	0.00	272.04	539.89	971.64	1,503.02	870.33	815.31
7/5/07 5:22	64.54	496,843.81	364.45	505,227.69	91.88	0.00	272.08	540.27	970.90	1,506.49	870.34	816.10
7/5/07 5:23	64.32	494,643.69	364.71	505,104.31	92.95	0.00	272.07	540.99	972.27	1,501.10	871.74	817.82
7/5/07 5:24	64.06	493,896.19	364.92	504,945.41	91.49	0.00	272.12	541.26	968.83	1,499.24	872.06	818.07
7/5/07 5:25	64.48	499,010.19	365.16	504,603.69	92.38	0.00	272.12	541.75	966.69	1,506.83	871.94	818.25
7/5/07 5:26	64.40	499,386.19	365.47	504,262.00	94.88	0.00	272.03	542.33	964.00	1,503.96	871.66	819.02
7/5/07 5:27	64.15	497,892.50	365.73	503,920.31	92.10	0.00	272.03	542.56	960.95	1,500.27	870.73	818.62
7/5/07 5:28	64.06	496,969.41	365.92	503,578.59	95.38	0.00	272.09	542.81	960.17	1,500.32	870.22	818.19
7/5/07 5:29	64.11	497,281.81	366.12	503,236.91	93.47	0.00	272.11	543.11	962.64	1,501.69	870.50	820.70
7/5/07 5:30	64.06	497,052.00	366.21	502,895.31	89.85	0.00	272.09	543.00	962.51	1,501.41	869.92	822.76
7/5/07 5:31	64.04	496,219.09	366.30	502,553.59	87.39	0.00	272.07	542.97	963.14	1,501.74	869.01	824.44
7/5/07 5:32	64.09	496,621.59	366.38	502,211.91	87.71	0.00	272.09	542.94	963.97	1,501.31	868.47	826.30
7/5/07 5:33	63.68	491,729.59	366.46	501,870.19	86.92	0.00	272.10	542.75	964.32	1,497.10	868.35	827.32
7/5/07 5:34	64.02	495,582.31	366.42	501,528.50	86.03	0.00	272.13	542.53	964.96	1,503.27	868.66	827.09
7/5/07 5:35	63.68	490,784.19	366.42	501,186.81	81.85	0.00	272.08	542.30	965.61	1,498.67	869.21	826.92
7/5/07 5:36	63.43	489,325.41	366.37	500,845.09	85.50	0.00	272.02	542.15	966.31	1,496.41	869.67	826.27
7/5/07 5:37	63.33	488,009.09	366.35	500,224.19	85.25	0.00	271.95	541.84	965.23	1,495.05	869.88	825.62
7/5/07 5:38	62.97	485,541.69	366.22	498,882.09	82.82	0.00	271.86	541.80	965.72	1,489.06	870.39	826.06
7/5/07 5:39	63.19	488,023.59	366.23	497,540.00	82.64	0.00	271.72	541.79	965.46	1,494.36	870.87	825.75
7/5/07 5:40	63.26	487,431.50	366.20	496,197.91	81.45	0.00	271.57	542.04	968.07	1,494.51	872.01	826.07
7/5/07 5:41	63.03	485,707.00	366.17	494,855.81	81.26	0.00	271.49	542.04	968.68	1,490.74	872.71	825.69
7/5/07 5:42	63.05	484,593.09	366.15	493,513.81	81.26	0.00	271.44	541.95	969.09	1,490.97	873.13	825.58
7/5/07 5:43	62.90	482,842.69	366.15	492,171.69	78.37	0.00	271.39	542.13	970.77	1,491.11	873.90	826.97
7/5/07 5:44	62.78	481,661.50	366.17	490,829.59	82.18	0.00	271.35	542.31	970.33	1,489.72	874.03	828.48
7/5/07 5:45	62.91	483,266.41	366.10	489,487.59	82.95	0.00	271.29	542.40	970.72	1,493.04	873.82	828.77
7/5/07 5:46	62.27	479,944.50	365.98	488,145.50	80.84	0.00	271.19	542.21	969.48	1,490.54	872.94	827.58
7/5/07 5:47	62.43	481,023.91	365.77	486,803.41	81.75	0.00	271.13	542.20	969.51	1,496.85	872.13	826.25
7/5/07 5:48	62.40	479,462.69	365.64	485,461.31	81.02	0.00	271.01	542.39	970.66	1,498.18	872.02	826.18
7/5/07 5:49	62.90	481,787.00	365.55	484,119.31	81.35	0.00	270.90	542.66	971.77	1,501.50	872.16	827.31

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 5:50	62.73	480,629.91	365.56	482,777.19	80.27	0.00	270.82	542.86	971.21	1,500.51	872.65	827.90
7/5/07 5:51	62.03	475,236.00	365.55	481,435.09	77.54	0.00	270.85	542.90	970.23	1,496.64	872.86	829.04
7/5/07 5:52	62.34	478,501.41	365.57	480,093.09	77.67	0.00	270.86	542.94	968.36	1,500.61	872.79	830.00
7/5/07 5:53	62.16	477,727.50	365.65	478,751.00	82.90	0.00	270.81	543.18	968.54	1,498.90	873.33	830.82
7/5/07 5:54	62.31	479,998.69	365.69	477,408.91	84.55	0.00	270.78	543.37	967.94	1,500.89	873.79	830.63
7/5/07 5:55	61.27	471,815.81	365.70	476,066.81	84.36	0.00	270.77	543.38	966.98	1,493.12	873.89	830.08
7/5/07 5:56	61.64	474,221.59	365.75	474,172.31	80.29	0.00	270.75	543.48	966.01	1,497.91	873.77	830.29
7/5/07 5:57	61.36	474,251.41	365.74	471,434.69	78.90	0.00	270.65	543.62	965.28	1,498.83	873.66	830.10
7/5/07 5:58	60.89	469,039.81	365.79	468,697.00	75.54	0.00	270.60	544.21	967.13	1,493.43	872.24	830.51
7/5/07 5:59	60.10	462,128.31	365.90	466,022.31	72.32	0.00	270.45	544.98	966.94	1,489.92	869.99	828.90
7/5/07 6:00	60.02	461,541.69	366.09	468,317.31	73.51	0.00	270.33	545.79	967.80	1,491.49	870.14	830.46
7/5/07 6:01	59.90	460,675.41	366.33	470,612.41	75.25	0.00	270.03	546.40	967.70	1,494.60	870.76	832.48
7/5/07 6:02	59.91	460,704.09	366.57	472,907.41	75.54	0.00	269.74	547.03	968.43	1,496.76	871.98	834.73
7/5/07 6:03	60.20	463,125.19	366.80	475,202.50	77.81	0.00	269.48	547.66	970.84	1,500.03	873.52	837.22
7/5/07 6:04	60.26	463,484.50	366.92	477,497.50	78.07	0.00	269.32	547.87	971.13	1,500.84	874.07	837.98
7/5/07 6:05	60.97	467,987.69	366.84	479,792.50	78.03	0.00	269.23	548.11	971.53	1,505.32	874.19	837.53
7/5/07 6:06	61.38	472,067.81	366.72	482,087.59	80.85	0.00	269.16	548.72	972.84	1,508.21	874.32	837.27
7/5/07 6:07	62.02	475,780.50	366.49	484,192.69	78.67	0.00	269.16	549.30	973.66	1,508.58	874.89	837.79
7/5/07 6:08	61.92	475,330.31	366.31	485,402.09	78.18	0.00	269.25	549.46	973.84	1,505.63	875.74	839.39
7/5/07 6:09	62.20	476,857.81	366.07	486,611.59	76.74	0.00	269.48	549.42	973.09	1,505.17	876.37	839.43
7/5/07 6:10	62.30	478,040.69	365.80	487,821.00	73.57	0.00	269.67	549.10	971.75	1,504.19	876.52	838.25
7/5/07 6:11	62.64	482,271.81	365.41	489,030.50	72.95	0.00	269.76	548.81	971.27	1,506.45	876.31	836.65
7/5/07 6:12	62.50	479,593.19	364.92	490,240.00	73.10	0.00	269.88	548.46	970.83	1,501.79	875.75	834.94
7/5/07 6:13	62.46	479,985.50	364.27	491,449.41	76.60	0.00	270.08	548.27	969.89	1,502.81	874.91	833.41
7/5/07 6:14	63.31	487,111.81	363.67	492,658.91	77.21	0.00	270.13	548.20	970.08	1,509.38	874.72	832.64
7/5/07 6:15	62.59	481,376.00	363.25	493,868.31	77.34	0.00	270.16	548.12	970.49	1,497.74	875.16	832.74
7/5/07 6:16	62.96	485,591.59	362.89	493,921.00	75.78	0.00	270.31	547.66	968.78	1,504.78	875.33	832.02
7/5/07 6:17	63.26	488,313.31	362.70	493,133.00	77.66	0.00	270.38	547.31	969.09	1,508.95	875.95	832.35
7/5/07 6:18	62.65	482,968.41	362.62	492,345.00	78.84	0.00	270.35	547.36	969.59	1,496.78	876.00	832.92
7/5/07 6:19	62.46	481,471.41	362.48	491,425.59	76.35	0.00	270.36	547.14	967.75	1,499.18	873.24	830.96
7/5/07 6:20	62.41	481,939.91	362.50	490,403.91	72.58	0.00	270.30	547.55	969.09	1,496.99	872.71	830.90
7/5/07 6:21	61.29	471,962.00	362.53	489,382.19	69.42	0.00	270.25	547.51	966.96	1,490.75	872.78	830.35
7/5/07 6:22	61.19	472,174.19	362.61	488,360.50	67.39	0.00	270.26	547.38	965.92	1,493.77	873.16	830.17
7/5/07 6:23	60.71	470,343.09	362.63	487,338.81	69.80	0.00	270.02	547.50	967.05	1,493.10	874.11	830.78
7/5/07 6:24	60.77	468,851.69	362.61	486,317.09	71.54	0.00	269.86	547.39	967.26	1,497.96	874.74	830.43
7/5/07 6:25	60.83	468,574.59	362.61	485,437.91	72.25	0.00	269.72	547.56	969.72	1,496.43	875.75	831.00
7/5/07 6:26	60.88	469,150.81	362.59	486,215.59	69.83	0.00	269.56	547.67	970.71	1,497.81	876.53	831.55
7/5/07 6:27	60.88	469,527.91	362.53	486,993.31	67.03	0.00	269.53	547.57	971.00	1,498.89	877.14	831.45
7/5/07 6:28	61.50	473,205.31	362.42	487,770.91	68.94	0.00	269.52	547.41	972.37	1,504.89	877.65	831.80
7/5/07 6:29	61.90	475,566.91	362.31	488,548.59	68.72	0.00	269.52	547.12	972.89	1,506.45	877.97	831.83
7/5/07 6:30	61.42	471,330.19	362.14	489,326.31	70.16	0.00	269.59	546.85	972.46	1,498.35	878.08	831.81
7/5/07 6:31	61.56	473,806.09	361.99	490,103.91	69.43	0.00	269.71	546.60	971.32	1,501.52	877.98	831.65
7/5/07 6:32	61.12	468,600.19	361.83	490,881.59	73.38	0.00	269.81	546.65	970.74	1,496.63	878.06	832.13
7/5/07 6:33	61.85	475,255.81	361.62	491,659.31	74.71	0.00	269.86	546.83	970.58	1,505.37	878.20	832.44
7/5/07 6:34	61.81	475,791.00	361.46	491,669.91	72.18	0.00	269.86	547.05	970.47	1,502.14	878.56	832.49
7/5/07 6:35	61.19	470,859.09	361.28	491,042.31	70.61	0.00	269.84	546.87	969.74	1,496.03	878.67	832.73
7/5/07 6:36	61.94	477,474.50	361.06	490,414.69	69.79	0.00	269.82	546.64	968.52	1,505.23	878.44	831.91
7/5/07 6:37	61.68	476,284.31	360.95	489,787.09	68.69	0.00	269.82	546.84	969.06	1,500.94	878.89	832.07
7/5/07 6:38	61.19	472,362.81	360.91	489,159.50	70.97	0.00	269.77	546.93	967.97	1,496.83	879.03	832.34
7/5/07 6:39	60.88	470,861.19	360.88	488,531.91	72.08	0.00	269.74	546.89	965.96	1,497.34	878.87	831.64

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 6:40	61.51	474,374.91	360.93	487,904.31	73.21	0.00	269.67	547.21	966.74	1,504.07	879.22	831.57
7/5/07 6:41	61.18	471,184.59	360.96	487,276.69	74.26	0.00	269.51	547.56	967.19	1,498.68	879.65	832.12
7/5/07 6:42	61.49	474,517.41	361.03	486,649.09	77.55	0.00	269.43	547.89	967.98	1,502.45	879.95	832.32
7/5/07 6:43	61.97	478,957.69	361.10	486,021.50	79.09	0.00	269.35	548.22	969.59	1,506.58	880.58	832.53
7/5/07 6:44	62.30	479,172.91	361.18	485,939.31	80.38	0.00	269.39	548.62	971.51	1,505.40	881.46	833.12
7/5/07 6:45	61.69	474,031.50	361.27	485,909.31	79.35	0.00	269.49	548.54	971.10	1,497.37	881.65	833.59
7/5/07 6:46	62.06	478,277.91	361.29	485,879.41	75.96	0.00	269.69	548.50	970.46	1,503.34	881.46	833.22
7/5/07 6:47	62.49	478,852.41	361.37	485,476.69	73.01	0.00	269.76	548.75	971.59	1,502.24	881.96	833.53
7/5/07 6:48	61.53	473,815.41	361.44	484,314.19	71.77	0.00	269.94	548.56	969.83	1,495.30	882.02	833.75
7/5/07 6:49	61.93	476,853.69	361.49	483,151.81	71.89	0.00	270.12	548.39	968.39	1,501.81	881.72	833.84
7/5/07 6:50	61.72	475,688.69	361.59	481,989.31	73.75	0.00	270.18	548.39	967.72	1,499.53	881.70	833.17
7/5/07 6:51	61.62	474,097.69	361.63	480,826.91	73.82	0.00	270.26	548.38	967.44	1,498.76	881.63	832.81
7/5/07 6:52	60.93	468,880.09	361.60	479,664.41	72.35	0.00	270.29	548.16	965.97	1,493.97	880.74	832.32
7/5/07 6:53	61.29	473,159.91	361.58	478,502.00	70.58	0.00	270.28	547.97	966.40	1,501.20	879.78	831.85
7/5/07 6:54	62.33	479,699.09	361.52	477,961.41	69.83	0.00	270.17	547.96	968.74	1,509.12	879.28	831.33
7/5/07 6:55	62.03	476,450.41	361.49	478,900.91	68.75	0.00	270.19	547.84	971.28	1,500.32	879.19	831.34
7/5/07 6:56	62.19	476,164.59	361.40	479,840.50	67.70	0.00	270.27	547.41	970.90	1,501.53	878.37	830.67
7/5/07 6:57	62.57	479,765.31	361.40	480,780.09	67.51	0.00	270.38	547.31	972.29	1,506.20	878.21	830.85
7/5/07 6:58	62.68	481,143.19	361.41	481,719.59	69.82	0.00	270.41	547.37	973.26	1,502.99	878.41	831.20
7/5/07 6:59	62.79	483,141.31	361.40	482,659.19	74.00	0.00	270.48	546.92	971.87	1,505.74	878.11	831.82
7/5/07 7:00	63.51	487,078.31	361.40	483,598.81	73.97	0.00	270.53	546.79	973.15	1,509.55	878.35	833.12
7/5/07 7:01	63.59	487,464.50	361.45	484,538.31	71.87	0.00	270.58	546.57	973.43	1,509.32	878.68	833.59
7/5/07 7:02	63.05	484,785.09	361.46	485,477.91	72.50	0.00	270.75	546.16	972.31	1,499.42	878.49	833.83
7/5/07 7:03	63.43	487,081.19	361.47	486,417.50	71.48	0.00	270.94	545.70	970.48	1,506.83	877.84	834.36
7/5/07 7:04	63.56	488,866.81	361.46	487,357.09	73.47	0.00	270.97	545.54	970.74	1,508.16	878.01	834.65
7/5/07 7:05	63.33	487,452.31	361.49	488,296.59	74.39	0.00	271.02	545.25	969.77	1,503.07	878.13	834.55
7/5/07 7:06	63.16	487,050.50	361.52	489,236.19	74.71	0.00	271.09	544.88	968.76	1,501.19	878.08	834.41
7/5/07 7:07	63.28	487,147.91	361.54	490,175.81	76.29	0.00	271.14	544.50	968.97	1,503.42	878.29	834.41
7/5/07 7:08	63.54	488,854.50	361.54	491,115.31	73.27	0.00	271.14	544.26	969.55	1,506.85	878.73	834.54
7/5/07 7:09	62.82	483,792.59	361.59	492,054.91	72.26	0.00	271.20	544.01	969.71	1,493.23	878.97	833.88
7/5/07 7:10	62.81	484,085.59	361.59	488,426.31	71.58	0.00	271.20	543.54	967.94	1,496.53	878.25	832.88
7/5/07 7:11	62.91	484,411.50	361.58	484,778.50	71.82	0.00	271.22	543.43	969.23	1,497.13	878.49	833.22
7/5/07 7:12	61.73	475,054.69	361.56	481,130.81	71.39	0.00	271.17	543.26	967.73	1,489.45	878.65	833.13
7/5/07 7:13	61.71	476,649.00	361.67	478,438.91	70.98	0.00	271.16	543.26	966.92	1,494.30	878.91	833.38
7/5/07 7:14	61.20	471,499.00	361.73	476,310.41	71.07	0.00	271.00	543.55	967.76	1,491.34	879.75	835.22
7/5/07 7:15	60.65	468,562.41	361.79	474,181.91	71.69	0.00	270.79	543.55	966.22	1,491.61	879.83	835.90
7/5/07 7:16	60.88	469,998.81	361.87	476,166.50	73.03	0.00	270.53	543.73	967.24	1,496.41	880.24	836.63
7/5/07 7:17	60.83	468,238.00	361.94	478,209.91	73.70	0.00	270.22	544.02	968.29	1,495.94	880.74	836.80
7/5/07 7:18	60.64	466,675.00	362.00	480,253.19	75.77	0.00	269.98	544.10	968.85	1,496.19	881.06	836.29
7/5/07 7:19	61.48	472,717.41	362.10	482,296.50	77.13	0.00	269.84	544.47	970.61	1,505.07	881.65	836.95
7/5/07 7:20	61.75	474,357.69	362.16	484,339.91	77.74	0.00	269.74	544.80	972.87	1,505.25	882.47	837.87
7/5/07 7:21	62.43	478,272.00	362.27	486,383.19	80.10	0.00	269.69	544.96	974.22	1,509.05	883.20	838.77
7/5/07 7:22	62.29	477,147.00	362.35	487,733.31	82.52	0.00	269.81	545.17	975.35	1,503.92	883.89	839.25
7/5/07 7:23	63.16	481,653.19	362.42	488,644.81	83.60	0.00	269.90	545.17	974.46	1,507.83	884.24	838.97
7/5/07 7:24	62.79	483,808.19	362.44	489,556.41	81.28	0.00	270.07	545.43	974.79	1,505.07	884.76	838.93
7/5/07 7:25	62.31	477,579.81	362.50	486,185.09	78.92	0.00	270.26	545.38	972.57	1,499.01	884.60	838.82
7/5/07 7:26	63.22	485,547.81	362.54	484,224.19	78.33	0.00	270.45	545.39	970.60	1,507.80	884.35	838.71
7/5/07 7:27	63.01	484,465.91	362.63	484,015.81	75.93	0.00	270.50	545.81	971.45	1,504.05	884.90	840.26
7/5/07 7:28	62.33	478,489.31	362.71	483,859.50	75.98	0.00	270.59	545.66	969.57	1,498.52	884.77	840.96
7/5/07 7:29	62.35	479,435.00	362.74	484,788.31	78.92	0.00	270.65	545.80	968.95	1,500.33	884.66	841.27

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 7:30	63.24	487,045.41	362.84	485,717.00	82.78	0.00	270.61	546.17	970.48	1,508.69	885.08	842.17
7/5/07 7:31	62.35	477,624.41	362.89	486,645.81	83.31	0.00	270.52	546.42	970.90	1,495.52	885.49	841.86
7/5/07 7:32	62.11	477,478.81	362.95	486,800.69	80.78	0.00	270.57	546.16	968.41	1,495.89	884.93	841.23
7/5/07 7:33	62.67	484,187.41	362.99	486,817.09	82.08	0.00	270.54	546.37	968.76	1,503.74	884.90	841.58
7/5/07 7:34	62.63	483,452.50	363.05	486,833.50	78.26	0.00	270.45	546.73	969.99	1,501.20	885.59	841.95
7/5/07 7:35	62.29	479,425.81	363.18	487,276.69	77.02	0.00	270.47	546.79	969.52	1,498.43	885.82	841.39
7/5/07 7:36	61.20	472,356.41	363.20	473,709.31	75.87	0.00	270.48	546.62	967.86	1,493.31	883.96	840.55
7/5/07 7:37	61.35	471,850.31	363.28	479,380.81	76.76	0.00	270.45	547.20	968.96	1,496.61	880.75	837.71
7/5/07 7:38	60.92	468,625.59	363.38	475,907.59	75.71	0.00	270.34	547.72	969.57	1,493.05	880.10	837.55
7/5/07 7:39	61.00	469,521.81	363.48	478,063.00	77.62	0.00	270.20	547.84	969.57	1,496.42	880.12	837.43
7/5/07 7:40	61.43	473,320.59	363.58	479,882.59	74.27	0.00	270.02	548.08	971.32	1,502.75	881.19	838.22
7/5/07 7:41	61.10	469,878.50	363.70	479,795.59	76.43	0.00	269.90	548.06	972.00	1,497.83	882.42	838.30
7/5/07 7:42	60.63	466,302.81	363.67	480,139.41	79.47	0.00	269.89	547.66	971.28	1,495.74	882.79	838.88
7/5/07 7:43	61.88	477,822.09	363.68	483,827.81	79.65	0.00	269.83	547.77	972.23	1,507.48	883.32	840.07
7/5/07 7:44	61.70	473,787.31	363.62	489,742.81	81.33	0.00	269.77	548.25	974.26	1,500.89	884.48	841.49
7/5/07 7:45	61.43	472,682.41	363.54	484,802.31	81.85	0.00	269.83	548.31	973.25	1,499.13	885.09	841.68
7/5/07 7:46	61.41	473,120.81	363.42	486,527.59	81.91	0.00	269.87	547.95	971.72	1,502.63	885.24	842.24
7/5/07 7:47	61.84	476,291.59	363.28	490,499.41	82.29	0.00	269.91	548.10	972.75	1,504.51	885.85	843.68
7/5/07 7:48	61.28	472,753.00	363.16	487,006.31	79.69	0.00	269.83	547.94	971.03	1,498.03	886.15	844.28
7/5/07 7:49	61.10	472,298.31	362.94	484,152.91	78.07	0.00	269.87	547.88	969.01	1,497.80	885.88	844.69
7/5/07 7:50	61.51	474,824.91	362.69	488,685.91	79.16	0.00	269.82	548.14	969.46	1,503.32	886.18	845.13
7/5/07 7:51	61.23	473,078.59	362.44	489,327.31	80.47	0.00	269.73	548.47	969.41	1,499.69	886.62	845.40
7/5/07 7:52	61.92	480,749.31	362.16	491,224.00	81.65	0.00	269.64	548.56	969.32	1,506.24	886.97	845.65
7/5/07 7:53	62.13	478,950.00	361.97	495,850.81	82.09	0.00	269.56	548.58	969.81	1,506.39	887.35	846.53
7/5/07 7:54	62.37	481,820.50	361.79	496,663.19	80.06	0.00	269.55	548.38	970.59	1,505.05	887.65	847.75
7/5/07 7:55	62.59	482,959.59	361.68	495,728.69	81.23	0.00	269.66	548.22	970.79	1,505.28	887.66	848.44
7/5/07 7:56	63.22	487,894.91	361.58	498,145.09	88.10	0.00	269.79	548.08	971.21	1,511.32	888.08	848.09
7/5/07 7:57	63.44	489,453.50	361.53	502,706.69	91.21	0.00	269.94	548.35	973.45	1,511.43	889.06	849.00
7/5/07 7:58	63.69	490,058.59	361.56	503,047.41	92.45	0.00	270.13	548.16	974.22	1,512.56	889.63	850.01
7/5/07 7:59	64.14	493,612.69	361.55	503,802.00	91.53	0.00	270.33	548.12	974.59	1,520.72	890.13	850.84
7/5/07 8:00	64.38	495,658.00	361.61	505,841.69	91.82	0.00	270.56	548.10	975.45	1,524.70	890.96	852.29
7/5/07 8:01	64.89	500,269.59	361.75	507,191.41	94.45	0.00	270.81	548.10	974.95	1,526.82	891.59	853.26
7/5/07 8:02	64.68	500,865.91	361.83	506,818.69	90.87	0.00	271.12	547.86	972.89	1,518.83	891.92	853.65
7/5/07 8:03	65.44	508,690.41	361.89	511,827.50	88.93	0.00	271.38	547.61	971.31	1,522.53	892.24	854.52
7/5/07 8:04	65.00	504,857.81	362.02	512,281.41	87.21	0.00	271.74	547.25	969.85	1,512.83	892.62	855.42
7/5/07 8:05	64.81	503,586.09	362.15	509,298.31	85.23	0.00	272.01	546.80	967.26	1,508.68	892.41	855.66
7/5/07 8:06	64.91	504,163.69	362.23	506,721.09	84.95	0.00	272.28	546.51	966.04	1,509.26	892.20	855.78
7/5/07 8:07	64.39	500,812.19	362.36	508,977.00	83.90	0.00	272.48	546.50	966.88	1,499.95	892.60	855.65
7/5/07 8:08	64.19	498,685.50	362.46	503,467.81	85.01	0.00	272.67	546.31	965.43	1,497.99	892.48	855.01
7/5/07 8:09	64.21	499,857.31	362.58	501,698.09	84.22	0.00	272.74	546.03	965.95	1,500.60	892.23	854.61
7/5/07 8:10	64.17	498,711.81	362.67	503,354.00	88.57	0.00	272.77	546.12	968.44	1,499.76	892.08	853.53
7/5/07 8:11	63.72	494,421.59	362.67	499,187.00	88.58	0.00	272.76	545.62	968.32	1,495.74	890.80	851.76
7/5/07 8:12	63.61	493,422.91	362.55	497,341.81	87.43	0.00	272.76	545.14	969.13	1,495.91	889.38	849.70
7/5/07 8:13	63.32	490,265.09	362.46	497,605.69	90.04	0.00	272.68	544.97	970.21	1,494.69	888.57	849.13
7/5/07 8:14	63.27	488,266.09	362.41	493,964.59	88.94	0.00	272.54	544.90	970.97	1,496.10	888.43	849.23
7/5/07 8:15	63.02	486,548.41	362.41	493,633.69	87.98	0.00	272.38	544.80	971.26	1,493.63	888.09	848.87
7/5/07 8:16	63.31	489,594.50	362.36	492,172.81	87.00	0.00	272.30	544.48	971.15	1,499.06	887.53	848.33
7/5/07 8:17	63.41	489,407.00	362.38	494,953.81	89.17	0.00	272.14	544.43	972.51	1,503.61	887.49	848.00
7/5/07 8:18	63.34	488,727.41	362.38	495,119.81	87.55	0.00	272.00	544.40	972.49	1,502.50	887.40	848.25
7/5/07 8:19	63.24	487,809.09	362.37	495,942.00	84.33	0.00	271.97	544.17	971.59	1,498.27	887.09	848.52

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 8:20	63.27	488,408.31	362.37	493,380.91	81.15	0.00	271.99	544.27	971.10	1,500.44	887.03	849.44
7/5/07 8:21	63.29	489,211.91	362.39	494,086.41	78.88	0.00	271.98	544.31	970.51	1,500.19	886.99	849.61
7/5/07 8:22	63.15	487,758.00	362.40	492,576.69	76.51	0.00	272.01	544.31	968.73	1,497.12	886.89	849.35
7/5/07 8:23	63.47	491,252.91	362.44	493,675.50	78.78	0.00	272.02	544.51	968.85	1,505.09	887.31	850.21
7/5/07 8:24	62.81	486,278.31	362.54	493,815.81	76.00	0.00	272.01	544.83	968.41	1,492.23	887.99	851.10
7/5/07 8:25	62.65	486,661.91	362.63	490,851.50	74.07	0.00	271.99	545.03	966.29	1,491.78	888.24	852.11
7/5/07 8:26	62.65	487,405.41	362.75	490,360.31	75.04	0.00	271.93	545.40	966.13	1,492.40	888.58	853.89
7/5/07 8:27	62.47	485,322.41	362.91	489,600.31	77.07	0.00	271.84	545.98	965.97	1,491.44	889.31	855.18
7/5/07 8:28	62.40	485,460.81	363.10	489,096.50	79.29	0.00	271.76	546.51	965.32	1,491.65	890.19	856.08
7/5/07 8:29	62.47	486,586.81	363.31	488,874.50	82.23	0.00	271.68	546.93	965.52	1,495.37	890.64	857.09
7/5/07 8:30	62.38	485,283.19	363.47	489,559.41	83.98	0.00	271.66	547.24	966.50	1,494.37	890.71	857.44
7/5/07 8:31	62.51	486,794.41	363.53	488,141.31	83.06	0.00	271.63	547.45	966.11	1,497.05	890.04	856.71
7/5/07 8:32	62.49	485,995.50	363.56	488,959.81	83.66	0.00	271.54	547.68	966.44	1,497.68	889.40	856.40
7/5/07 8:33	62.51	487,026.00	363.58	487,763.59	85.70	0.00	271.52	547.85	965.97	1,499.08	888.79	856.21
7/5/07 8:34	62.44	485,909.31	363.61	489,658.31	83.32	0.00	271.51	547.95	965.09	1,498.73	888.30	855.95
7/5/07 8:35	62.38	485,738.69	363.64	488,986.59	83.66	0.00	271.45	547.95	964.08	1,498.16	887.69	856.30
7/5/07 8:36	62.88	490,455.31	363.70	489,593.69	82.65	0.00	271.50	548.00	963.46	1,509.00	887.36	856.93
7/5/07 8:37	62.21	485,194.81	363.83	493,311.59	84.25	0.00	271.53	548.21	964.18	1,494.99	887.74	856.97
7/5/07 8:38	62.11	484,909.09	363.96	488,105.00	83.20	0.00	271.57	547.98	961.73	1,495.50	887.18	856.42
7/5/07 8:39	61.72	482,687.69	364.01	485,996.09	81.29	0.00	271.63	547.77	960.12	1,494.64	886.49	855.91
7/5/07 8:40	62.25	487,580.41	364.12	490,653.59	86.01	0.00	271.58	547.94	960.77	1,503.91	886.41	856.09
7/5/07 8:41	60.91	478,429.31	364.27	485,007.50	84.16	0.00	271.53	547.84	960.63	1,492.22	886.14	855.28
7/5/07 8:42	60.35	473,596.09	364.37	477,467.00	86.36	0.00	271.51	547.50	959.94	1,492.04	885.13	854.03
7/5/07 8:43	61.06	478,460.41	364.46	481,858.81	86.56	0.00	271.37	547.60	961.79	1,501.72	884.85	853.67
7/5/07 8:44	60.75	475,251.41	364.58	483,945.19	86.47	0.00	271.10	547.99	964.36	1,496.99	885.15	853.69
7/5/07 8:45	61.18	479,662.31	364.73	485,105.19	82.34	0.00	270.89	547.99	965.06	1,503.97	885.08	854.00
7/5/07 8:46	61.17	477,766.69	364.87	488,368.81	79.47	0.00	270.83	548.13	967.09	1,500.12	885.11	854.24
7/5/07 8:47	61.50	482,886.31	364.99	488,767.41	84.69	0.00	270.75	548.03	967.11	1,503.13	884.93	854.09
7/5/07 8:48	61.29	478,779.91	365.10	485,420.41	83.77	0.00	270.76	547.77	967.05	1,500.13	884.37	853.67
7/5/07 8:49	61.31	481,675.31	365.13	490,439.91	82.97	0.00	270.80	547.51	966.01	1,502.62	883.28	852.74
7/5/07 8:50	61.78	485,237.81	365.13	492,524.31	81.23	0.00	270.82	547.39	966.61	1,505.02	882.75	852.70
7/5/07 8:51	61.28	481,032.09	365.09	492,257.31	78.11	0.00	270.85	546.95	966.16	1,499.30	882.16	851.72
7/5/07 8:52	60.51	475,021.41	365.01	485,864.81	79.75	0.00	270.94	546.44	965.61	1,494.43	881.11	851.00
7/5/07 8:53	60.79	476,669.41	364.98	488,522.09	76.58	0.00	270.91	546.12	966.25	1,500.18	880.36	850.60
7/5/07 8:54	61.19	479,447.81	364.94	491,571.59	75.80	0.00	270.74	546.08	968.16	1,504.10	880.63	850.99
7/5/07 8:55	60.13	469,631.59	364.99	489,596.41	77.29	0.00	270.63	545.96	969.34	1,491.12	880.87	851.72
7/5/07 8:56	60.21	472,171.50	365.00	483,363.50	76.80	0.00	270.61	545.56	967.61	1,495.95	880.38	851.72
7/5/07 8:57	60.36	473,646.31	365.03	483,547.69	77.90	0.00	270.45	545.39	967.66	1,497.50	880.22	852.12
7/5/07 8:58	60.36	472,898.31	365.11	483,243.69	79.11	0.00	270.22	545.49	967.55	1,499.28	880.15	852.65
7/5/07 8:59	59.63	467,837.81	365.20	479,856.00	77.02	0.00	270.09	545.37	966.73	1,495.52	879.84	852.28
7/5/07 9:00	60.27	473,041.59	365.23	484,432.19	77.75	0.00	269.95	545.42	967.22	1,502.57	879.85	852.29
7/5/07 9:01	59.63	468,978.31	365.35	477,625.09	77.57	0.00	269.76	545.43	967.00	1,497.15	879.82	851.94
7/5/07 9:02	59.76	468,040.41	365.35	479,151.81	79.24	0.00	269.63	545.38	967.70	1,498.36	879.49	851.22
7/5/07 9:03	60.08	470,159.69	365.34	482,068.19	76.43	0.00	269.47	545.38	969.43	1,502.68	879.30	850.56
7/5/07 9:04	59.85	467,260.31	365.33	483,404.81	75.30	0.00	269.41	545.27	970.74	1,498.65	878.80	849.76
7/5/07 9:05	60.73	472,681.59	365.26	484,324.19	77.50	0.00	269.43	545.11	971.83	1,506.27	878.43	849.72
7/5/07 9:06	60.91	475,199.19	365.28	488,415.91	77.11	0.00	269.43	544.97	973.15	1,503.81	878.59	849.32
7/5/07 9:07	61.37	479,456.00	365.25	489,752.59	80.36	0.00	269.52	544.63	972.84	1,508.15	878.49	848.96
7/5/07 9:08	61.26	478,733.50	365.14	490,528.91	81.24	0.00	269.67	544.03	971.94	1,503.86	877.89	848.11
7/5/07 9:09	61.41	478,743.09	364.99	492,014.31	79.74	0.00	269.88	543.36	970.46	1,504.14	877.18	847.22

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 9:10	61.34	478,489.91	364.88	489,039.91	78.15	0.00	270.08	542.86	969.05	1,502.71	876.55	846.62
7/5/07 9:11	61.35	480,912.09	364.78	489,533.09	79.47	0.00	270.26	542.45	967.77	1,503.29	876.09	845.72
7/5/07 9:12	61.40	481,887.00	364.71	490,269.81	79.43	0.00	270.37	542.14	967.87	1,503.38	875.99	845.44
7/5/07 9:13	60.28	473,659.91	364.61	488,205.19	78.22	0.00	270.50	541.59	966.45	1,493.98	875.46	844.48
7/5/07 9:14	60.11	473,056.69	364.49	480,673.50	79.96	0.00	270.57	540.96	964.80	1,494.69	874.58	843.95
7/5/07 9:15	59.39	467,223.31	364.37	480,596.09	79.91	0.00	270.51	540.85	964.25	1,491.05	873.85	843.24
7/5/07 9:16	59.73	469,790.31	364.23	479,575.50	76.12	0.00	270.44	540.74	964.38	1,497.18	873.47	842.86
7/5/07 9:17	59.67	469,946.00	364.10	479,870.09	80.74	0.00	270.24	540.85	966.02	1,495.82	873.82	842.57
7/5/07 9:18	59.16	465,318.50	364.07	477,121.19	85.13	0.00	269.98	540.62	967.32	1,493.92	873.99	842.51
7/5/07 9:19	59.11	464,627.59	364.01	472,710.31	85.35	0.00	269.81	540.39	968.78	1,497.39	873.86	842.75
7/5/07 9:20	59.35	465,298.81	363.93	479,490.91	83.10	0.00	269.57	540.73	971.55	1,498.55	874.80	844.38
7/5/07 9:21	59.07	462,920.00	363.90	473,319.00	80.93	0.00	269.36	540.73	971.65	1,497.24	875.21	845.41
7/5/07 9:22	59.35	466,002.09	363.96	476,587.31	78.85	0.00	269.23	540.82	971.40	1,501.73	875.26	846.60
7/5/07 9:23	60.18	471,364.19	363.98	478,923.59	80.49	0.00	269.13	541.08	972.64	1,506.19	876.14	847.69
7/5/07 9:24	60.03	470,198.19	364.07	480,792.00	79.96	0.00	269.14	541.24	972.25	1,503.27	876.87	847.21
7/5/07 9:25	60.57	473,725.81	364.18	482,697.50	84.16	0.00	269.24	541.22	971.45	1,505.94	877.82	847.32
7/5/07 9:26	60.41	473,333.50	364.28	484,467.19	84.37	0.00	269.39	541.26	970.58	1,501.84	878.41	848.06
7/5/07 9:27	60.63	477,069.31	364.44	482,049.41	81.70	0.00	269.58	541.22	969.31	1,502.46	878.77	848.89
7/5/07 9:28	60.32	473,711.00	364.48	481,851.41	83.06	0.00	269.76	541.15	968.24	1,500.21	878.66	849.33
7/5/07 9:29	60.62	475,865.59	364.59	483,293.31	80.03	0.00	270.00	541.26	967.80	1,502.75	878.87	850.18
7/5/07 9:30	60.43	474,936.19	364.71	484,003.09	78.48	0.00	270.11	541.28	968.10	1,501.37	879.20	850.49
7/5/07 9:31	60.47	474,839.00	364.75	482,734.91	79.20	0.00	270.20	541.21	968.06	1,500.81	879.37	850.66
7/5/07 9:32	60.18	473,724.41	364.84	478,855.09	79.46	0.00	270.25	541.33	968.18	1,498.58	879.49	851.00
7/5/07 9:33	59.64	469,701.59	364.90	476,999.00	80.78	0.00	270.24	541.58	967.38	1,495.90	879.55	849.38
7/5/07 9:34	59.96	472,431.41	365.00	475,264.09	80.79	0.00	270.18	542.11	968.06	1,501.58	880.17	848.40
7/5/07 9:35	58.93	466,695.00	365.06	473,529.31	80.32	0.00	270.05	542.39	967.62	1,492.44	880.56	847.91
7/5/07 9:36	59.42	468,580.69	365.09	475,195.81	76.53	0.00	270.00	542.68	967.51	1,499.75	880.72	848.31
7/5/07 9:37	59.96	472,697.91	365.17	479,348.69	75.36	0.00	269.80	543.22	969.13	1,502.64	881.21	848.77
7/5/07 9:38	59.95	473,125.41	365.28	479,422.50	73.75	0.00	269.64	543.76	969.56	1,502.26	881.96	848.29
7/5/07 9:39	60.65	479,380.41	365.45	479,798.91	71.55	0.00	269.67	544.24	970.48	1,507.44	882.71	847.99
7/5/07 9:40	61.01	479,972.50	365.66	486,140.09	74.35	0.00	269.74	544.81	971.73	1,506.77	883.93	849.10
7/5/07 9:41	61.66	484,933.41	365.89	489,524.81	76.71	0.00	269.90	545.01	971.88	1,510.04	884.84	849.89
7/5/07 9:42	62.27	489,212.31	366.11	493,132.59	77.28	0.00	270.09	545.19	972.05	1,514.51	885.81	850.94
7/5/07 9:43	62.16	488,344.00	366.29	494,753.00	78.27	0.00	270.43	545.35	972.55	1,508.49	886.89	852.54
7/5/07 9:44	62.35	490,602.50	366.47	495,061.81	76.72	0.00	270.75	545.15	971.22	1,512.98	887.52	852.95
7/5/07 9:45	62.25	490,509.81	366.65	495,370.50	80.83	0.00	271.03	545.01	970.93	1,511.22	888.19	854.10
7/5/07 9:46	62.12	490,894.00	366.85	496,490.00	81.12	0.00	271.33	545.06	969.84	1,510.09	888.52	854.86
7/5/07 9:47	62.33	493,071.09	367.05	497,513.31	80.30	0.00	271.55	545.15	970.47	1,514.20	889.31	855.74
7/5/07 9:48	62.42	493,118.81	367.27	498,536.59	77.47	0.00	271.75	545.22	970.04	1,515.46	889.69	856.07
7/5/07 9:49	62.09	491,535.31	367.45	499,559.81	74.01	0.00	271.87	545.24	969.79	1,510.09	890.11	856.05
7/5/07 9:50	61.92	492,601.09	367.67	500,583.09	75.53	0.00	271.97	545.17	968.17	1,508.45	889.76	855.53
7/5/07 9:51	62.47	496,289.81	367.82	501,606.41	77.72	0.00	272.05	545.27	967.83	1,517.87	889.85	855.76
7/5/07 9:52	62.24	494,890.91	367.96	501,639.31	80.36	0.00	272.09	545.46	968.15	1,507.98	890.10	855.94
7/5/07 9:53	62.29	494,547.59	368.11	498,882.00	78.26	0.00	272.18	545.10	966.22	1,507.45	889.31	854.94
7/5/07 9:54	62.16	493,847.50	368.16	498,225.50	77.59	0.00	272.26	544.85	966.93	1,503.69	888.81	854.16
7/5/07 9:55	62.46	496,910.31	368.14	497,568.91	76.25	0.00	272.31	544.64	967.46	1,508.20	887.95	851.93
7/5/07 9:56	62.51	498,138.00	368.19	496,912.41	73.23	0.00	272.34	544.56	969.17	1,507.63	887.82	851.36
7/5/07 9:57	61.67	490,455.09	368.22	496,255.91	75.52	0.00	272.39	544.11	969.94	1,496.70	887.51	851.28
7/5/07 9:58	61.65	489,491.09	368.23	495,599.31	73.37	0.00	272.41	543.69	969.40	1,498.11	886.79	851.47
7/5/07 9:59	61.76	490,091.91	368.19	495,100.31	71.26	0.00	272.40	543.49	969.66	1,500.57	886.49	852.09

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG)	SH OUTLET FLUE GAS TEMP (DEG)
7/5/07 10:00	61.84	490,478.59	368.24	494,723.69	72.67	0.00	272.30	543.43	970.71	1,499.76	886.70	852.01
7/5/07 10:01	61.84	490,218.09	368.32	494,347.19	72.47	0.00	272.30	543.04	970.09	1,500.69	886.63	852.07
7/5/07 10:02	61.95	490,411.19	368.36	493,970.59	73.98	0.00	272.28	542.92	970.32	1,501.95	886.94	852.56
7/5/07 10:03	61.66	489,021.09	368.43	493,594.09	74.27	0.00	272.26	542.80	969.85	1,498.58	887.23	853.37
7/5/07 10:04	61.51	487,450.41	368.57	493,217.50	76.38	0.00	272.21	542.63	968.36	1,495.68	887.05	853.57
7/5/07 10:05	61.47	486,838.91	368.69	492,840.91	76.98	0.00	272.18	542.65	968.04	1,495.96	887.34	854.49
7/5/07 10:06	61.22	486,334.91	368.77	492,464.41	74.40	0.00	272.20	542.54	966.71	1,492.21	886.83	854.59
7/5/07 10:07	61.11	485,100.50	368.84	492,087.81	71.26	0.00	272.14	542.61	967.00	1,488.83	886.76	853.95
7/5/07 10:08	61.09	485,344.00	368.96	491,711.31	71.82	0.00	272.07	542.70	967.73	1,490.09	886.98	853.40
7/5/07 10:09	60.93	483,544.69	368.97	491,334.69	74.63	0.00	271.94	542.75	969.23	1,488.24	886.93	851.90
7/5/07 10:10	60.81	482,631.69	368.93	490,958.19	75.91	0.00	271.87	542.66	970.64	1,488.97	886.68	850.04
7/5/07 10:11	60.83	480,809.81	368.87	490,581.59	75.93	0.00	271.77	542.68	973.43	1,490.61	886.77	849.68
7/5/07 10:12	60.95	481,389.41	368.75	490,205.09	75.84	0.00	271.70	542.53	974.42	1,494.45	886.73	849.26
7/5/07 10:13	61.65	487,695.09	368.73	489,828.50	75.95	0.00	271.63	542.61	976.03	1,506.55	887.09	849.62
7/5/07 10:14	61.51	485,077.00	368.72	489,452.00	73.33	0.00	271.60	542.74	976.75	1,502.04	887.72	849.89
7/5/07 10:15	61.22	483,503.41	368.69	489,075.41	75.24	0.00	271.62	542.62	975.21	1,498.74	887.74	849.30
7/5/07 10:16	61.51	486,638.81	368.63	488,698.81	75.12	0.00	271.62	542.50	973.72	1,503.69	887.72	849.18
7/5/07 10:17	61.20	484,846.69	368.58	488,322.31	75.51	0.00	271.65	542.42	971.67	1,498.25	887.59	849.06
7/5/07 10:18	61.51	486,854.59	368.56	487,945.81	73.13	0.00	271.65	542.51	970.53	1,503.25	887.58	848.91
7/5/07 10:19	61.38	485,990.59	368.51	487,569.19	72.48	0.00	271.72	542.52	969.92	1,502.90	887.72	849.25
7/5/07 10:20	61.24	484,533.31	368.52	487,192.59	72.76	0.00	271.71	542.59	970.02	1,499.83	887.96	848.49
7/5/07 10:21	60.89	483,500.31	368.51	486,816.09	78.54	0.00	271.78	542.56	969.05	1,497.93	887.84	846.99
7/5/07 10:22	60.48	478,532.19	368.53	486,439.50	75.92	0.00	271.75	542.56	969.26	1,494.29	887.81	845.68
7/5/07 10:23	60.51	482,171.31	368.51	485,700.69	76.55	0.00	271.73	542.58	969.34	1,498.62	887.87	844.91
7/5/07 10:24	60.29	478,070.50	368.58	483,944.00	78.65	0.00	271.66	542.69	969.81	1,496.02	888.05	844.73
7/5/07 10:25	60.03	475,168.31	368.63	482,187.31	83.33	0.00	271.63	542.89	970.61	1,494.70	888.46	844.33
7/5/07 10:26	60.31	475,793.50	368.73	480,430.59	81.73	0.00	271.56	543.07	971.02	1,499.15	888.81	844.87
7/5/07 10:27	60.46	477,758.00	368.78	478,673.91	82.10	0.00	271.48	543.44	972.13	1,501.40	889.58	845.67
7/5/07 10:28	59.71	474,341.19	368.92	476,917.31	82.92	0.00	271.37	543.73	972.10	1,494.48	890.58	846.88
7/5/07 10:29	58.90	467,707.41	369.10	475,064.81	82.74	0.00	271.32	543.84	970.06	1,491.25	890.82	847.43
7/5/07 10:30	58.94	467,888.69	369.23	473,066.19	83.63	0.00	271.21	544.21	969.27	1,494.62	891.04	847.63
7/5/07 10:31	58.00	460,848.50	369.12	471,067.69	80.53	0.00	270.96	544.57	968.54	1,490.10	890.93	847.05
7/5/07 10:32	57.97	460,252.59	369.12	469,069.09	80.45	0.00	270.72	544.55	967.18	1,493.68	890.12	845.89
7/5/07 10:33	57.53	458,658.91	368.99	467,070.50	78.61	0.00	270.41	544.91	968.13	1,490.34	889.83	845.48
7/5/07 10:34	57.50	456,804.81	368.93	465,071.91	77.57	0.00	270.18	545.18	968.00	1,493.28	889.41	845.19
7/5/07 10:35	57.36	456,443.09	368.89	463,073.31	74.32	0.00	269.93	545.62	968.58	1,492.91	888.01	844.68
7/5/07 10:36	56.67	451,265.41	368.85	461,074.81	69.92	0.00	269.72	546.43	969.44	1,488.91	884.88	841.98
7/5/07 10:37	56.52	450,474.59	368.74	459,076.19	72.71	0.00	269.50	546.91	969.01	1,494.14	883.51	841.20
7/5/07 10:38	55.84	445,510.19	368.67	457,496.91	74.18	0.00	269.29	547.45	970.66	1,486.86	883.32	840.58
7/5/07 10:39	55.94	444,623.69	368.52	457,471.41	71.85	0.00	269.02	547.66	969.91	1,493.35	882.93	840.09
7/5/07 10:40	55.82	444,859.31	368.37	457,445.81	70.40	0.00	268.76	548.18	971.26	1,491.94	883.22	840.03
7/5/07 10:41	56.11	445,129.31	368.25	457,420.31	69.72	0.00	268.55	548.59	971.75	1,498.03	883.46	841.33
7/5/07 10:42	55.64	441,983.31	368.01	457,394.81	68.43	0.00	268.28	548.95	970.90	1,493.20	883.49	841.13
7/5/07 10:43	55.84	443,752.69	367.75	457,369.31	69.39	0.00	268.18	549.44	970.29	1,498.65	882.98	840.06
7/5/07 10:44	55.90	444,772.81	367.39	457,060.59	71.31	0.00	267.95	549.89	970.62	1,498.91	882.48	840.58
7/5/07 10:45	54.84	436,635.19	366.90	456,216.31	69.82	0.00	267.80	549.94	970.07	1,487.43	881.58	840.76
7/5/07 10:46	55.39	440,554.19	366.32	455,372.00	67.09	0.00	267.66	549.78	968.25	1,496.89	880.22	840.21
7/5/07 10:47	55.59	442,299.59	365.75	454,771.31	66.21	0.00	267.48	549.93	968.99	1,499.22	879.70	839.85
7/5/07 10:48	55.26	439,527.69	365.20	455,597.09	66.82	0.00	267.22	549.84	968.90	1,494.65	879.41	839.83
7/5/07 10:49	54.49	434,573.00	364.64	456,422.91	68.30	0.00	267.09	549.65	967.95	1,490.23	878.93	839.89

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 10:50	54.71	436,808.69	364.00	457,248.81	71.42	0.00	266.96	549.79	968.13	1,494.17	878.77	840.34
7/5/07 10:51	54.34	434,101.91	363.34	458,074.69	73.18	0.00	266.77	549.92	967.92	1,491.70	878.44	840.45
7/5/07 10:52	55.47	443,048.31	362.72	458,900.50	74.81	0.00	266.60	549.88	967.93	1,506.07	877.91	840.43
7/5/07 10:53	56.31	449,613.59	362.20	460,341.59	75.84	0.00	266.40	550.13	970.66	1,508.82	878.38	840.40
7/5/07 10:54	56.78	453,306.09	361.76	462,367.91	74.97	0.00	266.36	549.72	971.54	1,509.81	878.58	839.41
7/5/07 10:55	57.35	456,417.59	361.32	464,394.19	75.08	0.00	266.51	549.10	972.34	1,510.28	878.63	839.38
7/5/07 10:56	57.65	458,246.00	360.92	466,420.59	78.27	0.00	266.68	548.50	972.56	1,508.81	878.68	839.18
7/5/07 10:57	58.27	463,598.69	360.62	468,446.91	76.34	0.00	266.98	547.95	972.08	1,511.06	878.66	839.21
7/5/07 10:58	57.33	456,062.09	360.28	470,473.19	75.54	0.00	267.20	547.48	971.51	1,497.02	878.82	839.08
7/5/07 10:59	56.93	452,243.09	359.98	468,778.19	72.62	0.00	267.47	546.77	968.83	1,492.14	878.31	838.58
7/5/07 11:00	56.59	451,876.31	359.71	463,299.31	71.09	0.00	267.73	546.38	967.26	1,492.87	877.68	837.42
7/5/07 11:01	56.50	450,264.50	359.49	457,820.31	70.04	0.00	267.79	546.09	966.87	1,492.78	877.38	836.39
7/5/07 11:02	55.33	440,603.91	359.30	452,439.50	70.65	0.00	267.78	545.54	965.81	1,484.90	876.57	833.16
7/5/07 11:03	55.04	439,946.91	359.18	450,323.81	70.55	0.00	267.74	545.21	965.75	1,486.99	875.23	829.53
7/5/07 11:04	54.58	435,601.19	359.19	448,208.09	71.16	0.00	267.48	545.11	967.51	1,487.04	872.53	828.05
7/5/07 11:05	53.19	424,902.91	359.15	446,092.41	70.97	0.00	267.19	544.84	968.04	1,480.50	868.92	825.59
7/5/07 11:06	53.02	425,574.41	359.07	443,976.81	68.57	0.00	266.87	544.60	967.53	1,484.18	866.56	821.86
7/5/07 11:07	52.79	422,870.09	358.91	441,655.50	67.39	0.00	266.34	544.55	967.65	1,485.65	865.67	821.37
7/5/07 11:08	51.81	414,379.69	358.86	439,281.59	69.16	0.00	265.87	544.58	968.18	1,481.82	865.86	822.17
7/5/07 11:09	52.31	418,864.81	358.74	436,907.69	68.94	0.00	265.52	544.60	969.59	1,492.61	864.67	823.95
7/5/07 11:10	52.49	420,226.41	358.66	435,539.81	69.58	0.00	265.09	544.96	972.81	1,494.75	864.33	826.95
7/5/07 11:11	52.33	419,547.69	358.55	436,566.91	71.69	0.00	264.88	545.09	972.88	1,492.60	864.80	828.57
7/5/07 11:12	53.15	426,196.59	358.45	437,594.00	68.75	0.00	264.76	545.09	973.03	1,502.52	864.97	827.69
7/5/07 11:13	52.54	420,076.81	358.38	438,621.09	67.51	0.00	264.63	545.09	973.68	1,493.32	864.69	825.36
7/5/07 11:14	52.63	423,383.09	358.34	439,648.09	67.45	0.00	264.63	544.91	973.46	1,495.06	862.79	823.57
7/5/07 11:15	52.66	421,250.19	358.22	440,675.19	68.64	0.00	264.66	544.91	973.30	1,491.85	861.15	821.76
7/5/07 11:16	51.90	417,904.00	358.07	438,198.19	62.78	0.00	264.66	544.64	970.83	1,487.07	860.10	818.82
7/5/07 11:17	51.47	414,795.41	357.92	435,162.69	62.46	0.00	264.67	544.39	968.52	1,486.71	860.06	818.76
7/5/07 11:18	50.98	414,009.31	357.77	432,127.09	61.90	0.00	264.56	544.31	967.62	1,487.12	860.38	819.44
7/5/07 11:19	50.67	413,145.50	357.60	429,091.50	62.01	0.00	264.40	544.23	968.39	1,487.38	859.56	820.46
7/5/07 11:20	50.35	412,394.19	357.46	426,056.00	60.26	0.00	264.14	544.35	969.99	1,486.56	859.60	823.00
7/5/07 11:21	49.59	406,999.31	357.33	423,020.41	59.24	0.00	263.88	544.37	970.16	1,481.33	859.96	824.06
7/5/07 11:22	49.50	407,216.00	357.08	419,900.59	61.68	0.00	263.70	544.18	969.00	1,485.48	858.97	821.93
7/5/07 11:23	48.88	401,587.19	356.89	416,746.69	61.19	0.00	263.42	544.29	968.95	1,480.60	857.49	819.80
7/5/07 11:24	47.45	394,328.69	356.71	413,604.00	61.77	0.00	263.18	544.13	966.81	1,474.27	854.79	817.35
7/5/07 11:25	47.16	393,409.31	356.49	411,338.59	62.72	0.00	263.02	544.09	965.75	1,478.19	851.86	813.48
7/5/07 11:26	47.07	394,032.50	356.31	409,073.31	63.81	0.00	262.60	544.39	966.44	1,485.18	850.26	810.80
7/5/07 11:27	45.56	386,328.91	356.08	406,807.91	63.23	0.00	262.28	544.65	967.67	1,477.30	849.63	810.39
7/5/07 11:28	44.84	379,143.91	355.89	404,542.59	63.18	0.00	262.02	544.51	966.54	1,476.68	848.17	808.69
7/5/07 11:29	45.03	379,568.81	355.68	402,277.19	63.26	0.00	261.67	544.46	966.66	1,488.41	846.55	807.74
7/5/07 11:30	44.51	376,394.69	355.54	400,538.91	64.40	0.00	261.11	544.74	968.80	1,480.74	846.14	807.64
7/5/07 11:31	44.29	373,393.59	355.35	399,210.50	65.08	0.00	260.69	544.64	968.86	1,483.24	845.42	807.49
7/5/07 11:32	44.91	378,293.50	355.19	397,882.19	62.71	0.00	260.36	544.64	970.96	1,495.72	844.36	807.39
7/5/07 11:33	45.39	382,571.50	355.05	395,926.41	59.00	0.00	260.04	544.66	972.02	1,499.33	843.44	807.84
7/5/07 11:34	44.61	376,267.50	354.92	393,856.31	61.68	0.00	259.83	544.05	969.61	1,485.31	841.41	806.67
7/5/07 11:35	44.57	376,103.00	354.73	392,058.19	63.80	0.00	259.80	543.27	966.64	1,488.70	839.17	804.62
7/5/07 11:36	44.23	374,641.69	354.55	390,388.50	64.11	0.00	259.72	542.82	965.91	1,486.82	837.77	802.58
7/5/07 11:37	43.33	369,350.69	354.33	388,718.81	62.42	0.00	259.50	542.36	965.52	1,481.19	836.43	800.63
7/5/07 11:38	42.98	366,236.91	354.12	386,786.09	63.37	0.00	259.33	541.84	964.39	1,483.20	834.87	799.30
7/5/07 11:39	42.87	364,686.41	353.93	384,738.41	67.98	0.00	259.10	541.52	964.44	1,486.18	833.63	798.90

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FLOW (TPH)	PROPANE FUEL FLOW (SCFH)	FWP DISCH FLOW (DEGF)	ECONOMIZER TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 11:40	43.26	367,916.41	353.77	382,690.81	74.15	0.00	258.67	541.50	966.65	1,493.55	833.14	798.20
7/5/07 11:41	42.13	359,051.69	353.65	380,643.09	81.36	0.00	258.20	541.15	968.61	1,478.27	833.06	795.92
7/5/07 11:42	42.00	356,440.31	353.45	379,040.00	82.90	0.00	257.96	540.60	968.89	1,483.04	831.75	791.39
7/5/07 11:43	42.62	361,014.09	353.26	378,277.91	82.01	0.00	257.64	540.52	971.95	1,496.20	828.75	788.61
7/5/07 11:44	42.29	358,513.81	353.16	377,515.81	81.61	0.00	257.20	540.54	974.80	1,488.05	826.14	786.14
7/5/07 11:45	42.20	356,785.31	353.07	376,753.69	84.23	0.00	256.92	540.26	974.23	1,486.87	824.73	782.18
7/5/07 11:46	41.90	354,658.00	352.86	375,991.59	82.33	0.00	256.69	540.08	973.92	1,483.41	824.72	781.42
7/5/07 11:47	41.92	354,850.41	352.89	376,034.81	82.10	0.00	256.43	540.44	974.24	1,484.92	826.58	783.68
7/5/07 11:48	41.38	351,396.31	352.94	376,171.50	84.49	0.00	256.18	540.85	974.23	1,483.48	827.26	785.50
7/5/07 11:49	41.80	352,971.09	353.03	376,308.31	82.75	0.00	256.00	541.31	974.71	1,492.77	828.04	787.48
7/5/07 11:50	41.78	353,402.41	353.01	376,850.09	81.12	0.00	255.75	541.69	975.61	1,493.69	829.96	789.71
7/5/07 11:51	41.86	353,836.19	352.92	376,893.19	77.88	0.00	255.56	541.90	975.27	1,495.09	831.39	789.80
7/5/07 11:52	41.72	351,823.91	352.85	375,906.09	79.08	0.00	255.45	541.90	973.45	1,490.48	831.19	786.84
7/5/07 11:53	42.02	353,622.91	352.76	369,867.00	81.04	0.00	255.40	542.16	973.60	1,495.76	829.27	785.70
7/5/07 11:54	41.94	353,070.19	352.68	370,929.00	77.21	0.00	255.34	542.59	973.81	1,489.93	827.88	784.26
7/5/07 11:55	41.78	353,016.31	352.56	371,092.31	75.46	0.00	255.31	542.94	973.25	1,488.01	827.98	782.82
7/5/07 11:56	42.02	355,782.00	352.45	370,840.19	73.63	0.00	255.31	542.85	971.66	1,494.68	828.41	783.55
7/5/07 11:57	42.07	356,757.59	352.30	368,428.19	75.30	0.00	255.28	542.87	971.11	1,494.43	828.94	785.45
7/5/07 11:58	42.20	357,143.31	352.17	368,802.19	74.94	0.00	255.30	542.91	971.70	1,494.41	828.24	786.96
7/5/07 11:59	41.90	356,133.59	352.07	369,174.81	73.54	0.00	255.33	542.96	970.43	1,491.22	828.11	788.96
7/5/07 12:00	41.88	355,534.91	352.08	366,972.59	71.77	0.00	255.35	543.31	970.42	1,490.89	829.38	791.93
7/5/07 12:01	41.77	354,236.19	352.03	364,770.50	71.84	0.00	255.38	543.55	969.85	1,488.69	830.25	791.06
7/5/07 12:02	41.70	354,142.59	351.91	366,286.19	67.06	0.00	255.40	543.86	968.81	1,486.70	829.69	788.95
7/5/07 12:03	41.77	355,234.00	351.84	367,880.91	64.81	0.00	255.34	543.67	969.15	1,490.44	827.63	788.70
7/5/07 12:04	41.87	355,508.41	351.73	368,697.59	64.10	0.00	255.32	543.72	970.51	1,492.28	826.65	787.69
7/5/07 12:05	42.24	358,282.59	351.62	369,009.69	65.78	0.00	255.31	543.72	970.98	1,498.01	827.09	786.46
7/5/07 12:06	43.30	366,861.91	351.56	371,254.69	69.75	0.00	255.32	543.95	972.77	1,506.31	828.62	788.65
7/5/07 12:07	43.54	366,669.50	351.52	374,669.59	72.36	0.00	255.34	544.21	974.74	1,499.25	830.11	791.22
7/5/07 12:08	44.07	370,552.19	351.42	378,084.41	72.01	0.00	255.55	544.03	974.72	1,501.92	830.15	792.14
7/5/07 12:09	44.00	371,922.41	351.38	381,499.31	70.42	0.00	255.76	543.84	974.44	1,491.44	831.10	793.85
7/5/07 12:10	43.83	370,470.91	351.26	384,516.81	69.31	0.00	256.03	543.63	971.28	1,489.18	831.73	794.29
7/5/07 12:11	43.85	370,726.81	351.15	385,714.31	72.64	0.00	256.41	543.51	968.73	1,489.81	832.22	790.98
7/5/07 12:12	44.03	371,648.91	351.04	386,911.81	73.10	0.00	256.69	543.46	967.74	1,492.76	830.20	789.46
7/5/07 12:13	43.83	370,387.00	350.95	388,109.31	71.65	0.00	256.88	543.33	967.11	1,489.60	826.97	788.52
7/5/07 12:14	44.02	371,585.69	350.89	389,306.69	74.67	0.00	257.03	543.40	966.62	1,494.07	826.37	786.64
7/5/07 12:15	44.83	378,641.00	350.94	391,803.19	75.36	0.00	257.13	543.78	968.79	1,504.40	828.23	786.18
7/5/07 12:16	44.78	378,409.19	351.08	395,535.19	72.22	0.00	257.20	544.21	971.77	1,497.02	830.94	788.62
7/5/07 12:17	45.64	383,555.59	351.20	399,267.19	74.82	0.00	257.38	544.26	973.08	1,502.21	831.56	790.45
7/5/07 12:18	46.61	391,293.59	351.36	402,999.31	71.39	0.00	257.57	544.15	974.85	1,506.08	831.40	792.01
7/5/07 12:19	47.07	394,012.00	351.43	405,722.09	50.66	0.00	257.79	544.23	976.49	1,500.92	833.37	795.08
7/5/07 12:20	47.09	394,474.50	351.51	408,003.81	43.57	0.00	258.21	543.98	975.14	1,501.18	835.16	796.36
7/5/07 12:21	47.85	400,565.09	351.61	410,285.50	52.31	0.00	258.61	543.96	975.56	1,499.15	836.83	795.87
7/5/07 12:22	49.00	409,141.09	351.71	412,567.31	66.48	0.00	259.08	543.80	975.71	1,506.38	836.34	795.46
7/5/07 12:23	48.84	409,472.19	351.94	414,849.00	73.06	0.00	259.60	543.63	975.27	1,500.42	835.29	794.98
7/5/07 12:24	48.75	408,347.31	352.12	417,130.69	78.59	0.00	260.14	543.43	973.45	1,496.38	836.13	792.83
7/5/07 12:25	49.36	413,989.69	352.35	419,908.50	82.22	0.00	260.69	543.29	972.26	1,501.98	838.37	793.16
7/5/07 12:26	48.90	409,672.41	352.60	423,262.81	81.51	0.00	261.13	543.43	972.11	1,491.49	841.31	795.90
7/5/07 12:27	48.97	410,930.19	352.88	423,711.19	81.26	0.00	261.54	543.46	970.83	1,493.22	842.12	798.09
7/5/07 12:28	48.92	409,417.50	353.22	424,046.31	78.75	0.00	261.87	543.61	970.55	1,492.28	843.42	800.76
7/5/07 12:29	49.12	412,087.19	353.56	424,381.50	79.44	0.00	262.16	544.09	969.75	1,496.32	846.61	804.24

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 12:30	48.35	406,018.41	353.94	424,716.59	80.99	0.00	262.37	544.56	968.55	1,488.24	849.98	804.97
7/5/07 12:31	48.76	409,116.50	354.31	425,051.81	85.15	0.00	262.55	545.10	969.30	1,495.13	852.49	804.87
7/5/07 12:32	48.61	407,547.41	354.70	425,386.91	84.06	0.00	262.56	545.60	970.80	1,493.81	852.08	805.58
7/5/07 12:33	48.38	407,138.00	355.10	425,722.09	87.12	0.00	262.64	546.02	971.40	1,490.96	851.39	805.32
7/5/07 12:34	48.72	409,174.91	355.42	426,057.31	85.15	0.00	262.68	546.47	970.65	1,498.14	852.90	803.26
7/5/07 12:35	49.35	413,324.19	355.71	426,392.41	82.68	0.00	262.75	547.13	971.51	1,503.45	855.76	804.90
7/5/07 12:36	50.44	421,528.91	355.92	427,921.31	78.65	0.00	262.84	547.64	973.28	1,507.04	858.45	807.47
7/5/07 12:37	50.46	422,397.50	356.11	432,076.41	77.39	0.00	262.99	547.73	973.59	1,504.62	858.56	810.18
7/5/07 12:38	51.05	426,112.91	356.24	436,231.59	76.67	0.00	263.31	547.87	974.32	1,504.79	859.50	813.15
7/5/07 12:39	52.20	435,454.00	356.39	440,386.69	76.87	0.00	263.69	548.12	974.40	1,510.34	861.72	816.74
7/5/07 12:40	52.65	439,266.31	356.54	444,541.81	80.07	0.00	264.11	548.35	976.23	1,506.58	864.44	815.51
7/5/07 12:41	53.35	443,938.09	356.74	448,697.00	82.57	0.00	264.60	548.06	977.17	1,507.37	863.67	811.85
7/5/07 12:42	53.83	446,652.81	356.90	452,852.09	81.15	0.00	265.20	547.49	976.77	1,506.99	859.60	810.62
7/5/07 12:43	54.22	450,566.19	357.06	457,007.31	79.76	0.00	265.70	547.28	977.14	1,502.65	857.44	808.31
7/5/07 12:44	53.73	447,124.31	357.26	460,208.00	78.55	0.00	266.22	546.97	974.16	1,496.84	857.96	806.18
7/5/07 12:45	53.11	444,338.50	357.45	459,871.91	77.31	0.00	266.81	546.83	971.64	1,493.75	859.47	803.35
7/5/07 12:46	53.42	446,546.59	357.70	459,535.91	74.83	0.00	267.13	546.74	970.14	1,498.10	859.22	802.60
7/5/07 12:47	52.76	442,135.59	357.97	459,199.81	69.76	0.00	267.32	546.49	968.44	1,491.03	856.52	803.02
7/5/07 12:48	52.88	443,191.81	358.21	458,863.81	66.76	0.00	267.46	546.37	967.38	1,493.83	855.49	801.53
7/5/07 12:49	52.69	441,127.00	358.40	458,527.69	66.41	0.00	267.47	546.40	967.65	1,493.01	856.96	801.01
7/5/07 12:50	52.24	437,907.41	358.59	458,191.59	69.22	0.00	267.44	546.49	968.50	1,492.67	858.90	803.61
7/5/07 12:51	52.54	438,668.69	358.76	457,855.59	71.64	0.00	267.37	546.61	970.67	1,498.37	860.01	806.55
7/5/07 12:52	53.03	442,821.81	359.01	457,519.50	71.56	0.00	267.26	546.72	973.01	1,502.37	859.81	809.28
7/5/07 12:53	54.74	455,450.59	359.23	459,860.31	71.75	0.00	267.24	546.90	975.28	1,511.79	861.27	812.22
7/5/07 12:54	54.16	451,075.31	359.47	464,016.81	74.20	0.00	267.33	547.04	977.60	1,500.32	864.02	814.69
7/5/07 12:55	54.45	452,243.59	359.63	469,706.09	72.30	0.00	267.62	546.60	978.32	1,503.42	865.59	809.71
7/5/07 12:56	55.73	461,763.81	359.79	476,119.59	70.60	0.00	267.91	546.26	979.52	1,511.24	863.03	807.66
7/5/07 12:57	56.30	463,198.41	360.01	481,373.81	73.59	0.00	268.21	546.27	982.37	1,511.67	859.92	807.85
7/5/07 12:58	55.33	463,959.59	360.17	479,819.09	75.38	0.00	268.58	545.81	981.95	1,507.61	859.17	804.49
7/5/07 12:59	56.70	455,730.81	360.28	478,264.31	74.21	0.00	269.06	545.19	980.91	1,518.58	860.46	804.62
7/5/07 13:00	58.85	470,224.59	360.30	477,376.69	72.06	0.00	269.34	544.92	981.52	1,531.90	862.18	807.97
7/5/07 13:01	58.42	463,835.59	360.36	480,396.41	73.36	0.00	269.42	544.24	979.80	1,519.83	861.69	810.94
7/5/07 13:02	59.21	471,504.09	360.37	483,416.09	72.10	0.00	269.55	543.36	976.28	1,516.98	860.14	812.64
7/5/07 13:03	60.31	483,028.31	360.43	486,435.81	69.07	0.00	269.62	542.69	973.53	1,523.38	860.86	814.72
7/5/07 13:04	59.62	476,689.19	360.48	489,455.59	66.33	0.00	269.68	542.10	971.93	1,506.93	862.19	813.69
7/5/07 13:05	60.18	480,099.19	360.44	491,375.09	64.68	0.00	269.93	540.88	968.98	1,510.97	861.43	808.36
7/5/07 13:06	61.08	488,445.69	360.43	493,012.50	67.05	0.00	270.16	540.07	970.61	1,513.39	858.85	807.35
7/5/07 13:07	60.64	485,257.50	360.54	494,649.81	67.80	0.00	270.36	539.23	971.34	1,506.52	856.86	806.22
7/5/07 13:08	60.05	481,876.81	360.64	496,106.59	69.48	0.00	270.53	538.31	970.57	1,501.65	857.44	803.05
7/5/07 13:09	60.06	481,640.19	360.80	493,805.69	70.42	0.00	270.63	537.62	970.72	1,501.57	859.07	804.81
7/5/07 13:10	60.00	481,570.69	360.92	491,504.69	68.91	0.00	270.77	536.96	970.79	1,501.43	860.03	807.28
7/5/07 13:11	59.13	473,283.69	360.98	489,203.69	66.76	0.00	270.87	536.22	971.10	1,493.47	859.02	808.35
7/5/07 13:12	59.28	474,617.41	361.03	486,902.81	65.39	0.00	270.96	535.47	969.41	1,497.20	858.41	809.18
7/5/07 13:13	59.23	474,491.41	361.03	484,601.81	65.26	0.00	270.86	535.13	970.08	1,498.10	859.59	810.74
7/5/07 13:14	59.11	474,315.81	361.04	482,300.81	61.27	0.00	270.85	534.90	970.31	1,496.93	860.08	808.41
7/5/07 13:15	57.74	463,095.19	361.15	479,999.81	58.20	0.00	270.80	534.44	969.51	1,488.46	859.11	804.96
7/5/07 13:16	57.28	460,041.69	361.27	479,214.59	59.17	0.00	270.73	533.97	968.25	1,489.57	857.91	803.56
7/5/07 13:17	57.04	458,238.59	361.35	479,871.19	65.32	0.00	270.57	533.74	967.29	1,491.82	856.57	801.56
7/5/07 13:18	57.12	459,476.31	361.42	480,527.81	70.12	0.00	270.26	533.75	967.50	1,495.59	856.47	800.85
7/5/07 13:19	57.58	461,827.19	361.52	481,184.50	72.36	0.00	269.94	533.79	969.20	1,500.58	857.17	803.00

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	Biomass FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 13:20	57.87	462,671.09	361.71	481,841.09	75.58	0.00	269.76	533.72	970.35	1,503.57	857.53	803.90
7/5/07 13:21	57.91	465,238.19	361.89	482,497.69	83.96	0.00	269.66	533.80	971.81	1,500.65	858.10	805.02
7/5/07 13:22	57.84	464,390.00	362.22	483,154.31	89.34	0.00	269.65	533.92	971.51	1,499.93	859.01	807.13
7/5/07 13:23	58.74	471,200.81	362.49	483,811.00	89.14	0.00	269.71	534.06	970.79	1,508.25	860.54	807.84
7/5/07 13:24	59.13	474,570.91	362.73	484,959.50	87.78	0.00	269.76	534.40	971.71	1,508.39	862.27	806.70
7/5/07 13:25	59.77	480,124.81	362.90	486,419.31	85.94	0.00	269.87	534.81	971.80	1,510.68	863.11	806.56
7/5/07 13:26	59.23	474,312.59	363.07	487,879.19	83.87	0.00	270.07	535.47	971.58	1,501.51	863.91	806.18
7/5/07 13:27	59.50	476,777.91	363.22	489,339.00	83.18	0.00	270.33	536.40	970.84	1,502.90	864.27	804.04
7/5/07 13:28	59.51	477,544.31	363.31	490,798.81	80.15	0.00	270.52	537.35	969.98	1,503.56	865.14	803.68
7/5/07 13:29	59.21	475,269.81	363.45	492,258.59	79.54	0.00	270.70	538.05	968.15	1,500.47	865.33	804.33
7/5/07 13:30	59.96	483,437.31	363.61	493,718.41	77.88	0.00	270.81	538.70	967.97	1,507.85	865.50	805.25
7/5/07 13:31	60.64	488,390.59	363.77	495,178.19	75.72	0.00	270.85	539.22	968.15	1,510.02	865.46	805.92
7/5/07 13:32	61.26	491,794.19	364.00	496,007.31	78.98	0.00	270.98	539.80	970.25	1,514.72	866.47	807.50
7/5/07 13:33	61.28	492,136.69	364.20	496,311.50	84.34	0.00	271.18	540.27	971.20	1,516.49	867.20	808.15
7/5/07 13:34	61.69	495,992.00	364.32	496,615.69	94.43	0.00	271.47	540.39	969.52	1,522.82	866.54	807.30
7/5/07 13:35	61.52	494,956.50	364.42	496,919.91	96.89	0.00	271.75	540.32	966.74	1,515.88	865.04	806.79
7/5/07 13:36	61.79	498,063.31	364.35	497,224.19	97.58	0.00	272.03	540.08	963.00	1,520.94	862.74	805.63
7/5/07 13:37	61.17	495,841.59	364.31	497,528.41	93.51	0.00	272.27	539.86	960.00	1,512.06	860.57	803.97
7/5/07 13:38	60.59	490,936.50	364.18	497,832.69	94.11	0.00	272.51	539.22	958.42	1,498.22	859.18	804.26
7/5/07 13:39	60.51	490,619.59	364.08	497,275.50	64.03	0.00	272.71	538.58	955.67	1,496.57	857.65	805.76
7/5/07 13:40	60.18	488,774.59	363.98	494,075.59	19.06	0.00	272.69	538.20	954.63	1,489.57	856.41	807.58
7/5/07 13:41	59.76	486,009.09	363.93	490,875.81	4.78	0.00	272.66	537.73	954.84	1,485.17	855.45	809.55
7/5/07 13:42	58.96	478,653.91	363.90	487,676.00	14.70	0.00	272.57	537.23	955.99	1,474.96	855.08	811.40
7/5/07 13:43	57.52	465,143.50	363.90	484,476.09	49.77	0.00	272.40	536.80	958.44	1,472.23	855.21	811.23
7/5/07 13:44	57.23	463,749.41	363.90	475,163.50	75.68	0.00	272.18	536.53	961.28	1,480.21	855.43	810.03
7/5/07 13:45	55.19	446,668.19	363.92	463,384.31	78.82	0.00	271.75	536.32	963.00	1,467.90	855.04	808.04
7/5/07 13:46	52.69	424,917.19	363.81	451,502.31	76.58	0.00	271.34	535.90	961.39	1,456.79	852.71	804.62
7/5/07 13:47	50.39	410,023.69	363.50	437,481.41	70.73	0.00	270.56	535.62	959.10	1,450.67	849.66	800.92
7/5/07 13:48	48.21	383,389.59	363.17	423,460.59	66.83	0.00	269.23	535.78	957.14	1,437.83	846.34	797.29
7/5/07 13:49	44.30	388,664.50	362.70	407,230.91	69.53	0.00	267.66	535.92	953.45	1,430.63	842.04	793.30
7/5/07 13:50	40.83	358,327.50	362.24	389,502.91	75.27	0.00	266.06	536.19	951.80	1,423.38	838.10	789.39
7/5/07 13:51	37.86	331,839.59	361.66	367,113.00	77.70	0.00	264.46	536.49	951.25	1,422.55	833.98	785.62
7/5/07 13:52	36.52	321,847.31	360.99	347,261.81	75.36	0.00	262.26	537.12	951.86	1,440.71	829.68	781.68
7/5/07 13:53	36.49	319,946.91	360.39	341,600.91	83.06	0.00	259.43	538.26	956.68	1,459.83	826.52	779.07
7/5/07 13:54	36.43	318,308.81	359.84	335,508.09	88.63	0.00	256.88	539.76	962.19	1,469.81	824.17	777.20
7/5/07 13:55	35.77	311,629.50	359.33	331,044.81	87.31	0.00	255.16	540.72	965.15	1,476.14	821.46	774.85
7/5/07 13:56	35.97	311,267.00	358.74	329,908.00	85.90	0.00	254.11	541.68	968.82	1,481.24	819.09	772.73
7/5/07 13:57	36.66	316,597.50	358.20	329,854.91	89.02	0.00	253.04	542.52	971.17	1,494.57	817.08	770.87
7/5/07 13:58	37.30	320,898.81	357.71	332,882.81	91.26	0.00	252.41	543.37	972.98	1,501.53	815.53	769.31
7/5/07 13:59	39.25	332,734.41	357.26	345,857.91	90.26	0.00	252.02	544.26	974.34	1,510.17	814.43	768.47
7/5/07 14:00	42.33	357,238.81	356.95	358,832.91	88.92	0.00	251.71	545.17	976.22	1,526.15	814.48	768.49
7/5/07 14:01	43.30	367,080.81	356.71	371,808.00	88.30	0.00	251.77	545.94	977.38	1,519.08	815.38	769.08
7/5/07 14:02	45.29	381,927.81	356.44	385,010.50	88.62	0.00	252.12	546.02	975.30	1,525.15	815.60	768.61
7/5/07 14:03	48.29	405,805.81	356.22	398,249.31	89.89	0.00	252.78	546.09	974.93	1,530.64	816.29	768.75
7/5/07 14:04	49.77	418,183.09	356.07	411,488.09	86.44	0.00	253.61	546.16	974.82	1,525.45	818.05	769.88
7/5/07 14:05	50.10	421,569.69	356.01	420,758.91	82.23	0.00	254.65	545.89	972.65	1,517.47	819.53	770.47
7/5/07 14:06	51.16	429,525.50	355.98	420,584.81	80.70	0.00	256.37	545.67	971.20	1,516.19	821.01	771.28
7/5/07 14:07	51.05	428,681.19	355.96	420,410.59	76.73	0.00	258.00	545.49	970.38	1,508.26	822.80	772.47
7/5/07 14:08	50.30	424,649.59	355.97	420,236.50	76.33	0.00	259.61	545.30	968.82	1,496.40	824.32	773.13
7/5/07 14:09	50.10	422,248.41	355.94	420,062.31	73.40	0.00	260.73	545.02	966.54	1,493.03	825.40	773.57

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 14:10	50.13	422,219.09	355.99	420,134.59	73.15	0.00	261.77	544.87	965.74	1,493.35	826.48	773.92
7/5/07 14:11	49.85	419,859.00	355.98	420,290.91	68.88	0.00	262.41	544.76	965.68	1,491.69	827.81	774.98
7/5/07 14:12	49.57	418,722.50	355.95	420,447.09	66.31	0.00	262.87	544.66	966.29	1,490.42	828.77	775.37
7/5/07 14:13	50.01	421,101.69	355.95	420,603.41	64.46	0.00	263.19	544.67	968.02	1,498.76	829.84	775.80
7/5/07 14:14	49.91	419,742.19	356.00	420,759.59	62.19	0.00	263.40	544.75	970.99	1,494.36	831.19	776.74
7/5/07 14:15	49.90	419,334.31	355.98	420,915.91	62.07	0.00	263.68	544.50	971.54	1,493.99	831.72	776.76
7/5/07 14:16	50.62	423,917.31	355.93	421,072.09	63.53	0.00	263.93	544.19	972.59	1,503.18	832.38	777.13
7/5/07 14:17	50.55	422,004.81	355.90	421,228.41	62.69	0.00	264.16	543.99	973.84	1,497.98	833.32	777.58
7/5/07 14:18	50.48	421,378.50	355.89	421,384.59	64.25	0.00	264.43	543.54	973.58	1,496.29	833.64	777.63
7/5/07 14:19	50.36	420,634.59	355.79	421,540.81	68.70	0.00	264.72	542.78	972.50	1,496.29	834.04	777.75
7/5/07 14:20	50.69	424,101.59	355.82	421,697.09	71.60	0.00	264.97	542.14	972.70	1,501.14	834.89	778.11
7/5/07 14:21	50.68	425,580.00	355.76	421,853.31	70.52	0.00	265.16	541.38	972.60	1,499.99	835.74	778.68
7/5/07 14:22	50.12	419,647.81	355.74	422,009.59	72.83	0.00	265.39	540.61	972.28	1,488.98	836.40	779.26
7/5/07 14:23	49.54	415,514.91	355.66	420,293.50	71.83	0.00	265.57	540.30	970.08	1,483.07	836.32	778.87
7/5/07 14:24	48.92	410,243.19	355.53	415,719.69	74.77	0.00	265.69	540.59	967.96	1,482.55	835.75	778.16
7/5/07 14:25	47.77	401,848.59	355.41	411,145.91	72.93	0.00	265.67	541.25	966.42	1,478.15	835.01	777.63
7/5/07 14:26	47.14	397,059.81	355.32	406,572.09	70.46	0.00	265.51	541.80	964.28	1,482.15	834.04	776.97
7/5/07 14:27	45.86	389,051.69	355.20	401,998.31	69.21	0.00	265.04	542.32	964.02	1,477.90	833.41	776.65
7/5/07 14:28	45.54	386,018.91	355.07	397,424.41	72.49	0.00	264.45	542.64	964.09	1,484.55	832.70	776.00
7/5/07 14:29	45.61	388,097.09	355.01	394,008.59	73.24	0.00	263.65	543.02	965.47	1,487.11	832.69	776.16
7/5/07 14:30	44.44	377,853.31	355.04	391,938.59	71.89	0.00	263.02	543.24	967.37	1,477.51	833.36	776.75
7/5/07 14:31	44.06	374,158.09	355.02	389,868.59	70.58	0.00	262.44	543.03	966.49	1,481.54	832.76	776.01
7/5/07 14:32	44.22	375,791.09	354.94	387,798.59	72.48	0.00	261.91	543.12	967.84	1,486.00	832.84	776.17
7/5/07 14:33	43.92	373,636.09	354.91	385,728.59	69.20	0.00	261.25	543.19	968.61	1,484.83	833.09	776.42
7/5/07 14:34	44.01	373,232.59	354.82	383,658.50	71.05	0.00	260.85	543.42	969.21	1,490.03	833.23	776.31
7/5/07 14:35	44.00	372,491.59	354.81	383,198.00	72.47	0.00	260.46	543.63	969.92	1,490.71	833.38	776.32
7/5/07 14:36	44.02	373,014.81	354.67	384,373.91	72.45	0.00	260.18	543.80	970.73	1,490.10	833.33	776.36
7/5/07 14:37	44.33	375,438.31	354.55	385,549.91	69.71	0.00	259.96	543.89	970.35	1,496.04	833.00	775.99
7/5/07 14:38	45.07	380,195.50	354.47	386,725.91	67.81	0.00	259.90	544.29	971.81	1,504.95	833.08	776.07
7/5/07 14:39	45.49	383,748.41	354.41	387,901.81	58.98	0.00	259.78	544.58	972.06	1,503.44	833.34	776.18
7/5/07 14:40	45.27	382,250.81	354.38	389,077.81	67.21	0.00	259.83	544.74	971.02	1,498.89	833.33	776.09
7/5/07 14:41	44.98	380,906.41	354.28	390,253.81	71.87	0.00	259.95	544.79	969.11	1,493.42	832.80	775.54
7/5/07 14:42	45.38	382,852.41	354.17	391,429.69	71.54	0.00	260.00	544.97	968.05	1,493.88	832.24	775.06
7/5/07 14:43	44.78	380,080.31	354.10	392,605.69	71.36	0.00	260.03	544.98	966.44	1,484.81	831.55	774.57
7/5/07 14:44	45.16	381,572.81	353.98	393,781.69	72.93	0.00	260.09	545.02	965.28	1,493.49	830.72	774.03
7/5/07 14:45	45.97	389,923.09	353.94	394,957.59	72.27	0.00	260.02	545.24	966.76	1,501.36	830.62	774.29
7/5/07 14:46	46.07	390,683.09	353.96	396,553.00	74.13	0.00	259.94	545.46	968.81	1,498.03	831.07	774.67
7/5/07 14:47	46.14	390,781.81	353.93	398,432.91	73.60	0.00	259.95	545.43	969.56	1,497.17	831.13	774.59
7/5/07 14:48	46.74	395,471.00	353.82	400,312.69	74.41	0.00	260.11	545.23	970.52	1,498.85	831.04	774.64
7/5/07 14:49	46.69	394,448.31	353.66	402,192.59	68.72	0.00	260.20	544.95	971.12	1,496.45	830.53	774.15
7/5/07 14:50	47.05	397,650.09	353.47	404,072.50	68.30	0.00	260.35	544.63	971.24	1,497.14	829.92	773.65
7/5/07 14:51	47.49	400,861.41	353.33	405,952.31	64.90	0.00	260.64	544.49	971.56	1,498.68	829.58	773.47
7/5/07 14:52	47.47	400,757.81	353.22	407,832.19	62.21	0.00	260.87	544.33	971.88	1,492.78	829.47	773.50
7/5/07 14:53	48.64	408,692.09	353.14	409,712.09	62.55	0.00	261.07	544.09	972.07	1,503.83	829.56	773.40
7/5/07 14:54	48.82	410,120.31	353.10	411,591.91	63.07	0.00	261.36	543.97	973.75	1,496.18	830.44	774.02
7/5/07 14:55	49.59	416,602.81	353.08	413,471.81	61.34	0.00	261.73	543.59	973.77	1,505.76	830.98	774.43
7/5/07 14:56	49.62	416,323.00	353.12	415,351.69	60.54	0.00	262.10	543.41	974.45	1,498.21	831.91	775.28
7/5/07 14:57	49.87	417,743.81	353.18	417,231.50	63.39	0.00	262.60	543.17	973.94	1,499.85	832.94	776.41
7/5/07 14:58	49.85	417,792.41	353.25	419,111.41	66.17	0.00	263.01	543.04	973.54	1,499.29	833.80	777.24
7/5/07 14:59	49.97	419,585.59	353.34	420,991.31	67.48	0.00	263.31	542.91	974.10	1,496.89	834.66	777.61

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FLOW (TPH)	PROPANE FUEL FLOW (SCFH)	FWP DISCH FLOW (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 15:00	50.49	424,312.41	353.36	422,871.19	66.37	0.00	263.56	542.63	973.81	1,503.13	835.38	777.80
7/5/07 15:01	50.37	423,529.00	353.39	424,751.00	65.78	0.00	263.88	542.31	973.23	1,496.01	836.02	778.16
7/5/07 15:02	49.97	418,450.31	353.38	426,112.31	66.38	0.00	264.18	541.93	972.49	1,489.40	836.20	778.37
7/5/07 15:03	50.06	420,537.50	353.44	427,296.81	67.28	0.00	264.47	541.86	971.68	1,493.77	835.89	779.15
7/5/07 15:04	49.92	418,950.81	353.60	428,481.31	67.54	0.00	264.60	542.44	972.84	1,491.51	833.90	778.34
7/5/07 15:05	50.33	422,707.09	353.81	429,665.81	63.13	0.00	264.69	542.86	973.60	1,499.50	834.03	779.00
7/5/07 15:06	50.20	421,122.59	354.03	430,850.31	61.10	0.00	264.79	542.84	974.76	1,495.58	834.75	779.77
7/5/07 15:07	50.17	421,128.50	354.19	432,034.91	60.23	0.00	264.90	542.74	975.77	1,494.93	836.66	781.74
7/5/07 15:08	50.21	421,067.31	354.34	433,219.41	61.78	0.00	264.92	542.49	975.12	1,497.04	838.09	782.77
7/5/07 15:09	50.33	421,434.91	354.42	434,403.91	62.36	0.00	265.02	542.43	975.59	1,498.08	839.38	783.12
7/5/07 15:10	50.20	421,172.31	354.39	435,588.41	61.81	0.00	265.10	542.17	974.00	1,494.80	840.12	783.18
7/5/07 15:11	50.60	424,674.19	354.27	436,773.00	64.41	0.00	265.16	542.25	973.16	1,500.68	840.73	783.29
7/5/07 15:12	50.18	421,625.50	354.07	437,957.50	65.84	0.00	265.19	542.40	971.94	1,494.33	841.08	783.07
7/5/07 15:13	50.35	422,120.81	353.80	439,142.00	66.93	0.00	265.28	542.39	971.01	1,498.45	841.43	783.19
7/5/07 15:14	50.63	424,257.69	353.54	440,411.31	72.08	0.00	265.31	542.38	971.05	1,500.10	842.05	783.69
7/5/07 15:15	50.98	428,674.41	353.29	441,918.69	72.68	0.00	265.32	542.30	971.32	1,499.90	843.40	784.88
7/5/07 15:16	50.70	427,161.31	353.06	443,426.00	74.55	0.00	265.39	542.14	970.84	1,496.04	844.87	785.87
7/5/07 15:17	51.04	428,441.81	352.79	444,933.41	74.03	0.00	265.56	542.07	970.40	1,500.82	846.09	786.44
7/5/07 15:18	51.51	432,477.59	352.48	446,440.81	74.71	0.00	265.67	542.31	971.13	1,500.83	847.63	787.42
7/5/07 15:19	51.40	431,222.59	352.10	446,461.09	73.32	0.00	265.75	542.47	970.06	1,497.53	848.78	787.88
7/5/07 15:20	52.09	435,949.81	351.80	446,338.69	72.60	0.00	265.84	542.56	969.65	1,502.98	849.56	788.08
7/5/07 15:21	53.04	443,772.00	351.64	446,216.41	76.13	0.00	265.96	542.70	970.64	1,505.86	850.68	788.77
7/5/07 15:22	52.88	443,454.41	351.49	446,094.09	77.35	0.00	266.12	542.79	971.10	1,502.20	851.72	789.52
7/5/07 15:23	52.19	428,974.41	351.46	445,652.69	80.27	0.00	266.41	542.56	970.54	1,500.56	852.25	789.91
7/5/07 15:24	52.83	431,162.59	351.39	444,757.00	80.16	0.00	266.70	542.47	970.06	1,504.98	852.44	789.77
7/5/07 15:25	54.04	438,725.81	351.38	443,861.31	76.61	0.00	266.72	542.68	969.91	1,510.89	852.69	789.80
7/5/07 15:26	54.02	437,782.50	351.40	442,965.50	77.46	0.00	266.62	542.80	968.70	1,507.54	852.94	789.98
7/5/07 15:27	54.81	442,240.31	351.52	443,797.09	77.55	0.00	266.60	542.95	968.91	1,506.81	853.26	790.23
7/5/07 15:28	55.86	450,034.41	351.62	444,984.50	73.17	0.00	266.58	543.01	968.77	1,512.51	853.66	790.62
7/5/07 15:29	55.07	443,850.09	351.71	446,171.91	71.77	0.00	266.70	543.03	969.07	1,498.53	854.07	790.94
7/5/07 15:30	55.16	442,697.59	351.84	445,089.09	70.78	0.00	266.90	542.77	967.46	1,504.48	853.77	790.63
7/5/07 15:31	55.61	447,091.91	351.93	442,356.69	75.65	0.00	267.09	542.84	968.43	1,504.79	854.07	791.03
7/5/07 15:32	54.93	440,922.59	352.00	439,624.31	74.49	0.00	267.23	542.73	967.88	1,493.89	853.85	790.80
7/5/07 15:33	54.11	434,137.69	352.11	436,939.31	75.54	0.00	267.35	542.44	965.17	1,489.65	853.03	789.89
7/5/07 15:34	53.19	427,712.41	352.18	434,350.69	75.59	0.00	267.42	542.39	963.84	1,483.11	852.29	789.38
7/5/07 15:35	52.88	424,674.09	352.24	431,762.09	74.70	0.00	267.28	542.40	962.58	1,486.19	851.44	788.61
7/5/07 15:36	52.00	420,858.19	352.25	429,173.50	72.96	0.00	267.15	542.57	962.50	1,481.61	850.78	787.98
7/5/07 15:37	51.38	415,542.00	352.34	426,584.91	70.13	0.00	266.87	542.77	962.96	1,482.90	850.22	787.80
7/5/07 15:38	51.26	415,421.09	352.36	423,996.31	72.40	0.00	266.57	542.98	963.80	1,487.58	849.60	787.37
7/5/07 15:39	51.56	418,083.19	352.41	421,407.69	70.39	0.00	266.14	543.29	965.77	1,493.11	849.25	787.29
7/5/07 15:40	52.15	421,734.19	352.45	422,286.00	68.93	0.00	265.81	543.66	968.35	1,500.77	849.41	787.56
7/5/07 15:41	51.72	418,004.69	352.49	424,244.19	67.56	0.00	265.53	543.76	969.84	1,493.56	849.35	787.37
7/5/07 15:42	52.61	424,224.09	352.54	426,202.41	65.04	0.00	265.39	543.81	970.74	1,503.57	849.03	787.30
7/5/07 15:43	53.46	429,967.00	352.56	428,160.50	65.86	0.00	265.25	544.00	972.35	1,507.76	849.18	787.63
7/5/07 15:44	53.93	432,104.81	352.65	430,118.69	67.07	0.00	265.27	544.11	973.30	1,505.55	849.50	788.11
7/5/07 15:45	53.43	428,603.91	352.67	431,860.00	65.98	0.00	265.32	543.78	971.71	1,500.06	849.23	787.93
7/5/07 15:46	53.73	432,614.09	352.72	430,347.41	64.89	0.00	265.52	543.66	971.03	1,503.72	849.17	788.01
7/5/07 15:47	52.76	426,532.81	352.72	428,834.81	62.87	0.00	265.66	543.34	969.06	1,491.29	848.91	787.58
7/5/07 15:48	52.91	427,867.81	352.70	429,525.69	63.44	0.00	265.82	542.99	966.81	1,494.93	847.99	786.65
7/5/07 15:49	52.80	426,731.59	352.64	430,618.31	64.41	0.00	265.87	542.95	967.02	1,493.20	847.77	786.73

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 15:50	52.08	420,730.31	352.65	431,710.81	64.77	0.00	265.84	542.80	966.74	1,486.49	847.53	786.36
7/5/07 15:51	52.33	423,572.31	352.59	432,803.41	64.85	0.00	265.80	542.66	966.43	1,492.41	846.96	785.93
7/5/07 15:52	52.76	425,642.09	352.60	433,895.91	66.55	0.00	265.64	542.89	968.31	1,498.27	847.06	787.00
7/5/07 15:53	52.68	424,052.50	352.68	434,777.59	69.33	0.00	265.42	543.35	970.54	1,495.28	847.62	787.67
7/5/07 15:54	52.13	420,514.19	352.76	433,995.69	70.82	0.00	265.38	543.58	970.28	1,491.59	847.40	787.59
7/5/07 15:55	52.36	423,393.50	352.77	433,213.81	69.74	0.00	265.33	543.88	970.12	1,498.36	847.07	787.58
7/5/07 15:56	52.94	426,009.19	352.86	432,431.81	69.62	0.00	265.29	544.19	970.87	1,502.49	847.13	787.71
7/5/07 15:57	52.93	426,642.00	352.93	436,480.31	70.54	0.00	265.20	544.32	969.98	1,499.56	847.00	787.62
7/5/07 15:58	53.58	431,780.09	353.00	442,033.41	68.01	0.00	265.25	544.24	968.87	1,505.47	846.75	787.38
7/5/07 15:59	54.64	440,174.41	353.04	447,586.41	66.57	0.00	265.32	544.32	969.47	1,510.02	847.07	787.85
7/5/07 16:00	53.89	435,406.00	353.16	448,761.00	64.19	0.00	265.41	544.21	969.02	1,496.75	847.63	788.24
7/5/07 16:01	54.86	442,766.41	353.29	446,965.50	63.94	0.00	265.71	543.96	968.39	1,507.45	848.06	788.90
7/5/07 16:02	54.84	440,703.41	353.48	448,035.91	66.90	0.00	265.85	543.92	969.25	1,504.01	848.85	789.56
7/5/07 16:03	54.56	437,565.00	353.59	450,262.81	65.95	0.00	266.21	543.47	968.61	1,498.25	848.83	789.44
7/5/07 16:04	54.83	441,357.50	353.64	452,489.59	67.25	0.00	266.41	542.83	967.24	1,501.60	848.15	788.67
7/5/07 16:05	55.80	448,634.09	353.72	454,716.41	67.31	0.00	266.47	542.44	967.79	1,508.51	848.24	789.69
7/5/07 16:06	55.63	446,907.09	353.78	456,114.50	69.68	0.00	266.61	542.06	969.33	1,501.64	848.97	790.25
7/5/07 16:07	55.30	445,056.81	353.89	457,121.09	67.21	0.00	266.76	541.30	968.93	1,497.89	848.98	790.07
7/5/07 16:08	55.29	445,060.19	353.96	458,127.69	66.61	0.00	266.89	540.55	968.35	1,500.78	848.72	789.81
7/5/07 16:09	55.18	444,474.19	354.04	459,134.31	67.29	0.00	267.09	540.08	969.51	1,503.14	848.98	790.27
7/5/07 16:10	55.60	447,647.50	354.12	460,140.91	68.45	0.00	267.17	539.60	968.73	1,506.77	849.01	790.32
7/5/07 16:11	55.63	447,736.41	354.18	461,147.59	66.83	0.00	267.19	539.30	968.39	1,504.63	848.98	790.47
7/5/07 16:12	55.89	450,089.59	354.28	461,914.19	67.57	0.00	267.26	539.15	968.80	1,500.62	849.43	791.27
7/5/07 16:13	55.47	447,240.31	354.38	461,443.81	66.44	0.00	267.33	538.58	966.65	1,498.14	849.07	790.67
7/5/07 16:14	56.09	451,736.00	354.46	460,973.41	65.77	0.00	267.44	538.44	965.96	1,505.77	849.15	791.24
7/5/07 16:15	55.31	445,062.19	354.60	456,288.50	68.94	0.00	267.46	538.38	966.84	1,491.00	849.91	791.62
7/5/07 16:16	54.48	438,262.59	354.69	453,645.00	69.36	0.00	267.61	537.89	964.79	1,486.93	849.53	790.93
7/5/07 16:17	54.97	441,290.19	354.76	453,055.81	69.80	0.00	267.66	537.67	964.54	1,494.73	849.15	790.29
7/5/07 16:18	55.03	443,021.69	354.81	452,466.59	69.71	0.00	267.52	537.72	967.13	1,497.08	849.57	791.43
7/5/07 16:19	54.42	437,626.50	354.90	451,877.41	71.42	0.00	267.39	537.68	969.05	1,490.33	850.14	792.05
7/5/07 16:20	54.28	436,339.69	355.00	451,288.09	73.61	0.00	267.36	537.53	969.32	1,492.95	850.10	792.16
7/5/07 16:21	54.72	440,026.59	355.14	450,698.91	72.28	0.00	267.26	537.69	971.19	1,499.57	850.68	793.03
7/5/07 16:22	54.41	437,032.59	355.29	451,523.50	71.30	0.00	267.14	537.85	972.03	1,495.76	851.46	793.47
7/5/07 16:23	54.83	440,296.69	355.48	452,403.09	71.63	0.00	266.97	538.07	971.96	1,501.34	851.89	793.46
7/5/07 16:24	55.29	443,021.09	355.65	453,282.81	72.47	0.00	266.91	538.32	972.13	1,504.71	852.73	793.80
7/5/07 16:25	55.14	442,210.09	355.81	454,162.41	68.57	0.00	266.86	538.58	971.66	1,498.26	853.55	794.09
7/5/07 16:26	55.07	442,643.31	355.92	455,042.09	66.07	0.00	266.93	538.53	969.89	1,501.58	853.75	793.71
7/5/07 16:27	55.93	449,211.19	355.98	455,921.69	65.13	0.00	267.01	538.94	971.09	1,508.12	854.48	794.65
7/5/07 16:28	55.79	447,709.81	356.08	455,099.41	65.95	0.00	267.06	539.17	971.78	1,501.45	854.99	794.64
7/5/07 16:29	55.54	446,172.00	356.09	453,590.31	67.34	0.00	267.18	538.88	970.41	1,500.79	854.08	794.34
7/5/07 16:30	55.45	445,458.50	355.99	452,081.19	69.13	0.00	267.34	538.93	970.69	1,496.61	853.60	793.98
7/5/07 16:31	55.95	448,547.00	355.93	450,572.19	69.42	0.00	267.45	538.88	970.20	1,503.18	853.01	793.64
7/5/07 16:32	55.05	442,193.41	355.93	449,063.09	73.08	0.00	267.49	538.98	969.48	1,490.45	852.92	793.59
7/5/07 16:33	54.82	440,959.91	355.96	448,141.91	76.61	0.00	267.56	539.02	967.26	1,492.86	852.70	793.35
7/5/07 16:34	55.14	444,756.41	356.03	447,592.81	79.57	0.00	267.55	539.34	967.47	1,499.63	853.16	793.81
7/5/07 16:35	54.89	442,158.09	356.10	447,043.50	81.68	0.00	267.41	539.66	967.63	1,496.81	853.68	793.91
7/5/07 16:36	54.86	441,349.19	356.22	446,494.31	83.99	0.00	267.35	539.80	967.75	1,497.63	853.88	794.20
7/5/07 16:37	54.60	438,031.31	356.26	445,945.19	82.34	0.00	267.28	539.92	968.06	1,493.58	854.05	794.18
7/5/07 16:38	54.56	439,319.09	356.32	445,396.00	81.55	0.00	267.25	540.05	967.93	1,495.46	853.94	794.23
7/5/07 16:39	54.97	443,917.81	356.38	444,846.81	81.48	0.00	267.18	540.19	968.13	1,502.71	853.80	793.84

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 16:40	55.11	441,855.00	356.43	444,297.59	80.03	0.00	267.09	540.52	969.06	1,501.35	854.00	794.31
7/5/07 16:41	55.06	441,114.91	356.50	443,748.41	75.35	0.00	267.10	540.74	969.17	1,499.65	854.32	794.58
7/5/07 16:42	54.72	438,641.41	356.58	443,199.19	76.27	0.00	267.14	540.75	968.24	1,494.28	854.20	794.36
7/5/07 16:43	54.70	439,756.50	356.59	442,650.00	77.27	0.00	267.22	540.77	966.88	1,496.34	853.90	794.01
7/5/07 16:44	54.89	440,463.59	356.68	442,100.81	77.54	0.00	267.20	540.99	967.33	1,496.85	854.02	794.60
7/5/07 16:45	54.76	439,488.81	356.80	441,551.59	73.88	0.00	267.17	541.14	966.71	1,495.70	853.76	794.81
7/5/07 16:46	54.34	437,483.41	356.94	441,002.41	73.28	0.00	267.19	541.19	966.89	1,494.07	853.75	794.89
7/5/07 16:47	53.63	430,295.91	357.09	440,453.19	67.82	0.00	267.17	541.29	967.22	1,487.89	853.64	795.41
7/5/07 16:48	53.40	428,363.19	357.21	441,669.41	67.14	0.00	267.07	541.15	966.17	1,492.83	852.95	794.41
7/5/07 16:49	54.14	435,169.69	357.32	443,338.41	65.48	0.00	266.85	541.57	968.32	1,500.51	853.10	794.75
7/5/07 16:50	54.44	437,258.69	357.46	442,861.00	63.17	0.00	266.54	542.04	970.14	1,501.46	853.84	795.34
7/5/07 16:51	54.41	436,838.19	357.58	441,832.91	62.48	0.00	266.42	541.98	970.60	1,501.16	854.07	795.41
7/5/07 16:52	54.28	435,995.59	357.66	440,804.81	63.46	0.00	266.36	542.06	970.63	1,498.96	854.15	795.02
7/5/07 16:53	54.43	438,465.91	357.76	439,776.81	64.98	0.00	266.30	542.10	970.55	1,499.69	853.94	794.75
7/5/07 16:54	53.94	433,974.69	357.73	438,748.69	65.16	0.00	266.30	541.99	969.60	1,494.65	853.35	794.04
7/5/07 16:55	53.78	432,818.41	357.69	437,720.59	64.59	0.00	266.31	542.06	969.35	1,494.21	852.51	793.37
7/5/07 16:56	53.86	433,286.41	357.63	436,692.50	63.49	0.00	266.30	542.27	969.66	1,493.18	852.31	793.93
7/5/07 16:57	53.34	429,516.00	357.53	435,665.50	63.58	0.00	266.22	542.18	968.61	1,491.41	851.39	793.03
7/5/07 16:58	53.56	431,406.69	357.40	434,721.09	65.19	0.00	266.16	542.21	969.10	1,497.12	850.50	792.16
7/5/07 16:59	53.83	432,868.50	357.26	433,776.81	64.54	0.00	266.01	542.38	970.17	1,499.67	850.03	791.63
7/5/07 17:00	53.39	430,414.91	357.21	432,832.41	62.09	0.00	265.90	542.32	969.86	1,494.85	849.50	790.93
7/5/07 17:01	52.87	425,561.50	357.18	431,888.00	65.24	0.00	265.81	542.46	969.58	1,489.12	849.17	790.64
7/5/07 17:02	52.53	423,801.81	357.18	430,943.69	71.44	0.00	265.75	542.46	968.52	1,486.90	848.74	790.11
7/5/07 17:03	51.57	416,574.91	357.17	430,301.91	73.14	0.00	265.70	542.44	967.04	1,484.71	848.09	789.37
7/5/07 17:04	51.65	419,427.91	357.12	429,989.09	75.82	0.00	265.50	542.64	966.94	1,485.33	847.66	788.97
7/5/07 17:05	52.03	420,503.09	357.08	429,676.31	73.02	0.00	265.24	542.87	967.13	1,496.57	847.50	788.68
7/5/07 17:06	51.58	415,203.59	357.08	429,363.41	71.86	0.00	264.93	543.09	968.27	1,488.66	847.37	788.15
7/5/07 17:07	51.54	416,410.91	356.99	429,050.59	73.81	0.00	264.76	543.10	968.57	1,491.06	846.82	787.42
7/5/07 17:08	51.39	417,882.69	356.94	428,737.81	73.49	0.00	264.66	543.18	968.95	1,494.95	846.35	786.97
7/5/07 17:09	51.75	419,383.81	356.83	428,425.00	73.48	0.00	264.50	543.28	969.66	1,497.75	845.90	786.59
7/5/07 17:10	51.40	413,714.81	356.69	427,183.50	74.12	0.00	264.43	543.34	970.80	1,488.17	845.54	786.11
7/5/07 17:11	50.81	413,140.81	356.53	423,898.81	71.20	0.00	264.35	543.07	969.31	1,490.65	844.29	784.87
7/5/07 17:12	50.76	414,040.50	356.32	420,614.19	74.03	0.00	264.34	543.07	969.31	1,489.74	843.57	784.27
7/5/07 17:13	49.16	400,999.69	356.17	417,329.59	73.52	0.00	264.27	543.08	968.20	1,475.46	842.80	783.64
7/5/07 17:14	48.89	402,080.81	356.00	414,045.00	76.76	0.00	264.15	542.85	965.98	1,481.44	841.36	782.49
7/5/07 17:15	47.75	398,110.00	355.85	410,760.41	76.90	0.00	263.95	542.93	965.32	1,475.77	840.34	781.77
7/5/07 17:16	46.51	389,616.31	355.70	407,475.81	78.70	0.00	263.72	542.85	964.37	1,471.87	839.13	780.85
7/5/07 17:17	46.41	392,183.00	355.54	404,191.09	81.50	0.00	263.37	542.84	964.01	1,479.04	837.93	780.05
7/5/07 17:18	45.87	389,605.81	355.42	400,906.50	82.00	0.00	262.96	543.04	965.68	1,480.32	837.28	779.50
7/5/07 17:19	44.73	379,871.91	355.28	392,012.00	78.74	0.00	262.51	543.14	966.88	1,477.35	836.58	778.84
7/5/07 17:20	43.58	370,247.91	355.11	380,853.91	75.84	0.00	262.23	543.03	966.74	1,472.61	835.21	777.47
7/5/07 17:21	42.06	358,436.59	354.83	369,695.81	73.85	0.00	261.70	542.91	966.08	1,467.26	833.28	775.81
7/5/07 17:22	39.72	339,405.31	354.41	361,663.59	69.74	0.00	261.05	542.62	963.99	1,457.74	830.38	773.31
7/5/07 17:23	39.27	334,787.81	353.92	351,601.81	70.80	0.00	260.17	542.47	962.31	1,469.73	827.05	770.70
7/5/07 17:24	40.14	342,524.81	353.46	346,316.19	74.00	0.00	258.75	542.95	964.00	1,487.86	824.82	769.32
7/5/07 17:25	40.11	342,228.59	353.04	352,745.50	72.15	0.00	257.40	543.42	966.15	1,485.05	823.11	768.20
7/5/07 17:26	40.72	345,950.69	352.61	358,422.19	71.22	0.00	256.32	543.40	968.01	1,496.01	821.21	767.01
7/5/07 17:27	41.21	349,249.59	352.26	363,885.50	64.38	0.00	255.74	543.45	970.89	1,499.59	820.06	766.81
7/5/07 17:28	42.00	356,474.81	351.96	369,348.81	61.49	0.00	255.39	543.50	973.10	1,504.39	819.46	766.79
7/5/07 17:29	43.27	366,214.31	351.82	373,080.41	64.01	0.00	255.25	543.55	974.42	1,509.70	819.42	767.16

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	Biomass FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 17:30	43.19	365,541.41	351.62	373,046.69	60.12	0.00	255.25	543.55	974.60	1,502.72	819.67	767.64
7/5/07 17:31	43.65	368,796.81	351.48	372,418.69	56.15	0.00	255.47	543.48	973.52	1,502.60	819.61	767.79
7/5/07 17:32	43.60	368,484.19	351.35	371,790.69	56.17	0.00	255.68	543.30	971.67	1,499.10	819.63	767.92
7/5/07 17:33	43.83	370,918.69	351.22	371,162.59	53.84	0.00	256.02	543.16	970.05	1,497.55	819.62	768.02
7/5/07 17:34	43.11	365,972.31	351.05	370,534.59	54.59	0.00	256.25	542.97	968.06	1,484.96	819.55	768.12
7/5/07 17:35	43.38	369,695.41	350.95	369,836.09	55.56	0.00	256.54	542.74	965.77	1,494.05	819.43	768.08
7/5/07 17:36	43.33	369,198.19	350.85	368,662.41	55.97	0.00	256.71	542.91	966.62	1,490.31	820.12	768.92
7/5/07 17:37	43.05	366,432.81	350.77	367,488.69	58.72	0.00	256.83	542.75	966.61	1,484.86	820.37	768.98
7/5/07 17:38	42.70	364,400.00	350.61	366,841.31	57.48	0.00	256.92	542.36	965.85	1,486.93	820.06	768.71
7/5/07 17:39	42.80	363,643.09	350.46	371,159.59	57.19	0.00	256.89	542.36	967.33	1,488.16	820.21	769.14
7/5/07 17:40	43.26	366,916.09	350.35	375,477.91	56.84	0.00	256.84	542.55	969.41	1,495.99	820.63	769.60
7/5/07 17:41	43.56	368,595.81	350.19	379,796.19	60.44	0.00	256.81	542.66	971.53	1,497.04	821.36	770.09
7/5/07 17:42	44.03	372,401.59	350.10	384,114.50	61.74	0.00	256.77	542.57	972.39	1,502.34	821.57	770.33
7/5/07 17:43	46.31	389,840.69	349.98	388,526.19	58.28	0.00	256.90	542.66	974.23	1,511.84	822.25	771.10
7/5/07 17:44	46.69	392,806.09	349.98	393,091.09	61.71	0.00	257.01	542.64	975.45	1,507.05	823.58	772.34
7/5/07 17:45	47.16	397,109.31	350.06	397,655.91	61.07	0.00	257.43	542.44	974.39	1,504.66	824.87	773.44
7/5/07 17:46	48.42	406,211.00	350.20	402,220.69	63.04	0.00	257.93	542.33	974.02	1,506.70	826.80	774.84
7/5/07 17:47	48.17	405,410.41	350.41	406,785.50	67.90	0.00	258.58	542.19	972.36	1,500.08	828.62	775.78
7/5/07 17:48	48.33	406,756.41	350.63	409,855.19	70.16	0.00	259.35	541.94	970.42	1,500.42	830.13	776.84
7/5/07 17:49	48.33	408,069.81	350.93	410,642.69	69.93	0.00	260.02	542.04	969.52	1,497.65	832.17	779.14
7/5/07 17:50	47.92	405,468.41	351.25	411,430.31	72.77	0.00	260.61	542.33	968.70	1,490.12	834.40	780.89
7/5/07 17:51	47.37	401,376.91	351.63	412,217.81	79.97	0.00	261.03	542.48	967.21	1,486.44	835.91	782.13
7/5/07 17:52	47.72	402,770.50	351.99	413,005.41	82.64	0.00	261.42	542.86	967.05	1,493.35	837.57	783.04
7/5/07 17:53	47.89	403,984.81	352.34	413,792.91	83.42	0.00	261.57	543.39	968.41	1,495.58	839.50	784.46
7/5/07 17:54	47.86	403,134.41	352.69	414,580.50	81.33	0.00	261.69	543.86	969.30	1,494.98	840.89	785.11
7/5/07 17:55	49.85	418,197.69	352.98	415,368.00	77.80	0.00	261.80	544.43	971.27	1,511.56	842.56	786.56
7/5/07 17:56	49.45	415,599.81	353.30	416,623.69	78.21	0.00	261.87	545.03	973.60	1,501.05	844.66	788.43
7/5/07 17:57	49.08	413,283.91	353.59	417,881.41	80.69	0.00	262.15	545.10	973.70	1,496.79	845.93	789.08
7/5/07 17:58	49.47	413,847.31	353.85	419,139.00	81.33	0.00	262.42	545.33	974.71	1,500.03	847.06	790.17
7/5/07 17:59	48.97	410,324.50	354.12	420,396.69	78.32	0.00	262.68	545.42	973.80	1,492.15	847.69	790.13
7/5/07 18:00	49.28	412,580.91	354.35	421,654.31	75.90	0.00	262.98	545.57	973.40	1,496.44	848.61	791.87
7/5/07 18:01	50.69	422,958.69	354.64	424,301.50	74.22	0.00	263.17	546.13	974.64	1,506.93	850.52	794.07
7/5/07 18:02	52.13	433,934.00	354.98	429,577.00	70.53	0.00	263.32	546.66	976.13	1,513.00	852.59	796.02
7/5/07 18:03	51.83	431,923.31	355.33	434,852.59	68.89	0.00	263.63	546.79	975.68	1,502.31	854.12	796.71
7/5/07 18:04	52.46	437,734.59	355.63	436,559.59	69.43	0.00	264.13	546.56	973.94	1,506.68	854.93	796.96
7/5/07 18:05	52.05	431,230.00	355.92	436,309.59	70.48	0.00	264.61	546.53	972.33	1,501.30	855.68	797.44
7/5/07 18:06	52.18	425,822.00	356.20	434,514.19	70.94	0.00	265.17	546.53	970.75	1,504.27	856.00	797.18
7/5/07 18:07	53.05	430,562.59	356.48	432,590.31	70.62	0.00	265.55	547.09	970.50	1,507.95	856.95	798.06
7/5/07 18:08	52.56	424,899.69	356.84	430,505.00	68.45	0.00	265.67	547.58	969.76	1,498.97	857.82	798.46
7/5/07 18:09	52.67	426,800.00	357.21	428,419.81	73.89	0.00	265.70	547.84	968.25	1,501.25	858.56	799.14
7/5/07 18:10	52.91	428,922.00	357.62	426,334.59	76.42	0.00	265.64	548.25	968.39	1,502.32	859.67	799.70
7/5/07 18:11	52.32	423,027.09	358.01	424,249.31	77.47	0.00	265.49	548.72	969.12	1,494.51	860.71	800.10
7/5/07 18:12	52.33	423,060.00	358.33	422,164.09	82.08	0.00	265.45	549.01	969.34	1,494.09	861.24	799.88
7/5/07 18:13	52.06	421,454.31	358.65	420,078.91	88.10	0.00	265.38	549.29	969.35	1,491.71	861.12	799.24
7/5/07 18:14	51.93	420,452.59	358.88	417,993.69	89.13	0.00	265.29	549.61	969.29	1,491.70	861.00	798.92
7/5/07 18:15	51.41	417,069.41	359.13	415,908.41	92.18	0.00	265.24	549.91	969.27	1,489.55	860.84	798.66
7/5/07 18:16	50.48	410,169.81	359.27	413,823.19	92.93	0.00	265.16	550.10	968.78	1,483.44	860.25	798.08
7/5/07 18:17	49.81	406,652.00	359.41	411,738.00	90.93	0.00	265.07	550.40	968.28	1,480.40	859.33	797.25
7/5/07 18:18	49.62	406,290.41	359.54	409,652.81	91.28	0.00	264.91	551.04	968.49	1,483.22	856.73	796.11
7/5/07 18:19	48.79	401,692.09	359.73	408,515.00	87.56	0.00	264.66	552.10	969.63	1,479.90	854.86	794.67

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 18:20	47.85	395,302.09	359.99	408,726.81	86.02	0.00	264.44	552.90	969.75	1,476.94	854.05	794.14
7/5/07 18:21	48.20	399,950.91	360.22	408,938.50	86.76	0.00	264.15	553.30	969.66	1,487.40	853.58	793.70
7/5/07 18:22	47.72	396,214.59	360.40	409,150.19	92.08	0.00	263.83	553.90	971.79	1,483.97	854.01	794.06
7/5/07 18:23	46.75	388,620.50	360.51	409,361.91	92.64	0.00	263.52	554.09	971.64	1,479.27	853.91	793.69
7/5/07 18:24	47.11	393,442.59	360.49	409,573.59	90.21	0.00	263.30	554.31	970.91	1,489.00	853.46	792.95
7/5/07 18:25	46.89	393,377.31	360.47	409,785.31	90.55	0.00	262.98	554.90	971.58	1,489.69	853.67	792.91
7/5/07 18:26	47.06	394,597.69	360.38	409,997.09	84.94	0.00	262.73	555.55	972.01	1,492.31	853.69	792.48
7/5/07 18:27	47.84	401,067.41	360.21	410,208.81	84.68	0.00	262.54	556.18	972.55	1,503.69	854.10	792.62
7/5/07 18:28	47.94	400,815.19	359.97	415,686.69	80.65	0.00	262.37	556.66	973.97	1,502.89	855.00	793.21
7/5/07 18:29	49.23	407,478.09	359.69	422,004.09	77.10	0.00	262.26	556.89	974.87	1,509.11	855.76	793.74
7/5/07 18:30	50.78	416,118.59	359.40	428,321.59	75.74	0.00	262.25	557.02	975.79	1,516.14	857.00	794.94
7/5/07 18:31	51.44	418,984.00	359.14	434,639.00	73.85	0.00	262.36	557.07	976.15	1,514.31	858.28	795.80
7/5/07 18:32	52.14	422,538.81	358.80	440,956.41	72.41	0.00	262.58	556.90	975.21	1,513.05	858.88	795.96
7/5/07 18:33	54.31	436,887.59	358.46	447,273.91	69.89	0.00	262.93	556.90	974.93	1,521.96	859.97	797.01
7/5/07 18:34	53.77	432,984.91	358.10	446,529.31	71.71	0.00	263.29	556.91	973.43	1,510.00	860.93	797.71
7/5/07 18:35	53.97	434,995.00	357.83	444,329.81	69.72	0.00	263.85	556.78	971.07	1,505.95	861.16	797.60
7/5/07 18:36	54.34	436,812.59	357.66	442,130.19	66.89	0.00	264.26	556.77	969.23	1,507.17	861.50	797.90
7/5/07 18:37	54.24	436,280.00	357.51	439,930.69	63.80	0.00	264.57	556.71	967.70	1,501.71	861.51	797.59
7/5/07 18:38	53.92	434,048.50	357.45	437,731.09	64.71	0.00	264.90	556.49	966.53	1,496.70	861.67	797.89
7/5/07 18:39	53.66	432,816.81	357.39	435,531.50	65.61	0.00	265.10	556.13	965.28	1,493.55	861.78	798.19
7/5/07 18:40	53.52	431,568.50	357.40	433,332.00	63.63	0.00	265.24	555.69	964.78	1,494.92	861.73	798.24
7/5/07 18:41	53.20	428,650.59	357.41	431,132.41	68.26	0.00	265.27	555.47	965.96	1,490.46	862.04	798.70
7/5/07 18:42	52.60	424,676.81	357.44	428,932.91	67.95	0.00	265.29	555.17	966.01	1,488.52	862.05	798.88
7/5/07 18:43	52.62	424,347.19	357.51	426,733.31	68.23	0.00	265.27	555.07	967.41	1,490.64	862.21	799.24
7/5/07 18:44	51.50	415,887.09	357.57	425,191.69	70.04	0.00	265.13	554.86	968.06	1,485.14	862.25	799.65
7/5/07 18:45	51.33	413,306.50	357.62	426,088.00	70.02	0.00	265.09	554.79	969.55	1,484.86	862.47	800.45
7/5/07 18:46	51.29	413,978.69	357.65	426,984.31	69.72	0.00	264.95	554.56	970.04	1,489.18	861.76	800.14
7/5/07 18:47	51.43	416,399.50	357.61	427,880.59	72.20	0.00	264.81	554.33	970.88	1,491.77	860.95	799.71
7/5/07 18:48	51.43	416,072.31	357.59	428,776.91	74.99	0.00	264.67	554.10	971.55	1,492.68	860.20	799.37
7/5/07 18:49	52.00	420,258.09	357.58	429,673.31	76.10	0.00	264.62	554.04	972.63	1,501.56	859.85	799.32
7/5/07 18:50	51.83	417,824.00	357.62	430,569.59	74.38	0.00	264.63	553.97	972.93	1,496.82	859.81	799.22
7/5/07 18:51	52.10	421,407.09	357.63	431,465.91	76.04	0.00	264.72	553.68	971.93	1,501.41	859.41	798.81
7/5/07 18:52	52.62	422,782.41	357.67	431,812.69	76.26	0.00	264.78	553.74	972.55	1,500.19	859.91	799.41
7/5/07 18:53	52.51	423,559.59	357.84	429,903.09	77.59	0.00	264.85	553.87	972.17	1,498.89	860.80	800.51
7/5/07 18:54	52.58	424,715.41	358.03	427,993.50	80.32	0.00	264.95	553.99	971.30	1,500.31	861.74	801.03
7/5/07 18:55	52.58	424,553.91	358.29	426,083.91	77.17	0.00	265.04	554.22	970.30	1,499.18	862.82	802.03
7/5/07 18:56	52.12	421,137.50	358.62	424,174.31	77.05	0.00	265.07	554.47	969.47	1,492.30	864.30	803.41
7/5/07 18:57	51.33	415,424.31	358.90	422,264.69	78.27	0.00	265.14	554.67	968.11	1,487.00	865.41	804.69
7/5/07 18:58	51.54	418,930.81	359.17	420,439.31	82.18	0.00	265.11	554.96	966.98	1,493.08	865.94	805.09
7/5/07 18:59	50.87	412,822.91	359.49	418,627.31	83.92	0.00	264.93	555.63	968.07	1,485.81	867.29	806.37
7/5/07 19:00	50.32	409,309.91	359.75	416,815.31	86.36	0.00	264.73	555.97	967.05	1,486.24	867.26	805.87
7/5/07 19:01	50.78	413,476.09	359.99	415,003.31	84.62	0.00	264.61	556.40	967.26	1,493.21	867.06	805.55
7/5/07 19:02	50.00	408,197.41	360.11	413,191.41	86.69	0.00	264.33	556.91	967.81	1,485.85	867.17	806.24
7/5/07 19:03	50.15	410,547.69	360.19	411,379.41	85.08	0.00	264.12	557.21	967.18	1,489.87	866.48	805.49
7/5/07 19:04	50.20	409,273.69	360.33	409,567.41	83.59	0.00	264.04	557.62	967.78	1,491.97	866.44	806.90
7/5/07 19:05	49.31	402,320.50	360.41	407,755.41	84.62	0.00	263.93	557.87	967.30	1,483.83	865.93	806.46
7/5/07 19:06	49.63	406,168.00	360.51	407,708.81	81.62	0.00	263.91	558.13	966.59	1,491.54	865.23	806.07
7/5/07 19:07	49.61	407,818.50	360.53	408,025.81	77.99	0.00	263.78	558.37	966.22	1,490.94	864.58	805.25
7/5/07 19:08	48.76	401,594.81	360.47	408,342.81	75.12	0.00	263.71	558.39	965.51	1,485.52	863.79	804.41
7/5/07 19:09	48.80	401,917.69	360.58	408,659.81	76.82	0.00	263.68	558.55	965.12	1,490.18	863.22	803.63

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FLOW (TPH)	PROPANE FUEL FLOW (SCFH)	FWP DISCH FLOW (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 19:10	49.33	406,777.19	360.69	408,976.81	82.58	0.00	263.56	558.81	966.62	1,499.94	863.32	803.97
7/5/07 19:11	49.30	406,138.09	360.74	409,293.81	83.45	0.00	263.46	559.17	968.71	1,497.81	863.77	804.96
7/5/07 19:12	49.57	408,302.00	360.84	409,610.81	79.69	0.00	263.41	559.21	969.77	1,500.28	863.94	804.79
7/5/07 19:13	50.07	410,121.69	360.94	409,927.81	74.81	0.00	263.41	559.25	971.34	1,501.91	864.37	805.60
7/5/07 19:14	49.43	405,025.91	360.98	410,244.81	73.82	0.00	263.48	559.39	971.94	1,490.92	861.81	803.97
7/5/07 19:15	50.05	410,282.31	361.09	410,561.81	75.50	0.00	263.53	559.55	971.79	1,501.08	859.98	802.34
7/5/07 19:16	49.84	407,261.31	361.26	410,878.81	77.52	0.00	263.52	559.89	972.37	1,497.06	859.65	802.22
7/5/07 19:17	49.30	404,767.31	361.31	411,195.91	78.32	0.00	263.52	559.78	971.37	1,489.27	859.38	801.76
7/5/07 19:18	49.27	405,945.81	361.42	411,512.91	78.52	0.00	263.49	559.82	971.09	1,490.79	859.43	801.87
7/5/07 19:19	48.90	401,774.50	361.45	411,829.91	79.01	0.00	263.38	559.71	970.00	1,486.20	859.61	801.59
7/5/07 19:20	48.19	397,909.09	361.44	412,187.59	72.05	0.00	263.29	559.65	968.83	1,482.64	859.20	800.65
7/5/07 19:21	47.99	397,148.19	361.35	413,480.69	70.36	0.00	263.11	559.86	968.09	1,483.83	858.82	799.78
7/5/07 19:22	47.82	395,760.81	361.22	414,773.81	69.28	0.00	262.93	560.20	968.00	1,489.11	858.61	799.20
7/5/07 19:23	47.48	394,000.31	361.07	416,066.81	69.07	0.00	262.68	560.53	968.77	1,485.52	858.50	798.84
7/5/07 19:24	47.76	397,517.41	360.85	417,360.00	70.94	0.00	262.39	560.62	969.24	1,493.00	858.29	798.49
7/5/07 19:25	47.57	394,992.69	360.65	418,653.09	71.09	0.00	262.19	560.63	970.43	1,490.40	858.55	798.55
7/5/07 19:26	47.78	396,916.00	360.42	419,946.19	68.72	0.00	262.11	560.46	970.64	1,495.22	858.66	798.45
7/5/07 19:27	48.81	403,835.69	360.19	421,239.31	68.94	0.00	261.99	560.56	972.76	1,506.09	859.71	799.48
7/5/07 19:28	49.53	407,335.91	359.99	423,279.09	69.84	0.00	261.96	560.73	974.46	1,507.70	861.08	800.65
7/5/07 19:29	50.98	416,766.81	359.77	427,417.19	67.48	0.00	262.09	560.79	975.95	1,514.97	862.52	801.98
7/5/07 19:30	52.53	426,278.50	359.59	431,555.19	69.43	0.00	262.23	560.64	976.57	1,518.73	863.97	803.07
7/5/07 19:31	53.29	428,298.81	359.49	435,693.19	67.81	0.00	262.53	560.20	975.58	1,517.71	865.20	804.30
7/5/07 19:32	54.48	436,516.59	359.44	439,831.19	68.73	0.00	262.95	559.87	975.56	1,518.09	866.68	805.73
7/5/07 19:33	55.22	441,389.00	359.49	443,969.19	66.61	0.00	263.42	559.59	974.56	1,517.43	868.26	807.26
7/5/07 19:34	55.49	442,976.59	359.52	448,107.31	68.30	0.00	263.96	559.13	972.92	1,514.57	869.48	807.98
7/5/07 19:35	56.24	448,389.19	359.58	452,245.31	71.15	0.00	264.48	558.62	972.21	1,512.46	870.40	808.74
7/5/07 19:36	56.59	450,861.59	359.67	456,383.31	72.57	0.00	265.00	557.90	971.83	1,506.00	871.17	809.21
7/5/07 19:37	56.49	447,346.69	359.66	456,487.81	69.18	0.00	265.40	556.96	970.24	1,507.32	871.21	809.73
7/5/07 19:38	56.79	450,015.19	359.62	453,003.41	69.64	0.00	265.78	556.55	971.00	1,503.05	871.59	810.46
7/5/07 19:39	56.79	449,953.41	359.52	449,519.00	70.49	0.00	266.17	556.04	970.30	1,501.69	871.50	810.19
7/5/07 19:40	56.11	445,420.59	359.72	446,034.59	73.04	0.00	266.43	555.52	969.26	1,494.81	871.84	811.10
7/5/07 19:41	55.78	442,541.09	359.81	442,550.19	76.95	0.00	266.65	555.34	969.59	1,492.19	872.99	812.66
7/5/07 19:42	55.00	435,739.19	359.93	439,065.81	77.68	0.00	266.74	555.18	969.28	1,488.87	874.40	814.43
7/5/07 19:43	54.98	436,153.09	360.10	437,240.81	80.33	0.00	266.73	555.00	968.52	1,493.46	875.10	814.99
7/5/07 19:44	54.58	431,589.31	360.20	437,478.69	77.08	0.00	266.61	555.26	969.67	1,489.16	876.21	816.18
7/5/07 19:45	54.23	430,089.00	360.31	437,716.41	78.81	0.00	266.49	555.26	969.24	1,491.71	876.72	816.64
7/5/07 19:46	54.71	432,263.09	360.40	437,954.31	76.28	0.00	266.37	555.56	970.07	1,499.13	877.45	817.83
7/5/07 19:47	54.25	429,390.09	360.46	438,192.09	76.85	0.00	266.23	555.89	971.52	1,491.92	878.21	817.29
7/5/07 19:48	54.49	431,791.31	360.65	438,429.91	78.61	0.00	266.19	555.93	971.84	1,498.41	877.80	815.64
7/5/07 19:49	53.54	424,385.50	360.88	438,667.69	78.40	0.00	266.19	556.11	973.75	1,487.61	875.37	816.72
7/5/07 19:50	53.93	426,431.00	361.11	438,905.50	80.70	0.00	266.19	556.31	973.71	1,496.05	873.02	816.12
7/5/07 19:51	54.03	428,594.50	361.47	439,169.59	80.13	0.00	266.12	556.76	973.63	1,497.66	873.18	815.66
7/5/07 19:52	54.68	432,822.00	361.85	441,512.19	81.60	0.00	266.07	557.20	973.12	1,505.90	874.92	818.19
7/5/07 19:53	55.22	435,339.69	362.22	443,854.91	83.03	0.00	266.01	557.58	974.51	1,503.11	877.71	821.70
7/5/07 19:54	55.84	440,440.19	362.60	446,197.50	84.74	0.00	266.08	557.56	974.94	1,507.32	878.02	825.09
7/5/07 19:55	55.88	441,659.00	362.94	448,540.19	81.95	0.00	266.13	557.70	975.55	1,502.96	879.01	828.75
7/5/07 19:56	56.39	444,844.81	363.24	450,882.81	82.67	0.00	266.24	557.72	973.61	1,506.26	880.50	830.85
7/5/07 19:57	56.94	450,877.00	363.49	453,225.41	85.42	0.00	266.36	557.93	972.85	1,506.23	881.88	830.78
7/5/07 19:58	56.49	446,191.00	363.78	455,568.09	78.60	0.00	266.53	557.99	972.24	1,498.08	881.73	828.98
7/5/07 19:59	56.47	447,042.31	364.02	457,350.59	78.38	0.00	266.73	557.87	972.32	1,499.33	879.94	829.36

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FLOW (TPH)	PROPANE FUEL FLOW (SCFH)	FWP DISCH FLOW (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 20:00	56.06	443,843.00	364.21	458,278.31	86.69	0.00	266.88	557.81	972.13	1,493.95	878.44	828.10
7/5/07 20:01	55.65	441,829.81	364.30	459,205.91	90.44	0.00	266.90	557.59	970.30	1,502.84	877.38	825.92
7/5/07 20:02	56.17	444,872.50	364.38	460,133.59	87.56	0.00	266.80	557.61	970.17	1,503.85	878.00	825.97
7/5/07 20:03	56.28	446,120.59	364.40	461,849.91	87.10	0.00	266.70	557.57	970.25	1,503.94	878.53	826.60
7/5/07 20:04	56.09	445,395.00	364.56	463,728.59	82.18	0.00	266.61	557.65	971.63	1,500.23	878.38	827.81
7/5/07 20:05	56.54	448,081.59	364.74	465,607.41	80.60	0.00	266.59	557.82	972.96	1,503.61	879.79	830.27
7/5/07 20:06	56.13	444,116.19	364.99	467,486.09	80.95	0.00	266.56	558.00	972.37	1,495.65	881.61	831.68
7/5/07 20:07	57.27	454,137.09	365.21	469,364.91	83.25	0.00	266.63	557.96	971.96	1,507.59	882.68	831.78
7/5/07 20:08	56.59	447,351.19	365.45	469,735.41	84.12	0.00	266.62	558.07	972.01	1,496.73	883.19	832.24
7/5/07 20:09	56.62	448,647.19	365.68	468,231.31	85.02	0.00	266.74	557.87	970.90	1,498.42	882.07	831.08
7/5/07 20:10	56.65	448,049.09	365.92	466,727.19	90.08	0.00	266.85	557.84	971.35	1,498.08	881.75	829.57
7/5/07 20:11	56.20	445,615.41	366.16	465,223.09	93.97	0.00	266.93	557.69	971.26	1,492.49	882.29	828.84
7/5/07 20:12	55.70	440,738.31	366.34	463,718.91	96.39	0.00	266.99	557.40	969.28	1,489.16	882.99	828.52
7/5/07 20:13	55.88	443,066.31	366.46	462,214.81	90.29	0.00	267.00	557.15	968.32	1,496.73	883.04	828.64
7/5/07 20:14	55.28	438,068.50	366.55	460,710.69	84.81	0.00	266.90	556.92	968.49	1,490.85	882.29	828.98
7/5/07 20:15	55.85	442,749.00	366.59	459,206.59	85.57	0.00	266.76	556.52	968.45	1,501.51	881.89	828.57
7/5/07 20:16	56.09	442,845.19	366.60	459,876.00	82.45	0.00	266.60	556.58	970.55	1,501.82	882.32	828.06
7/5/07 20:17	55.39	438,454.09	366.63	461,826.50	79.53	0.00	266.54	556.19	971.11	1,492.52	881.14	826.02
7/5/07 20:18	56.56	447,404.31	366.63	463,777.00	77.49	0.00	266.51	555.71	970.08	1,506.96	879.24	824.28
7/5/07 20:19	56.31	444,836.91	366.68	463,065.69	75.97	0.00	266.47	555.45	970.54	1,501.70	877.57	823.64
7/5/07 20:20	56.88	450,420.31	366.80	461,869.19	74.10	0.00	266.51	554.97	970.06	1,505.93	876.33	821.95
7/5/07 20:21	56.94	448,540.69	366.88	460,672.69	75.41	0.00	266.52	554.67	971.53	1,501.82	876.65	823.38
7/5/07 20:22	56.34	443,140.91	366.89	459,476.31	76.35	0.00	266.61	554.07	969.68	1,493.67	876.25	823.18
7/5/07 20:23	56.85	449,722.91	366.93	458,679.50	78.05	0.00	266.73	553.81	968.04	1,503.50	875.81	823.51
7/5/07 20:24	56.52	447,229.81	367.05	457,891.19	76.45	0.00	266.78	553.68	967.34	1,498.04	876.05	825.02
7/5/07 20:25	56.09	443,932.50	367.23	457,102.91	77.41	0.00	266.79	553.52	966.39	1,492.82	876.81	825.92
7/5/07 20:26	56.14	444,606.19	367.40	456,314.69	80.73	0.00	266.84	553.53	967.10	1,493.41	878.52	825.78
7/5/07 20:27	54.00	427,410.00	367.62	453,040.50	78.90	0.00	266.84	553.23	968.26	1,478.81	878.99	824.56
7/5/07 20:28	53.76	428,294.81	367.71	446,459.81	79.68	0.00	266.79	553.15	969.57	1,482.32	876.41	823.83
7/5/07 20:29	54.10	428,818.91	367.88	443,653.91	80.51	0.00	266.46	553.70	972.66	1,490.52	875.04	823.54
7/5/07 20:30	53.22	421,993.31	368.13	441,917.81	79.31	0.00	265.96	554.12	973.85	1,485.66	875.19	821.16
7/5/07 20:31	53.96	426,743.69	368.27	440,181.69	78.79	0.00	265.64	554.48	974.67	1,495.98	876.81	822.14
7/5/07 20:32	54.22	428,444.09	368.48	438,445.59	74.40	0.00	265.31	555.10	977.56	1,500.79	879.40	825.40
7/5/07 20:33	53.69	424,406.59	368.64	436,709.50	73.66	0.00	265.11	554.92	977.57	1,493.33	879.15	826.70
7/5/07 20:34	54.71	430,872.31	368.77	440,129.81	75.73	0.00	265.04	555.36	977.69	1,506.24	879.54	828.07
7/5/07 20:35	55.60	437,870.50	368.83	445,630.69	76.53	0.00	264.90	555.79	978.24	1,509.29	881.49	829.75
7/5/07 20:36	55.69	438,010.91	368.89	451,131.59	78.14	0.00	264.93	555.89	977.88	1,505.32	882.87	828.35
7/5/07 20:37	56.89	445,985.31	368.90	456,632.50	76.37	0.00	265.13	555.77	978.28	1,513.78	882.42	827.90
7/5/07 20:38	56.43	441,727.59	368.86	462,133.41	71.77	0.00	265.29	555.58	979.31	1,502.61	880.22	828.47
7/5/07 20:39	56.60	443,851.81	368.90	463,217.19	71.27	0.00	265.62	555.18	977.70	1,503.71	878.41	826.61
7/5/07 20:40	57.12	448,918.81	368.91	463,964.09	72.26	0.00	265.94	554.95	976.73	1,504.64	879.15	826.47
7/5/07 20:41	56.63	445,583.00	368.93	464,204.09	71.77	0.00	266.12	554.53	972.67	1,499.17	880.32	827.69
7/5/07 20:42	57.10	449,559.31	368.99	463,993.00	72.46	0.00	266.29	554.37	972.45	1,502.96	881.50	830.05
7/5/07 20:43	56.77	447,052.69	369.05	463,781.91	72.04	0.00	266.38	554.18	972.24	1,498.16	881.30	832.40
7/5/07 20:44	57.17	449,683.81	369.14	463,570.81	73.04	0.00	266.54	554.03	972.34	1,502.77	882.15	834.17
7/5/07 20:45	57.07	448,447.00	369.25	463,359.81	79.39	0.00	266.59	554.11	972.74	1,496.42	884.32	835.76
7/5/07 20:46	56.79	447,871.31	369.34	463,148.69	77.09	0.00	266.67	553.78	971.64	1,495.91	885.10	835.14
7/5/07 20:47	57.27	451,081.81	369.40	462,937.59	73.70	0.00	266.71	553.67	972.48	1,502.92	884.38	835.94
7/5/07 20:48	57.16	448,896.50	369.51	462,726.50	73.36	0.00	266.71	553.90	973.89	1,498.12	882.93	838.17
7/5/07 20:49	57.05	450,682.59	369.71	462,515.41	77.70	0.00	266.77	553.91	972.81	1,497.19	882.30	838.86

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 20:50	57.39	452,493.91	369.96	462,304.31	75.76	0.00	266.86	554.27	973.26	1,501.92	883.96	840.85
7/5/07 20:51	56.94	447,001.09	370.18	462,093.31	75.58	0.00	266.90	554.74	973.41	1,492.31	886.16	845.51
7/5/07 20:52	56.34	442,825.69	370.33	461,615.59	75.66	0.00	266.99	554.59	970.30	1,490.33	886.26	848.11
7/5/07 20:53	56.97	446,415.31	370.52	461,076.41	77.17	0.00	267.05	554.83	970.18	1,499.37	886.08	851.89
7/5/07 20:54	56.11	440,325.69	370.66	460,537.19	78.06	0.00	267.03	555.10	970.35	1,489.44	887.25	854.75
7/5/07 20:55	56.16	441,587.69	370.80	459,997.91	77.33	0.00	267.03	555.36	969.95	1,491.34	888.49	854.78
7/5/07 20:56	55.94	439,180.59	370.96	459,458.81	78.04	0.00	267.01	555.25	969.62	1,493.30	888.72	852.31
7/5/07 20:57	56.06	441,193.41	371.08	458,919.50	78.04	0.00	266.96	555.11	970.16	1,497.08	885.85	850.97
7/5/07 20:58	56.07	439,531.69	371.24	458,380.31	78.95	0.00	266.82	555.07	970.63	1,497.50	882.64	850.55
7/5/07 20:59	56.14	440,182.59	371.41	457,841.09	79.75	0.00	266.75	555.14	970.80	1,500.21	882.02	849.05
7/5/07 21:00	56.23	441,340.41	371.55	457,301.91	84.96	0.00	266.68	555.30	971.09	1,498.70	883.40	849.93
7/5/07 21:01	57.02	447,728.41	371.73	456,762.69	84.19	0.00	266.66	555.50	971.74	1,507.16	885.22	852.87
7/5/07 21:02	56.61	443,046.59	371.86	457,019.59	89.26	0.00	266.71	555.66	972.49	1,500.44	885.28	855.18
7/5/07 21:03	57.30	449,153.00	372.01	457,337.31	86.72	0.00	266.71	555.85	972.73	1,505.04	885.34	857.30
7/5/07 21:04	57.11	447,875.00	372.15	457,654.91	83.09	0.00	266.79	556.07	972.22	1,500.90	886.71	859.14
7/5/07 21:05	56.79	445,512.59	372.27	457,972.50	77.73	0.00	266.88	556.26	970.84	1,497.63	887.65	858.42
7/5/07 21:06	57.59	452,072.81	372.32	458,290.19	77.16	0.00	267.00	556.47	970.49	1,504.47	887.19	856.09
7/5/07 21:07	57.11	447,477.31	372.42	458,607.81	81.90	0.00	267.09	556.47	970.15	1,497.42	884.52	855.25
7/5/07 21:08	57.66	452,671.81	372.52	458,639.59	82.49	0.00	267.16	556.50	969.57	1,503.25	881.70	853.92
7/5/07 21:09	57.89	454,539.59	372.67	458,632.00	83.22	0.00	267.23	556.54	969.23	1,504.88	881.82	851.82
7/5/07 21:10	57.17	450,152.09	372.72	458,624.50	82.73	0.00	267.31	556.53	968.08	1,494.87	883.07	852.40
7/5/07 21:11	56.67	445,738.91	372.76	458,616.91	85.20	0.00	267.43	556.49	966.78	1,490.62	883.98	853.96
7/5/07 21:12	56.62	445,760.09	372.80	457,880.19	86.71	0.00	267.47	556.50	966.12	1,492.39	883.29	855.20
7/5/07 21:13	56.14	441,339.41	372.81	456,975.19	90.06	0.00	267.40	556.61	965.69	1,491.81	883.12	856.48
7/5/07 21:14	56.40	443,343.09	372.86	456,070.19	92.62	0.00	267.27	557.03	966.52	1,495.92	884.44	858.42
7/5/07 21:15	55.67	436,722.19	372.91	455,165.09	91.71	0.00	267.11	557.29	968.32	1,489.50	885.83	855.72
7/5/07 21:16	55.96	438,914.31	372.93	454,260.09	88.29	0.00	266.98	557.18	969.02	1,496.77	884.71	852.63
7/5/07 21:17	56.64	443,842.81	372.92	453,355.09	87.51	0.00	266.86	557.22	972.35	1,504.59	881.22	852.26
7/5/07 21:18	57.03	445,590.59	372.89	455,290.31	87.01	0.00	266.68	557.24	974.90	1,503.72	878.88	850.61
7/5/07 21:19	57.62	450,293.19	372.87	457,497.91	86.91	0.00	266.69	557.12	974.57	1,506.92	879.38	848.38
7/5/07 21:20	57.45	448,856.81	372.91	459,705.50	88.38	0.00	266.77	557.02	973.34	1,503.38	880.96	850.31
7/5/07 21:21	58.29	455,979.59	372.96	461,913.00	88.66	0.00	266.93	557.10	973.12	1,508.40	882.71	853.32
7/5/07 21:22	58.20	453,736.00	373.09	464,120.59	92.51	0.00	267.10	556.98	972.42	1,503.50	882.93	856.04
7/5/07 21:23	58.95	460,985.31	373.16	466,328.19	91.02	0.00	267.30	556.67	971.13	1,508.25	883.93	858.46
7/5/07 21:24	58.68	458,460.00	373.21	468,535.81	89.04	0.00	267.47	556.55	971.33	1,502.20	885.58	860.23
7/5/07 21:25	58.23	455,553.81	373.18	470,081.81	88.28	0.00	267.73	555.81	969.83	1,495.64	885.47	855.62
7/5/07 21:26	58.00	454,933.09	373.09	467,167.50	89.40	0.00	267.98	555.00	968.85	1,496.17	881.45	850.10
7/5/07 21:27	57.85	453,357.59	373.00	464,253.31	89.17	0.00	268.05	554.42	967.82	1,496.03	875.90	847.35
7/5/07 21:28	57.79	452,451.91	372.94	461,339.00	83.68	0.00	268.04	554.04	967.46	1,495.92	872.75	842.93
7/5/07 21:29	56.89	446,490.50	372.83	458,424.81	83.53	0.00	267.98	553.62	966.71	1,488.19	872.26	840.43
7/5/07 21:30	57.10	447,770.19	372.73	456,556.91	79.37	0.00	267.87	553.11	965.58	1,493.32	872.02	836.44
7/5/07 21:31	56.69	446,521.31	372.62	457,179.69	76.17	0.00	267.67	552.82	966.00	1,491.01	869.72	835.00
7/5/07 21:32	56.37	442,675.91	372.61	457,802.41	73.22	0.00	267.50	552.69	966.34	1,491.12	866.47	835.52
7/5/07 21:33	56.07	442,328.50	372.60	458,425.19	70.91	0.00	267.29	552.65	966.51	1,491.98	865.64	832.96
7/5/07 21:34	56.15	439,755.19	372.58	459,047.91	70.47	0.00	267.12	552.64	967.07	1,494.53	867.04	833.76
7/5/07 21:35	56.48	442,046.19	372.64	459,670.69	70.95	0.00	266.89	552.86	968.65	1,500.18	869.33	836.66
7/5/07 21:36	57.01	444,093.41	372.73	460,519.81	71.82	0.00	266.74	553.11	971.79	1,504.09	870.82	840.01
7/5/07 21:37	58.09	452,299.69	372.89	462,894.59	72.94	0.00	266.68	553.23	974.71	1,509.68	871.79	843.81
7/5/07 21:38	57.89	450,859.69	373.01	465,269.50	74.29	0.00	266.69	553.13	975.14	1,504.45	873.64	846.58
7/5/07 21:39	58.38	454,566.59	373.07	467,644.41	73.55	0.00	266.86	553.06	975.60	1,506.24	875.76	845.98

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 21:40	58.53	456,222.91	373.16	470,019.19	74.17	0.00	267.08	552.62	976.02	1,504.52	876.61	839.56
7/5/07 21:41	58.45	454,334.59	373.19	472,394.09	73.94	0.00	267.27	551.99	974.94	1,501.74	872.78	837.20
7/5/07 21:42	58.60	455,638.91	373.22	474,769.00	76.72	0.00	267.50	551.30	973.65	1,503.29	868.23	835.91
7/5/07 21:43	59.23	462,191.50	373.18	477,143.81	80.94	0.00	267.65	550.65	973.99	1,507.82	866.88	831.38
7/5/07 21:44	59.38	462,835.41	373.10	479,518.69	83.37	0.00	267.78	550.21	974.51	1,506.14	868.06	830.80
7/5/07 21:45	59.76	466,390.81	373.01	481,893.59	80.62	0.00	267.96	549.64	974.46	1,508.43	869.26	830.83
7/5/07 21:46	60.56	471,783.69	373.00	484,268.41	83.59	0.00	268.02	549.11	975.57	1,509.54	868.53	830.83
7/5/07 21:47	60.04	467,717.31	372.99	486,643.31	84.65	0.00	268.20	548.39	974.68	1,502.83	867.68	830.07
7/5/07 21:48	60.37	470,073.81	372.85	488,619.81	82.21	0.00	268.47	547.74	973.47	1,505.33	868.00	828.79
7/5/07 21:49	61.70	481,537.09	372.74	490,494.19	86.34	0.00	268.56	547.42	974.03	1,514.19	868.96	824.90
7/5/07 21:50	61.56	479,361.41	372.71	492,368.50	87.30	0.00	268.70	547.08	976.29	1,507.32	869.21	820.69
7/5/07 21:51	61.29	475,334.41	372.65	494,242.91	90.52	0.00	268.96	546.28	975.43	1,504.19	866.35	819.07
7/5/07 21:52	62.04	482,013.09	372.53	493,909.59	90.55	0.00	269.17	545.69	976.03	1,508.39	864.64	816.87
7/5/07 21:53	61.18	476,062.59	372.43	493,224.31	88.98	0.00	269.39	545.14	975.49	1,499.03	865.17	814.01
7/5/07 21:54	61.99	482,499.91	372.29	492,539.09	86.54	0.00	269.60	544.67	973.56	1,505.77	866.34	813.89
7/5/07 21:55	61.89	480,120.59	372.21	491,853.91	87.54	0.00	269.78	544.19	973.06	1,503.31	867.29	815.16
7/5/07 21:56	61.21	478,327.19	372.11	491,168.69	91.26	0.00	269.87	543.60	972.43	1,496.74	866.61	816.32
7/5/07 21:57	60.84	473,862.59	372.01	490,233.69	95.06	0.00	270.02	542.90	970.48	1,496.48	866.89	817.44
7/5/07 21:58	60.72	472,982.41	371.97	488,154.31	91.48	0.00	270.09	542.64	970.26	1,496.42	868.38	819.14
7/5/07 21:59	60.11	468,084.31	371.96	486,075.00	89.37	0.00	270.12	542.41	970.11	1,492.23	869.04	817.93
7/5/07 22:00	59.52	463,827.41	371.94	483,995.69	91.04	0.00	270.10	541.97	968.76	1,490.56	868.08	816.04
7/5/07 22:01	59.20	461,287.81	371.92	481,916.31	88.34	0.00	269.94	541.58	968.16	1,494.56	866.63	815.37
7/5/07 22:02	58.88	458,569.69	371.90	479,837.00	86.69	0.00	269.78	541.68	969.35	1,490.60	866.17	815.80
7/5/07 22:03	58.13	453,411.31	371.91	477,757.69	87.75	0.00	269.54	541.50	968.25	1,488.03	866.15	817.16
7/5/07 22:04	58.55	456,530.81	371.88	475,678.31	93.06	0.00	269.24	541.79	968.68	1,495.81	866.65	820.15
7/5/07 22:05	58.17	452,043.19	371.91	473,203.69	88.99	0.00	268.99	542.11	969.84	1,491.65	866.69	822.23
7/5/07 22:06	57.59	447,148.69	371.83	468,063.69	91.77	0.00	268.80	542.14	968.89	1,489.22	865.92	823.42
7/5/07 22:07	57.27	445,856.91	371.73	462,923.81	89.71	0.00	268.62	542.29	967.88	1,492.55	865.26	825.15
7/5/07 22:08	57.18	444,569.00	371.67	457,783.81	90.73	0.00	268.38	542.81	968.26	1,490.95	866.08	825.72
7/5/07 22:09	57.17	444,524.19	371.57	452,643.81	87.19	0.00	268.14	543.15	967.73	1,494.81	866.32	822.91
7/5/07 22:10	55.92	435,078.31	371.43	447,503.91	85.00	0.00	267.92	543.45	967.17	1,484.69	865.77	819.91
7/5/07 22:11	55.72	434,324.31	371.29	447,064.19	82.21	0.00	267.77	543.73	966.21	1,487.29	865.14	816.39
7/5/07 22:12	55.99	435,714.00	371.19	449,202.00	82.42	0.00	267.48	544.25	966.25	1,493.41	864.86	811.99
7/5/07 22:13	56.14	437,195.00	371.09	451,339.81	85.82	0.00	267.14	544.93	966.76	1,498.07	865.15	810.86
7/5/07 22:14	56.31	438,116.81	371.04	453,477.59	85.50	0.00	266.92	545.65	968.91	1,497.82	865.14	810.62
7/5/07 22:15	56.61	440,384.69	370.97	455,615.31	83.23	0.00	266.77	545.95	969.12	1,502.38	864.42	809.10
7/5/07 22:16	56.82	441,432.59	370.88	457,753.19	81.11	0.00	266.68	546.44	970.48	1,503.00	863.62	808.65
7/5/07 22:17	57.14	443,133.41	370.75	459,890.91	80.02	0.00	266.62	547.00	971.77	1,499.56	864.01	808.96
7/5/07 22:18	57.51	446,381.81	370.67	462,028.81	75.71	0.00	266.65	547.33	970.58	1,505.05	863.86	808.27
7/5/07 22:19	57.92	449,879.19	370.56	464,166.50	75.62	0.00	266.71	547.87	969.82	1,506.38	863.54	807.97
7/5/07 22:20	58.13	451,795.19	370.51	466,304.31	76.96	0.00	266.77	548.39	968.08	1,504.77	862.95	808.17
7/5/07 22:21	58.29	454,438.31	370.42	468,442.09	77.64	0.00	266.83	548.59	965.90	1,504.98	861.95	807.76
7/5/07 22:22	58.42	454,749.81	370.36	470,579.91	75.28	0.00	266.92	548.87	965.62	1,504.66	861.59	807.46
7/5/07 22:23	58.84	458,052.31	370.40	472,290.69	74.64	0.00	267.12	549.36	967.93	1,502.99	862.94	809.95
7/5/07 22:24	58.81	458,276.50	370.48	472,691.09	74.72	0.00	267.26	549.45	967.67	1,503.58	863.93	812.50
7/5/07 22:25	58.75	458,557.69	370.63	473,091.59	74.84	0.00	267.42	549.74	968.14	1,499.41	864.81	815.45
7/5/07 22:26	58.83	458,575.31	370.78	473,492.09	73.34	0.00	267.54	549.91	967.99	1,499.78	865.65	818.04
7/5/07 22:27	58.18	453,740.41	370.91	473,892.59	75.25	0.00	267.62	549.80	966.55	1,495.78	866.38	819.79
7/5/07 22:28	58.73	458,266.09	371.02	474,293.09	71.38	0.00	267.75	549.90	966.99	1,501.52	867.65	821.51
7/5/07 22:29	58.43	455,595.41	370.96	474,693.59	72.90	0.00	267.75	549.79	968.08	1,496.39	868.29	820.97

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 22:30	58.57	458,295.19	370.89	475,094.09	71.90	0.00	267.77	549.39	967.72	1,500.55	867.97	819.06
7/5/07 22:31	59.71	466,918.59	370.71	475,494.59	73.88	0.00	267.79	549.21	969.45	1,509.82	867.97	817.78
7/5/07 22:32	59.69	464,649.59	370.57	476,529.31	75.63	0.00	267.82	549.04	971.21	1,505.48	868.17	816.54
7/5/07 22:33	59.48	463,111.59	370.39	477,780.19	73.48	0.00	267.96	548.55	970.75	1,502.82	867.84	814.53
7/5/07 22:34	60.02	466,133.59	370.26	479,031.00	72.41	0.00	268.12	548.21	971.34	1,504.27	867.68	813.37
7/5/07 22:35	60.74	471,501.81	370.13	480,281.91	73.83	0.00	268.28	547.89	972.08	1,507.36	867.84	812.49
7/5/07 22:36	59.98	466,226.19	370.01	477,808.59	73.42	0.00	268.51	547.42	971.80	1,498.30	868.05	811.40
7/5/07 22:37	60.25	468,231.31	369.88	474,279.81	74.13	0.00	268.76	546.96	970.52	1,502.80	867.99	810.52
7/5/07 22:38	59.73	464,006.41	369.76	470,751.00	73.17	0.00	268.93	546.59	970.28	1,496.07	868.06	809.98
7/5/07 22:39	59.18	459,938.19	369.69	467,222.31	74.40	0.00	269.09	546.16	968.62	1,492.70	867.76	809.16
7/5/07 22:40	58.99	459,397.50	369.55	463,693.50	74.97	0.00	269.17	545.79	967.43	1,492.78	867.41	808.08
7/5/07 22:41	58.01	450,876.59	369.48	460,164.69	77.23	0.00	269.10	545.58	966.32	1,485.84	866.18	807.36
7/5/07 22:42	57.27	446,095.81	369.39	456,635.91	79.37	0.00	269.00	545.87	965.52	1,485.20	862.26	804.30
7/5/07 22:43	57.22	447,167.09	369.39	453,107.19	85.39	0.00	268.78	546.44	965.94	1,490.49	860.93	803.51
7/5/07 22:44	56.08	435,516.69	369.32	449,578.41	87.75	0.00	268.42	546.73	966.55	1,482.94	860.21	802.71
7/5/07 22:45	55.95	435,403.31	369.25	446,049.59	85.98	0.00	268.14	546.93	967.39	1,486.67	860.06	802.28
7/5/07 22:46	55.80	432,189.00	369.15	442,520.81	84.96	0.00	267.84	547.14	968.67	1,489.38	860.30	801.87
7/5/07 22:47	55.63	430,929.91	369.01	442,339.19	82.19	0.00	267.39	547.57	970.36	1,489.40	860.88	801.94
7/5/07 22:48	55.95	433,155.50	368.83	444,589.59	82.96	0.00	267.04	547.99	971.11	1,495.34	861.32	801.87
7/5/07 22:49	56.09	435,111.19	368.59	446,840.09	85.11	0.00	266.70	548.75	972.18	1,497.25	862.10	802.18
7/5/07 22:50	56.07	433,392.00	368.29	449,090.50	85.74	0.00	266.48	549.45	972.80	1,497.51	862.83	802.44
7/5/07 22:51	56.09	433,829.31	367.87	451,340.91	85.90	0.00	266.37	549.82	972.24	1,497.72	862.97	802.19
7/5/07 22:52	57.37	442,342.81	367.43	453,591.31	83.95	0.00	266.30	550.14	973.15	1,508.50	863.68	802.86
7/5/07 22:53	56.87	436,963.91	366.92	454,658.81	82.10	0.00	266.24	550.19	972.71	1,495.75	864.16	802.78
7/5/07 22:54	56.69	438,213.69	366.37	455,391.00	79.53	0.00	266.31	549.97	970.56	1,498.50	863.68	801.89
7/5/07 22:55	57.00	441,011.50	365.78	456,123.19	76.19	0.00	266.32	549.99	969.84	1,501.94	863.72	801.79
7/5/07 22:56	56.43	436,929.09	365.11	456,855.31	75.01	0.00	266.31	550.06	968.53	1,494.82	863.60	801.45
7/5/07 22:57	56.68	439,439.69	364.45	457,587.50	72.72	0.00	266.23	550.19	967.40	1,499.65	863.34	801.07
7/5/07 22:58	57.23	443,023.09	363.87	458,120.81	71.73	0.00	266.15	550.60	968.01	1,500.76	863.67	801.42
7/5/07 22:59	56.72	439,028.69	363.36	456,777.69	69.73	0.00	266.08	550.44	966.92	1,494.09	863.47	801.09
7/5/07 23:00	56.61	438,756.59	362.91	455,434.59	70.74	0.00	266.07	550.23	965.90	1,495.67	862.75	800.09
7/5/07 23:01	56.72	441,137.19	362.49	454,091.50	69.45	0.00	266.01	550.28	966.08	1,500.02	862.41	799.81
7/5/07 23:02	56.82	441,799.81	362.17	452,710.50	70.97	0.00	265.94	550.51	967.38	1,498.28	862.60	799.94
7/5/07 23:03	56.28	436,818.00	361.87	451,155.41	71.29	0.00	265.86	550.38	967.01	1,492.42	862.23	799.51
7/5/07 23:04	56.53	438,305.00	361.60	449,600.41	70.96	0.00	265.93	550.28	966.70	1,497.27	861.70	799.18
7/5/07 23:05	57.06	441,235.91	361.35	449,328.09	70.29	0.00	265.84	550.64	968.66	1,501.43	861.98	799.54
7/5/07 23:06	57.05	442,905.59	361.19	449,419.31	67.88	0.00	265.80	550.94	969.40	1,501.19	862.23	799.79
7/5/07 23:07	57.32	443,364.91	361.03	449,510.50	66.97	0.00	265.89	551.31	971.07	1,501.73	860.79	800.12
7/5/07 23:08	57.92	447,007.69	360.97	449,601.69	63.47	0.00	265.98	551.69	972.07	1,506.70	858.87	798.66
7/5/07 23:09	56.94	439,382.91	360.90	449,692.91	66.29	0.00	266.05	551.76	972.90	1,491.47	858.86	799.04
7/5/07 23:10	56.78	437,706.31	360.81	450,646.81	64.28	0.00	266.22	551.23	971.32	1,492.29	858.63	798.74
7/5/07 23:11	57.72	445,699.41	360.68	451,799.69	65.36	0.00	266.33	550.83	970.94	1,504.28	858.58	798.54
7/5/07 23:12	57.61	444,023.31	360.58	452,952.69	66.58	0.00	266.35	550.72	972.32	1,500.35	859.18	799.04
7/5/07 23:13	56.95	438,798.59	360.41	453,502.09	67.71	0.00	266.36	550.17	971.00	1,492.41	859.28	798.86
7/5/07 23:14	56.59	437,121.59	360.22	451,248.09	67.21	0.00	266.44	549.87	969.91	1,492.56	859.49	798.68
7/5/07 23:15	56.52	439,070.00	360.09	448,994.19	66.28	0.00	266.45	549.99	969.69	1,493.04	860.22	799.29
7/5/07 23:16	55.38	427,110.31	359.92	446,740.19	69.03	0.00	266.36	549.84	968.27	1,485.61	860.37	799.01
7/5/07 23:17	55.22	428,354.00	359.70	444,486.19	70.40	0.00	266.14	549.66	967.34	1,488.12	860.18	798.78
7/5/07 23:18	55.64	432,525.31	359.51	442,597.41	70.53	0.00	265.82	549.70	968.73	1,495.49	860.84	799.49
7/5/07 23:19	55.24	428,865.41	359.23	444,543.09	70.78	0.00	265.52	549.59	968.92	1,491.91	860.97	799.36

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/5/07 23:20	55.55	431,474.81	358.99	446,488.81	69.87	0.00	265.34	549.49	969.65	1,499.03	861.02	799.33
7/5/07 23:21	56.11	432,646.81	358.73	448,434.50	71.89	0.00	265.17	549.79	972.56	1,503.18	861.94	800.27
7/5/07 23:22	56.40	434,514.69	358.46	450,380.09	74.93	0.00	265.04	549.92	973.30	1,503.32	862.72	801.16
7/5/07 23:23	56.97	439,041.00	358.19	452,325.81	76.40	0.00	265.05	549.97	973.36	1,506.55	863.33	801.48
7/5/07 23:24	58.14	447,391.09	357.99	454,271.50	80.64	0.00	265.11	549.99	974.14	1,511.98	864.31	802.43
7/5/07 23:25	58.45	451,262.81	357.87	456,217.19	80.77	0.00	265.24	549.78	973.49	1,509.84	864.84	802.90
7/5/07 23:26	58.53	451,523.59	357.72	458,162.81	81.61	0.00	265.56	549.32	971.78	1,505.53	864.64	802.51
7/5/07 23:27	58.47	451,744.91	357.45	460,108.50	83.14	0.00	265.83	548.69	969.79	1,501.90	863.77	801.79
7/5/07 23:28	58.11	448,388.41	357.17	460,563.00	81.59	0.00	266.13	547.90	967.22	1,498.41	862.17	800.41
7/5/07 23:29	58.29	450,134.31	356.92	459,690.59	77.41	0.00	266.42	547.42	966.65	1,500.45	861.26	800.59
7/5/07 23:30	58.48	452,395.50	356.76	458,818.31	74.43	0.00	266.59	547.29	967.72	1,501.81	861.55	802.26
7/5/07 23:31	57.52	445,403.41	356.63	457,945.91	76.16	0.00	266.69	546.69	966.59	1,491.81	860.80	802.03
7/5/07 23:32	58.01	448,950.31	356.47	457,073.59	77.57	0.00	266.75	546.31	967.29	1,499.30	860.06	801.67
7/5/07 23:33	58.18	450,190.50	356.40	456,189.41	80.76	0.00	266.72	546.16	968.96	1,500.38	859.93	801.71
7/5/07 23:34	58.31	450,266.19	356.34	456,664.81	82.19	0.00	266.65	545.88	969.30	1,502.89	859.69	801.46
7/5/07 23:35	59.55	460,385.09	356.32	464,227.00	81.37	0.00	266.62	545.76	970.44	1,509.54	859.87	801.40
7/5/07 23:36	59.21	457,957.59	356.33	466,127.09	82.77	0.00	266.72	545.45	970.94	1,502.92	860.30	801.86
7/5/07 23:37	58.70	453,516.41	356.30	461,257.19	82.49	0.00	266.90	544.85	969.57	1,494.56	859.97	801.37
7/5/07 23:38	59.19	457,331.00	356.22	459,060.31	84.59	0.00	267.13	544.29	967.79	1,503.33	859.46	801.56
7/5/07 23:39	59.18	457,942.91	356.15	462,504.00	83.54	0.00	267.33	544.14	967.96	1,501.90	859.43	801.71
7/5/07 23:40	58.59	452,178.09	356.13	463,613.00	83.12	0.00	267.49	543.96	968.11	1,492.51	859.51	802.17
7/5/07 23:41	58.81	453,359.69	356.08	456,618.19	84.93	0.00	267.63	543.47	966.50	1,496.26	859.25	802.93
7/5/07 23:42	57.88	447,296.50	356.04	453,850.69	83.89	0.00	267.74	543.12	966.12	1,490.18	859.28	804.67
7/5/07 23:43	58.23	450,253.59	356.00	456,852.91	82.48	0.00	267.73	542.79	966.06	1,495.78	859.58	806.05
7/5/07 23:44	57.53	444,955.50	355.97	450,320.81	80.99	0.00	267.67	542.37	965.58	1,490.60	859.66	806.58
7/5/07 23:45	56.86	439,753.00	355.91	446,329.91	79.41	0.00	267.62	541.95	965.09	1,488.44	859.15	806.12
7/5/07 23:46	57.80	447,384.41	355.87	447,985.19	78.00	0.00	267.49	541.78	966.23	1,502.84	859.06	806.10
7/5/07 23:47	57.62	445,150.81	355.84	452,323.31	74.50	0.00	267.21	541.67	967.35	1,493.17	859.30	806.59
7/5/07 23:48	57.94	444,969.69	355.84	449,494.91	75.85	0.00	267.10	541.36	967.36	1,500.38	859.06	805.85
7/5/07 23:49	58.80	454,377.81	355.84	459,993.69	76.68	0.00	266.98	541.30	969.80	1,507.76	859.63	806.75
7/5/07 23:50	58.14	448,060.91	355.86	457,161.50	77.36	0.00	266.90	541.00	970.12	1,499.16	860.11	807.10
7/5/07 23:51	58.32	450,542.41	355.85	455,424.81	77.82	0.00	267.00	540.54	968.74	1,500.80	859.71	806.51
7/5/07 23:52	59.00	455,865.19	355.83	460,290.50	75.71	0.00	267.08	540.31	968.03	1,507.71	859.76	807.33
7/5/07 23:53	58.37	449,923.31	355.81	459,755.00	75.16	0.00	267.15	540.42	968.76	1,496.45	860.25	808.03
7/5/07 23:54	57.30	442,875.59	355.80	454,857.31	72.40	0.00	267.26	540.06	966.11	1,488.22	859.65	806.76
7/5/07 23:55	57.74	446,498.00	355.74	452,105.59	70.56	0.00	267.35	539.98	965.45	1,497.43	859.31	806.61
7/5/07 23:56	57.96	447,715.41	355.75	457,334.41	68.06	0.00	267.26	540.18	967.51	1,498.41	860.10	808.20
7/5/07 23:57	57.72	445,521.69	355.76	454,123.31	69.71	0.00	267.13	540.15	968.25	1,496.21	860.62	809.08
7/5/07 23:58	57.76	445,299.81	355.79	455,529.81	71.82	0.00	267.05	540.06	968.84	1,496.29	860.99	810.24
7/5/07 23:59	57.70	445,467.00	355.72	453,425.81	75.16	0.00	266.94	539.87	969.34	1,498.43	861.30	810.63
7/6/07 0:00	57.55	443,326.59	355.74	453,640.31	75.73	0.00	266.86	540.00	970.83	1,496.61	861.70	810.34
7/6/07 0:01	57.57	443,935.41	355.75	450,729.69	73.28	0.00	266.75	540.01	971.24	1,497.14	861.59	809.56
7/6/07 0:02	57.52	443,404.50	355.78	450,832.19	74.00	0.00	266.69	540.12	971.59	1,496.17	861.60	809.97
7/6/07 0:03	57.08	438,548.19	355.81	453,366.31	74.10	0.00	266.61	540.31	971.57	1,491.20	861.54	809.39
7/6/07 0:04	57.16	441,189.00	355.82	447,695.31	72.15	0.00	266.55	540.19	969.94	1,497.71	860.79	809.00
7/6/07 0:05	56.50	436,244.91	355.81	446,397.41	71.63	0.00	266.52	540.41	968.81	1,491.23	860.41	808.94
7/6/07 0:06	56.77	438,686.00	355.82	443,354.09	72.76	0.00	266.37	540.59	967.95	1,496.22	859.83	808.21
7/6/07 0:07	56.65	439,089.91	355.87	446,128.81	72.10	0.00	266.27	540.98	967.73	1,498.70	859.59	807.15
7/6/07 0:08	56.17	429,846.31	355.90	441,351.41	72.29	0.00	266.13	541.14	967.32	1,486.91	859.30	806.26
7/6/07 0:09	56.20	434,479.19	355.93	441,340.50	71.34	0.00	266.06	541.36	967.12	1,496.79	859.27	805.90

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/6/07 0:10	56.04	435,145.41	356.08	441,410.81	72.52	0.00	265.91	541.73	968.29	1,493.50	860.07	806.67
7/6/07 0:11	56.32	434,439.09	356.26	443,610.19	73.82	0.00	265.76	542.19	969.58	1,498.26	861.11	807.58
7/6/07 0:12	56.47	434,903.50	356.40	440,782.31	71.17	0.00	265.67	542.40	969.86	1,499.91	861.73	807.64
7/6/07 0:13	56.41	434,659.41	356.51	444,443.59	74.11	0.00	265.65	542.74	971.10	1,496.11	862.54	808.68
7/6/07 0:14	57.07	440,200.00	356.62	444,483.50	75.13	0.00	265.62	542.91	971.23	1,505.26	862.94	808.55
7/6/07 0:15	56.75	436,279.00	356.74	444,872.59	76.24	0.00	265.61	543.17	971.41	1,498.94	863.39	808.76
7/6/07 0:16	57.52	442,716.69	356.87	448,646.19	77.60	0.00	265.66	543.42	971.53	1,505.06	864.00	809.10
7/6/07 0:17	57.60	443,440.59	356.99	453,639.59	76.92	0.00	265.72	543.82	972.27	1,501.48	864.82	809.53
7/6/07 0:18	58.32	449,828.41	357.14	454,907.19	75.60	0.00	265.83	543.96	971.62	1,507.86	865.39	809.45
7/6/07 0:19	58.34	450,494.91	357.21	454,320.00	78.26	0.00	265.97	544.09	970.82	1,505.79	865.91	810.08
7/6/07 0:20	58.76	453,229.81	357.35	458,414.69	79.63	0.00	266.07	544.25	969.77	1,506.73	866.19	810.05
7/6/07 0:21	59.70	460,647.50	357.44	463,302.69	77.19	0.00	266.24	544.42	969.60	1,510.68	866.35	810.33
7/6/07 0:22	59.81	462,965.09	357.62	468,516.19	75.45	0.00	266.44	544.45	969.30	1,510.97	866.94	811.92
7/6/07 0:23	60.37	466,184.19	357.72	467,098.59	77.68	0.00	266.67	544.39	969.58	1,510.08	867.67	813.67
7/6/07 0:24	60.11	463,670.09	357.82	467,871.69	78.08	0.00	266.98	544.05	968.36	1,503.54	867.87	813.86
7/6/07 0:25	60.45	466,924.31	357.96	466,073.09	76.71	0.00	267.34	543.68	967.11	1,506.70	867.61	813.20
7/6/07 0:26	59.71	461,231.69	358.04	469,617.00	73.93	0.00	267.63	543.59	966.55	1,495.67	867.84	812.66
7/6/07 0:27	59.37	458,638.69	358.14	464,018.91	75.41	0.00	267.83	543.26	964.95	1,492.27	867.33	811.60
7/6/07 0:28	58.33	449,444.41	358.19	458,697.31	80.02	0.00	267.94	542.98	964.41	1,484.32	866.73	811.53
7/6/07 0:29	58.90	456,365.91	358.25	459,511.00	78.58	0.00	267.99	542.90	965.12	1,499.16	866.77	813.28
7/6/07 0:30	57.95	447,176.41	358.35	457,358.50	78.10	0.00	267.80	543.12	967.63	1,487.68	867.49	815.81
7/6/07 0:31	56.70	436,563.19	358.50	448,853.09	78.15	0.00	267.66	543.01	967.30	1,479.30	867.57	817.20
7/6/07 0:32	56.77	436,319.50	358.63	441,884.09	78.38	0.00	267.52	543.02	967.20	1,486.78	867.20	817.52
7/6/07 0:33	57.03	440,363.69	358.69	445,033.69	77.15	0.00	267.15	543.30	968.31	1,496.29	866.90	816.83
7/6/07 0:34	56.98	439,354.19	358.79	447,667.50	74.07	0.00	266.80	543.50	969.91	1,494.45	866.80	815.94
7/6/07 0:35	57.34	440,765.91	358.79	446,517.00	76.17	0.00	266.57	543.48	969.82	1,499.90	866.32	814.82
7/6/07 0:36	57.24	438,859.81	358.85	449,202.31	75.26	0.00	266.36	543.49	970.88	1,496.51	866.27	814.10
7/6/07 0:37	58.12	447,371.00	358.88	452,545.59	75.30	0.00	266.27	543.52	971.64	1,506.62	866.23	813.76
7/6/07 0:38	58.02	446,616.19	358.91	450,204.59	75.49	0.00	266.29	543.47	971.82	1,503.14	866.11	813.00
7/6/07 0:39	58.16	446,623.31	358.92	458,360.59	79.30	0.00	266.31	543.35	972.30	1,502.06	865.89	812.99
7/6/07 0:40	59.00	457,336.31	358.90	459,828.31	82.98	0.00	266.39	543.07	972.66	1,511.66	865.73	814.60
7/6/07 0:41	59.58	456,975.41	358.75	468,083.50	84.12	0.00	266.50	542.84	974.51	1,507.23	866.01	815.66
7/6/07 0:42	59.95	458,049.19	358.70	465,934.91	82.77	0.00	266.74	542.40	973.41	1,504.99	865.50	814.33
7/6/07 0:43	59.96	460,481.50	358.64	468,467.91	72.54	0.00	266.99	541.99	972.83	1,506.10	865.02	813.76
7/6/07 0:44	59.26	455,565.81	358.58	468,972.91	70.76	0.00	267.25	541.62	971.22	1,496.25	864.63	813.08
7/6/07 0:45	58.93	453,365.50	358.47	461,814.00	76.55	0.00	267.46	541.04	968.56	1,493.16	863.58	811.55
7/6/07 0:46	58.74	453,402.91	358.38	461,827.81	79.34	0.00	267.52	540.67	965.87	1,495.42	862.66	810.57
7/6/07 0:47	58.45	449,966.00	358.28	460,399.81	80.04	0.00	267.48	540.50	965.28	1,492.60	862.03	809.73
7/6/07 0:48	58.36	450,317.31	358.27	460,069.19	81.00	0.00	267.37	540.36	964.66	1,495.05	861.51	809.92
7/6/07 0:49	58.34	450,101.09	358.25	459,482.09	85.15	0.00	267.22	540.32	966.30	1,494.92	861.79	811.93
7/6/07 0:50	58.10	448,485.69	358.18	456,824.31	85.25	0.00	267.06	540.19	966.71	1,494.72	861.68	812.50
7/6/07 0:51	58.52	451,058.91	358.23	458,113.69	86.62	0.00	266.91	540.25	968.10	1,500.95	861.76	812.07
7/6/07 0:52	58.36	449,931.59	358.26	461,096.50	86.21	0.00	266.77	540.37	969.77	1,498.57	862.19	812.20
7/6/07 0:53	57.92	446,902.09	358.25	456,183.81	83.33	0.00	266.78	540.22	969.54	1,494.49	861.98	811.34
7/6/07 0:54	58.11	447,298.91	358.13	455,867.91	81.01	0.00	266.76	540.16	970.01	1,497.46	861.85	811.51
7/6/07 0:55	58.28	448,439.81	358.20	457,447.59	79.58	0.00	266.70	540.16	970.53	1,499.36	862.29	813.19
7/6/07 0:56	58.34	449,316.00	358.22	459,800.81	77.68	0.00	266.68	540.08	971.47	1,500.57	862.99	814.85
7/6/07 0:57	58.43	448,853.81	358.26	461,622.31	75.71	0.00	266.70	539.92	971.74	1,498.03	863.40	815.93
7/6/07 0:58	57.95	443,903.00	358.18	454,928.59	74.13	0.00	266.76	539.37	970.13	1,492.54	862.81	814.56
7/6/07 0:59	58.45	450,452.00	358.16	456,789.41	75.98	0.00	266.84	539.03	969.57	1,503.82	862.34	813.52

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/6/07 1:00	58.22	447,358.41	358.22	462,357.81	78.47	0.00	266.80	539.00	970.35	1,495.29	862.69	813.09
7/6/07 1:01	57.37	443,357.81	358.14	451,452.00	77.75	0.00	266.91	538.40	967.96	1,492.08	861.99	811.84
7/6/07 1:02	57.71	447,145.31	358.18	451,783.59	79.42	0.00	266.92	538.30	967.89	1,498.39	862.15	811.68
7/6/07 1:03	57.51	443,452.19	358.34	451,874.00	80.23	0.00	266.79	538.53	968.84	1,495.28	863.03	812.19
7/6/07 1:04	57.27	442,161.50	358.43	452,666.81	82.07	0.00	266.67	538.77	969.26	1,494.50	863.93	812.33
7/6/07 1:05	57.66	445,726.09	358.60	451,856.19	80.64	0.00	266.52	538.96	969.92	1,501.34	864.84	813.11
7/6/07 1:06	57.31	440,801.69	358.74	452,853.69	80.58	0.00	266.38	539.26	971.14	1,495.37	865.99	814.93
7/6/07 1:07	58.03	447,051.09	358.85	451,714.59	80.13	0.00	266.24	539.56	971.90	1,504.46	867.04	815.79
7/6/07 1:08	58.48	449,823.81	359.02	456,484.31	79.44	0.00	266.17	540.24	973.47	1,506.92	868.19	816.46
7/6/07 1:09	58.83	449,793.81	359.18	460,433.00	75.84	0.00	266.13	540.81	973.95	1,502.89	869.00	816.43
7/6/07 1:10	60.17	462,981.50	359.27	467,488.41	73.53	0.00	266.19	541.21	974.45	1,517.09	870.06	818.07
7/6/07 1:11	60.20	460,979.31	359.56	472,607.59	72.48	0.00	266.31	541.69	976.07	1,506.14	871.65	819.93
7/6/07 1:12	60.18	461,547.91	359.67	469,819.59	72.02	0.00	266.58	541.66	974.00	1,503.88	871.89	819.66
7/6/07 1:13	60.29	463,522.31	359.74	472,305.91	76.72	0.00	266.90	541.65	972.11	1,504.73	872.02	821.46
7/6/07 1:14	60.69	466,640.69	359.89	469,824.09	76.59	0.00	267.17	541.66	970.54	1,505.69	871.97	822.49
7/6/07 1:15	60.10	462,546.09	359.96	471,370.59	78.31	0.00	267.44	541.46	968.65	1,496.86	871.34	821.03
7/6/07 1:16	60.42	466,264.59	359.92	466,249.69	80.94	0.00	267.78	541.05	966.98	1,503.32	870.25	819.57
7/6/07 1:17	60.52	466,402.59	359.88	471,148.00	82.87	0.00	267.96	540.94	967.47	1,502.34	869.79	819.06
7/6/07 1:18	60.28	472,412.59	359.93	472,648.31	84.14	0.00	268.09	540.79	968.40	1,505.26	869.76	818.54
7/6/07 1:19	60.27	465,067.81	359.93	469,804.81	83.08	0.00	268.20	540.51	969.23	1,499.05	869.68	818.22
7/6/07 1:20	60.80	467,324.91	359.98	471,471.41	80.41	0.00	268.30	540.29	969.92	1,504.06	869.28	817.08
7/6/07 1:21	61.33	470,624.31	360.08	477,167.69	79.51	0.00	268.33	540.33	971.53	1,505.73	869.25	817.35
7/6/07 1:22	60.26	462,777.19	360.15	472,693.59	81.16	0.00	268.38	540.01	971.13	1,495.22	869.12	816.39
7/6/07 1:23	60.32	463,631.31	360.14	471,230.31	79.50	0.00	268.58	539.66	969.43	1,500.10	868.20	815.70
7/6/07 1:24	60.81	468,128.19	360.22	472,496.00	79.86	0.00	268.59	539.80	970.02	1,501.68	868.24	815.77
7/6/07 1:25	60.48	466,061.41	360.40	472,213.59	80.32	0.00	268.58	539.88	969.55	1,499.38	868.38	815.95
7/6/07 1:26	60.89	469,556.00	360.53	476,963.59	78.40	0.00	268.63	540.08	970.25	1,501.81	869.43	816.49
7/6/07 1:27	61.80	475,407.91	360.86	479,216.41	80.30	0.00	268.67	540.29	970.92	1,508.41	871.01	817.40
7/6/07 1:28	61.03	469,203.91	361.14	480,022.19	83.49	0.00	268.77	540.48	971.24	1,498.96	872.38	818.37
7/6/07 1:29	62.41	480,576.91	361.49	481,655.31	83.94	0.00	268.92	540.61	972.78	1,511.07	873.85	819.45
7/6/07 1:30	62.48	480,972.31	361.77	486,084.31	80.54	0.00	269.05	540.86	975.01	1,508.56	875.66	820.74
7/6/07 1:31	62.18	474,886.31	362.12	486,217.69	81.17	0.00	269.27	540.77	974.59	1,499.77	876.80	821.06
7/6/07 1:32	62.60	480,412.31	362.31	487,020.09	81.52	0.00	269.55	540.58	973.66	1,506.64	877.61	822.10
7/6/07 1:33	63.44	487,442.91	362.59	489,040.19	80.72	0.00	269.74	540.93	974.65	1,512.48	879.15	823.57
7/6/07 1:34	62.93	482,498.09	362.88	486,645.50	81.39	0.00	269.87	541.04	974.18	1,500.38	880.29	824.26
7/6/07 1:35	62.46	479,326.00	363.15	485,179.41	80.46	0.00	270.05	540.83	971.10	1,500.76	880.23	823.74
7/6/07 1:36	63.06	485,725.19	363.36	484,166.00	81.49	0.00	270.18	541.00	970.25	1,506.04	880.49	823.71
7/6/07 1:37	62.90	483,856.59	363.58	483,152.59	87.64	0.00	270.24	541.40	969.31	1,500.61	881.08	824.29
7/6/07 1:38	62.61	481,123.00	363.82	482,139.19	90.54	0.00	270.32	541.56	967.81	1,499.21	881.28	823.96
7/6/07 1:39	62.14	479,971.41	364.02	481,125.81	93.35	0.00	270.36	541.70	967.02	1,498.08	881.27	824.08
7/6/07 1:40	61.71	476,859.81	364.18	480,112.41	94.42	0.00	270.38	541.94	966.80	1,495.34	881.27	823.96
7/6/07 1:41	61.29	467,813.00	364.35	479,316.50	92.22	0.00	270.33	542.16	966.51	1,488.36	881.00	824.01
7/6/07 1:42	61.04	469,946.00	364.48	478,601.31	91.90	0.00	270.24	542.44	966.83	1,495.15	880.75	824.06
7/6/07 1:43	61.20	471,235.09	364.64	477,886.31	90.25	0.00	270.08	542.88	968.57	1,498.95	881.43	825.03
7/6/07 1:44	60.86	469,880.69	364.78	476,763.31	87.43	0.00	269.84	543.33	970.73	1,496.72	882.47	825.82
7/6/07 1:45	60.24	460,844.81	364.93	474,450.31	85.38	0.00	269.63	543.39	970.35	1,489.96	882.27	824.84
7/6/07 1:46	61.08	469,709.19	364.99	477,553.00	83.22	0.00	269.52	543.55	970.82	1,503.85	882.06	824.43
7/6/07 1:47	61.61	473,979.00	365.20	480,655.59	79.49	0.00	269.36	544.32	972.87	1,505.41	883.12	825.55
7/6/07 1:48	61.18	469,712.31	365.40	480,160.69	79.36	0.00	269.24	544.79	972.48	1,501.89	884.13	826.20
7/6/07 1:49	61.72	475,099.81	365.63	479,459.69	77.85	0.00	269.33	545.13	972.38	1,506.18	884.91	827.80

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/6/07 1:50	61.97	474,568.91	365.87	478,758.81	79.21	0.00	269.36	545.51	973.12	1,503.94	885.88	829.57
7/6/07 1:51	61.90	474,728.69	366.02	478,690.41	79.22	0.00	269.45	545.61	972.08	1,503.46	885.72	829.01
7/6/07 1:52	61.41	472,747.19	366.13	479,021.19	78.24	0.00	269.59	546.10	971.57	1,498.43	883.53	828.20
7/6/07 1:53	60.76	466,458.59	366.33	479,351.91	78.10	0.00	269.72	546.92	970.89	1,492.79	881.43	825.94
7/6/07 1:54	61.21	468,283.09	366.48	479,682.69	78.00	0.00	269.78	547.37	969.79	1,495.57	880.91	825.40
7/6/07 1:55	61.46	474,611.19	366.69	480,013.41	80.72	0.00	269.77	547.87	970.24	1,505.63	881.42	825.90
7/6/07 1:56	60.44	464,940.00	366.92	480,344.19	83.25	0.00	269.67	548.37	971.07	1,493.09	882.65	826.35
7/6/07 1:57	60.75	467,190.69	367.11	480,674.91	82.54	0.00	269.62	548.66	970.30	1,499.33	883.62	826.77
7/6/07 1:58	61.05	467,143.69	367.30	481,005.69	83.21	0.00	269.48	549.32	972.03	1,497.57	885.19	828.69
7/6/07 1:59	61.64	474,623.41	367.44	481,336.41	82.64	0.00	269.35	550.24	972.09	1,506.10	886.39	829.58
7/6/07 2:00	61.66	474,246.69	367.56	482,436.59	78.67	0.00	269.22	551.14	972.80	1,504.60	887.47	830.50
7/6/07 2:01	61.49	471,520.00	367.53	483,626.19	75.82	0.00	269.19	551.53	973.19	1,499.54	888.56	831.11
7/6/07 2:02	61.98	475,796.31	367.42	484,815.81	75.18	0.00	269.26	551.59	972.09	1,505.60	889.04	830.85
7/6/07 2:03	62.77	484,010.31	367.30	486,005.31	73.20	0.00	269.30	551.71	972.27	1,511.55	889.67	830.78
7/6/07 2:04	62.65	481,798.31	367.07	487,194.91	71.74	0.00	269.37	551.78	972.47	1,508.25	890.09	830.42
7/6/07 2:05	62.90	484,435.69	366.80	488,384.50	70.58	0.00	269.52	551.64	972.11	1,506.02	890.16	831.03
7/6/07 2:06	63.24	485,235.91	366.47	489,574.09	74.21	0.00	269.69	551.68	972.35	1,506.74	890.52	831.69
7/6/07 2:07	63.27	483,707.00	366.09	490,763.69	73.20	0.00	269.90	551.68	971.52	1,501.12	890.87	831.78
7/6/07 2:08	63.34	487,781.59	365.77	491,953.31	73.11	0.00	270.04	551.53	970.18	1,507.51	891.13	831.83
7/6/07 2:09	63.03	484,082.41	365.63	493,142.81	73.06	0.00	270.18	551.44	970.03	1,499.54	892.02	832.62
7/6/07 2:10	63.19	484,286.69	365.51	494,332.41	74.22	0.00	270.31	551.03	968.59	1,501.04	892.44	832.85
7/6/07 2:11	63.12	485,600.81	365.54	495,522.00	73.33	0.00	270.47	550.75	968.50	1,500.18	892.95	834.04
7/6/07 2:12	62.29	480,700.00	365.52	494,160.09	74.66	0.00	270.52	550.36	967.05	1,495.18	893.04	835.30
7/6/07 2:13	61.65	476,207.41	365.52	491,398.91	76.82	0.00	270.50	550.26	966.59	1,492.13	893.09	836.22
7/6/07 2:14	61.98	477,398.09	365.54	488,637.69	75.79	0.00	270.42	550.36	966.35	1,498.36	892.84	835.89
7/6/07 2:15	61.44	471,551.31	365.54	485,876.50	72.91	0.00	270.28	550.48	966.86	1,491.82	892.37	834.94
7/6/07 2:16	61.67	472,100.69	365.51	483,115.31	70.97	0.00	270.14	550.17	966.51	1,496.55	890.39	833.07
7/6/07 2:17	62.12	478,751.69	365.40	480,895.50	71.05	0.00	269.97	550.41	969.04	1,504.22	886.37	830.07
7/6/07 2:18	62.39	478,115.31	365.40	482,325.41	69.30	0.00	269.83	550.65	971.97	1,503.81	884.51	828.24
7/6/07 2:19	62.21	477,370.91	365.37	483,755.31	73.89	0.00	269.78	550.30	973.21	1,502.06	883.39	826.92
7/6/07 2:20	62.98	478,465.09	365.34	485,185.09	74.55	0.00	269.82	549.89	973.96	1,503.50	883.24	826.57
7/6/07 2:21	63.26	486,736.31	365.33	486,615.00	77.75	0.00	269.88	549.52	974.96	1,508.58	883.69	827.55
7/6/07 2:22	63.26	484,173.41	365.41	488,044.81	77.63	0.00	270.00	549.27	974.89	1,505.47	884.88	828.90
7/6/07 2:23	63.18	480,930.00	365.45	489,474.69	77.39	0.00	270.18	549.24	974.34	1,499.56	886.27	830.02
7/6/07 2:24	63.33	485,009.41	365.50	490,904.59	78.84	0.00	270.34	549.23	973.02	1,505.22	887.31	830.50
7/6/07 2:25	63.23	483,828.81	365.59	492,334.50	79.82	0.00	270.51	549.24	972.26	1,502.81	888.84	832.17
7/6/07 2:26	63.19	485,795.59	365.61	493,764.31	79.27	0.00	270.60	549.12	971.68	1,503.07	890.24	834.74
7/6/07 2:27	63.18	485,507.09	365.62	495,194.19	79.50	0.00	270.71	548.91	970.93	1,502.60	891.26	836.21
7/6/07 2:28	63.28	485,688.81	365.65	496,189.31	78.46	0.00	270.77	548.81	970.91	1,504.53	892.00	836.49
7/6/07 2:29	62.98	483,873.69	365.64	496,061.91	79.63	0.00	270.74	548.73	970.27	1,501.68	892.31	835.99
7/6/07 2:30	63.44	487,435.69	365.60	495,934.59	79.00	0.00	270.69	548.92	971.92	1,507.23	892.87	836.32
7/6/07 2:31	63.44	487,995.91	365.55	495,807.19	76.76	0.00	270.60	549.12	972.81	1,505.68	893.62	836.53
7/6/07 2:32	63.53	489,367.31	365.46	495,679.81	77.15	0.00	270.60	549.19	972.76	1,508.28	894.46	837.28
7/6/07 2:33	63.59	489,282.41	365.43	495,552.41	78.36	0.00	270.58	549.23	971.80	1,507.31	894.93	837.39
7/6/07 2:34	63.84	490,248.09	365.43	495,425.00	80.01	0.00	270.60	549.24	971.26	1,509.52	895.56	838.41
7/6/07 2:35	63.71	489,744.09	365.46	495,297.59	76.44	0.00	270.64	549.14	970.03	1,506.00	896.24	840.14
7/6/07 2:36	63.92	492,479.31	365.50	495,170.19	71.44	0.00	270.73	548.93	967.81	1,511.62	896.14	841.47
7/6/07 2:37	63.75	491,338.81	365.55	495,042.81	68.53	0.00	270.78	548.90	967.24	1,506.99	896.36	843.09
7/6/07 2:38	63.86	491,098.31	365.61	494,915.41	74.50	0.00	270.89	548.92	967.36	1,507.09	896.57	844.72
7/6/07 2:39	63.71	491,595.09	365.66	494,788.00	75.90	0.00	271.00	548.81	967.10	1,508.38	896.32	844.25

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FLOW (LB/HR)	PROPANE FUEL FLOW (TPH)	FWP DISCH FLOW (SCFH)	ECONOMIZER TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEG F)	SH OUTLET FLUE GAS TEMP (DEG F)
7/6/07 2:40	63.71	489,623.41	365.70	494,660.59	78.25	0.00	271.08	548.49	966.01	1,505.29	895.68	842.98
7/6/07 2:41	63.88	493,873.00	365.70	494,533.19	79.90	0.00	271.17	548.34	965.75	1,508.99	895.13	841.85
7/6/07 2:42	63.92	492,252.91	365.81	494,405.81	77.92	0.00	271.22	548.29	966.90	1,508.08	895.32	841.65
7/6/07 2:43	63.83	492,372.31	365.86	494,278.41	81.45	0.00	271.31	548.13	966.78	1,506.79	895.09	840.99
7/6/07 2:44	63.32	487,332.19	365.87	494,151.09	79.91	0.00	271.45	547.79	966.05	1,497.26	894.50	840.43
7/6/07 2:45	63.69	489,775.81	365.92	493,568.00	80.19	0.00	271.51	547.78	966.37	1,501.30	894.07	840.33
7/6/07 2:46	63.40	488,769.81	365.94	492,730.50	80.37	0.00	271.49	547.97	967.79	1,498.87	894.21	839.89
7/6/07 2:47	63.39	488,863.00	365.94	491,893.00	79.53	0.00	271.51	547.92	966.54	1,497.61	893.61	838.95
7/6/07 2:48	63.00	485,245.69	365.94	491,055.41	80.40	0.00	271.50	547.92	966.18	1,490.83	893.36	838.90
7/6/07 2:49	62.86	483,672.09	365.97	490,217.91	80.72	0.00	271.48	547.94	966.10	1,487.40	893.18	839.38
7/6/07 2:50	62.23	479,558.09	366.00	489,380.41	81.35	0.00	271.42	547.90	965.44	1,481.10	892.69	838.33
7/6/07 2:51	61.86	478,230.19	365.96	488,542.91	81.76	0.00	271.35	547.73	964.16	1,485.12	891.65	836.96
7/6/07 2:52	61.74	475,142.81	365.86	487,705.41	81.22	0.00	271.20	547.75	965.12	1,488.49	890.78	836.08
7/6/07 2:53	61.68	474,934.09	365.77	486,867.81	81.74	0.00	270.96	547.63	966.48	1,492.69	889.79	834.95
7/6/07 2:54	61.91	473,128.31	365.68	486,030.31	78.06	0.00	270.76	547.36	967.26	1,492.57	888.66	834.84
7/6/07 2:55	62.14	475,568.69	365.55	485,192.81	78.38	0.00	270.54	547.22	968.00	1,501.45	887.46	833.78
7/6/07 2:56	62.72	479,506.19	365.50	484,166.31	80.89	0.00	270.35	547.42	970.20	1,501.63	887.18	833.90
7/6/07 2:57	61.82	474,841.41	365.40	482,851.31	81.27	0.00	270.22	547.07	969.78	1,497.24	886.55	832.65
7/6/07 2:58	61.64	476,527.41	365.35	481,536.41	80.44	0.00	270.24	546.75	968.97	1,500.61	885.73	831.04
7/6/07 2:59	61.50	478,822.41	365.25	480,221.41	79.88	0.00	270.18	546.64	968.49	1,501.93	885.18	830.07
7/6/07 3:00	61.29	471,816.19	365.16	478,906.50	83.29	0.00	270.13	546.47	967.79	1,492.92	884.53	828.81
7/6/07 3:01	61.17	473,683.31	365.03	477,510.19	83.79	0.00	270.12	546.07	966.50	1,498.59	883.49	827.30
7/6/07 3:02	61.08	470,178.09	364.97	475,980.81	83.75	0.00	270.04	546.24	967.67	1,495.60	883.15	826.60
7/6/07 3:03	60.69	463,651.91	364.89	474,451.41	82.64	0.00	269.93	546.16	967.58	1,490.48	882.63	825.62
7/6/07 3:04	60.33	465,020.69	364.81	472,922.00	82.59	0.00	269.78	546.03	967.32	1,495.65	882.08	824.39
7/6/07 3:05	60.82	467,987.81	364.81	471,392.69	83.54	0.00	269.64	546.54	969.15	1,500.28	882.77	824.92
7/6/07 3:06	60.56	465,088.31	364.92	469,863.31	83.34	0.00	269.36	547.00	970.46	1,496.92	884.03	825.94
7/6/07 3:07	60.56	461,285.50	365.05	468,333.91	85.55	0.00	269.17	547.19	970.67	1,492.89	884.83	826.74
7/6/07 3:08	60.56	466,411.81	365.08	466,804.50	85.18	0.00	269.09	547.34	970.39	1,500.76	884.86	826.44
7/6/07 3:09	60.25	462,781.00	365.13	465,275.09	88.52	0.00	268.93	547.57	970.50	1,496.62	885.22	826.50
7/6/07 3:10	59.91	458,335.50	365.11	463,745.69	84.24	0.00	268.79	547.97	969.91	1,491.38	885.39	826.49
7/6/07 3:11	59.60	458,735.69	365.11	463,218.31	81.89	0.00	268.74	548.09	968.43	1,496.44	884.87	825.63
7/6/07 3:12	59.76	459,719.09	365.07	463,470.09	82.00	0.00	268.61	548.57	969.24	1,497.71	885.22	825.82
7/6/07 3:13	59.74	460,389.91	365.11	463,721.91	78.61	0.00	268.43	548.98	969.96	1,498.11	885.67	826.11
7/6/07 3:14	59.36	456,158.09	365.11	463,973.69	78.20	0.00	268.31	549.00	969.10	1,494.73	885.36	825.24
7/6/07 3:15	58.87	455,268.31	365.09	464,225.50	80.28	0.00	268.26	549.25	969.30	1,495.46	885.21	825.11
7/6/07 3:16	59.28	455,360.31	365.06	464,477.31	79.95	0.00	268.15	549.44	968.64	1,500.00	884.86	824.50
7/6/07 3:17	59.38	457,575.91	365.03	463,865.09	79.10	0.00	268.01	549.91	969.85	1,499.76	884.97	824.45
7/6/07 3:18	58.66	450,198.09	365.01	461,838.09	74.75	0.00	267.90	550.03	969.66	1,489.59	884.82	824.41
7/6/07 3:19	58.58	451,124.00	364.97	459,811.09	75.03	0.00	267.88	549.92	968.13	1,496.04	883.94	823.50
7/6/07 3:20	58.67	456,622.69	364.91	457,784.00	72.76	0.00	267.77	550.23	968.92	1,504.29	883.92	823.25
7/6/07 3:21	58.30	455,772.91	364.87	459,091.69	71.29	0.00	267.63	550.73	969.93	1,497.35	884.14	823.28
7/6/07 3:22	58.29	449,540.81	364.85	461,344.41	71.25	0.00	267.59	550.62	968.65	1,495.58	883.59	822.43
7/6/07 3:23	58.94	455,936.19	364.84	463,597.09	69.66	0.00	267.52	551.12	970.15	1,504.41	884.02	823.03
7/6/07 3:24	59.35	455,809.19	364.91	465,849.91	69.61	0.00	267.40	551.56	971.35	1,501.67	884.82	823.83
7/6/07 3:25	60.27	463,499.81	364.99	468,102.59	70.31	0.00	267.40	552.01	972.42	1,510.91	885.42	823.22
7/6/07 3:26	60.06	460,783.69	365.13	470,341.81	71.90	0.00	267.41	552.18	973.20	1,503.45	885.10	822.47
7/6/07 3:27	59.91	458,990.50	365.30	472,575.09	71.40	0.00	267.58	552.26	974.33	1,500.99	882.33	823.98
7/6/07 3:28	59.96	461,647.91	365.44	474,808.41	71.36	0.00	267.67	552.27	972.69	1,503.45	879.71	823.22
7/6/07 3:29	60.73	471,341.09	365.64	476,822.69	70.83	0.00	267.81	552.50	972.21	1,508.38	879.44	822.57

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/6/07 3:30	60.97	469,327.50	365.80	478,221.59	71.75	0.00	267.86	552.53	971.81	1,501.97	880.52	824.62
7/6/07 3:31	60.93	469,358.09	365.94	479,620.50	75.94	0.00	268.10	552.03	970.80	1,501.86	881.35	826.53
7/6/07 3:32	61.66	476,047.41	366.04	481,019.41	77.22	0.00	268.22	551.78	973.01	1,509.37	880.76	830.30
7/6/07 3:33	61.48	472,580.50	366.25	482,418.31	75.95	0.00	268.33	551.84	974.68	1,501.81	881.83	833.99
7/6/07 3:34	61.30	471,777.09	366.41	483,817.19	73.06	0.00	268.47	551.38	972.09	1,500.05	882.64	835.41
7/6/07 3:35	61.19	472,310.91	366.51	483,699.91	71.10	0.00	268.66	550.84	970.22	1,498.24	882.84	833.60
7/6/07 3:36	61.34	472,100.09	366.58	482,970.81	74.82	0.00	268.65	550.55	970.61	1,500.49	882.09	831.99
7/6/07 3:37	60.54	469,243.41	366.74	482,241.59	78.68	0.00	268.71	550.39	972.92	1,496.63	880.40	832.23
7/6/07 3:38	59.93	461,780.19	366.86	481,628.09	78.40	0.00	268.71	549.69	971.04	1,491.91	878.82	830.39
7/6/07 3:39	60.13	464,528.59	366.90	481,268.81	75.27	0.00	268.61	549.39	970.18	1,495.86	878.74	829.51
7/6/07 3:40	59.93	463,200.19	367.00	480,909.69	76.66	0.00	268.39	549.19	969.36	1,496.97	880.08	830.46
7/6/07 3:41	59.76	459,235.09	367.09	480,550.41	75.50	0.00	268.16	549.06	970.02	1,492.17	880.83	831.33
7/6/07 3:42	59.56	457,109.19	367.21	480,191.19	75.79	0.00	267.95	548.68	971.03	1,492.18	880.26	832.99
7/6/07 3:43	59.37	453,731.19	367.27	479,832.00	75.77	0.00	267.83	548.51	971.12	1,492.42	880.69	835.37
7/6/07 3:44	59.59	460,984.31	367.35	479,472.81	77.17	0.00	267.63	548.63	971.86	1,504.84	882.10	836.39
7/6/07 3:45	59.88	461,364.09	367.46	480,002.41	75.63	0.00	267.36	548.84	972.98	1,502.48	883.30	835.70
7/6/07 3:46	59.43	457,794.81	367.57	480,654.19	77.66	0.00	267.25	548.54	972.40	1,495.19	883.04	835.31
7/6/07 3:47	59.89	462,005.81	367.67	481,305.91	77.05	0.00	267.27	548.30	972.54	1,503.00	881.86	835.15
7/6/07 3:48	60.12	461,599.00	367.79	481,957.69	77.58	0.00	267.32	548.39	973.49	1,501.55	881.77	833.95
7/6/07 3:49	60.47	460,192.50	367.87	482,609.50	80.28	0.00	267.36	548.38	973.22	1,498.41	882.58	833.63
7/6/07 3:50	60.64	463,270.31	367.91	483,261.19	83.49	0.00	267.44	548.16	970.52	1,503.52	882.98	833.39
7/6/07 3:51	59.96	462,213.81	367.98	483,167.50	81.28	0.00	267.52	548.31	970.73	1,498.25	883.55	834.29
7/6/07 3:52	59.77	460,404.50	368.04	481,935.91	82.26	0.00	267.61	548.20	969.73	1,497.49	883.10	834.19
7/6/07 3:53	59.70	461,161.59	368.11	480,704.31	80.23	0.00	267.67	548.16	969.34	1,499.49	883.47	833.77
7/6/07 3:54	59.31	458,254.50	368.13	479,472.69	81.40	0.00	267.68	548.14	969.59	1,493.21	883.91	833.41
7/6/07 3:55	59.08	456,291.09	368.14	478,241.09	80.11	0.00	267.63	548.07	968.56	1,494.10	883.02	833.06
7/6/07 3:56	59.41	459,144.09	368.20	477,009.50	79.65	0.00	267.52	548.25	968.13	1,500.73	881.82	833.45
7/6/07 3:57	58.45	451,386.91	368.25	475,777.91	79.38	0.00	267.34	548.40	967.73	1,490.35	880.47	833.20
7/6/07 3:58	58.78	453,611.09	368.29	474,546.31	79.23	0.00	267.27	548.43	967.65	1,495.21	879.80	832.66
7/6/07 3:59	58.40	450,776.09	368.29	473,314.69	65.75	0.00	267.14	548.55	967.83	1,492.53	879.75	832.82
7/6/07 4:00	59.27	457,314.31	368.30	472,083.09	71.32	0.00	267.00	548.81	967.52	1,502.90	879.58	831.96

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/4/07 14:00	848.58	344,679.41	254,343.59	72,370.91	2.52	33.56	8.60	273.98	0.00	56.00	31.15	8,337.73
7/4/07 14:01	848.61	344,555.31	255,638.41	72,436.90	3.14	33.69	8.50	274.34	0.00	59.30	31.30	6,206.45
7/4/07 14:02	849.05	340,786.59	253,874.91	71,897.48	3.59	33.73	8.40	274.62	0.00	58.60	31.70	5,559.05
7/4/07 14:03	849.33	358,741.91	258,247.41	72,356.36	3.36	33.75	8.19	274.62	0.00	58.70	32.00	5,724.52
7/4/07 14:04	849.35	366,835.81	258,583.80	71,831.88	3.43	32.50	8.16	275.32	0.00	65.00	34.85	6,095.61
7/4/07 14:05	849.67	354,540.91	255,209.09	71,904.16	3.43	32.00	8.12	275.70	0.00	65.00	35.38	8,291.20
7/4/07 14:06	849.81	367,032.81	252,268.41	72,577.79	3.43	32.69	8.08	275.70	0.00	64.70	35.20	8,414.27
7/4/07 14:07	850.47	364,433.81	250,326.59	72,267.28	3.43	32.75	8.04	275.36	0.00	64.90	35.20	7,318.65
7/4/07 14:08	851.20	356,573.09	249,685.50	72,630.64	4.48	33.00	8.00	275.70	0.00	64.30	34.15	6,750.76
7/4/07 14:09	851.53	352,537.41	251,095.00	72,201.34	3.71	33.75	7.96	275.70	0.00	63.00	33.80	6,841.02
7/4/07 14:10	851.77	360,057.09	251,289.91	71,840.61	3.62	33.75	7.92	275.03	0.00	62.10	32.80	7,266.26
7/4/07 14:11	852.46	362,228.09	253,776.59	73,870.94	3.68	34.00	7.88	274.62	0.00	60.70	33.15	5,848.04
7/4/07 14:12	852.24	349,925.50	251,229.50	73,181.59	5.70	34.19	7.84	273.98	0.00	59.80	32.40	5,669.35
7/4/07 14:13	851.64	351,122.59	251,790.50	71,799.22	3.66	34.25	7.81	273.67	0.00	58.80	31.20	5,625.97
7/4/07 14:14	851.83	356,347.09	254,446.91	72,766.88	2.10	33.94	7.50	272.72	0.00	58.40	31.75	0.00
7/4/07 14:15	852.24	360,855.31	256,111.09	72,446.92	5.91	34.25	7.18	272.31	0.00	58.00	31.85	0.00
7/4/07 14:16	852.93	353,812.19	254,803.20	71,784.85	6.11	34.81	6.85	272.03	0.00	58.70	30.90	0.00
7/4/07 14:17	853.69	370,187.91	253,856.20	71,442.00	3.97	34.75	6.44	272.31	0.00	58.50	31.80	4,497.96
7/4/07 14:18	852.23	364,270.41	257,737.50	71,692.04	7.19	34.56	6.38	272.31	0.00	58.40	31.30	5,402.11
7/4/07 14:19	852.69	369,633.09	252,189.30	71,502.79	5.50	34.56	6.31	272.98	0.00	58.90	31.40	5,816.15
7/4/07 14:20	853.80	380,961.19	250,944.91	71,145.41	4.95	34.75	6.25	273.36	0.00	58.20	31.95	6,395.26
7/4/07 14:21	854.26	358,902.81	251,544.91	71,729.62	6.95	34.75	6.18	273.67	0.00	58.40	31.50	8,323.62
7/4/07 14:22	854.25	366,511.41	251,989.00	72,075.68	4.70	35.00	6.11	273.65	0.00	58.60	31.35	9,142.55
7/4/07 14:23	854.06	344,065.59	248,282.80	71,264.29	5.45	34.50	6.05	273.38	0.00	58.40	30.95	8,198.10
7/4/07 14:24	853.80	363,422.81	254,177.70	72,437.66	7.01	34.69	5.98	274.31	0.00	64.70	34.45	8,484.93
7/4/07 14:25	853.68	349,179.59	250,089.59	71,263.64	7.01	34.75	5.92	275.01	0.00	65.00	34.65	5,959.39
7/4/07 14:26	853.53	349,245.09	252,186.59	71,623.80	7.01	34.94	5.85	275.34	0.00	65.30	34.70	6,137.78
7/4/07 14:27	853.27	355,971.81	254,294.09	71,326.16	7.01	34.56	5.79	275.01	0.00	65.10	34.85	4,897.98
7/4/07 14:28	853.69	355,196.41	252,835.00	71,508.81	3.14	34.50	5.72	275.01	0.00	64.00	34.35	5,418.01
7/4/07 14:29	854.31	358,413.41	253,923.00	72,358.38	2.98	34.50	5.65	275.34	0.00	63.00	34.00	5,668.73
7/4/07 14:30	854.68	374,451.50	255,324.80	72,417.36	4.57	34.75	5.59	275.01	0.00	61.90	33.05	7,379.66
7/4/07 14:31	855.24	368,351.50	255,930.59	71,646.28	6.50	34.69	5.52	275.01	0.00	61.10	32.80	8,579.08
7/4/07 14:32	855.78	354,721.59	253,512.09	71,773.49	4.92	34.75	5.46	275.34	0.00	59.70	31.90	8,595.05
7/4/07 14:33	855.92	373,980.69	254,524.59	71,814.80	4.27	34.75	5.39	274.62	0.00	59.10	31.05	0.00
7/4/07 14:34	855.75	359,882.19	253,473.50	71,810.60	7.01	34.00	5.33	274.31	0.00	58.70	31.15	0.00
7/4/07 14:35	855.63	367,889.50	254,925.59	71,263.89	5.22	34.19	5.26	273.98	0.00	58.90	31.20	5,650.74
7/4/07 14:36	854.67	348,784.59	252,255.91	70,267.41	6.14	34.00	5.19	273.67	0.00	59.00	31.05	0.00
7/4/07 14:37	854.73	363,859.59	256,167.70	71,379.92	3.47	33.75	5.13	274.31	0.00	58.50	31.00	9,778.21
7/4/07 14:38	855.15	361,217.09	254,031.91	70,974.16	5.90	33.75	5.06	275.01	0.00	58.10	31.95	0.00
7/4/07 14:39	855.52	359,270.50	255,960.91	71,126.66	4.92	33.94	5.00	275.01	0.00	58.40	31.80	0.00
7/4/07 14:40	855.19	360,240.59	253,474.00	70,680.56	6.48	33.81	4.93	275.01	0.00	58.40	30.90	0.00
7/4/07 14:41	855.71	357,173.31	253,529.20	71,142.30	4.90	33.94	4.86	275.34	0.00	58.60	31.90	0.00
7/4/07 14:42	856.73	358,575.41	253,534.00	71,084.87	5.04	34.00	4.80	276.01	0.00	58.40	31.50	3,239.08
7/4/07 14:43	857.57	358,028.41	251,240.91	70,906.91	5.38	33.73	4.73	275.98	0.00	58.70	31.05	0.00
7/4/07 14:44	857.12	344,971.31	256,592.59	72,160.78	7.33	33.79	4.67	276.34	0.00	65.20	34.35	5,584.04
7/4/07 14:45	856.50	357,373.50	260,357.41	71,664.24	7.33	34.15	4.60	276.34	0.00	65.10	34.80	0.00
7/4/07 14:46	856.66	358,713.69	256,383.91	70,688.84	7.33	33.14	4.68	276.34	0.00	64.80	34.50	5,989.79
7/4/07 14:47	855.60	343,794.50	256,640.80	71,504.80	7.33	33.45	4.78	276.32	0.00	65.00	34.60	0.00
7/4/07 14:48	855.23	362,155.59	257,078.30	70,959.52	5.23	33.75	4.88	276.34	0.00	64.40	34.90	8,546.55
7/4/07 14:49	854.10	348,095.81	254,575.91	70,568.75	6.71	32.94	4.98	276.01	0.00	63.50	33.65	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/4/07 14:50	854.03	345,835.69	254,744.80	70,969.38	5.06	33.19	5.09	276.01	0.00	62.20	33.40	3,476.07
7/4/07 14:51	853.21	345,529.50	252,659.20	70,409.15	6.67	32.81	5.19	275.82	0.00	60.90	33.10	0.00
7/4/07 14:52	853.47	344,165.19	251,527.91	70,446.65	3.88	32.81	5.29	276.01	0.00	59.90	31.75	0.00
7/4/07 14:53	853.30	342,162.31	253,159.41	70,788.78	4.49	32.00	5.39	276.34	0.00	58.90	31.95	1,191.63
7/4/07 14:54	853.16	343,929.81	252,424.00	70,610.48	3.12	31.50	5.49	276.65	0.00	58.20	31.95	0.00
7/4/07 14:55	852.77	338,330.41	251,096.41	70,063.84	4.83	31.88	5.59	276.67	0.00	58.20	31.95	5,540.76
7/4/07 14:56	852.19	344,519.00	252,728.80	70,947.08	4.01	31.97	5.69	276.67	0.00	58.10	31.05	0.00
7/4/07 14:57	852.57	356,341.91	256,322.80	71,763.38	5.13	32.00	5.79	276.34	0.00	58.70	31.20	6,371.88
7/4/07 14:58	851.96	347,608.69	250,968.59	70,273.70	7.14	32.00	5.89	276.34	0.00	58.40	31.75	0.00
7/4/07 14:59	852.18	343,348.81	251,802.00	70,824.98	5.02	31.38	5.99	275.70	0.00	58.50	31.50	8,168.31
7/4/07 15:00	852.02	369,998.41	256,699.59	70,968.44	5.63	31.07	6.09	275.70	0.00	58.10	31.20	0.00
7/4/07 15:01	852.31	349,300.41	250,562.30	70,017.52	8.31	31.00	6.19	275.98	0.00	58.70	31.95	923.04
7/4/07 15:02	851.25	339,733.81	249,939.50	70,795.09	5.85	30.91	6.29	275.34	0.00	58.80	31.30	0.00
7/4/07 15:03	851.15	350,983.81	250,506.50	71,468.84	3.80	29.78	6.39	275.34	0.00	59.00	31.30	0.00
7/4/07 15:04	851.57	339,364.91	249,252.20	71,214.01	6.17	29.80	6.49	275.34	0.00	65.00	34.90	4,157.11
7/4/07 15:05	851.48	337,471.81	247,916.50	70,929.11	6.17	30.13	6.59	275.34	0.00	65.10	34.70	0.00
7/4/07 15:06	851.02	333,795.59	247,400.50	70,324.77	6.17	29.97	6.69	275.32	0.00	65.20	34.70	5,399.92
7/4/07 15:07	851.14	347,463.09	249,826.41	70,600.81	6.17	28.84	6.79	275.70	0.00	65.00	34.80	0.00
7/4/07 15:08	852.21	336,818.69	247,389.50	70,770.02	4.90	29.06	6.90	275.98	0.00	64.50	35.05	6,087.05
7/4/07 15:09	852.21	353,218.00	248,223.80	71,798.42	5.10	28.63	7.01	276.32	0.00	63.30	34.15	0.00
7/4/07 15:10	852.03	338,086.59	248,289.00	70,562.62	5.12	29.14	7.13	276.65	0.00	62.30	34.05	8,735.53
7/4/07 15:11	851.78	350,388.19	248,245.91	70,554.91	3.94	29.13	7.22	276.65	0.00	61.10	33.45	0.00
7/4/07 15:12	852.19	336,472.31	246,525.00	70,917.30	5.50	28.22	7.39	276.34	0.00	60.00	32.30	8,908.47
7/4/07 15:13	850.93	346,462.59	248,598.00	70,907.90	5.34	27.75	7.56	276.34	0.00	58.50	31.35	0.00
7/4/07 15:14	850.17	337,992.50	246,554.00	70,320.81	4.81	27.88	7.73	276.34	0.00	58.40	31.15	5,470.75
7/4/07 15:15	850.16	358,202.09	251,289.00	71,621.45	3.21	27.75	7.90	276.34	0.00	58.30	31.67	0.00
7/4/07 15:16	850.48	358,171.50	250,950.80	71,070.00	6.87	28.00	8.07	276.34	0.00	58.40	32.03	0.00
7/4/07 15:17	849.68	333,752.91	247,234.30	69,837.84	6.93	27.72	8.17	275.98	0.00	58.00	31.20	5,272.33
7/4/07 15:18	849.07	345,395.59	248,398.59	71,169.68	3.99	27.25	8.26	275.32	0.00	58.50	31.00	0.00
7/4/07 15:19	849.18	339,498.41	247,600.59	69,762.20	4.20	26.63	8.36	275.70	0.00	58.30	31.70	6,834.83
7/4/07 15:20	847.88	336,351.81	246,963.00	70,423.65	5.23	26.72	8.37	275.70	0.00	58.30	31.70	0.00
7/4/07 15:21	847.32	329,398.19	247,337.00	69,769.22	4.82	26.50	8.47	275.70	0.00	58.70	31.10	8,576.06
7/4/07 15:22	846.61	348,925.50	251,183.30	71,669.27	2.60	26.41	8.57	275.70	0.00	58.70	31.90	0.00
7/4/07 15:23	846.48	336,651.00	249,666.91	70,431.27	6.09	26.25	8.67	275.70	0.00	58.50	31.45	8,942.30
7/4/07 15:24	845.66	344,159.81	251,646.41	70,753.36	5.31	26.17	8.77	275.34	0.00	64.60	34.55	0.00
7/4/07 15:25	845.73	354,120.00	253,309.30	71,413.63	5.31	25.84	8.87	275.34	0.00	64.70	34.75	0.00
7/4/07 15:26	846.40	347,418.59	249,353.59	70,220.22	5.31	25.69	8.97	275.70	0.00	64.50	35.35	1,981.89
7/4/07 15:27	846.47	338,116.69	254,731.80	71,792.09	5.31	25.53	9.07	275.70	0.00	64.90	35.40	0.00
7/4/07 15:28	846.01	336,172.19	247,417.09	69,181.17	8.30	25.16	9.17	275.70	0.00	64.30	34.00	5,748.62
7/4/07 15:29	846.49	347,164.31	249,286.30	70,819.96	3.56	24.78	9.28	276.65	0.00	62.90	34.05	0.00
7/4/07 15:30	847.72	343,495.50	250,843.09	70,483.20	5.31	24.14	9.38	277.01	0.00	61.00	33.25	7,101.76
7/4/07 15:31	847.69	338,835.91	248,923.80	70,796.27	6.12	25.89	9.48	277.01	0.00	59.90	31.70	0.00
7/4/07 15:32	847.65	354,883.19	248,638.20	70,697.93	5.35	25.13	9.58	277.01	0.00	58.50	31.55	8,606.49
7/4/07 15:33	848.84	343,351.59	248,899.41	71,277.64	3.57	25.00	9.68	276.63	0.00	58.80	31.85	0.00
7/4/07 15:34	849.51	338,322.81	249,408.50	71,805.18	4.54	25.05	9.78	276.34	0.00	58.60	31.15	777.91
7/4/07 15:35	849.20	328,987.19	246,527.00	70,937.73	5.01	25.00	9.88	276.34	0.00	58.40	31.60	0.00
7/4/07 15:36	849.44	345,783.91	249,889.20	71,582.27	2.55	25.01	9.98	275.98	0.00	58.60	31.60	0.00
7/4/07 15:37	850.00	352,006.81	247,933.91	70,665.85	4.80	24.75	10.09	275.98	0.00	58.30	31.20	1,859.45
7/4/07 15:38	850.33	355,433.00	249,691.41	70,917.95	5.43	24.90	10.17	275.98	0.00	58.10	31.95	0.00
7/4/07 15:39	849.89	339,130.81	247,669.09	70,764.72	7.67	25.63	10.19	275.70	0.00	58.40	31.10	6,167.57

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 15:40	850.01	348,100.81	246,014.00	70,787.70	3.43	25.23	10.20	275.34	0.00	58.30	31.25	0.00
7/4/07 15:41	850.78	328,106.91	245,126.41	70,485.68	5.03	25.00	10.08	274.62	0.00	58.30	32.00	8,054.67
7/4/07 15:42	851.24	334,982.19	248,337.91	70,783.33	3.00	25.59	9.94	274.65	0.00	58.30	31.60	0.00
7/4/07 15:43	851.91	347,055.00	248,457.91	70,022.06	5.20	26.00	9.80	274.62	0.00	58.40	31.30	6,703.42
7/4/07 15:44	852.30	349,441.59	252,459.30	72,118.71	4.73	25.94	9.65	274.62	0.00	65.00	34.50	0.00
7/4/07 15:45	853.03	362,348.41	250,011.41	70,747.38	4.73	25.75	9.62	274.65	0.00	64.80	34.85	6,490.85
7/4/07 15:46	853.66	348,371.59	251,694.50	71,491.01	4.73	25.88	9.58	275.01	0.00	65.20	35.25	0.00
7/4/07 15:47	853.73	337,074.41	248,414.09	71,537.92	4.73	25.78	9.55	275.34	0.00	65.20	35.45	0.00
7/4/07 15:48	853.71	325,944.19	247,585.20	70,621.72	4.17	26.13	9.52	275.01	0.00	64.10	34.55	4,248.27
7/4/07 15:49	853.81	348,368.31	249,902.91	70,016.33	3.39	26.00	9.48	275.01	0.00	62.80	33.35	0.00
7/4/07 15:50	854.34	343,430.41	248,916.30	70,916.81	5.46	25.88	9.45	275.01	0.00	61.70	33.45	7,550.14
7/4/07 15:51	854.89	349,178.31	251,738.50	71,353.34	3.93	26.00	9.42	275.98	0.00	60.50	33.15	0.00
7/4/07 15:52	855.35	328,533.81	247,110.50	70,362.19	6.10	26.83	9.38	275.32	0.00	59.30	32.35	8,859.03
7/4/07 15:53	855.24	338,391.81	248,990.70	70,832.18	2.74	26.88	9.35	275.67	0.00	58.40	31.75	0.00
7/4/07 15:54	856.03	347,617.19	251,615.91	71,264.15	3.82	27.09	9.31	275.67	0.00	58.50	31.55	8,399.46
7/4/07 15:55	856.89	340,814.09	249,938.09	70,699.02	5.00	26.78	9.28	275.32	0.00	58.70	31.30	0.00
7/4/07 15:56	857.84	345,700.81	251,766.80	70,780.16	5.18	27.77	9.25	275.70	0.00	58.70	31.65	0.00
7/4/07 15:57	859.17	355,901.81	249,846.41	71,063.04	5.33	27.89	9.21	275.70	0.00	58.80	31.05	3,163.32
7/4/07 15:58	860.07	351,541.09	252,865.91	71,786.42	5.87	28.09	9.18	275.70	0.00	58.30	31.95	0.00
7/4/07 15:59	861.30	334,495.31	247,843.50	70,459.83	5.71	28.00	9.15	275.70	0.00	58.10	31.60	5,878.79
7/4/07 16:00	861.83	350,481.00	250,800.59	71,227.39	4.08	28.63	9.15	275.70	0.00	58.50	31.20	0.00
7/4/07 16:01	862.00	345,265.59	249,730.50	70,556.16	6.57	29.13	9.09	275.34	0.00	58.70	31.95	6,192.87
7/4/07 16:02	862.47	346,263.00	251,340.50	71,433.34	4.34	29.02	9.02	275.34	0.00	58.80	31.40	0.00
7/4/07 16:03	863.31	336,451.19	250,284.20	70,347.48	4.60	28.75	8.96	275.36	0.00	58.70	31.15	9,788.79
7/4/07 16:04	863.92	333,414.00	248,454.30	70,358.84	3.21	29.05	8.89	275.34	0.00	64.90	34.40	0.00
7/4/07 16:05	864.36	338,723.91	251,056.80	70,675.64	3.21	29.75	8.83	275.34	0.00	65.50	35.45	0.00
7/4/07 16:06	864.93	344,635.81	251,239.20	71,058.23	3.21	30.22	8.76	275.70	0.00	65.00	35.20	3,903.18
7/4/07 16:07	865.23	343,958.50	250,373.70	70,786.25	3.21	30.76	8.70	275.70	0.00	64.60	35.15	0.00
7/4/07 16:08	865.89	337,311.19	251,171.30	71,442.13	4.22	30.00	8.63	275.34	0.00	64.50	34.25	6,422.61
7/4/07 16:09	865.37	355,564.81	251,253.80	70,681.61	5.94	31.03	8.57	274.62	0.00	63.30	34.05	0.00
7/4/07 16:10	865.97	346,366.41	250,370.59	70,568.27	5.38	30.50	8.50	274.62	0.00	62.10	33.50	8,493.19
7/4/07 16:11	866.43	353,629.69	251,295.30	71,939.56	3.15	30.63	8.44	275.34	0.00	60.90	33.15	0.00
7/4/07 16:12	866.60	342,868.69	248,337.59	70,361.44	6.80	31.13	8.32	275.34	0.00	59.50	32.50	9,143.35
7/4/07 16:13	866.48	349,686.50	251,353.59	70,926.41	4.38	30.38	8.34	275.01	0.00	58.50	31.85	0.00
7/4/07 16:14	866.73	348,027.81	249,725.30	71,320.04	4.42	30.53	8.37	275.34	0.00	58.60	31.30	5,741.26
7/4/07 16:15	866.12	340,701.09	249,859.41	70,708.75	6.08	30.38	8.39	275.34	0.00	58.40	31.05	1,441.01
7/4/07 16:16	865.05	366,123.19	251,951.80	71,294.17	3.79	30.38	8.41	275.70	0.00	58.30	31.95	0.00
7/4/07 16:17	865.06	338,537.50	250,421.70	70,888.80	4.65	30.63	8.43	275.70	0.00	58.60	31.50	0.00
7/4/07 16:18	864.61	338,211.19	250,957.20	70,619.62	3.55	30.68	8.45	275.70	0.00	58.80	31.15	0.00
7/4/07 16:19	864.06	334,018.50	249,086.30	70,128.40	4.03	30.29	8.53	275.01	0.00	58.70	49.75	0.00
7/4/07 16:20	863.65	336,863.69	252,418.80	70,735.20	2.16	30.25	8.51	274.62	0.00	58.60	50.75	0.00
7/4/07 16:21	864.14	356,091.91	253,028.59	71,386.67	3.11	30.09	8.48	274.62	0.00	58.50	49.15	0.00
7/4/07 16:22	864.05	351,978.31	256,927.91	71,633.75	6.43	29.91	8.46	275.01	0.00	58.40	0.00	0.00
7/4/07 16:23	863.74	340,592.00	252,844.20	71,436.22	5.24	30.13	8.44	274.62	0.00	58.50	0.00	0.00
7/4/07 16:24	863.71	361,052.00	256,528.50	71,419.66	4.47	30.13	8.42	274.98	0.00	65.20	0.00	0.00
7/4/07 16:25	864.41	355,256.91	252,630.70	70,932.23	4.47	29.81	8.39	275.70	0.00	65.00	0.00	0.00
7/4/07 16:26	864.57	345,569.41	254,559.59	70,471.72	4.47	31.59	8.37	275.34	0.00	65.00	0.00	0.00
7/4/07 16:27	864.10	351,387.50	254,747.30	70,931.16	4.47	30.99	8.35	274.98	0.00	65.20	0.00	0.00
7/4/07 16:28	864.70	348,215.50	255,246.59	70,597.01	3.63	30.63	8.32	274.65	0.00	64.70	0.00	9,478.57
7/4/07 16:29	863.10	325,955.59	255,396.70	70,451.83	5.19	29.72	8.30	275.01	0.00	64.70	0.00	7,505.18

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/4/07 16:30	862.58	352,861.81	252,679.80	70,866.78	4.17	29.63	8.28	275.01	0.00	64.40	0.00	6,471.89
7/4/07 16:31	862.66	354,007.41	255,059.30	70,389.13	3.09	29.84	8.26	276.01	0.00	64.10	0.00	5,796.00
7/4/07 16:32	864.19	344,665.69	255,829.00	70,941.13	3.67	30.25	8.23	275.98	0.00	63.50	0.00	6,236.05
7/4/07 16:33	865.36	338,848.50	260,587.91	71,952.70	5.06	30.63	8.21	277.03	0.00	62.60	0.00	7,053.81
7/4/07 16:34	865.58	341,995.41	255,074.09	70,680.73	6.07	30.88	8.19	277.03	0.00	62.60	0.00	7,959.23
7/4/07 16:35	865.74	358,602.41	258,453.91	70,709.45	4.84	30.88	8.16	276.36	0.00	63.10	0.00	8,455.19
7/4/07 16:36	867.04	359,382.31	256,301.20	71,169.32	5.70	31.09	8.14	275.98	0.00	63.00	33.65	6,461.66
7/4/07 16:37	868.40	352,532.69	255,650.91	70,533.64	6.34	30.88	8.12	275.70	0.00	63.00	33.40	6,788.06
7/4/07 16:38	868.41	356,534.69	255,474.80	70,937.16	7.29	30.75	8.10	275.70	0.00	62.60	33.60	8,129.43
7/4/07 16:39	869.14	358,334.59	257,977.09	71,497.96	5.62	31.00	8.07	275.34	0.00	61.90	33.25	6,097.33
7/4/07 16:40	870.20	342,828.69	254,185.20	70,152.11	5.80	30.88	8.05	275.70	0.00	61.40	32.80	6,034.92
7/4/07 16:41	870.25	341,611.81	255,170.20	70,627.93	4.45	31.84	8.03	275.34	0.00	60.80	33.25	5,676.98
7/4/07 16:42	870.09	348,770.31	256,506.59	70,553.43	4.20	31.97	8.01	275.01	0.00	59.90	32.65	5,898.14
7/4/07 16:43	871.38	341,556.59	252,816.30	69,872.86	3.96	31.63	7.98	274.65	0.00	58.30	31.90	6,194.47
7/4/07 16:44	872.23	339,612.81	255,965.41	71,420.63	6.04	31.95	7.96	274.31	0.00	64.30	35.25	0.00
7/4/07 16:45	872.26	337,516.31	253,128.80	70,152.95	6.04	32.00	7.94	273.65	0.00	64.90	35.20	0.00
7/4/07 16:46	872.60	353,056.81	255,668.80	70,930.80	6.04	31.25	7.86	273.00	0.00	65.10	35.00	0.00
7/4/07 16:47	874.16	351,820.91	252,697.41	70,533.05	6.04	31.00	7.74	273.38	0.00	64.80	34.55	0.00
7/4/07 16:48	875.12	351,006.59	255,631.09	71,029.69	5.69	31.89	7.62	273.67	0.00	64.80	34.90	0.00
7/4/07 16:49	875.22	351,616.81	253,890.30	70,674.19	7.21	31.97	7.50	273.98	0.00	63.80	34.45	0.00
7/4/07 16:50	875.56	351,389.19	253,982.09	71,546.23	4.73	31.63	7.38	274.31	0.00	63.20	33.75	0.00
7/4/07 16:51	876.20	351,594.59	251,631.70	71,270.49	5.23	31.97	7.26	274.31	0.00	61.80	33.10	0.00
7/4/07 16:52	875.70	348,165.50	251,211.91	70,817.73	7.83	32.25	7.14	274.62	0.00	61.20	35.95	0.00
7/4/07 16:53	874.94	342,801.50	250,055.09	70,124.71	6.23	32.81	7.02	274.62	0.00	60.30	35.05	0.00
7/4/07 16:54	875.43	347,389.50	250,771.30	71,341.41	4.13	32.25	6.90	275.01	0.00	59.40	34.35	0.00
7/4/07 16:55	875.80	340,644.81	251,193.80	70,842.73	5.74	32.25	6.79	275.01	0.00	58.50	34.30	0.00
7/4/07 16:56	875.18	330,983.91	247,377.50	70,685.06	5.02	32.00	6.67	275.01	0.00	58.30	34.40	0.00
7/4/07 16:57	874.09	349,460.50	251,917.70	72,139.44	2.66	32.19	6.55	275.34	0.00	58.70	34.35	0.00
7/4/07 16:58	873.95	362,493.09	248,520.59	70,799.84	6.54	32.19	6.48	275.34	0.00	58.50	33.70	0.00
7/4/07 16:59	874.20	344,715.09	249,883.91	71,519.55	4.22	32.69	6.56	275.34	0.00	58.10	33.85	0.00
7/4/07 17:00	873.98	335,534.91	247,933.00	71,243.31	5.36	31.69	6.70	276.01	0.00	58.90	33.90	0.00
7/4/07 17:01	873.04	352,640.69	251,381.59	71,431.91	5.76	31.91	6.84	275.98	0.00	58.30	34.60	0.00
7/4/07 17:02	872.64	341,146.31	248,667.41	71,107.03	4.88	31.28	6.97	276.34	0.00	58.40	34.65	13,854.42
7/4/07 17:03	872.87	345,673.00	246,513.70	70,402.52	5.39	31.75	7.11	276.65	0.00	58.40	34.45	13,633.75
7/4/07 17:04	872.51	354,207.00	252,224.30	71,772.88	6.42	31.75	7.25	276.34	0.00	64.90	37.65	13,499.04
7/4/07 17:05	873.59	350,375.91	249,506.80	71,019.34	6.42	30.13	7.39	276.34	0.00	65.10	37.85	13,691.40
7/4/07 17:06	875.51	340,681.19	251,354.80	71,624.19	6.42	31.13	7.57	276.34	0.00	65.00	38.10	4,097.30
7/4/07 17:07	873.94	339,226.91	248,547.80	70,621.15	6.42	31.75	7.77	276.65	0.00	65.10	37.70	11,311.08
7/4/07 17:08	868.39	343,147.91	250,572.50	70,477.22	3.50	31.09	7.97	276.65	0.00	64.40	37.50	12,040.08
7/4/07 17:09	864.14	332,664.00	251,026.30	70,543.08	3.67	30.00	8.10	276.65	0.00	62.80	36.40	12,101.56
7/4/07 17:10	860.23	346,570.91	251,642.70	70,186.29	2.86	30.75	8.31	276.63	0.00	61.10	35.20	12,032.95
7/4/07 17:11	855.19	336,205.81	252,042.09	70,593.70	4.03	29.88	8.51	276.65	0.00	59.40	35.00	4,857.63
7/4/07 17:12	854.04	349,354.50	256,067.70	72,030.33	2.18	29.97	8.71	276.65	0.00	58.50	34.00	11,008.20
7/4/07 17:13	856.00	350,342.50	254,025.70	70,495.36	5.67	30.19	8.92	276.65	0.00	58.20	34.60	10,634.84
7/4/07 17:14	858.40	348,622.19	255,753.00	71,128.23	4.02	29.75	9.12	276.65	0.00	57.90	34.65	10,620.46
7/4/07 17:15	859.99	351,054.50	256,664.50	70,540.06	7.03	30.00	9.33	276.34	0.00	58.40	34.25	10,610.04
7/4/07 17:16	862.73	357,288.81	255,037.50	70,683.73	4.77	29.38	9.53	276.32	0.00	58.70	33.80	4,292.50
7/4/07 17:17	862.53	371,142.09	260,803.30	71,997.27	4.04	28.97	9.73	276.34	0.00	58.50	33.95	9,148.20
7/4/07 17:18	859.18	340,355.00	253,689.80	70,181.96	7.85	29.75	9.94	276.34	0.00	58.60	34.00	8,965.75
7/4/07 17:19	856.21	360,053.09	260,233.41	70,703.38	3.85	29.63	10.14	276.34	0.00	58.40	34.55	8,990.67

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/4/07 17:20	854.12	345,169.31	254,277.30	70,907.07	5.20	29.25	10.34	276.34	0.00	58.80	34.65	9,171.27
7/4/07 17:21	851.61	348,781.09	257,035.30	70,572.96	3.75	29.38	10.55	276.34	0.00	58.10	34.25	11,372.30
7/4/07 17:22	851.95	345,765.69	256,236.09	71,207.70	4.48	29.49	10.75	276.34	0.00	57.90	34.10	10,515.39
7/4/07 17:23	852.80	352,847.69	255,656.09	69,879.33	4.78	29.75	10.96	275.70	0.00	58.30	33.70	10,515.35
7/4/07 17:24	854.19	355,524.59	260,242.41	71,302.69	7.35	29.50	11.03	275.01	0.00	65.20	37.75	10,398.33
7/4/07 17:25	857.24	358,263.50	257,262.41	70,325.58	7.35	29.72	10.90	274.31	0.00	65.10	37.90	10,331.93
7/4/07 17:26	859.80	346,158.50	258,299.70	70,855.50	7.35	29.50	10.77	273.98	0.00	65.00	38.00	8,884.78
7/4/07 17:27	859.55	351,155.41	260,665.91	70,228.76	7.35	28.16	10.64	273.96	0.00	64.80	38.00	8,608.29
7/4/07 17:28	858.36	335,057.41	260,037.20	70,596.38	4.47	28.88	10.64	273.96	0.00	64.00	37.60	8,661.25
7/4/07 17:29	857.98	345,053.31	259,903.70	70,283.27	4.14	28.63	10.69	273.96	0.00	63.40	36.80	8,958.94
7/4/07 17:30	857.14	365,835.00	263,216.00	71,095.22	5.15	28.88	10.74	275.01	0.00	62.70	36.55	8,765.29
7/4/07 17:31	857.59	359,911.69	261,153.91	70,417.13	7.38	29.22	10.78	275.98	0.00	61.60	36.05	11,757.49
7/4/07 17:32	858.87	359,490.59	261,764.50	70,657.62	6.58	29.88	10.83	276.34	0.00	61.10	35.35	10,426.74
7/4/07 17:33	860.44	359,044.91	257,970.59	69,910.35	5.99	29.78	10.88	275.98	0.00	59.80	34.80	10,344.44
7/4/07 17:34	861.59	360,717.91	259,438.09	69,621.91	5.99	30.00	10.92	275.98	0.00	59.50	34.45	10,385.70
7/4/07 17:35	863.13	353,153.50	258,708.41	70,034.23	5.28	30.00	10.97	276.01	0.00	58.70	34.10	10,461.47
7/4/07 17:36	863.43	341,960.31	257,871.50	71,451.28	4.62	30.00	11.02	276.34	0.00	59.10	33.80	8,589.53
7/4/07 17:37	862.04	355,055.69	259,604.59	70,770.33	4.78	29.88	12.50	275.98	0.00	58.10	34.10	8,832.24
7/4/07 17:38	860.68	345,361.69	257,194.09	70,564.08	6.10	29.88	12.45	275.01	0.00	58.80	34.35	8,594.82
7/4/07 17:39	860.22	345,744.81	259,429.50	70,716.38	3.76	29.78	12.43	274.34	0.00	58.60	34.70	8,837.40
7/4/07 17:40	859.37	359,181.81	258,740.09	70,693.43	5.30	30.25	12.09	273.65	0.00	59.00	34.55	8,443.55
7/4/07 17:41	859.24	344,233.19	258,244.59	71,438.63	6.18	29.63	11.74	273.38	0.00	58.30	34.00	12,742.41
7/4/07 17:42	861.26	362,708.41	261,586.30	71,982.80	5.35	30.12	11.40	273.41	0.00	58.30	33.80	12,567.95
7/4/07 17:43	863.03	354,491.50	256,966.91	70,578.28	6.26	29.84	11.05	273.65	0.00	58.40	34.05	12,499.54
7/4/07 17:44	865.41	368,389.09	258,484.00	70,796.11	6.31	30.00	10.75	273.98	0.00	64.60	37.45	12,721.27
7/4/07 17:45	867.43	354,336.59	258,453.70	71,785.23	6.31	30.00	10.49	273.98	0.00	64.70	37.85	4,100.09
7/4/07 17:46	868.10	347,532.81	257,364.70	71,263.02	6.32	29.88	10.42	274.62	0.00	64.90	37.75	11,183.47
7/4/07 17:47	865.67	348,570.59	256,371.91	70,393.64	6.31	29.98	10.56	275.01	0.00	65.20	38.15	11,311.49
7/4/07 17:48	863.95	347,399.41	258,073.91	71,070.27	4.25	30.00	10.69	275.34	0.00	65.10	37.65	11,672.31
7/4/07 17:49	861.43	339,547.81	255,842.00	70,574.46	5.27	30.38	10.68	275.34	0.00	64.10	37.50	11,267.33
7/4/07 17:50	859.03	338,949.50	257,002.00	71,103.16	2.91	29.88	10.67	275.34	0.00	63.60	37.30	4,505.44
7/4/07 17:51	859.33	355,568.31	260,779.30	72,043.87	3.47	29.95	10.66	275.01	0.00	63.10	36.58	11,321.95
7/4/07 17:52	860.13	347,046.69	259,311.80	71,645.66	7.93	29.78	10.64	275.01	0.00	61.50	36.05	11,252.74
7/4/07 17:53	861.71	353,017.41	259,257.59	71,953.90	5.39	30.13	10.63	274.98	0.00	60.90	35.05	11,059.89
7/4/07 17:54	863.98	366,376.41	258,176.00	71,391.10	6.73	30.09	10.62	275.34	0.00	59.50	35.05	10,934.87
7/4/07 17:55	866.84	354,749.00	251,871.00	69,819.71	7.07	29.88	10.60	275.34	0.00	58.70	34.15	2,857.98
7/4/07 17:56	865.75	357,004.81	259,396.80	72,138.45	5.70	29.75	10.59	275.70	0.00	59.00	34.55	8,908.88
7/4/07 17:57	863.36	353,211.81	252,299.09	70,845.96	6.47	29.88	10.58	275.70	0.00	58.10	34.45	9,410.66
7/4/07 17:58	861.53	358,541.69	260,347.59	72,151.07	5.15	30.13	10.56	275.70	0.00	58.50	34.10	9,139.37
7/4/07 17:59	859.18	338,807.09	254,200.41	70,188.95	7.11	29.84	10.55	275.34	0.00	58.80	34.10	9,391.08
7/4/07 18:00	856.81	340,148.41	254,819.80	70,821.05	3.63	30.00	10.54	275.01	0.00	58.30	34.70	10,123.16
7/4/07 18:01	858.33	353,311.31	256,173.30	71,122.18	3.92	29.13	10.53	275.34	0.00	58.50	34.55	9,606.18
7/4/07 18:02	860.97	341,019.91	254,351.41	71,289.77	5.02	29.00	10.51	275.70	0.00	58.70	34.20	9,587.89
7/4/07 18:03	862.13	333,009.50	251,855.80	69,968.23	5.97	29.72	10.57	276.01	0.00	58.50	33.80	9,332.51
7/4/07 18:04	863.12	348,007.41	256,044.09	71,774.84	5.33	29.88	10.62	275.70	0.00	65.20	37.60	9,602.71
7/4/07 18:05	864.31	368,110.31	255,814.09	71,294.70	5.33	29.44	10.64	275.70	0.00	65.20	37.85	8,355.73
7/4/07 18:06	862.99	342,042.19	253,107.50	70,798.82	5.33	30.25	10.65	275.32	0.00	65.30	38.35	8,098.88
7/4/07 18:07	859.69	351,628.81	254,144.91	71,207.91	5.33	30.00	10.62	275.32	0.00	65.20	37.95	8,413.32
7/4/07 18:08	858.23	363,647.19	252,770.91	70,725.91	5.77	29.01	10.59	275.34	0.00	64.30	38.00	8,326.94
7/4/07 18:09	855.84	337,386.09	250,358.50	70,646.55	6.32	29.13	10.53	275.34	0.00	63.40	37.20	8,450.59

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 18:10	855.05	345,795.91	251,695.59	71,013.55	3.09	28.88	10.65	275.70	0.00	63.10	37.10	12,402.93
7/4/07 18:11	856.94	337,007.81	249,956.91	70,105.00	5.77	28.94	10.77	275.70	0.00	61.80	36.65	11,477.70
7/4/07 18:12	859.89	352,287.00	254,222.80	71,383.06	4.00	29.03	10.89	276.01	0.00	61.30	35.85	11,208.71
7/4/07 18:13	862.28	355,259.50	252,588.30	70,311.19	6.98	29.03	11.02	276.34	0.00	60.90	35.40	11,150.99
7/4/07 18:14	864.52	337,430.69	249,506.50	70,371.84	6.47	28.88	11.14	276.34	0.00	60.30	35.00	11,440.91
7/4/07 18:15	866.18	342,340.91	249,367.20	70,356.55	4.56	29.72	11.26	276.34	0.00	59.80	34.70	10,272.00
7/4/07 18:16	864.41	344,452.09	253,010.80	72,210.62	3.83	28.74	11.43	276.01	0.00	59.20	34.75	10,360.72
7/4/07 18:17	860.49	337,548.09	249,012.59	70,700.95	6.73	29.25	11.47	275.98	0.00	59.00	34.20	10,272.61
7/4/07 18:18	857.55	334,025.69	249,807.70	70,339.40	3.98	28.64	11.63	275.70	0.00	58.40	34.65	10,029.87
7/4/07 18:19	855.29	374,202.50	252,468.30	71,867.52	3.06	28.88	11.84	276.01	0.00	58.20	34.05	9,909.02
7/4/07 18:20	854.13	341,435.19	250,510.59	71,141.30	10.63	28.88	11.69	275.01	0.00	58.80	33.90	10,743.08
7/4/07 18:21	855.58	345,470.19	251,178.70	71,253.10	6.22	29.23	11.58	274.62	0.00	58.30	33.75	10,366.63
7/4/07 18:22	857.44	348,796.31	248,569.70	70,622.44	5.21	29.04	11.46	274.31	0.00	58.10	34.20	10,331.24
7/4/07 18:23	859.81	342,519.41	247,726.30	71,060.94	4.71	27.95	11.34	274.31	0.00	58.40	34.65	10,259.53
7/4/07 18:24	862.37	354,392.19	247,395.91	70,873.20	5.41	28.50	11.22	274.98	0.00	65.10	37.45	6,036.42
7/4/07 18:25	863.00	327,271.50	245,098.70	70,571.66	5.41	28.13	11.10	274.65	0.00	65.10	37.80	8,570.64
7/4/07 18:26	859.87	342,406.09	248,559.50	71,485.87	5.41	27.88	11.10	275.03	0.00	65.00	37.90	8,916.14
7/4/07 18:27	856.57	340,280.41	247,482.09	72,539.06	5.41	28.00	11.09	275.34	0.00	65.00	38.15	8,930.79
7/4/07 18:28	853.43	342,791.81	248,255.80	71,206.66	5.15	28.00	11.09	276.01	0.00	64.30	37.75	8,763.14
7/4/07 18:29	850.38	351,900.69	249,690.91	71,544.57	5.58	29.23	11.08	276.34	0.00	64.10	37.85	4,235.06
7/4/07 18:30	850.32	342,225.50	248,868.59	71,315.14	5.08	28.67	11.07	275.70	0.00	63.90	37.25	10,411.56
7/4/07 18:31	852.00	332,778.19	246,971.41	70,879.41	5.88	28.03	11.07	275.34	0.00	63.20	36.80	10,333.80
7/4/07 18:32	854.08	339,674.91	248,022.41	71,285.13	3.51	27.75	11.06	275.01	0.00	62.80	37.05	10,316.70
7/4/07 18:33	857.20	344,564.91	251,030.59	72,270.04	3.42	27.88	11.05	275.01	0.00	62.30	36.25	10,348.21
7/4/07 18:34	860.34	353,206.59	251,410.20	71,416.88	6.21	28.13	11.05	274.96	0.00	61.40	35.60	0.00
7/4/07 18:35	860.56	333,708.69	247,101.59	71,467.53	5.55	28.03	11.04	274.62	0.00	60.70	35.70	8,769.47
7/4/07 18:36	857.09	347,281.09	248,844.91	70,706.35	3.00	27.88	11.03	275.01	0.00	60.20	34.90	9,060.06
7/4/07 18:37	854.16	345,269.00	247,536.30	70,778.73	4.49	27.50	11.03	274.98	0.00	59.30	34.30	9,044.59
7/4/07 18:38	850.04	343,907.31	249,128.91	70,985.02	4.87	27.42	11.02	275.01	0.00	58.60	34.20	8,822.41
7/4/07 18:39	847.29	343,015.41	248,875.80	70,393.41	4.66	28.05	11.01	275.34	0.00	58.80	34.50	10,574.94
7/4/07 18:40	848.72	353,371.91	248,719.09	70,574.54	4.11	27.00	11.01	275.70	0.00	58.40	34.35	11,183.85
7/4/07 18:41	851.39	372,364.41	254,021.91	71,516.73	6.00	27.75	11.00	275.70	0.00	58.90	34.05	11,303.44
7/4/07 18:42	853.20	341,446.91	249,203.20	71,239.30	7.12	27.75	10.99	275.70	0.00	58.90	33.75	11,235.60
7/4/07 18:43	854.69	338,101.59	249,539.50	70,609.42	4.69	27.93	10.99	275.70	0.00	58.40	34.15	11,265.70
7/4/07 18:44	856.67	333,759.69	248,228.30	70,444.87	2.84	28.13	10.98	275.70	0.00	65.30	37.70	10,686.29
7/4/07 18:45	857.62	330,436.81	249,332.09	70,317.64	2.84	27.75	10.97	275.70	0.00	65.00	37.75	10,657.58
7/4/07 18:46	858.94	322,712.69	250,404.00	70,003.77	2.84	27.88	10.97	275.32	0.00	64.70	38.00	10,807.46
7/4/07 18:47	860.32	369,826.91	253,931.09	71,591.18	2.84	28.88	11.08	275.67	0.00	65.00	38.05	10,698.14
7/4/07 18:48	861.81	343,060.91	252,841.00	71,087.94	7.87	28.45	11.19	275.98	0.00	64.70	37.60	10,886.80
7/4/07 18:49	863.57	351,236.31	252,514.09	71,335.70	5.41	28.84	11.31	275.98	0.00	63.70	37.45	8,929.26
7/4/07 18:50	862.23	347,738.91	250,852.09	70,166.25	6.05	27.88	11.42	276.01	0.00	64.00	37.00	9,193.27
7/4/07 18:51	857.95	346,575.69	249,930.70	70,621.93	4.65	27.63	11.54	276.34	0.00	63.70	36.85	9,096.36
7/4/07 18:52	853.48	357,808.09	253,973.91	70,867.53	5.87	28.03	11.65	276.34	0.00	63.00	36.65	8,835.72
7/4/07 18:53	849.20	335,786.59	251,004.50	70,678.72	6.39	28.02	11.77	276.01	0.00	62.70	36.70	8,958.72
7/4/07 18:54	848.21	356,195.31	254,375.50	72,097.90	3.68	28.00	11.88	275.98	0.00	61.90	36.35	12,506.70
7/4/07 18:55	849.54	342,430.00	249,598.00	70,192.78	7.56	27.64	11.88	275.98	0.00	62.00	35.80	11,421.71
7/4/07 18:56	850.65	355,658.69	254,680.20	71,166.16	5.30	28.13	11.83	275.34	0.00	61.50	36.00	11,263.84
7/4/07 18:57	851.98	343,367.81	251,107.30	70,425.55	7.74	27.13	11.78	275.01	0.00	60.70	36.10	11,254.43
7/4/07 18:58	854.59	337,060.81	248,364.30	69,933.08	3.25	26.88	11.73	275.01	0.00	60.30	35.05	11,353.44
7/4/07 18:59	855.71	339,170.91	248,460.59	69,860.13	4.03	27.09	11.69	275.70	0.00	60.20	35.20	10,026.13

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 19:00	853.04	337,577.91	247,764.80	70,572.41	4.29	26.88	11.64	275.70	0.00	59.70	34.50	9,879.32
7/4/07 19:01	848.35	350,778.69	251,745.70	72,113.59	4.23	26.91	11.59	275.70	0.00	59.70	34.55	9,761.61
7/4/07 19:02	844.35	347,695.31	247,873.20	70,044.23	7.10	26.88	11.54	275.34	0.00	58.40	34.30	10,359.23
7/4/07 19:03	841.08	350,642.09	251,037.00	72,251.38	5.10	27.13	11.49	275.01	0.00	58.20	34.00	5,747.13
7/4/07 19:04	840.38	341,465.31	248,660.70	70,190.64	6.19	26.98	11.44	275.01	0.00	64.90	37.50	10,480.83
7/4/07 19:05	842.25	347,979.91	250,554.50	71,826.89	6.19	27.13	11.39	275.01	0.00	65.00	38.20	10,511.70
7/4/07 19:06	843.84	346,968.00	251,157.20	70,713.48	6.19	27.75	11.34	275.01	0.00	64.90	37.90	10,365.79
7/4/07 19:07	845.49	333,832.31	248,674.00	70,104.13	6.19	28.59	11.30	274.31	0.00	64.90	37.90	10,416.19
7/4/07 19:08	848.44	347,546.19	249,698.20	71,431.97	2.78	27.91	11.25	274.62	0.00	64.85	38.30	541.03
7/4/07 19:09	849.02	340,733.69	246,971.91	70,454.23	6.17	27.84	11.20	275.01	0.00	64.95	37.60	8,952.39
7/4/07 19:10	846.55	338,578.19	248,848.41	71,548.33	3.46	27.84	11.11	275.01	0.00	64.90	38.30	8,918.78
7/4/07 19:11	844.67	352,570.09	247,937.20	71,038.88	4.47	28.06	11.06	275.32	0.00	64.55	37.40	9,345.10
7/4/07 19:12	842.25	333,017.81	245,777.80	70,573.34	2.50	27.75	11.02	275.70	0.00	64.45	38.30	9,459.16
7/4/07 19:13	840.78	346,113.19	252,374.59	71,764.53	2.50	29.13	11.03	275.70	0.00	64.20	37.80	11,383.11
7/4/07 19:14	840.74	338,115.31	248,661.70	71,087.04	6.80	28.16	11.03	274.98	0.00	62.88	36.80	10,856.91
7/4/07 19:15	841.57	358,684.69	250,790.70	70,672.16	4.76	28.28	11.07	275.34	0.00	63.30	36.70	10,640.52
7/4/07 19:16	842.00	352,355.50	250,703.50	71,084.10	5.04	27.88	11.04	274.98	0.00	62.30	36.00	10,590.86
7/4/07 19:17	842.28	333,650.09	247,959.80	70,739.75	6.44	28.75	11.00	275.34	0.00	61.65	35.90	10,819.60
7/4/07 19:18	843.14	354,627.81	254,655.80	71,788.39	4.59	28.06	10.96	275.32	0.00	60.75	35.95	9,946.64
7/4/07 19:19	843.69	349,150.91	250,300.00	70,261.84	5.94	28.02	10.93	275.34	0.00	59.70	34.80	9,282.12
7/4/07 19:20	843.72	339,149.31	250,749.00	71,444.62	4.32	29.86	10.89	276.32	0.00	59.50	34.50	9,684.37
7/4/07 19:21	842.66	330,706.31	249,337.91	70,718.66	4.49	29.13	10.85	275.70	0.00	59.25	34.30	9,650.42
7/4/07 19:22	841.69	343,584.41	250,621.00	71,310.03	3.61	29.16	10.81	275.32	0.00	58.95	34.70	10,054.68
7/4/07 19:23	841.70	343,476.09	252,982.80	71,399.80	5.17	28.87	10.78	274.98	0.00	58.35	33.90	9,365.64
7/4/07 19:24	843.23	342,071.59	251,061.50	70,727.24	3.31	29.22	10.74	274.60	0.00	64.80	37.90	8,730.44
7/4/07 19:25	844.62	354,687.19	252,716.20	71,556.31	3.31	28.75	10.70	274.62	0.00	65.20	37.70	8,787.72
7/4/07 19:26	845.06	346,275.50	251,191.59	70,679.43	3.31	29.50	10.67	274.62	0.00	65.10	38.00	8,693.07
7/4/07 19:27	846.08	354,221.31	252,225.50	70,985.81	3.31	29.84	10.63	274.62	0.00	65.00	38.00	5,083.65
7/4/07 19:28	847.37	345,327.50	251,924.30	70,625.13	4.79	30.17	10.59	275.01	0.00	64.90	37.70	9,059.29
7/4/07 19:29	847.87	353,703.59	252,497.30	70,753.38	4.50	30.00	10.56	275.01	0.00	65.10	38.10	9,289.27
7/4/07 19:30	847.82	338,452.09	252,157.91	70,925.09	5.35	29.97	10.52	274.62	0.00	65.35	37.60	8,934.88
7/4/07 19:31	847.39	343,413.41	253,250.50	71,286.63	4.22	29.88	10.48	274.98	0.00	65.15	38.50	9,245.42
7/4/07 19:32	847.28	356,802.50	254,543.59	70,646.49	4.90	29.88	10.45	274.98	0.00	65.15	37.80	3,934.65
7/4/07 19:33	848.65	358,666.59	255,909.41	71,007.83	5.21	29.84	10.41	275.70	0.00	64.65	37.80	10,479.34
7/4/07 19:34	849.61	338,955.19	251,420.00	70,091.52	7.88	29.91	10.37	275.70	0.00	64.65	38.00	10,354.30
7/4/07 19:35	849.86	339,267.81	252,354.20	70,614.03	3.68	30.31	10.34	275.70	0.00	63.45	36.70	10,504.44
7/4/07 19:36	850.97	341,253.50	249,130.70	69,944.95	2.37	29.63	10.30	275.70	0.00	62.85	36.90	10,417.14
7/4/07 19:37	851.74	343,438.91	252,970.80	71,168.26	4.37	30.11	10.26	275.70	0.00	61.80	35.90	4,595.95
7/4/07 19:38	850.91	336,009.50	250,977.00	69,795.65	4.82	30.61	10.16	275.34	0.00	59.95	35.60	8,999.71
7/4/07 19:39	848.48	356,107.81	254,323.59	71,625.23	3.12	30.72	10.21	275.34	0.00	59.35	35.30	9,373.13
7/4/07 19:40	845.40	345,079.59	248,516.00	70,338.01	7.66	30.63	10.26	275.34	0.00	58.90	33.90	9,588.36
7/4/07 19:41	842.29	361,360.41	253,342.70	71,899.92	4.99	30.67	10.31	275.34	0.00	58.35	34.30	9,951.19
7/4/07 19:42	839.33	350,090.31	249,212.80	70,324.03	7.26	30.09	10.40	275.32	0.00	58.75	34.60	0.00
7/4/07 19:43	837.94	346,548.09	249,364.30	70,815.11	5.67	29.78	10.29	275.32	0.00	58.25	34.40	0.00
7/4/07 19:44	838.03	347,123.50	249,778.09	70,670.58	5.83	29.59	10.19	274.62	0.00	64.75	37.30	0.00
7/4/07 19:45	838.61	335,782.19	248,328.30	70,832.77	5.83	29.72	10.08	275.01	0.00	65.00	38.20	0.00
7/4/07 19:46	840.14	350,186.19	251,982.30	71,997.89	5.83	29.53	9.97	274.62	0.00	64.95	37.50	0.00
7/4/07 19:47	841.78	329,523.00	246,089.59	70,630.32	5.83	29.68	9.86	274.62	0.00	65.25	38.40	0.00
7/4/07 19:48	842.85	340,016.09	249,154.50	71,428.29	3.28	29.25	9.89	274.31	0.00	65.30	37.90	0.00
7/4/07 19:49	844.35	338,362.69	248,182.41	70,863.70	5.24	28.81	9.90	274.65	0.00	65.20	37.80	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 19:50	845.66	346,572.50	254,525.41	72,622.02	3.10	28.63	9.86	275.34	0.00	64.80	37.80	0.00
7/4/07 19:51	846.83	342,437.59	247,932.91	71,364.74	7.37	28.47	9.94	276.34	0.00	64.95	38.10	0.00
7/4/07 19:52	847.80	345,944.59	248,106.80	71,160.81	5.06	28.26	10.12	276.34	0.00	64.45	38.00	0.00
7/4/07 19:53	848.40	347,567.31	246,207.50	70,592.52	5.61	28.25	10.30	276.34	0.00	64.60	37.50	0.00
7/4/07 19:54	848.89	344,508.19	245,748.20	70,831.02	5.14	28.03	10.47	277.03	0.00	64.95	38.30	0.00
7/4/07 19:55	848.97	342,169.91	247,792.80	71,462.51	6.35	28.22	10.65	276.34	0.00	64.80	37.60	0.00
7/4/07 19:56	848.22	335,293.41	246,266.30	70,356.14	5.80	28.13	10.83	275.98	0.00	64.30	37.50	7,766.60
7/4/07 19:57	846.32	331,705.31	246,708.50	70,764.89	4.28	28.08	11.01	275.70	0.00	64.25	37.70	5,582.92
7/4/07 19:58	846.64	332,455.41	244,853.59	70,439.93	3.69	27.22	11.18	275.70	0.00	64.50	37.40	5,897.66
7/4/07 19:59	847.37	345,778.91	248,349.09	71,559.27	3.88	27.75	11.36	276.01	0.00	63.65	37.50	7,851.76
7/4/07 20:00	848.30	333,133.19	245,234.70	71,080.42	6.44	26.59	11.62	276.01	0.00	63.60	36.90	8,333.24
7/4/07 20:01	848.97	353,715.00	248,097.41	71,681.23	3.33	27.88	11.52	275.98	0.00	63.55	37.30	8,055.47
7/4/07 20:02	849.46	334,446.09	245,508.30	71,057.77	6.47	27.63	11.43	276.01	0.00	63.20	36.90	8,419.06
7/4/07 20:03	850.09	344,245.69	244,714.30	70,887.80	4.59	28.13	11.34	275.34	0.00	63.35	36.50	8,176.54
7/4/07 20:04	850.95	348,359.09	249,561.30	71,917.20	5.33	27.22	11.25	275.34	0.00	64.65	37.40	7,496.80
7/4/07 20:05	851.67	341,290.09	243,446.30	70,549.59	5.33	27.50	11.16	275.34	0.00	65.20	38.50	5,768.07
7/4/07 20:06	851.28	344,763.09	249,040.59	71,193.02	5.33	28.08	11.07	275.34	0.00	65.15	38.00	5,549.27
7/4/07 20:07	851.29	332,562.81	242,640.20	70,657.93	5.33	27.13	10.97	274.62	0.00	65.20	37.70	5,543.24
7/4/07 20:08	851.29	343,663.09	246,124.20	71,328.69	3.37	28.09	10.88	274.31	0.00	65.00	38.10	6,478.78
7/4/07 20:09	851.64	331,243.81	244,879.59	70,776.20	5.16	28.13	10.79	274.29	0.00	64.65	37.50	6,945.18
7/4/07 20:10	851.23	340,403.59	245,354.20	70,882.55	4.18	27.91	10.70	273.36	0.00	64.50	38.10	8,177.58
7/4/07 20:11	850.96	330,710.41	245,924.50	71,587.67	4.61	28.03	10.61	273.36	0.00	64.25	37.90	8,183.31
7/4/07 20:12	851.39	347,148.50	243,059.00	70,861.95	3.99	27.91	10.28	273.38	0.00	63.75	37.40	0.00
7/4/07 20:13	850.77	341,164.41	247,546.80	71,621.93	6.64	27.84	9.98	272.98	0.00	63.30	36.60	0.00
7/4/07 20:14	850.16	343,078.59	244,027.00	70,267.67	6.11	28.24	9.75	272.98	0.00	62.40	36.40	9,232.21
7/4/07 20:15	847.56	334,573.59	245,087.91	69,875.25	5.65	27.88	9.53	272.69	0.00	62.50	36.30	6,785.75
7/4/07 20:16	847.41	340,488.31	245,194.80	70,321.95	2.93	27.88	9.31	273.38	0.00	62.10	36.20	5,699.54
7/4/07 20:17	847.21	347,007.31	244,157.41	70,514.21	4.79	27.88	9.08	274.31	0.00	62.00	36.60	5,607.92
7/4/07 20:18	846.59	331,567.50	244,846.80	70,679.14	7.15	27.78	8.86	274.98	0.00	61.10	35.40	6,374.65
7/4/07 20:19	846.94	351,453.69	249,906.41	71,738.52	3.92	28.11	8.63	275.34	0.00	61.25	35.60	7,346.33
7/4/07 20:20	847.56	338,483.00	245,940.80	70,922.16	6.86	27.96	8.57	275.32	0.00	60.65	35.70	7,746.42
7/4/07 20:21	847.34	343,114.69	247,221.80	70,870.27	6.06	28.00	8.50	275.34	0.00	60.25	34.90	8,430.86
7/4/07 20:22	847.29	349,708.00	247,010.41	69,770.10	5.90	27.88	8.43	275.01	0.00	60.35	34.60	5,974.56
7/4/07 20:23	847.42	330,035.59	243,580.80	70,523.84	5.13	28.04	8.34	275.01	0.00	60.00	35.50	6,935.18
7/4/07 20:24	847.07	338,182.69	247,125.91	71,032.88	6.32	28.13	8.28	275.01	0.00	64.80	37.40	7,915.95
7/4/07 20:25	847.13	331,936.41	246,247.70	70,991.10	6.32	28.06	8.22	275.01	0.00	64.90	38.00	6,063.08
7/4/07 20:26	847.31	346,478.19	249,868.00	71,675.48	6.32	28.09	8.16	274.62	0.00	64.95	38.10	5,683.69
7/4/07 20:27	848.04	339,694.31	246,929.50	71,219.21	6.32	27.59	8.16	274.62	0.00	64.90	37.90	5,607.68
7/4/07 20:28	848.11	342,902.31	249,024.59	71,411.07	5.14	27.88	8.11	274.98	0.00	64.90	38.30	5,730.67
7/4/07 20:29	847.97	344,633.09	245,079.59	70,733.12	7.57	27.94	8.06	274.62	0.00	64.60	37.40	6,257.83
7/4/07 20:30	848.99	349,846.09	247,500.59	71,107.30	4.24	28.97	8.01	274.62	0.00	64.20	37.10	0.00
7/4/07 20:31	849.05	345,579.41	245,279.91	71,093.16	6.96	28.63	7.96	274.62	0.00	64.40	37.20	0.00
7/4/07 20:32	848.01	331,685.09	244,224.09	70,696.90	7.37	28.59	7.91	273.98	0.00	64.25	37.70	0.00
7/4/07 20:33	847.98	349,777.41	247,039.30	71,141.81	4.27	28.53	7.86	273.98	0.00	63.95	37.80	0.00
7/4/07 20:34	848.41	326,550.50	241,454.41	70,932.21	5.91	27.66	7.81	273.96	0.00	63.78	37.30	0.00
7/4/07 20:35	847.76	326,206.00	241,243.50	70,891.55	4.53	27.88	7.76	273.96	0.00	63.80	37.90	0.00
7/4/07 20:36	846.02	333,996.09	243,765.09	71,054.45	4.71	27.69	7.71	274.31	0.00	63.80	37.00	0.00
7/4/07 20:37	845.03	334,200.09	243,361.91	71,178.33	4.86	26.88	7.66	275.01	0.00	63.10	36.90	0.00
7/4/07 20:38	844.42	334,706.09	245,462.50	72,116.83	4.36	27.09	7.61	275.01	0.00	63.15	36.90	5,821.55
7/4/07 20:39	842.61	335,763.69	242,656.50	70,968.39	6.61	26.97	7.56	275.01	0.00	62.65	36.90	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 20:40	841.73	349,049.00	244,745.41	71,161.15	5.61	25.78	7.51	275.34	0.00	61.75	36.20	6,299.36
7/4/07 20:41	841.38	346,288.31	244,612.30	71,005.52	6.50	26.00	7.46	275.98	0.00	61.70	35.80	0.00
7/4/07 20:42	841.60	329,374.00	241,474.09	71,559.02	5.72	25.78	7.41	276.01	0.00	60.95	36.00	8,485.44
7/4/07 20:43	841.91	344,156.31	244,882.70	70,505.54	4.06	26.25	7.36	277.01	0.00	61.25	35.30	0.00
7/4/07 20:44	842.66	335,026.59	241,235.91	71,160.38	5.11	25.35	7.42	277.34	0.00	64.85	38.00	582.42
7/4/07 20:45	843.40	341,094.81	245,221.30	72,568.95	5.11	25.75	7.60	277.34	0.00	65.20	37.70	0.00
7/4/07 20:46	843.07	332,361.59	239,975.00	70,939.46	5.11	25.91	7.78	276.65	0.00	64.80	38.40	0.00
7/4/07 20:47	841.19	337,626.91	242,308.59	71,856.03	5.11	25.63	7.96	275.98	0.00	65.15	37.90	0.00
7/4/07 20:48	840.39	331,470.31	241,300.80	70,495.42	4.47	25.59	8.14	276.34	0.00	64.50	37.60	0.00
7/4/07 20:49	839.42	325,877.81	237,555.41	70,300.13	4.76	25.22	8.32	276.01	0.00	64.05	37.70	5,833.61
7/4/07 20:50	838.80	334,458.09	239,913.50	70,840.21	3.37	25.13	8.50	275.70	0.00	63.40	37.40	0.00
7/4/07 20:51	839.12	337,874.81	242,601.91	70,979.43	5.23	23.91	8.68	275.01	0.00	62.55	36.20	6,978.77
7/4/07 20:52	839.15	329,676.00	237,216.80	70,651.73	5.91	24.00	8.86	275.70	0.00	62.20	36.10	0.00
7/4/07 20:53	838.95	329,826.91	236,603.80	70,209.77	4.56	24.09	9.04	275.98	0.00	61.20	35.40	6,394.75
7/4/07 20:54	838.84	333,025.59	236,545.80	70,656.88	5.00	23.78	9.22	276.32	0.00	60.65	36.20	0.00
7/4/07 20:55	839.97	345,741.59	238,091.41	70,420.01	2.35	23.00	9.40	276.65	0.00	59.85	34.90	7,787.60
7/4/07 20:56	839.45	336,770.69	238,290.00	71,256.37	4.51	23.00	9.58	276.34	0.00	59.35	35.00	0.00
7/4/07 20:57	838.21	294,466.69	234,801.30	70,503.02	5.29	22.75	9.76	276.32	0.00	58.40	34.10	0.00
7/4/07 20:58	837.35	334,808.09	238,513.70	70,966.26	2.87	22.75	9.94	276.34	0.00	58.55	34.60	0.00
7/4/07 20:59	837.47	335,333.41	238,052.50	70,474.67	4.82	21.75	10.12	276.32	0.00	58.45	34.00	0.00
7/4/07 21:00	837.56	333,733.59	239,449.80	69,878.63	4.48	21.81	10.30	276.65	0.00	57.95	33.70	5,171.82
7/4/07 21:01	838.32	328,427.59	237,078.91	69,866.80	4.60	21.88	10.48	277.32	0.00	58.35	34.50	0.00
7/4/07 21:02	839.98	341,355.31	242,963.70	71,407.82	2.45	22.00	10.66	277.34	0.00	58.65	34.60	6,418.51
7/4/07 21:03	841.27	323,287.31	237,535.09	69,694.30	6.36	21.34	10.84	277.32	0.00	58.35	34.60	0.00
7/4/07 21:04	842.03	352,953.91	240,520.59	70,890.26	4.95	20.63	11.02	277.34	0.00	65.40	36.90	6,322.29
7/4/07 21:05	841.98	346,033.81	242,200.00	69,898.31	4.95	20.97	11.20	276.65	0.00	65.15	38.50	0.00
7/4/07 21:06	842.37	333,222.50	238,842.80	70,575.55	4.95	20.91	11.38	276.34	0.00	65.00	37.70	3,759.49
7/4/07 21:07	841.92	334,369.91	241,932.00	71,203.07	4.95	21.00	11.56	276.01	0.00	64.95	38.20	0.00
7/4/07 21:08	841.74	334,327.59	240,635.20	69,916.22	3.88	20.44	11.74	275.34	0.00	64.50	37.50	0.00
7/4/07 21:09	842.76	349,023.31	243,714.80	71,069.02	2.44	19.75	11.92	274.98	0.00	63.00	37.40	1,081.73
7/4/07 21:10	843.79	338,633.81	243,497.91	71,193.08	4.89	21.01	12.10	276.01	0.00	61.85	36.20	0.00
7/4/07 21:11	843.87	334,803.69	244,171.30	70,226.80	5.84	22.84	12.16	275.70	0.00	60.90	35.50	5,096.82
7/4/07 21:12	844.43	335,879.91	243,528.50	71,346.27	2.88	21.75	12.11	275.01	0.00	60.10	35.40	0.00
7/4/07 21:13	844.85	342,817.31	245,274.59	71,317.83	2.65	21.63	12.07	274.31	0.00	59.60	34.40	6,787.31
7/4/07 21:14	844.89	336,085.09	245,162.80	70,292.45	4.96	21.05	12.02	274.31	0.00	58.90	33.90	0.00
7/4/07 21:15	844.61	331,647.91	245,323.30	70,677.32	3.41	20.91	11.97	274.31	0.00	58.70	33.80	7,999.75
7/4/07 21:16	844.97	346,882.41	246,861.00	70,836.51	1.94	20.88	11.93	274.98	0.00	58.45	33.90	0.00
7/4/07 21:17	845.99	331,941.00	246,754.59	70,506.48	2.86	21.94	11.88	276.01	0.00	58.40	34.40	8,582.00
7/4/07 21:18	846.32	341,112.41	247,944.70	71,127.30	3.64	22.69	11.83	275.98	0.00	58.25	34.60	0.00
7/4/07 21:19	846.53	335,359.81	248,308.41	71,088.13	4.22	21.88	11.78	275.70	0.00	58.40	34.20	5,879.91
7/4/07 21:20	846.56	354,412.69	254,346.30	72,037.05	2.59	22.00	11.74	275.34	0.00	58.55	33.70	0.00
7/4/07 21:21	847.27	346,890.59	250,952.20	71,214.26	5.29	21.56	11.69	275.70	0.00	58.40	33.90	0.00
7/4/07 21:22	847.58	339,882.59	252,010.30	70,796.95	4.03	22.89	11.64	275.70	0.00	58.25	33.90	2,838.70
7/4/07 21:23	848.07	359,155.91	255,380.80	71,429.81	1.88	23.13	11.65	276.01	0.00	58.40	34.60	0.00
7/4/07 21:24	848.72	346,918.19	255,151.00	71,894.94	5.05	22.41	11.68	275.98	0.00	64.35	37.70	6,242.26
7/4/07 21:25	849.10	355,817.59	256,897.70	71,106.03	5.05	23.75	11.72	276.01	0.00	65.10	37.90	0.00
7/4/07 21:26	849.62	346,875.69	255,397.80	71,313.76	5.04	23.13	11.75	275.70	0.00	65.10	38.00	8,482.64
7/4/07 21:27	849.71	367,803.50	259,709.00	71,792.06	5.04	21.88	11.78	275.70	0.00	64.75	38.30	0.00
7/4/07 21:28	850.57	359,633.09	259,958.00	71,047.50	6.53	22.13	11.81	276.01	0.00	64.15	37.40	9,862.52
7/4/07 21:29	850.49	337,369.09	256,392.59	70,385.77	6.23	22.00	11.84	276.65	0.00	63.30	36.80	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/4/07 21:30	850.67	364,552.09	261,682.09	70,216.48	3.36	22.63	11.87	277.03	0.00	62.80	37.20	0.00
7/4/07 21:31	851.26	358,981.31	258,744.80	70,165.05	5.47	23.63	11.91	277.34	0.00	61.95	36.00	3,095.69
7/4/07 21:32	851.24	358,624.19	262,187.59	70,815.37	5.34	24.75	11.94	277.03	0.00	61.60	35.80	0.00
7/4/07 21:33	851.37	351,813.41	261,722.20	71,167.76	6.17	25.00	11.97	276.34	0.00	61.30	36.50	5,614.37
7/4/07 21:34	851.50	368,992.81	266,177.91	72,245.69	5.17	24.88	12.00	275.34	0.00	61.20	35.20	0.00
7/4/07 21:35	851.92	343,241.09	259,485.50	70,273.29	7.97	24.84	12.03	275.34	0.00	60.90	35.50	6,893.17
7/4/07 21:36	852.88	382,250.50	269,255.81	71,353.70	3.62	24.91	12.06	274.62	0.00	60.65	36.10	0.00
7/4/07 21:37	852.07	349,462.41	258,873.41	70,134.52	8.97	25.00	12.10	274.29	0.00	60.70	35.00	6,572.26
7/4/07 21:38	851.80	355,635.09	258,765.80	70,648.75	5.06	25.13	12.13	274.31	0.00	60.00	34.80	0.00
7/4/07 21:39	852.38	348,611.91	258,763.00	70,189.27	4.04	25.09	12.16	274.31	0.00	59.75	35.20	8,520.70
7/4/07 21:40	853.06	345,625.81	257,607.91	69,295.99	2.99	25.03	11.99	274.31	0.00	59.30	35.00	0.00
7/4/07 21:41	853.63	352,056.31	259,901.59	70,518.17	3.10	25.88	11.79	274.31	0.00	58.95	34.60	0.00
7/4/07 21:42	853.96	345,597.81	257,428.70	69,753.15	4.94	26.00	11.73	274.62	0.00	58.10	33.90	562.91
7/4/07 21:43	852.68	343,208.81	258,636.91	70,787.40	3.06	25.88	11.66	275.01	0.00	58.15	33.80	0.00
7/4/07 21:44	852.50	348,835.81	258,313.91	70,192.58	2.99	26.13	11.67	275.01	0.00	64.90	37.50	4,275.62
7/4/07 21:45	852.96	350,250.31	260,244.80	71,479.27	2.99	27.05	11.61	275.34	0.00	64.75	37.60	0.00
7/4/07 21:46	853.19	339,438.09	258,154.00	70,708.28	2.99	26.00	11.54	275.33	0.00	64.95	38.20	6,003.72
7/4/07 21:47	853.08	355,318.00	258,382.41	70,900.28	2.98	25.88	11.48	275.34	0.00	64.90	37.80	0.00
7/4/07 21:48	853.73	350,115.69	260,590.00	71,440.16	5.44	26.67	11.42	275.34	0.00	64.85	38.30	9,054.50
7/4/07 21:49	853.70	357,047.50	260,830.20	71,374.56	6.57	26.88	11.36	275.01	0.00	64.90	37.90	0.00
7/4/07 21:50	854.16	354,848.19	257,188.59	70,324.88	5.76	26.78	11.30	275.01	0.00	64.15	37.90	10,529.28
7/4/07 21:51	855.19	355,538.31	257,351.50	70,765.10	4.31	26.63	11.28	275.01	0.00	63.95	37.10	0.00
7/4/07 21:52	856.14	353,512.50	258,399.80	70,842.82	7.01	27.13	11.30	275.01	0.00	63.65	36.70	0.00
7/4/07 21:53	857.03	357,183.31	259,237.41	70,701.20	7.15	27.09	11.34	275.01	0.00	62.95	37.10	1,496.88
7/4/07 21:54	858.06	356,256.31	259,707.00	71,219.03	5.54	25.91	11.39	275.32	0.00	62.45	36.50	0.00
7/4/07 21:55	858.85	348,265.91	254,676.70	70,807.69	7.21	26.33	11.41	275.96	0.00	62.70	36.70	6,592.15
7/4/07 21:56	858.64	349,212.69	255,559.91	70,628.32	4.32	26.91	11.57	276.34	0.00	62.45	36.10	0.00
7/4/07 21:57	858.71	343,352.91	253,947.80	70,349.26	4.79	26.03	11.73	276.65	0.00	61.85	36.20	8,410.34
7/4/07 21:58	858.10	348,552.91	251,715.91	70,140.06	4.06	26.00	11.89	277.01	0.00	61.80	36.30	0.00
7/4/07 21:59	858.22	346,913.31	254,326.20	70,509.76	3.95	25.88	12.05	276.65	0.00	61.10	36.00	9,125.04
7/4/07 22:00	857.63	336,615.69	253,193.59	70,839.13	5.56	26.98	12.21	276.67	0.00	61.20	35.00	0.00
7/4/07 22:01	857.16	342,666.91	252,608.00	70,691.41	5.11	26.66	12.37	275.98	0.00	60.70	35.80	0.00
7/4/07 22:02	857.28	359,962.31	258,214.41	72,513.44	2.77	26.00	12.53	275.70	0.00	60.30	35.50	516.34
7/4/07 22:03	857.73	341,665.19	252,857.70	71,245.20	8.65	26.00	12.69	275.33	0.00	60.00	34.60	0.00
7/4/07 22:04	858.13	341,747.91	252,381.30	70,678.90	4.60	27.16	12.85	275.34	0.00	64.90	37.50	4,538.81
7/4/07 22:05	858.64	354,589.91	252,303.20	70,305.54	4.60	26.00	12.91	275.34	0.00	65.15	38.00	0.00
7/4/07 22:06	860.21	349,669.59	252,323.20	70,876.70	4.60	26.13	13.01	275.70	0.00	65.05	37.60	8,287.80
7/4/07 22:07	861.13	345,258.81	251,799.00	70,780.41	4.60	26.28	13.11	276.01	0.00	64.95	38.50	0.00
7/4/07 22:08	862.53	354,176.19	252,212.50	71,494.12	4.22	26.88	13.22	276.01	0.00	64.80	37.60	9,663.37
7/4/07 22:09	862.18	341,349.31	251,458.80	71,060.78	6.25	26.50	13.32	276.01	0.00	65.35	38.40	0.00
7/4/07 22:10	861.57	340,279.91	250,041.70	71,603.61	4.47	26.09	13.42	276.00	0.00	65.20	38.40	0.00
7/4/07 22:11	860.53	339,731.69	249,763.70	70,314.95	5.50	25.92	13.53	275.70	0.00	65.00	37.60	1,985.10
7/4/07 22:12	859.13	338,858.69	249,840.30	70,851.55	4.30	25.66	13.57	275.34	0.00	65.05	38.50	0.00
7/4/07 22:13	858.40	342,317.41	249,423.80	70,239.40	4.21	26.00	13.54	275.34	0.00	64.80	37.80	6,010.64
7/4/07 22:14	858.11	345,283.69	249,539.70	70,833.93	3.48	25.45	13.51	275.01	0.00	64.50	38.10	0.00
7/4/07 22:15	857.75	348,253.19	248,735.20	70,532.29	6.26	25.78	13.53	275.02	0.00	64.20	37.50	6,337.88
7/4/07 22:16	857.39	335,637.50	249,115.91	70,512.62	4.68	26.13	13.55	275.01	0.00	64.05	37.10	0.00
7/4/07 22:17	857.97	340,977.50	249,222.30	70,476.18	5.53	26.16	13.56	275.70	0.00	63.40	36.60	8,617.75
7/4/07 22:18	857.39	333,238.41	247,411.41	70,226.23	5.60	25.50	13.58	275.35	0.00	63.55	37.20	0.00
7/4/07 22:19	857.11	343,766.00	249,984.91	72,649.30	3.39	25.88	13.60	275.34	0.00	63.05	36.50	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 22:20	856.94	339,462.59	246,681.70	70,350.57	7.06	25.20	13.61	275.32	0.00	62.75	36.50	0.00
7/4/07 22:21	857.47	349,825.00	250,622.91	71,507.05	4.38	26.00	13.63	276.32	0.00	61.90	36.80	0.00
7/4/07 22:22	857.72	354,405.31	251,946.00	72,453.57	8.28	26.50	11.65	275.98	0.00	62.20	36.10	0.00
7/4/07 22:23	857.59	354,029.50	251,507.91	70,752.43	8.31	25.95	11.84	275.69	0.00	61.85	35.50	0.00
7/4/07 22:24	857.77	338,860.09	248,970.70	71,514.82	6.50	26.00	12.02	276.32	0.00	65.30	37.30	0.00
7/4/07 22:25	859.10	349,944.91	246,442.59	70,706.94	6.50	26.78	12.20	277.34	0.00	65.15	38.40	0.00
7/4/07 22:26	859.37	339,554.09	246,063.09	71,453.64	6.50	27.89	12.38	277.34	0.00	64.80	37.90	0.00
7/4/07 22:27	860.31	346,825.41	246,372.30	71,096.84	6.50	28.00	12.56	277.34	0.00	64.70	38.20	0.00
7/4/07 22:28	860.39	338,247.50	244,973.09	70,839.43	6.33	27.88	12.66	276.66	0.00	65.15	38.20	0.00
7/4/07 22:29	860.65	337,279.50	243,562.91	70,917.24	4.11	27.88	12.60	275.70	0.00	65.35	37.80	0.00
7/4/07 22:30	859.76	338,331.41	245,096.70	70,977.79	6.01	28.60	12.54	275.34	0.00	65.15	38.40	0.00
7/4/07 22:31	860.30	337,075.81	244,634.09	70,816.98	3.90	28.00	12.48	275.01	0.00	64.50	37.50	0.00
7/4/07 22:32	860.60	335,631.41	243,960.91	70,749.14	3.77	28.00	12.42	274.62	0.00	64.65	37.90	0.00
7/4/07 22:33	860.14	333,079.41	244,626.91	71,051.74	5.21	28.45	12.36	274.62	0.00	64.20	37.60	0.00
7/4/07 22:34	857.47	335,392.81	245,001.30	70,973.29	4.42	28.65	12.30	273.97	0.00	63.85	37.80	8,939.12
7/4/07 22:35	855.67	334,644.31	243,915.41	70,445.98	4.79	28.47	12.24	273.98	0.00	63.60	37.40	8,753.59
7/4/07 22:36	855.35	352,922.59	247,854.50	71,515.82	3.38	28.81	12.18	274.31	0.00	63.20	37.40	5,845.45
7/4/07 22:37	854.42	339,773.41	243,729.30	70,887.15	7.95	28.50	12.12	274.62	0.00	63.15	36.20	6,271.15
7/4/07 22:38	854.03	333,571.91	244,194.70	71,312.94	4.70	28.38	12.06	274.62	0.00	62.05	36.00	5,845.41
7/4/07 22:39	855.03	344,661.19	244,504.00	71,199.78	3.82	28.38	12.00	275.01	0.00	61.20	35.90	7,307.11
7/4/07 22:40	856.69	332,559.50	244,471.50	71,603.30	5.53	28.03	11.94	275.35	0.00	60.80	36.10	8,458.06
7/4/07 22:41	857.22	329,504.81	243,969.41	71,560.42	5.14	29.09	11.88	275.34	0.00	60.95	35.00	8,389.24
7/4/07 22:42	857.41	335,960.00	242,728.20	70,428.08	4.00	28.25	11.82	275.34	0.00	60.45	35.80	8,471.66
7/4/07 22:43	857.93	339,012.69	243,285.80	71,105.95	2.86	27.88	11.76	275.35	0.00	59.80	35.30	6,597.26
7/4/07 22:44	858.15	333,879.41	243,056.70	71,281.48	4.57	28.66	11.70	276.01	0.00	64.80	37.10	6,958.07
7/4/07 22:45	858.04	337,382.00	241,381.91	70,856.82	4.57	28.69	11.61	276.01	0.00	64.60	38.10	6,208.07
7/4/07 22:46	857.65	334,533.91	243,010.30	71,286.28	4.57	28.63	11.48	275.34	0.00	65.05	37.80	5,757.52
7/4/07 22:47	858.16	335,510.19	242,517.91	71,210.29	4.57	28.38	11.35	275.01	0.00	65.20	38.40	5,645.15
7/4/07 22:48	858.43	325,006.31	240,663.41	70,964.49	4.07	28.75	11.22	274.64	0.00	64.65	37.40	6,166.07
7/4/07 22:49	858.24	336,485.50	243,683.00	71,498.05	3.21	29.16	11.10	274.31	0.00	64.65	38.20	5,764.46
7/4/07 22:50	858.92	358,165.69	243,347.00	72,126.19	3.56	28.91	10.97	273.66	0.00	63.90	37.60	0.00
7/4/07 22:51	858.94	339,992.19	243,532.00	71,757.42	7.01	29.09	10.76	273.40	0.00	63.95	37.50	0.00
7/4/07 22:52	858.02	334,520.69	243,261.20	72,102.74	4.59	29.16	10.50	272.69	0.00	63.45	36.90	0.00
7/4/07 22:53	856.67	339,638.81	245,768.91	71,470.20	5.75	28.13	10.24	272.70	0.00	62.95	37.00	0.00
7/4/07 22:54	853.46	340,470.31	240,270.41	70,644.70	5.83	28.04	9.98	272.31	0.00	62.15	36.40	7,835.67
7/4/07 22:55	851.11	326,213.91	244,700.59	71,997.09	4.65	28.05	9.73	272.70	0.00	60.65	35.30	8,610.94
7/4/07 22:56	850.05	343,236.69	242,407.00	70,827.73	5.71	28.28	9.47	273.00	0.00	60.10	35.45	7,515.63
7/4/07 22:57	849.36	341,975.09	243,521.50	70,573.27	5.50	27.88	9.21	273.66	0.00	59.25	34.40	6,401.94
7/4/07 22:58	850.15	339,202.91	242,176.41	71,688.96	4.58	28.35	8.95	274.62	0.00	58.85	34.40	5,944.23
7/4/07 22:59	851.54	338,364.81	241,706.50	71,468.19	3.68	27.97	8.69	275.01	0.00	58.25	34.00	5,714.27
7/4/07 23:00	852.38	340,531.91	244,588.91	71,310.73	4.21	28.91	8.40	275.70	0.00	58.20	33.70	5,985.38
7/4/07 23:01	853.01	358,681.41	245,938.30	70,979.49	4.68	28.77	8.41	275.70	0.00	58.95	33.80	7,526.89
7/4/07 23:02	853.83	339,560.31	243,161.20	70,704.23	6.82	28.75	8.43	275.98	0.00	58.40	34.10	6,736.58
7/4/07 23:03	854.59	337,876.41	246,940.80	71,430.99	3.52	29.00	8.44	276.00	0.00	58.25	34.30	6,838.71
7/4/07 23:04	855.73	336,961.09	242,836.00	70,727.14	3.18	28.91	8.46	276.01	0.00	65.10	37.90	7,447.65
7/4/07 23:05	855.90	328,673.41	242,432.30	71,332.09	3.18	29.53	8.48	275.70	0.00	65.10	37.60	8,687.99
7/4/07 23:06	856.26	331,494.69	243,799.41	71,086.59	3.18	29.50	8.49	275.35	0.00	65.20	38.40	7,350.05
7/4/07 23:07	856.62	333,391.91	244,622.91	72,127.39	3.18	29.50	8.51	274.99	0.00	65.10	37.50	6,600.62
7/4/07 23:08	857.46	334,945.91	244,127.00	71,363.12	4.55	29.97	8.41	275.01	0.00	65.00	38.20	5,557.37
7/4/07 23:09	856.73	347,246.81	248,921.59	72,420.37	5.16	30.00	8.24	274.31	0.00	65.30	37.70	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/4/07 23:10	856.51	343,890.81	246,689.80	71,616.99	6.44	29.00	8.07	273.97	0.00	65.05	38.20	0.00
7/4/07 23:11	856.21	337,851.00	246,097.20	71,518.28	6.88	28.88	7.90	273.97	0.00	64.75	38.10	0.00
7/4/07 23:12	857.00	354,474.41	246,963.70	72,026.63	3.71	29.22	7.73	274.31	0.00	64.55	37.50	0.00
7/4/07 23:13	856.40	332,244.81	245,452.09	71,989.34	5.50	29.72	7.55	274.31	0.00	64.45	37.70	0.00
7/4/07 23:14	855.84	336,888.41	245,863.41	71,918.95	2.95	30.13	7.38	274.31	0.00	64.00	37.70	0.00
7/4/07 23:15	854.89	342,232.50	245,891.00	71,706.03	4.50	29.25	7.21	273.96	0.00	63.40	36.90	0.00
7/4/07 23:16	854.56	315,184.41	243,236.59	70,830.08	4.26	29.33	7.04	273.65	0.00	62.95	36.80	0.00
7/4/07 23:17	854.29	350,937.81	247,265.91	70,855.96	2.53	29.16	7.01	273.96	0.00	62.45	36.00	0.00
7/4/07 23:18	854.60	344,585.00	248,490.70	71,262.81	6.02	29.00	6.88	273.96	0.00	61.95	35.80	0.00
7/4/07 23:19	855.48	345,983.00	252,779.91	72,815.09	3.70	29.88	6.76	274.61	0.00	61.85	35.80	0.00
7/4/07 23:20	855.41	331,193.00	245,295.09	71,809.80	6.72	29.72	6.64	274.99	0.00	61.25	36.10	0.00
7/4/07 23:21	854.99	343,754.50	247,393.59	71,485.45	3.31	30.38	6.51	274.99	0.00	60.80	35.60	0.00
7/4/07 23:22	855.44	329,223.69	246,838.00	71,612.63	4.38	30.00	6.60	274.99	0.00	60.65	35.70	13,661.83
7/4/07 23:23	857.48	346,546.00	247,776.20	71,653.46	2.54	29.78	6.72	275.70	0.00	60.35	35.10	13,514.73
7/4/07 23:24	859.36	344,252.81	248,870.09	72,135.30	6.09	29.75	6.84	276.00	0.00	65.30	37.80	13,660.91
7/4/07 23:25	861.02	348,470.69	252,068.70	71,929.66	6.09	29.13	6.95	275.98	0.00	65.00	38.00	13,599.41
7/4/07 23:26	862.68	350,745.59	250,679.59	72,247.66	6.09	28.25	7.07	276.65	0.00	64.90	38.20	1,140.02
7/4/07 23:27	861.22	353,213.41	253,430.50	72,912.92	6.09	27.91	7.19	277.02	0.00	65.10	37.70	13,175.84
7/4/07 23:28	855.94	332,504.09	247,890.30	71,717.00	8.64	28.75	7.31	277.34	0.00	64.45	38.30	10,403.28
7/4/07 23:29	852.39	349,201.09	251,879.41	72,267.17	3.91	28.91	7.61	277.33	0.00	64.05	37.70	12,657.19
7/4/07 23:30	849.55	350,226.69	250,477.41	72,138.02	5.44	28.88	7.82	277.32	0.00	63.30	36.70	12,513.87
7/4/07 23:31	845.93	347,421.19	250,783.20	71,502.62	6.25	29.13	8.02	277.68	0.00	62.05	36.10	11,000.71
7/4/07 23:32	844.88	338,144.41	247,557.30	71,228.20	6.57	29.00	8.18	276.65	0.00	61.40	35.50	11,145.74
7/4/07 23:33	846.76	355,185.81	247,457.20	71,129.91	3.65	28.75	8.27	276.29	0.00	60.75	35.80	10,712.83
7/4/07 23:34	849.20	343,528.69	248,272.91	71,512.36	6.05	28.88	8.37	275.70	0.00	60.45	35.80	10,633.03
7/4/07 23:35	852.82	367,011.41	251,854.59	72,286.12	3.36	28.66	8.46	275.70	0.00	59.95	35.30	10,716.73
7/4/07 23:36	854.93	334,998.69	247,681.00	71,977.41	5.65	29.09	8.55	275.70	0.00	60.15	35.60	9,413.78
7/4/07 23:37	852.88	335,017.31	247,672.70	71,538.88	3.40	29.19	8.64	275.34	0.00	59.30	34.70	8,522.12
7/4/07 23:38	848.91	345,647.31	249,945.80	72,666.43	2.99	28.13	8.73	274.99	0.00	58.45	34.30	9,759.87
7/4/07 23:39	846.05	346,266.41	248,058.20	71,273.34	6.38	27.73	8.82	275.01	0.00	58.15	34.20	9,565.67
7/4/07 23:40	842.52	343,099.19	248,964.30	71,036.23	4.85	27.78	8.91	274.99	0.00	58.25	34.60	9,256.27
7/4/07 23:41	839.77	344,219.09	250,748.91	71,547.54	4.20	27.99	9.01	275.01	0.00	58.30	34.60	12,042.79
7/4/07 23:42	839.98	357,627.31	253,649.41	71,684.76	5.33	27.41	9.10	275.01	0.00	58.85	34.00	10,508.11
7/4/07 23:43	841.37	350,775.09	253,046.00	71,949.03	6.21	26.75	9.19	275.33	0.00	58.65	33.80	10,400.51
7/4/07 23:44	842.70	347,965.00	255,685.20	72,082.84	4.39	26.88	9.28	275.33	0.00	64.95	37.00	10,432.42
7/4/07 23:45	844.05	339,062.31	250,214.09	70,403.49	4.39	26.91	9.37	275.70	0.00	65.15	38.00	10,493.46
7/4/07 23:46	845.84	361,297.41	253,440.50	71,693.94	4.39	26.81	9.46	276.33	0.00	65.05	37.60	9,174.63
7/4/07 23:47	846.14	351,121.41	250,981.59	70,859.76	4.39	26.88	9.55	276.33	0.00	64.95	38.50	9,097.90
7/4/07 23:48	844.81	338,640.50	251,190.09	71,996.57	5.05	28.41	9.65	277.02	0.00	65.05	38.10	8,815.20
7/4/07 23:49	843.94	356,231.41	253,104.70	72,088.00	4.84	27.00	9.74	277.01	0.00	65.15	38.10	8,986.43
7/4/07 23:50	842.73	341,430.09	250,781.09	70,705.44	5.41	26.88	9.83	277.03	0.00	64.75	37.90	8,964.90
7/4/07 23:51	842.30	348,062.19	253,651.80	71,798.52	3.31	26.85	9.92	277.02	0.00	64.20	37.10	11,027.08
7/4/07 23:52	842.10	344,252.81	250,923.20	71,387.02	6.10	27.13	10.01	276.66	0.00	64.00	37.35	10,490.12
7/4/07 23:53	843.05	342,558.09	254,003.30	72,855.93	3.35	26.75	10.09	276.34	0.00	63.45	37.00	10,491.64
7/4/07 23:54	843.81	340,427.91	249,784.80	71,292.98	6.58	26.84	10.17	276.01	0.00	63.55	36.60	10,350.49
7/4/07 23:55	844.11	335,879.31	250,326.09	71,564.88	4.11	26.88	10.24	275.34	0.00	62.95	36.85	10,190.34
7/4/07 23:56	843.46	353,420.50	251,649.20	71,560.24	4.90	26.72	10.32	275.34	0.00	62.25	37.10	8,788.19
7/4/07 23:57	843.15	343,356.19	251,277.41	71,708.27	5.87	25.88	10.40	275.01	0.00	62.30	36.40	8,768.27
7/4/07 23:58	843.82	350,186.69	251,672.20	71,810.71	4.33	25.88	10.36	275.34	0.00	61.95	36.80	8,619.32
7/4/07 23:59	843.78	339,172.91	250,980.59	71,413.02	6.34	25.75	10.41	275.70	0.00	62.10	36.00	8,636.97

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/5/07 0:00	842.87	348,217.69	254,537.80	72,838.72	4.44	25.95	10.47	275.70	0.00	62.15	36.60	5,042.60
7/5/07 0:01	843.89	346,428.81	251,252.80	72,127.09	7.09	25.88	10.52	275.98	0.00	62.05	36.60	12,692.77
7/5/07 0:02	847.11	350,014.09	253,596.91	72,122.76	5.80	25.88	10.63	276.01	0.00	61.90	35.90	12,724.69
7/5/07 0:03	849.42	341,584.59	252,290.80	72,344.55	7.07	25.97	10.81	276.00	0.00	62.35	36.50	12,784.05
7/5/07 0:04	851.91	361,398.91	254,188.41	72,163.74	3.52	25.63	11.00	275.98	0.00	65.05	37.80	12,605.70
7/5/07 0:05	854.80	341,682.91	252,005.59	72,051.46	3.52	24.88	11.21	275.98	0.00	65.10	38.10	0.00
7/5/07 0:06	855.13	345,869.41	248,567.59	71,140.39	3.52	24.71	11.38	276.65	0.00	65.20	37.80	11,520.18
7/5/07 0:07	851.38	339,499.50	249,716.70	72,136.77	3.52	25.09	11.56	276.33	0.00	65.15	38.20	11,883.12
7/5/07 0:08	848.16	345,194.00	250,694.59	72,430.65	4.45	25.13	11.73	275.70	0.00	65.20	37.70	11,838.75
7/5/07 0:09	845.12	352,462.41	253,640.20	72,984.66	6.10	23.88	11.90	275.69	0.00	65.00	38.40	11,479.58
7/5/07 0:10	842.35	346,845.09	250,715.80	72,781.92	7.63	23.88	12.08	275.70	0.00	65.45	38.10	9,921.88
7/5/07 0:11	842.85	355,573.09	251,213.59	72,039.84	5.41	23.88	12.25	276.34	0.00	65.85	38.10	11,078.09
7/5/07 0:12	844.71	345,712.09	249,929.41	71,869.31	7.15	22.91	12.42	276.34	0.00	66.40	38.60	10,998.39
7/5/07 0:13	845.82	340,121.69	249,093.59	71,563.11	5.29	22.75	12.60	276.08	0.00	66.50	38.70	11,254.61
7/5/07 0:14	848.09	339,052.09	247,303.80	71,558.63	4.21	23.00	12.77	276.65	0.00	66.70	38.80	11,084.63
7/5/07 0:15	850.29	346,016.59	246,730.80	71,588.64	4.03	22.84	12.97	276.65	0.00	66.95	39.00	8,281.39
7/5/07 0:16	850.11	354,492.50	249,966.09	72,452.26	3.89	22.88	13.26	276.66	0.00	67.30	39.10	9,071.14
7/5/07 0:17	847.38	339,583.91	246,715.00	71,357.01	8.26	22.97	13.48	276.66	0.00	67.05	39.70	9,106.91
7/5/07 0:18	845.59	340,291.81	248,158.70	71,306.02	3.21	23.13	13.66	276.34	0.00	66.85	39.50	9,254.25
7/5/07 0:19	843.24	343,589.31	248,858.41	71,773.55	3.35	22.88	13.83	276.33	0.00	66.25	39.20	9,803.15
7/5/07 0:20	841.91	342,375.59	247,467.91	71,979.09	3.74	22.84	13.96	275.98	0.00	65.85	38.30	10,852.10
7/5/07 0:21	843.34	335,717.69	247,995.00	72,484.67	4.24	22.85	13.98	275.34	0.00	65.90	38.60	9,973.00
7/5/07 0:22	844.92	337,948.41	248,371.00	71,757.75	5.58	23.00	14.01	275.34	0.00	65.70	38.00	9,596.58
7/5/07 0:23	846.38	347,769.59	249,482.70	72,265.23	4.90	23.09	14.04	275.33	0.00	65.00	38.10	9,375.39
7/5/07 0:24	847.47	344,515.31	249,383.30	72,542.96	4.79	21.94	14.06	275.34	0.00	64.95	37.70	9,325.28
7/5/07 0:25	848.63	349,065.59	248,005.80	72,068.16	4.79	21.88	14.09	275.01	0.00	64.85	37.90	8,611.56
7/5/07 0:26	847.38	352,451.50	250,109.41	71,820.34	4.79	22.03	14.12	275.70	0.00	65.35	38.40	8,677.50
7/5/07 0:27	845.00	351,546.81	250,058.80	71,923.23	4.79	22.00	14.15	275.98	0.00	65.20	37.80	8,640.32
7/5/07 0:28	842.37	338,309.69	247,755.20	71,309.42	6.58	22.25	14.17	276.34	0.00	65.00	38.20	8,611.46
7/5/07 0:29	840.39	356,790.91	250,267.00	72,420.47	1.94	21.88	14.20	276.66	0.00	64.90	37.40	8,551.60
7/5/07 0:30	840.08	340,310.81	248,867.80	71,810.27	7.45	21.09	14.23	276.34	0.00	64.70	37.50	11,811.81
7/5/07 0:31	842.17	342,185.50	248,576.70	71,878.93	3.76	22.84	14.25	276.32	0.00	64.40	37.20	11,505.49
7/5/07 0:32	845.02	343,134.69	250,411.80	71,514.25	3.26	23.13	14.28	275.70	0.00	64.30	37.40	11,398.16
7/5/07 0:33	848.37	345,647.41	247,686.30	71,210.38	2.63	23.00	14.31	275.70	0.00	65.10	38.50	11,330.90
7/5/07 0:34	850.63	343,287.50	248,879.80	72,104.29	3.74	22.88	14.33	275.69	0.00	65.15	37.90	10,967.67
7/5/07 0:35	850.97	339,593.41	249,672.00	71,670.55	5.22	23.53	14.36	275.70	0.00	65.05	37.70	9,663.09
7/5/07 0:36	848.22	351,836.69	251,442.30	71,954.48	4.07	23.09	14.39	275.33	0.00	65.00	37.90	9,582.24
7/5/07 0:37	844.73	342,313.50	252,186.50	72,064.09	5.27	22.66	14.41	274.62	0.00	64.45	37.80	10,067.13
7/5/07 0:38	842.02	352,452.09	253,227.41	72,040.94	5.26	23.88	14.44	274.62	0.00	63.95	37.70	10,299.92
7/5/07 0:39	839.85	346,193.81	252,875.20	72,183.13	4.87	24.09	14.47	274.31	0.00	64.10	37.10	6,661.94
7/5/07 0:40	840.89	354,575.09	249,597.70	71,274.70	4.62	24.09	14.38	274.62	0.00	63.75	37.30	10,485.63
7/5/07 0:41	843.12	340,251.41	249,295.91	71,885.05	5.86	24.22	14.26	274.98	0.00	63.80	37.30	10,464.86
7/5/07 0:42	844.74	350,156.31	253,529.59	72,361.29	2.52	24.88	14.15	275.01	0.00	63.60	37.40	10,446.13
7/5/07 0:43	846.89	348,631.19	252,242.59	72,275.97	5.35	24.76	14.04	275.01	0.00	63.40	37.50	10,259.92
7/5/07 0:44	850.31	352,221.91	255,576.20	73,044.12	5.30	25.07	13.93	274.31	0.00	64.95	38.10	2,243.75
7/5/07 0:45	851.62	351,201.50	253,911.80	72,485.95	5.30	25.09	13.82	274.33	0.00	64.90	37.70	8,678.16
7/5/07 0:46	849.67	343,280.41	252,197.50	72,225.52	5.30	24.97	13.71	274.31	0.00	65.05	38.30	9,004.22
7/5/07 0:47	848.65	359,262.31	254,877.30	72,160.56	5.30	24.79	13.60	274.64	0.00	65.05	38.20	8,963.19
7/5/07 0:48	846.69	343,655.59	252,282.59	71,937.01	5.64	25.03	13.49	275.01	0.00	65.15	37.90	9,060.47
7/5/07 0:49	843.91	346,691.09	253,555.30	71,935.43	5.14	26.63	13.38	275.70	0.00	65.25	38.50	5,258.19

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 0:50		843.90	347,308.50	252,616.30	72,775.67	4.90	26.13	13.27	275.34	0.00	65.30	37.90
7/5/07 0:51		846.22	359,976.91	256,696.20	72,537.63	2.91	25.91	13.12	275.70	0.00	65.60	38.50
7/5/07 0:52		848.33	350,785.09	252,812.80	71,815.89	7.07	26.68	13.04	275.70	0.00	65.55	38.20
7/5/07 0:53		849.36	347,984.59	253,204.30	71,836.46	5.36	26.75	12.96	275.70	0.00	65.50	38.00
7/5/07 0:54		851.62	359,217.00	251,971.91	72,071.89	4.41	26.71	12.88	275.34	0.00	65.35	38.60
7/5/07 0:55		850.94	343,322.00	253,088.20	72,069.35	6.57	26.88	12.80	275.34	0.00	65.35	38.10
7/5/07 0:56		847.96	356,620.41	254,401.30	72,648.41	5.47	27.93	12.72	275.34	0.00	65.25	38.20
7/5/07 0:57		845.54	348,966.69	252,024.41	72,192.38	4.60	27.03	12.64	274.99	0.00	65.05	38.20
7/5/07 0:58		842.37	341,428.91	255,103.41	72,351.45	3.68	26.88	12.56	274.99	0.00	64.40	37.70
7/5/07 0:59		840.60	347,551.09	252,488.09	71,946.17	5.11	26.84	12.48	275.01	0.00	64.50	37.70
7/5/07 1:00		842.13	346,539.09	252,553.50	71,972.70	3.77	27.13	12.40	274.98	0.00	64.50	38.20
7/5/07 1:01		844.08	349,396.31	254,145.80	73,031.37	2.55	27.22	12.31	275.34	0.00	64.50	38.00
7/5/07 1:02		845.28	343,785.69	253,763.00	72,855.94	3.76	27.53	12.23	275.01	0.00	64.20	37.10
7/5/07 1:03		846.51	342,825.59	254,186.30	72,631.83	5.03	28.00	12.15	274.99	0.00	63.70	37.40
7/5/07 1:04		847.88	344,694.00	254,238.20	72,228.23	3.71	28.00	12.07	274.62	0.00	64.80	38.10
7/5/07 1:05		850.47	359,974.91	255,887.09	72,405.04	3.71	27.25	11.99	274.64	0.00	65.10	37.80
7/5/07 1:06		852.01	354,133.81	256,352.80	73,486.32	3.71	28.97	11.91	274.64	0.00	65.00	38.30
7/5/07 1:07		853.00	350,481.41	255,746.09	73,284.81	3.71	28.88	11.83	274.31	0.00	64.95	37.70
7/5/07 1:08		854.59	353,095.81	256,689.09	72,645.09	4.50	28.03	11.75	274.31	0.00	65.00	38.40
7/5/07 1:09		856.76	350,805.59	257,091.00	73,580.60	4.79	27.89	11.67	274.64	0.00	64.70	37.50
7/5/07 1:10		855.39	344,481.50	255,705.30	73,008.59	5.03	28.78	11.59	275.01	0.00	65.80	38.30
7/5/07 1:11		851.28	359,552.81	257,986.50	73,575.20	3.73	29.09	11.51	274.62	0.00	66.65	38.60
7/5/07 1:12		847.92	361,519.31	258,490.70	72,899.20	5.72	28.88	11.43	274.99	0.00	66.60	39.00
7/5/07 1:13		844.61	355,107.59	258,675.50	73,016.02	6.19	29.78	11.30	274.99	0.00	67.45	39.60
7/5/07 1:14		843.55	349,529.41	255,022.80	72,433.42	6.17	29.24	11.32	275.01	0.00	67.35	39.55
7/5/07 1:15		844.71	353,006.09	257,361.50	72,755.45	4.46	28.84	11.34	275.01	0.00	68.20	39.90
7/5/07 1:16		846.73	353,056.00	259,001.09	73,244.56	4.47	28.88	11.36	275.35	0.00	67.90	40.10
7/5/07 1:17		848.24	352,614.50	257,951.20	72,875.52	5.74	29.88	11.38	275.70	0.00	68.30	39.65
7/5/07 1:18		850.15	349,635.69	258,057.09	72,582.79	5.97	29.88	11.40	276.34	0.00	68.45	40.25
7/5/07 1:19		851.91	362,109.00	257,879.30	72,504.44	3.72	29.94	11.42	276.01	0.00	68.30	40.10
7/5/07 1:20		849.14	350,084.00	255,580.80	72,185.00	7.08	30.50	11.44	276.00	0.00	68.30	39.80
7/5/07 1:21		844.82	337,492.09	254,424.00	72,013.44	4.48	30.91	11.46	275.34	0.00	67.25	39.55
7/5/07 1:22		840.55	353,503.00	256,980.41	72,333.72	4.86	29.84	11.34	274.62	0.00	68.70	39.75
7/5/07 1:23		839.28	360,783.59	255,899.20	72,262.84	4.99	30.27	11.25	275.01	0.00	67.15	39.65
7/5/07 1:24		839.25	351,457.09	256,843.41	73,092.11	7.63	31.00	11.14	274.99	0.00	65.10	38.25
7/5/07 1:25		840.69	344,925.19	254,892.09	72,807.92	7.62	30.13	11.21	275.34	0.00	64.85	37.85
7/5/07 1:26		842.62	350,694.69	255,342.30	72,635.88	7.62	29.88	11.29	275.34	0.00	65.00	38.30
7/5/07 1:27		843.78	358,654.69	257,923.09	74,028.72	7.62	29.94	11.31	276.33	0.00	65.10	38.00
7/5/07 1:28		844.80	348,231.09	252,208.30	72,589.86	7.24	30.19	11.32	276.34	0.00	65.70	38.35
7/5/07 1:29		844.38	343,178.69	252,453.91	72,112.66	3.93	30.88	11.33	276.33	0.00	66.65	38.85
7/5/07 1:30		841.91	352,591.19	253,159.30	72,209.20	3.11	30.97	11.35	275.98	0.00	67.15	39.35
7/5/07 1:31		839.50	343,328.31	252,071.70	71,809.35	4.73	30.88	11.36	275.70	0.00	67.55	39.20
7/5/07 1:32		836.05	348,231.19	253,656.09	72,359.50	4.90	30.84	11.37	275.34	0.00	68.55	40.45
7/5/07 1:33		834.92	354,135.59	254,450.30	73,110.23	4.77	31.13	11.38	275.20	0.00	69.35	40.75
7/5/07 1:34		835.68	349,694.91	255,389.91	72,863.86	7.15	31.13	11.40	274.62	0.00	69.20	41.10
7/5/07 1:35		836.81	356,631.91	253,423.41	72,381.92	7.18	31.13	11.41	275.01	0.00	70.80	41.60
7/5/07 1:36		837.61	349,860.41	251,449.70	71,435.76	5.96	30.97	11.42	275.01	0.00	71.70	41.50
7/5/07 1:37		839.04	349,230.19	253,184.41	72,394.11	4.44	30.75	11.43	275.34	0.00	72.65	41.60
7/5/07 1:38		840.09	343,692.31	250,064.80	72,244.42	6.25	30.96	11.45	275.34	0.00	70.75	41.70
7/5/07 1:39		839.79	337,109.50	249,391.30	71,917.89	4.52	31.25	11.46	275.01	0.00	71.85	41.80

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 1:40	838.77	362,726.00	253,673.70	73,284.73	2.65	31.09	11.47	274.99	0.00	71.70	41.75	9,594.79
7/5/07 1:41	837.36	342,243.41	251,032.30	72,913.86	9.45	30.63	11.50	275.01	0.00	71.95	41.70	9,804.93
7/5/07 1:42	834.61	345,743.50	252,814.30	73,503.49	5.51	31.00	11.47	275.01	0.00	71.20	41.55	9,844.58
7/5/07 1:43	832.89	340,919.69	249,414.59	72,439.65	6.54	30.84	11.44	275.01	0.00	70.55	41.55	8,991.13
7/5/07 1:44	833.36	345,670.59	249,510.00	72,372.70	3.78	31.13	11.41	275.01	0.00	65.60	38.85	8,997.31
7/5/07 1:45	834.01	339,584.81	247,655.20	72,200.07	3.78	31.13	11.38	275.01	0.00	65.05	38.05	8,844.47
7/5/07 1:46	835.05	339,446.81	246,315.30	72,303.52	3.78	29.29	11.34	275.35	0.00	64.95	38.30	8,853.25
7/5/07 1:47	835.83	346,268.19	248,423.09	72,719.60	3.78	30.00	11.31	275.01	0.00	65.05	38.10	2,636.54
7/5/07 1:48	837.27	339,550.00	246,187.70	71,987.16	5.61	29.64	11.28	275.34	0.00	65.25	38.10	9,269.67
7/5/07 1:49	837.39	344,678.81	249,407.20	72,846.35	5.81	29.88	11.25	275.34	0.00	65.85	38.85	9,225.13
7/5/07 1:50	837.44	351,556.91	248,754.00	72,526.84	6.13	30.03	11.22	275.35	0.00	67.15	39.30	8,945.72
7/5/07 1:51	836.62	351,265.00	248,664.70	72,981.05	5.93	28.96	11.27	275.34	0.00	67.85	39.70	9,441.17
7/5/07 1:52	835.70	344,380.91	247,306.91	71,969.48	6.86	29.03	11.44	275.70	0.00	68.15	40.10	7,001.71
7/5/07 1:53	836.71	340,130.09	246,409.20	72,545.45	5.23	28.88	11.49	275.70	0.00	69.35	40.30	10,458.16
7/5/07 1:54	839.04	350,422.59	247,333.59	72,442.87	4.64	29.00	11.55	275.70	0.00	69.55	40.60	10,499.44
7/5/07 1:55	841.29	337,099.19	243,250.80	71,711.61	3.86	28.88	11.60	276.34	0.00	69.10	40.60	10,492.79
7/5/07 1:56	842.68	334,175.19	245,399.20	72,212.65	4.17	29.69	11.65	275.98	0.00	68.95	40.60	10,563.46
7/5/07 1:57	844.37	345,966.41	244,425.50	71,075.97	5.87	30.13	11.71	275.34	0.00	69.25	40.50	8,350.16
7/5/07 1:58	844.24	352,984.09	245,741.91	72,658.26	3.72	28.94	11.65	275.33	0.00	68.75	40.00	9,848.94
7/5/07 1:59	841.36	337,679.91	248,469.80	72,367.70	6.12	28.97	11.55	275.01	0.00	67.30	39.85	9,822.84
7/5/07 2:00	837.55	332,076.69	243,767.41	71,853.79	5.04	28.88	11.45	274.62	0.00	66.75	38.90	9,391.31
7/5/07 2:01	834.20	340,357.81	247,339.50	72,220.20	2.08	27.88	11.34	274.31	0.00	64.70	37.80	9,504.05
7/5/07 2:02	831.68	346,240.69	247,019.00	73,139.55	3.00	27.88	11.24	274.35	0.00	63.15	36.65	0.00
7/5/07 2:03	830.03	333,932.91	245,870.59	72,249.08	5.22	28.69	11.13	274.31	0.00	61.50	35.80	0.00
7/5/07 2:04	829.71	344,587.31	248,250.00	72,645.09	2.15	28.63	10.94	274.31	0.00	64.35	37.90	0.00
7/5/07 2:05	829.20	347,982.50	248,757.59	72,371.48	2.15	28.59	10.74	273.65	0.00	64.95	37.70	0.00
7/5/07 2:06	830.57	355,337.31	249,344.00	73,369.13	2.15	28.61	10.54	273.65	0.00	64.80	38.10	0.00
7/5/07 2:07	830.13	340,594.09	247,871.70	72,441.34	2.15	28.66	10.34	273.65	0.00	64.80	38.00	0.00
7/5/07 2:08	829.73	348,895.69	250,177.41	72,085.53	5.05	27.04	10.16	273.66	0.00	65.00	38.10	0.00
7/5/07 2:09	830.61	345,875.81	249,437.50	73,056.56	4.20	27.00	10.16	274.31	0.00	65.40	38.15	0.00
7/5/07 2:10	831.38	332,682.09	246,997.00	72,144.08	5.80	27.00	10.16	274.62	0.00	65.85	38.40	0.00
7/5/07 2:11	831.68	347,487.69	250,423.00	72,401.28	3.61	26.88	10.16	275.32	0.00	66.15	38.65	0.00
7/5/07 2:12	832.66	351,065.81	253,278.80	72,586.81	4.57	26.00	10.16	275.33	0.00	65.95	38.55	0.00
7/5/07 2:13	834.56	352,226.31	253,619.41	73,477.66	5.04	25.94	10.16	276.00	0.00	66.35	39.05	0.00
7/5/07 2:14	835.20	341,774.69	250,791.59	72,435.52	6.56	26.81	10.16	275.98	0.00	67.30	39.45	0.00
7/5/07 2:15	833.57	356,990.19	253,449.50	72,645.05	5.40	26.97	10.16	275.70	0.00	67.05	39.10	8,010.88
7/5/07 2:16	833.47	350,423.69	252,511.00	73,014.36	6.92	26.00	10.16	276.00	0.00	66.95	39.35	8,592.05
7/5/07 2:17	835.31	348,137.91	252,972.00	72,798.09	4.77	25.91	10.31	276.64	0.00	67.30	39.50	8,551.44
7/5/07 2:18	836.97	341,440.69	253,180.80	72,766.98	5.23	25.75	10.38	277.00	0.00	68.60	39.25	7,527.76
7/5/07 2:19	837.75	333,878.31	252,394.41	73,081.16	3.86	27.00	10.46	277.12	0.00	68.55	40.00	7,175.22
7/5/07 2:20	838.08	352,156.59	257,735.00	73,651.41	4.68	25.91	10.53	276.65	0.00	68.80	40.25	5,798.54
7/5/07 2:21	838.73	362,142.69	256,898.91	73,295.40	5.78	25.99	10.61	276.65	0.00	68.25	40.10	5,926.59
7/5/07 2:22	838.36	354,059.50	261,044.50	74,136.41	8.65	26.00	10.68	275.70	0.00	67.85	39.50	6,382.04
7/5/07 2:23	837.76	360,050.81	255,235.09	72,677.31	7.12	26.50	10.76	274.61	0.00	67.55	39.70	5,860.90
7/5/07 2:24	838.29	343,472.50	251,618.20	72,529.25	6.49	26.09	10.84	274.31	0.00	65.15	38.55	6,910.22
7/5/07 2:25	838.69	347,245.69	255,037.91	72,623.76	6.49	26.76	10.91	273.66	0.00	65.10	37.75	7,314.76
7/5/07 2:26	838.80	360,254.81	255,112.41	72,612.71	6.49	26.59	10.69	273.38	0.00	65.05	38.15	8,687.83
7/5/07 2:27	839.68	352,435.09	254,897.20	73,021.78	6.49	26.00	10.41	273.00	0.00	64.75	37.90	7,876.40
7/5/07 2:28	840.20	347,953.91	253,868.20	72,523.45	6.75	27.22	10.12	273.66	0.00	64.90	38.00	7,087.55
7/5/07 2:29	841.11	338,875.19	251,078.50	72,658.53	5.76	27.77	9.83	273.65	0.00	65.45	38.00	6,001.48

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 2:30		841.58	345,271.91	251,185.70	72,690.95	4.62	27.46	9.55	272.69	0.00	66.55	38.75
7/5/07 2:31		841.63	342,310.00	252,998.20	73,141.89	4.93	27.91	9.26	272.69	0.00	67.25	37.45
7/5/07 2:32		841.32	351,846.19	252,110.70	72,220.03	5.82	27.53	8.97	272.01	0.00	67.25	38.80
7/5/07 2:33		841.77	341,675.09	252,647.91	73,321.99	6.59	27.75	8.68	272.00	0.00	67.80	37.40
7/5/07 2:34		841.03	374,927.91	251,571.91	73,133.35	6.50	27.91	8.40	272.99	0.00	67.35	39.10
7/5/07 2:35		840.83	347,888.50	251,224.00	73,040.20	7.73	27.84	8.11	273.37	0.00	68.15	38.25
7/5/07 2:36		841.14	353,576.41	252,106.80	73,485.81	6.07	27.63	7.82	273.96	0.00	69.00	39.38
7/5/07 2:37		841.30	341,567.09	247,547.20	72,294.27	8.61	27.07	7.54	274.31	0.00	70.18	39.05
7/5/07 2:38		841.93	345,605.09	250,329.80	73,215.92	5.16	26.88	7.25	274.98	0.00	69.15	39.40
7/5/07 2:39		843.14	349,673.69	248,838.30	72,403.68	5.91	26.75	6.99	275.33	0.00	70.35	41.20
7/5/07 2:40		843.75	343,877.31	249,953.00	72,848.20	6.56	26.97	7.06	275.70	0.00	70.70	41.65
7/5/07 2:41		844.05	347,963.00	247,891.70	72,753.73	5.82	27.00	7.13	275.70	0.00	70.90	41.40
7/5/07 2:42		844.39	333,560.09	245,800.91	72,661.07	5.69	27.00	7.12	276.00	0.00	71.25	41.55
7/5/07 2:43		845.05	346,908.19	244,365.09	72,577.37	3.39	26.75	7.16	276.01	0.00	69.80	41.65
7/5/07 2:44		844.99	345,931.41	245,537.80	72,621.95	6.65	27.00	7.19	276.34	0.00	65.50	38.00
7/5/07 2:45		844.87	335,973.00	242,129.91	72,001.46	6.65	27.03	7.23	276.34	0.00	65.05	38.15
7/5/07 2:46		845.25	332,781.41	243,778.00	72,139.95	6.65	27.00	7.27	275.34	0.00	65.10	38.10
7/5/07 2:47		845.90	346,042.09	246,396.30	72,873.46	6.65	26.03	7.30	275.34	0.00	64.95	37.75
7/5/07 2:48		846.54	332,922.31	242,306.80	72,456.73	5.46	26.81	7.34	274.99	0.00	65.30	38.35
7/5/07 2:49		846.70	342,888.50	244,129.09	72,053.73	3.53	27.13	7.29	274.99	0.00	65.80	38.50
7/5/07 2:50		847.18	346,850.81	243,487.00	72,598.01	4.65	26.69	7.18	274.30	0.00	65.80	38.70
7/5/07 2:51		847.55	346,032.31	244,964.59	72,655.14	6.83	26.88	7.06	273.97	0.00	66.05	38.50
7/5/07 2:52		847.78	340,271.19	242,704.30	71,590.98	6.23	26.98	6.98	273.98	0.00	66.55	38.90
7/5/07 2:53		848.53	349,329.69	247,560.91	72,671.66	5.50	26.97	6.83	273.97	0.00	66.45	38.90
7/5/07 2:54		849.61	339,938.50	245,685.00	72,227.51	5.58	26.97	6.67	273.97	0.00	66.25	38.65
7/5/07 2:55		849.82	337,067.41	246,253.09	73,065.59	4.95	26.00	6.52	274.30	0.00	66.05	38.85
7/5/07 2:56		850.70	344,667.81	246,551.30	72,489.89	4.44	26.13	6.37	274.61	0.00	66.10	38.50
7/5/07 2:57		851.38	329,436.19	245,308.00	72,757.24	4.48	26.00	6.38	275.33	0.00	66.05	38.40
7/5/07 2:58		847.51	348,456.59	247,223.70	72,449.10	3.68	25.98	6.41	276.00	0.00	65.40	38.15
7/5/07 2:59		842.75	338,264.50	247,293.09	73,313.35	4.59	25.88	6.45	275.98	0.00	64.60	37.90
7/5/07 3:00		839.25	348,014.50	246,744.00	71,763.66	5.00	25.75	6.63	276.65	0.00	64.90	37.95
7/5/07 3:01		834.96	346,133.81	248,675.91	72,959.11	5.31	26.03	6.81	277.01	0.00	64.30	37.70
7/5/07 3:02		831.93	344,887.69	248,066.80	72,466.63	5.19	26.00	6.99	277.01	0.00	63.75	37.15
7/5/07 3:03		832.23	342,416.81	246,671.70	71,873.15	5.90	25.97	7.16	276.65	0.00	63.45	37.15
7/5/07 3:04		834.81	342,648.41	249,549.70	72,739.73	4.25	25.25	7.34	276.33	0.00	64.85	37.65
7/5/07 3:05		838.07	333,817.09	245,779.70	72,334.26	4.26	25.09	7.52	276.65	0.00	65.05	38.10
7/5/07 3:06		841.23	331,992.91	246,898.00	72,188.50	4.25	26.48	7.70	276.66	0.00	65.10	38.00
7/5/07 3:07		842.67	345,109.81	247,969.70	72,790.84	4.26	26.38	7.87	276.33	0.00	65.05	37.80
7/5/07 3:08		841.27	352,143.50	248,790.91	71,782.42	5.53	26.25	8.05	276.34	0.00	64.85	38.05
7/5/07 3:09		839.33	347,407.81	248,811.91	72,286.18	4.87	26.22	8.23	276.01	0.00	65.30	38.05
7/5/07 3:10		837.65	351,709.31	249,157.41	72,430.84	5.20	25.66	8.41	276.32	0.00	65.70	38.70
7/5/07 3:11		834.61	351,701.59	253,405.59	73,546.85	6.16	25.84	8.49	276.32	0.00	65.95	38.55
7/5/07 3:12		833.56	339,665.91	247,686.09	72,727.45	7.02	26.00	8.53	275.98	0.00	65.55	38.50
7/5/07 3:13		835.27	357,214.00	248,399.41	72,532.82	3.93	25.97	8.56	275.34	0.00	65.55	38.45
7/5/07 3:14		836.12	336,630.69	247,804.20	72,326.60	8.71	26.03	8.60	275.34	0.00	66.65	38.80
7/5/07 3:15		837.93	347,294.81	248,685.50	72,767.41	4.64	26.13	8.64	275.34	0.00	65.90	38.60
7/5/07 3:16		840.49	339,527.00	247,569.80	72,480.77	5.77	25.88	8.56	275.34	0.00	65.85	38.75
7/5/07 3:17		842.04	339,380.81	244,908.41	72,277.28	3.46	25.91	8.58	275.33	0.00	66.40	38.75
7/5/07 3:18		841.17	347,496.91	243,690.80	71,951.84	4.79	25.75	8.63	275.34	0.00	66.80	38.90
7/5/07 3:19		839.88	335,334.19	244,175.00	73,153.84	5.36	25.78	8.59	274.99	0.00	66.90	39.15

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 3:20	838.46	342,514.50	242,449.80	71,794.52	4.08	26.00	8.54	275.01	0.00	66.90	39.25	9,096.39
7/5/07 3:21	836.84	335,859.41	244,177.00	72,064.52	3.84	26.25	8.50	275.35	0.00	67.30	39.15	3,715.91
7/5/07 3:22	836.73	332,158.31	245,057.50	72,111.36	4.78	26.00	8.46	275.01	0.00	67.75	39.45	10,691.04
7/5/07 3:23	836.47	342,918.81	244,510.09	72,550.09	5.77	26.00	8.42	275.01	0.00	67.85	39.65	10,401.45
7/5/07 3:24	836.97	340,703.50	246,513.00	73,593.66	5.76	25.84	8.37	275.01	0.00	65.65	38.20	10,328.64
7/5/07 3:25	838.03	345,659.59	246,273.30	72,869.92	5.76	26.00	8.33	275.34	0.00	65.05	37.70	10,415.95
7/5/07 3:26	839.42	349,087.31	244,736.30	72,867.34	5.76	26.00	8.29	275.32	0.00	64.80	38.05	3,386.86
7/5/07 3:27	838.47	335,830.81	241,313.70	72,202.23	5.76	26.97	8.24	275.35	0.00	65.05	38.00	8,963.96
7/5/07 3:28	837.84	338,247.69	241,229.20	72,675.32	4.44	26.88	8.20	274.62	0.00	65.00	38.10	8,328.37
7/5/07 3:29	836.95	341,265.91	241,096.80	72,418.36	5.15	26.25	8.16	274.31	0.00	64.85	37.90	8,472.13
7/5/07 3:30	836.20	342,423.19	243,944.80	72,738.52	4.43	26.63	8.12	274.31	0.00	65.35	38.10	8,557.71
7/5/07 3:31	835.26	345,315.41	244,429.70	73,149.16	6.08	26.63	8.07	274.31	0.00	66.10	38.60	13,279.29
7/5/07 3:32	836.88	326,000.41	240,517.30	71,609.26	6.83	26.31	8.03	274.31	0.00	66.65	38.80	12,852.62
7/5/07 3:33	839.15	337,868.59	241,922.50	72,281.11	3.76	26.95	7.99	274.31	0.00	67.10	39.15	12,576.60
7/5/07 3:34	841.30	343,236.81	244,766.59	72,906.91	5.47	26.41	7.95	275.01	0.00	67.35	39.45	12,680.29
7/5/07 3:35	843.91	339,898.69	244,821.70	72,848.88	6.52	26.59	7.90	275.34	0.00	69.05	40.05	12,792.85
7/5/07 3:36	845.97	335,778.00	244,726.59	72,881.82	6.24	26.50	7.86	275.70	0.00	69.55	40.95	11,448.62
7/5/07 3:37	844.47	337,062.31	244,398.70	72,744.77	5.09	26.63	7.82	276.00	0.00	70.60	41.05	11,896.58
7/5/07 3:38	841.39	349,544.19	244,712.59	72,769.98	4.14	26.50	7.87	276.66	0.00	70.75	41.40	12,014.74
7/5/07 3:39	840.12	349,297.50	243,622.91	72,716.30	4.95	26.25	8.03	276.66	0.00	71.35	41.90	11,041.69
7/5/07 3:40	837.37	330,364.69	241,558.00	72,326.88	5.43	26.99	8.19	276.33	0.00	71.25	41.75	11,293.84
7/5/07 3:41	835.75	343,195.19	243,188.59	73,296.22	4.32	26.63	8.35	275.99	0.00	69.85	41.58	12,620.10
7/5/07 3:42	837.52	337,723.41	239,516.09	72,110.47	6.16	26.47	8.29	275.70	0.00	72.40	41.85	11,107.97
7/5/07 3:43	839.81	329,802.81	241,366.50	73,074.52	2.95	26.96	8.26	275.70	0.00	72.15	41.75	11,214.07
7/5/07 3:44	841.35	331,801.81	238,591.80	71,975.53	3.37	26.61	8.23	275.01	0.00	66.10	38.50	10,914.97
7/5/07 3:45	844.46	351,004.91	249,078.09	73,297.65	3.37	26.28	8.20	274.64	0.00	65.00	38.25	10,932.67
7/5/07 3:46	846.34	335,446.19	240,902.41	72,537.77	3.37	26.38	8.35	275.34	0.00	65.00	38.00	9,034.21
7/5/07 3:47	844.28	339,810.50	243,919.59	73,240.26	3.37	26.38	8.39	275.33	0.00	65.05	37.85	9,500.17
7/5/07 3:48	841.34	344,702.31	241,318.59	72,674.02	5.91	26.50	8.43	275.34	0.00	65.20	38.25	9,502.35
7/5/07 3:49	838.75	339,717.41	240,868.20	72,280.09	6.57	26.38	8.46	275.35	0.00	65.50	38.25	9,595.86
7/5/07 3:50	835.69	340,175.00	242,954.41	72,550.97	4.33	26.34	8.50	275.33	0.00	65.40	38.25	9,407.74
7/5/07 3:51	834.50	340,542.19	242,784.30	72,775.91	6.06	26.50	8.54	275.34	0.00	65.75	38.25	10,131.50
7/5/07 3:52	834.98	335,648.09	241,983.30	72,530.73	5.87	26.50	8.58	275.70	0.00	65.95	38.50	9,758.15
7/5/07 3:53	836.47	336,715.91	243,736.70	72,680.40	3.23	26.38	8.62	275.98	0.00	65.85	38.45	9,485.02
7/5/07 3:54	838.22	336,353.50	242,992.80	72,373.13	4.94	25.78	8.65	275.98	0.00	65.65	38.50	9,413.12
7/5/07 3:55	841.03	345,455.09	246,980.00	74,203.20	3.99	25.97	8.69	276.48	0.00	65.60	38.25	3,533.46
7/5/07 3:56	842.43	340,387.41	241,876.59	72,687.02	7.23	25.25	8.73	276.63	0.00	65.75	38.45	8,610.13
7/5/07 3:57	840.93	340,542.69	243,774.41	72,033.83	5.26	25.75	8.77	276.65	0.00	65.50	38.80	8,535.26
7/5/07 3:58	838.87	338,631.41	243,718.70	72,651.88	3.73	26.00	8.81	276.32	0.00	65.30	38.10	8,442.58
7/5/07 3:59	835.78	338,553.31	243,620.20	72,135.19	5.33	24.94	8.84	275.70	0.00	65.40	38.20	8,474.45
7/5/07 4:00	833.07	341,962.69	246,255.59	72,642.98	4.75	24.91	8.88	275.72	0.00	65.30	38.35	3,478.01
7/5/07 4:01	833.43	345,528.50	244,515.80	72,735.61	5.03	25.00	8.92	275.84	0.00	65.40	37.80	11,378.41
7/5/07 4:02	835.79	338,965.19	247,293.80	72,806.95	5.98	24.92	8.96	276.34	0.00	65.35	38.35	11,383.50
7/5/07 4:03	838.71	341,373.09	245,583.91	72,710.56	4.37	25.75	9.00	276.32	0.00	65.65	38.25	11,391.69
7/5/07 4:04	841.35	343,891.50	243,209.30	71,993.27	4.33	25.63	9.04	276.33	0.00	64.90	37.95	11,348.13
7/5/07 4:05	844.29	340,330.41	245,789.70	72,554.89	4.33	25.94	9.07	275.70	0.00	64.80	37.95	3,970.89
7/5/07 4:06	845.30	347,716.69	247,516.80	72,599.09	4.33	25.03	9.11	275.70	0.00	64.55	38.00	9,609.42
7/5/07 4:07	842.50	333,664.81	244,829.20	72,154.97	4.33	25.28	9.15	275.70	0.00	65.20	37.95	10,366.54
7/5/07 4:08	840.97	353,471.50	248,990.20	72,098.37	2.34	25.78	9.19	275.70	0.00	65.25	37.85	9,795.60
7/5/07 4:09	837.54	338,850.19	246,100.80	72,371.64	7.30	25.88	9.23	274.98	0.00	65.40	38.50	10,349.27

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 4:10	835.36	345,874.81	248,266.59	72,241.80	4.03	26.13	9.26	274.99	0.00	65.30	38.10	10,612.48
7/5/07 4:11	836.87	348,397.09	249,201.70	72,973.78	5.82	26.13	9.30	274.65	0.00	65.40	38.20	10,400.69
7/5/07 4:12	840.02	350,208.31	246,864.30	72,430.57	5.00	25.91	9.34	274.62	0.00	65.30	38.35	10,340.17
7/5/07 4:13	840.97	342,792.81	246,436.20	72,217.88	6.34	25.88	9.38	274.62	0.00	65.80	38.45	10,310.14
7/5/07 4:14	842.97	349,355.31	251,057.30	72,330.80	4.86	25.88	9.42	274.62	0.00	66.10	38.40	10,345.29
7/5/07 4:15	845.67	337,828.00	249,210.59	72,002.74	5.13	24.88	9.45	274.64	0.00	66.30	38.65	8,686.62
7/5/07 4:16	845.11	357,940.81	253,970.41	73,276.14	6.63	25.00	9.48	274.62	0.00	67.25	39.30	8,928.65
7/5/07 4:17	842.54	349,330.19	252,597.20	73,115.59	8.00	25.38	9.50	275.34	0.00	66.95	39.55	8,888.89
7/5/07 4:18	841.09	356,424.00	252,147.50	72,615.88	6.25	25.88	9.62	276.01	0.00	67.40	39.20	8,712.46
7/5/07 4:19	838.77	334,585.91	247,046.70	72,268.10	6.50	25.78	9.74	276.01	0.00	68.15	39.35	8,815.67
7/5/07 4:20	837.82	343,582.50	249,486.30	72,238.84	3.62	25.75	9.86	276.32	0.00	67.55	39.80	11,666.04
7/5/07 4:21	840.34	352,281.00	251,170.80	72,723.29	5.59	25.94	9.98	276.33	0.00	67.85	39.95	10,393.82
7/5/07 4:22	843.94	349,186.91	253,761.80	73,487.79	6.19	26.00	10.10	276.65	0.00	68.45	40.40	10,442.96
7/5/07 4:23	846.26	337,293.50	249,540.00	72,921.08	6.94	25.88	10.22	276.65	0.00	69.60	40.60	10,331.88
7/5/07 4:24	849.10	356,667.41	250,376.09	72,663.96	4.96	25.88	10.34	276.33	0.00	65.30	38.15	10,379.03
7/5/07 4:25	851.60	339,938.41	248,138.80	72,970.38	4.96	25.13	10.46	276.33	0.00	64.95	38.10	9,184.66
7/5/07 4:26	850.33	345,400.09	246,884.80	71,968.73	4.96	25.25	10.57	275.85	0.00	64.95	38.00	9,210.99
7/5/07 4:27	846.78	339,182.31	250,480.30	74,043.00	4.96	25.25	10.69	275.70	0.00	64.85	37.95	9,103.33
7/5/07 4:28	844.45	342,662.09	250,049.30	73,501.70	5.45	25.38	10.71	275.69	0.00	64.95	38.05	8,886.83
7/5/07 4:29	841.54	345,179.00	251,861.00	73,454.02	6.03	25.13	10.70	275.70	0.00	65.45	37.90	8,896.88
7/5/07 4:30	840.62	341,375.81	247,539.30	74,249.21	6.98	25.13	10.68	275.34	0.00	65.75	38.60	11,808.85
7/5/07 4:31	841.88	338,374.09	242,632.30	72,383.62	6.47	25.25	10.67	275.34	0.00	65.90	38.35	11,549.53
7/5/07 4:32	843.83	348,488.59	248,975.91	73,235.07	2.89	25.25	10.66	275.32	0.00	66.35	38.60	11,328.22
7/5/07 4:33	844.74	331,954.81	245,672.80	73,077.84	6.62	25.00	10.60	275.34	0.00	66.25	38.60	11,388.38
7/5/07 4:34	845.55	341,630.31	244,448.20	73,079.46	4.97	26.13	10.59	275.01	0.00	66.40	38.85	6,545.36
7/5/07 4:35	847.04	339,313.09	246,940.91	73,712.16	3.96	25.00	10.59	274.99	0.00	66.85	39.15	10,960.55
7/5/07 4:36	849.04	336,088.09	242,658.00	73,223.34	4.89	25.16	10.58	275.34	0.00	67.50	39.35	10,745.15
7/5/07 4:37	849.72	338,149.91	243,711.30	73,735.38	4.33	25.38	10.57	275.34	0.00	68.25	39.55	10,678.94
7/5/07 4:38	850.12	349,830.69	245,374.09	72,235.45	5.13	25.88	10.56	275.34	0.00	68.45	39.65	10,726.75
7/5/07 4:39	850.89	343,433.09	244,688.50	72,263.06	5.65	25.06	10.55	275.34	0.00	68.40	39.65	4,033.96
7/5/07 4:40	851.03	332,916.31	243,448.00	72,867.51	4.01	24.75	10.54	275.34	0.00	68.80	40.55	8,861.82
7/5/07 4:41	847.62	348,051.31	245,092.91	73,261.02	4.40	25.00	10.54	275.70	0.00	69.15	40.95	8,837.45
7/5/07 4:42	843.13	339,497.50	240,756.09	72,446.11	5.10	25.91	10.53	275.70	0.00	69.05	40.30	9,092.16
7/5/07 4:43	838.35	339,749.91	242,942.09	72,781.71	4.18	26.03	10.48	275.34	0.00	68.85	40.78	8,916.33
7/5/07 4:44	834.99	327,975.41	240,822.20	72,335.38	4.18	26.00	10.41	276.00	0.00	64.82	38.08	4,026.10
7/5/07 4:45	834.77	344,657.31	248,658.00	72,604.60	4.18	25.75	10.33	275.34	0.00	64.75	38.20	11,432.43
7/5/07 4:46	836.07	344,365.59	246,324.80	71,856.65	4.18	25.97	10.26	275.34	0.00	65.05	37.85	11,241.69
7/5/07 4:47	838.66	332,816.00	241,391.80	72,631.68	4.18	26.75	10.19	275.34	0.00	65.00	37.90	11,325.77
7/5/07 4:48	840.40	336,667.00	242,911.80	72,627.78	3.13	27.88	10.11	275.34	0.00	65.25	37.95	11,371.07
7/5/07 4:49	842.01	330,376.81	243,531.09	72,069.02	3.31	27.75	10.04	274.62	0.00	65.30	38.50	7,860.55
7/5/07 4:50	842.00	346,373.50	244,238.20	72,855.02	3.28	26.75	9.97	274.31	0.00	65.30	38.50	10,472.60
7/5/07 4:51	838.28	334,548.31	240,004.70	71,570.81	5.15	27.01	9.89	274.31	0.00	66.40	38.55	10,499.10
7/5/07 4:52	834.22	334,804.81	241,982.91	72,361.20	2.27	27.84	9.82	274.31	0.00	66.55	39.05	10,188.37
7/5/07 4:53	830.93	342,585.19	245,368.20	72,396.54	3.28	27.81	9.75	274.31	0.00	66.80	39.15	10,504.45
7/5/07 4:54	829.85	345,156.09	249,464.80	72,902.84	3.81	27.88	9.67	275.33	0.00	66.85	38.80	11,901.38
7/5/07 4:55	831.25	340,077.09	239,416.70	72,213.99	6.40	27.81	9.60	275.33	0.00	67.10	39.30	10,537.13
7/5/07 4:56	833.28	336,270.69	243,441.00	73,187.78	2.91	27.88	9.53	274.99	0.00	66.60	39.10	10,545.01
7/5/07 4:57	835.42	336,903.09	241,557.59	71,897.59	3.76	28.88	9.49	275.98	0.00	67.40	39.10	10,560.42
7/5/07 4:58	836.51	340,769.19	243,979.00	72,641.44	3.40	28.97	9.43	275.34	0.00	67.00	38.80	10,540.11
7/5/07 4:59	837.10	344,910.81	243,159.50	72,637.56	4.95	28.88	9.37	275.33	0.00	67.45	39.70	9,487.83

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/07 5:00		836.18	339,281.09	244,548.50	73,243.41	3.03	29.00	9.32	275.01	0.00	67.45	39.25
7/07 5:01		834.21	341,542.81	240,706.41	72,718.68	3.69	28.94	9.26	275.01	0.00	66.80	38.95
7/07 5:02		831.37	331,730.91	243,846.70	72,470.98	4.76	30.03	9.20	274.64	0.00	67.15	39.70
7/07 5:03		828.52	356,584.91	252,109.30	73,389.23	3.69	29.00	9.15	274.99	0.00	66.90	39.00
7/07 5:04		828.47	349,290.91	248,112.09	73,209.63	6.98	29.13	9.09	274.65	0.00	65.10	37.90
7/07 5:05		829.96	347,175.81	243,736.30	72,598.11	6.98	29.38	9.05	275.34	0.00	65.10	38.50
7/07 5:06		830.16	354,427.41	250,338.09	73,410.62	6.98	30.22	9.05	275.34	0.00	65.15	37.60
7/07 5:07		830.81	339,687.00	246,093.70	72,788.73	6.98	28.91	9.06	275.34	0.00	65.05	38.10
7/07 5:08		832.54	338,974.59	245,775.20	73,398.84	3.21	29.59	9.07	275.33	0.00	65.15	38.00
7/07 5:09		833.74	341,106.69	246,131.59	72,494.13	3.87	30.00	9.07	275.34	0.00	65.15	37.80
7/07 5:10		833.80	341,383.81	249,907.41	73,303.34	3.11	30.00	9.08	275.70	0.00	65.85	38.90
7/07 5:11		833.45	350,347.81	256,020.20	73,794.88	5.35	29.56	9.09	275.70	0.00	65.80	38.50
7/07 5:12		833.24	338,880.69	249,981.30	73,607.97	6.10	30.00	9.10	275.98	0.00	66.40	39.00
7/07 5:13		832.98	351,675.50	254,283.00	72,928.95	4.39	30.19	9.10	276.00	0.00	67.00	39.30
7/07 5:14		834.22	350,816.31	248,195.70	73,098.71	4.96	29.63	9.11	276.32	0.00	67.00	39.20
7/07 5:15		835.74	351,240.91	251,009.30	73,947.35	4.55	29.84	9.12	276.32	0.00	67.30	39.70
7/07 5:16		836.57	345,730.50	248,753.41	72,964.08	5.07	30.24	9.12	276.34	0.00	67.55	38.90
7/07 5:17		836.69	343,154.19	248,132.70	73,758.02	4.71	29.88	9.13	276.01	0.00	68.35	39.60
7/07 5:18		838.09	345,895.00	250,908.70	73,865.94	3.71	30.00	9.14	276.34	0.00	67.85	39.60
7/07 5:19		838.69	339,950.81	249,494.70	73,387.93	5.91	30.63	9.15	276.34	0.00	68.05	39.40
7/07 5:20		839.03	347,879.19	252,093.41	73,526.26	3.57	30.84	9.15	275.70	0.00	68.85	40.10
7/07 5:21		838.89	342,643.19	247,894.09	73,815.21	5.67	30.63	9.16	275.34	0.00	69.00	40.90
7/07 5:22		839.10	344,627.31	250,832.59	73,434.55	4.17	31.16	9.17	275.34	0.00	69.05	40.30
7/07 5:23		840.47	352,260.91	252,242.80	72,942.73	3.66	30.83	9.18	274.62	0.00	69.40	41.00
7/07 5:24		842.14	339,010.31	247,957.80	72,933.90	8.04	31.00	9.18	274.62	0.00	65.10	38.30
7/07 5:25		844.77	355,022.19	251,144.20	73,207.24	8.04	31.34	9.19	274.31	0.00	64.80	38.10
7/07 5:26		846.86	346,466.31	248,395.70	72,861.08	8.04	30.91	9.20	275.01	0.00	64.70	38.10
7/07 5:27		848.69	340,550.81	250,442.70	73,215.58	8.04	30.88	9.21	275.33	0.00	65.05	37.70
7/07 5:28		850.09	339,348.09	247,450.09	73,075.02	6.26	31.06	9.21	275.01	0.00	64.90	38.20
7/07 5:29		848.87	354,940.00	250,694.59	72,715.14	3.00	30.82	9.22	275.70	0.00	65.05	37.40
7/07 5:30		845.86	342,000.09	250,054.80	73,837.74	5.66	29.85	9.23	275.98	0.00	63.65	36.90
7/07 5:31		843.17	342,263.19	246,891.70	73,002.45	5.55	30.88	9.23	275.70	0.00	62.50	36.90
7/07 5:32		840.24	340,020.50	249,779.00	73,215.55	3.05	30.88	9.24	275.67	0.00	61.05	35.60
7/07 5:33		838.03	347,217.69	248,264.50	72,867.74	6.12	31.72	9.25	275.98	0.00	60.50	35.30
7/07 5:34		837.81	354,132.59	250,873.30	73,030.26	3.67	31.88	9.26	275.51	0.00	59.85	34.50
7/07 5:35		837.44	346,031.50	253,403.50	73,552.98	6.97	31.63	9.26	275.34	0.00	59.30	34.90
7/07 5:36		837.48	353,191.69	249,127.20	72,619.09	5.42	31.84	9.27	275.01	0.00	59.30	34.50
7/07 5:37		836.66	346,150.50	252,531.41	73,536.13	6.04	31.78	9.28	274.64	0.00	59.85	35.40
7/07 5:38		836.30	342,011.31	247,845.80	73,005.97	5.68	31.34	9.29	274.65	0.00	59.60	35.20
7/07 5:39		836.16	344,755.81	248,869.41	73,077.29	5.54	31.26	9.29	274.65	0.00	59.70	34.50
7/07 5:40		837.00	350,343.00	249,809.80	73,192.73	3.81	30.66	9.30	275.33	0.00	59.05	35.20
7/07 5:41		837.53	344,207.81	248,668.09	72,918.22	5.72	31.09	9.31	275.34	0.00	59.50	35.10
7/07 5:42		837.51	338,947.41	247,002.50	73,168.16	5.10	31.00	9.32	275.70	0.00	59.65	34.20
7/07 5:43		837.16	362,827.81	248,976.00	72,526.96	3.36	30.00	9.32	275.70	0.00	59.13	34.20
7/07 5:44		835.69	344,002.41	247,289.70	72,991.12	6.36	30.75	8.90	276.31	0.00	64.80	37.80
7/07 5:45		835.20	346,928.00	254,730.59	73,686.86	6.36	31.03	9.00	276.65	0.00	65.20	37.80
7/07 5:46		834.26	339,958.19	247,730.00	73,926.98	6.36	30.13	10.52	276.33	0.00	64.75	38.10
7/07 5:47		833.82	344,162.19	250,119.59	73,301.99	6.36	30.03	10.53	276.00	0.00	64.95	37.50
7/07 5:48		833.66	332,876.81	250,825.80	73,054.71	5.76	28.75	10.53	275.70	0.00	64.60	38.10
7/07 5:49		833.29	352,918.31	250,051.50	73,110.03	4.05	29.66	10.54	275.01	0.00	63.55	37.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 5:50		833.26	346,281.81	250,366.20	73,712.41	5.59	30.05	10.54	274.62	0.00	63.00	36.40
7/5/07 5:51		832.76	341,023.59	247,105.20	72,654.55	5.19	30.13	10.55	274.64	0.00	62.40	35.90
7/5/07 5:52		831.95	346,881.59	250,366.20	73,509.83	5.19	28.83	10.55	274.48	0.00	62.30	36.00
7/5/07 5:53		832.39	342,724.31	247,552.00	73,277.52	4.41	29.03	10.56	275.01	0.00	62.10	36.80
7/5/07 5:54		833.07	346,940.19	247,484.20	73,500.26	4.99	28.75	10.56	274.99	0.00	62.30	35.90
7/5/07 5:55		833.01	333,471.09	248,237.41	74,172.73	5.32	29.00	10.57	275.01	0.00	61.60	35.90
7/5/07 5:56		832.59	358,159.19	251,713.70	74,134.05	4.58	28.61	10.57	274.62	0.00	61.25	36.40
7/5/07 5:57		832.26	337,362.50	249,147.00	73,390.18	7.12	28.78	10.58	274.82	0.00	61.05	35.00
7/5/07 5:58		831.28	349,121.19	248,071.70	73,740.69	5.14	28.70	10.58	275.34	0.00	60.55	35.40
7/5/07 5:59		830.61	343,371.91	247,570.91	73,964.91	6.60	28.63	10.59	275.70	0.00	60.25	35.30
7/5/07 6:00		830.12	353,606.09	252,494.41	73,722.30	4.38	28.53	10.59	275.70	0.00	59.95	35.40
7/5/07 6:01		829.44	344,686.81	247,260.59	74,237.95	7.87	28.28	10.69	276.34	0.00	58.95	34.80
7/5/07 6:02		829.22	340,433.31	248,762.00	73,187.57	5.57	28.47	10.81	276.95	0.00	58.40	34.70
7/5/07 6:03		829.65	347,216.31	248,189.00	74,247.84	3.80	28.28	10.93	277.01	0.00	58.45	34.20
7/5/07 6:04		829.35	342,753.69	245,714.80	73,342.18	6.66	28.13	11.05	277.01	0.00	64.75	37.90
7/5/07 6:05		829.36	346,350.00	248,128.70	74,122.21	6.66	27.66	11.17	276.00	0.00	64.90	38.10
7/5/07 6:06		830.02	343,280.69	246,548.30	72,920.16	6.66	27.00	11.29	275.98	0.00	65.20	38.00
7/5/07 6:07		830.73	348,376.91	249,589.59	74,625.36	6.66	27.00	11.41	275.98	0.00	65.00	37.90
7/5/07 6:08		830.63	345,087.41	247,244.00	74,900.80	6.02	26.97	11.53	275.70	0.00	64.55	38.10
7/5/07 6:09		831.38	347,875.59	241,442.59	73,265.13	5.06	26.84	11.65	275.70	0.00	63.60	37.40
7/5/07 6:10		832.44	342,717.69	243,655.09	73,535.41	3.32	26.84	11.77	275.70	0.00	63.70	36.90
7/5/07 6:11		833.33	338,208.59	243,118.20	73,711.02	4.02	26.84	11.90	275.34	0.00	63.10	36.50
7/5/07 6:12		833.33	341,954.91	245,934.50	73,901.73	3.88	26.91	12.02	275.01	0.00	62.45	37.10
7/5/07 6:13		833.17	329,982.91	244,874.09	73,330.71	5.26	26.50	12.14	273.98	0.00	61.90	36.50
7/5/07 6:14		833.83	351,962.91	243,459.09	73,434.15	5.09	25.75	12.05	273.67	0.00	60.95	35.50
7/5/07 6:15		834.99	337,111.50	239,987.50	73,620.15	4.42	26.13	11.85	272.98	0.00	60.60	35.60
7/5/07 6:16		835.97	350,975.19	245,910.09	74,061.26	3.94	26.63	11.65	272.99	0.00	60.05	35.60
7/5/07 6:17		836.77	332,617.50	243,216.80	73,660.44	5.88	26.88	11.45	273.12	0.00	59.75	34.70
7/5/07 6:18		836.50	338,481.59	243,155.00	73,924.73	4.66	27.00	11.25	273.66	0.00	59.70	34.30
7/5/07 6:19		835.88	334,425.00	242,985.20	73,239.25	6.18	27.00	11.05	273.53	0.00	58.85	34.00
7/5/07 6:20		837.23	347,669.41	245,501.00	74,172.94	3.12	26.82	10.85	274.62	0.00	59.10	33.90
7/5/07 6:21		838.08	342,849.09	246,654.91	74,282.28	7.35	26.84	10.65	275.70	0.00	58.80	34.80
7/5/07 6:22		838.57	341,048.31	244,859.80	74,287.29	6.10	26.88	10.45	276.34	0.00	59.00	34.90
7/5/07 6:23		838.91	358,567.19	248,873.59	73,225.57	5.88	26.50	10.70	276.34	0.00	59.20	34.90
7/5/07 6:24		839.00	341,017.81	243,055.09	73,450.98	8.95	26.64	10.95	276.64	0.00	64.65	36.90
7/5/07 6:25		839.72	341,235.81	240,509.59	73,477.75	8.95	26.47	11.00	276.34	0.00	64.90	38.40
7/5/07 6:26		840.17	343,023.31	244,086.80	73,599.83	8.95	26.38	11.06	276.34	0.00	65.15	37.60
7/5/07 6:27		840.42	334,691.31	242,977.91	73,305.00	8.95	25.88	11.11	276.00	0.00	65.10	38.00
7/5/07 6:28		840.48	341,535.50	249,373.70	74,234.01	3.41	26.03	11.16	275.70	0.00	64.90	38.00
7/5/07 6:29		841.11	342,960.69	247,302.30	74,571.30	6.63	26.00	11.22	275.83	0.00	64.60	37.90
7/5/07 6:30		841.40	332,240.31	241,659.91	73,993.34	5.71	25.13	11.27	275.33	0.00	64.70	37.60
7/5/07 6:31		841.27	354,303.69	251,832.20	74,514.59	4.69	26.05	11.33	274.99	0.00	64.55	38.30
7/5/07 6:32		841.43	340,402.31	240,819.09	73,914.82	7.16	25.88	11.38	275.01	0.00	64.70	38.00
7/5/07 6:33		841.57	351,786.31	247,460.50	73,934.31	3.98	25.88	11.43	274.61	0.00	64.80	37.90
7/5/07 6:34		841.98	327,657.31	238,630.59	73,891.64	5.61	25.97	11.35	274.62	0.00	64.60	38.00
7/5/07 6:35		841.49	329,014.41	239,810.20	73,603.67	3.59	26.84	11.13	274.33	0.00	64.45	37.70
7/5/07 6:36		841.89	347,167.09	243,962.59	74,165.16	4.61	26.75	10.91	274.31	0.00	63.75	37.10
7/5/07 6:37		842.74	342,464.19	241,827.30	73,825.40	6.37	26.50	10.69	274.31	0.00	63.60	37.10
7/5/07 6:38		842.69	339,842.50	241,839.41	74,665.43	5.94	26.64	10.47	273.98	0.00	63.65	36.90
7/5/07 6:39		842.70	335,249.81	240,471.09	74,178.19	6.74	26.63	10.25	273.97	0.00	64.35	37.70

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 6:40	843.44	343,910.91	244,306.59	75,524.09	4.30	26.41	10.19	274.62	0.00	64.73	37.50	0.00
7/5/07 6:41	843.83	340,405.81	240,792.80	73,975.68	7.24	26.63	10.28	275.34	0.00	64.85	38.40	0.00
7/5/07 6:42	844.45	335,503.00	237,516.59	74,291.91	4.81	26.38	10.38	275.34	0.00	64.80	37.70	0.00
7/5/07 6:43	845.18	342,191.41	242,873.41	74,087.12	3.72	26.53	10.47	275.60	0.00	65.85	38.30	0.00
7/5/07 6:44	845.61	341,898.91	239,907.80	74,040.88	6.51	26.38	10.56	276.00	0.00	65.05	38.20	0.00
7/5/07 6:45	845.03	328,820.69	238,520.70	73,825.20	6.51	26.63	10.65	276.01	0.00	64.95	37.90	0.00
7/5/07 6:46	844.79	336,111.00	237,189.30	73,081.83	6.51	26.63	10.74	276.01	0.00	65.00	38.30	0.00
7/5/07 6:47	845.75	339,446.09	236,768.20	73,231.02	6.51	25.38	10.83	276.35	0.00	64.75	37.50	0.00
7/5/07 6:48	845.09	328,566.41	235,465.00	73,584.14	5.78	24.75	10.92	276.65	0.00	64.90	38.40	0.00
7/5/07 6:49	844.43	338,173.19	239,018.70	74,665.26	4.30	24.63	11.01	276.35	0.00	64.75	37.50	0.00
7/5/07 6:50	844.41	335,525.91	236,419.50	73,417.10	7.21	24.99	11.22	276.35	0.00	64.50	37.80	0.00
7/5/07 6:51	845.07	357,557.50	243,863.59	75,050.65	5.45	24.84	11.48	276.34	0.00	65.05	37.70	0.00
7/5/07 6:52	843.51	318,841.19	232,886.50	73,461.63	8.66	24.16	11.74	276.11	0.00	65.45	38.60	0.00
7/5/07 6:53	842.13	328,813.31	234,309.91	73,170.06	2.54	23.88	12.01	276.33	0.00	64.30	37.70	0.00
7/5/07 6:54	842.26	333,523.00	235,696.91	73,847.33	3.14	23.88	12.14	276.34	0.00	64.05	37.80	0.00
7/5/07 6:55	842.43	330,360.59	235,441.30	73,950.35	4.21	22.88	12.26	276.01	0.00	63.50	36.80	0.00
7/5/07 6:56	841.52	330,165.81	235,511.91	72,985.33	5.15	24.13	12.37	276.34	0.00	63.05	37.10	0.00
7/5/07 6:57	841.19	332,817.59	236,600.50	74,143.65	2.48	23.03	12.49	276.00	0.00	62.55	36.60	0.00
7/5/07 6:58	841.64	338,292.50	238,860.50	73,201.27	5.02	22.75	12.61	275.70	0.00	62.05	36.70	0.00
7/5/07 6:59	840.40	334,310.09	236,710.41	73,280.13	6.02	23.13	12.73	275.70	0.00	61.60	35.80	0.00
7/5/07 7:00	840.05	344,371.50	241,479.91	73,428.19	3.43	22.88	12.93	275.98	0.00	60.65	35.50	0.00
7/5/07 7:01	840.19	341,958.81	241,202.41	73,783.56	6.35	21.88	13.07	275.98	0.00	59.20	34.30	0.00
7/5/07 7:02	839.50	327,191.09	232,268.80	72,541.14	6.47	22.91	13.14	275.98	0.00	58.95	34.20	0.00
7/5/07 7:03	838.09	334,445.81	236,371.30	72,590.08	3.65	23.00	13.33	276.00	0.00	59.05	34.10	0.00
7/5/07 7:04	838.64	329,896.00	237,978.30	73,659.38	3.58	22.50	13.56	276.00	0.00	62.25	36.60	0.00
7/5/07 7:05	838.79	332,240.81	235,902.80	73,760.74	3.58	22.38	13.55	275.34	0.00	64.90	37.90	0.00
7/5/07 7:06	838.61	333,079.59	237,096.50	73,384.45	3.58	22.50	13.43	275.34	0.00	65.10	38.00	0.00
7/5/07 7:07	838.85	338,542.81	237,976.59	73,206.00	3.58	21.41	13.56	275.34	0.00	65.15	38.20	0.00
7/5/07 7:08	839.27	333,551.91	237,094.30	73,587.27	4.89	21.53	13.63	275.34	0.00	64.60	37.90	0.00
7/5/07 7:09	839.83	327,309.19	236,059.41	73,500.34	4.40	21.72	13.70	275.17	0.00	64.30	37.80	0.00
7/5/07 7:10	839.34	324,204.09	236,187.20	72,543.99	5.96	21.63	13.77	275.01	0.00	64.10	37.60	0.00
7/5/07 7:11	839.74	351,963.00	238,993.91	72,987.57	3.74	20.95	13.84	275.34	0.00	63.50	37.70	0.00
7/5/07 7:12	839.82	330,181.59	235,831.70	72,636.59	8.40	20.75	13.91	275.70	0.00	63.10	37.40	0.00
7/5/07 7:13	840.27	334,871.00	238,538.80	73,445.79	4.02	21.16	13.99	276.34	0.00	63.65	36.90	0.00
7/5/07 7:14	840.30	334,061.09	235,652.41	73,620.53	5.52	20.41	14.06	276.65	0.00	63.65	37.50	0.00
7/5/07 7:15	839.42	332,676.91	236,734.91	73,712.50	5.84	20.25	14.38	277.01	0.00	63.10	37.20	0.00
7/5/07 7:16	839.39	335,243.50	236,925.00	73,773.67	5.20	20.25	14.60	276.65	0.00	63.55	36.40	0.00
7/5/07 7:17	840.47	336,224.41	236,249.91	73,531.93	4.97	20.00	14.82	276.65	0.00	63.30	36.70	0.00
7/5/07 7:18	841.42	328,472.59	235,152.59	73,265.50	5.34	20.00	15.03	276.34	0.00	64.00	36.80	0.00
7/5/07 7:19	841.77	335,307.31	237,233.59	74,060.43	3.99	19.13	15.25	276.34	0.00	64.20	37.50	0.00
7/5/07 7:20	842.80	329,840.41	234,972.50	73,637.25	6.07	18.59	15.46	276.65	0.00	63.90	37.30	0.00
7/5/07 7:21	843.34	338,584.69	235,660.00	73,153.46	5.20	18.88	15.68	276.66	0.00	64.55	37.40	0.00
7/5/07 7:22	844.11	329,676.19	232,700.41	73,181.34	5.34	18.90	15.90	276.65	0.00	64.55	37.70	0.00
7/5/07 7:23	844.20	335,525.41	233,053.30	72,436.24	5.56	19.13	16.11	276.00	0.00	64.60	37.50	0.00
7/5/07 7:24	844.98	330,363.50	235,573.70	74,097.48	5.48	18.91	16.33	275.98	0.00	64.85	37.90	0.00
7/5/07 7:25	844.77	326,810.81	233,497.00	72,933.38	5.48	18.75	16.54	275.34	0.00	64.95	38.20	0.00
7/5/07 7:26	844.95	331,832.69	232,749.20	73,186.25	5.48	18.75	16.76	275.34	0.00	65.20	37.50	0.00
7/5/07 7:27	845.32	339,879.81	235,609.41	74,362.89	5.48	17.88	16.84	274.62	0.00	65.05	38.40	0.00
7/5/07 7:28	844.24	328,065.81	231,681.20	73,058.87	8.36	19.00	16.77	275.01	0.00	64.50	37.40	0.00
7/5/07 7:29	843.17	326,908.19	230,434.00	72,777.73	5.28	19.09	16.71	274.80	0.00	64.30	37.10	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 7:30	843.59	332,303.09	231,978.00	72,754.09	2.91	19.91	16.65	275.34	0.00	63.60	37.30	0.00
7/5/07 7:31	844.63	321,781.59	229,150.09	73,490.84	4.77	19.66	16.59	275.01	0.00	63.30	36.40	0.00
7/5/07 7:32	843.60	326,477.19	233,217.50	73,471.73	5.60	20.09	16.53	274.31	0.00	63.00	36.70	0.00
7/5/07 7:33	843.46	332,685.91	233,056.59	73,253.34	4.12	19.97	16.47	274.31	0.00	63.05	37.10	0.00
7/5/07 7:34	844.37	328,402.00	233,834.09	73,382.09	4.32	19.09	16.40	274.47	0.00	62.70	36.70	0.00
7/5/07 7:35	845.09	333,326.41	233,784.20	73,875.73	5.94	19.78	16.34	275.01	0.00	63.30	37.40	2,953.87
7/5/07 7:36	842.64	325,371.81	233,625.00	72,816.02	7.71	20.22	16.28	275.01	0.00	63.30	37.30	5,653.67
7/5/07 7:37	842.49	339,444.31	234,350.00	73,174.52	4.85	19.03	16.22	275.02	0.00	63.30	37.30	6,582.59
7/5/07 7:38	843.03	332,232.31	233,442.00	72,986.19	6.35	19.13	16.16	275.70	0.00	62.92	36.40	8,244.07
7/5/07 7:39	843.63	327,637.00	230,869.30	72,941.86	5.42	19.00	16.10	276.29	0.00	62.85	37.20	8,404.51
7/5/07 7:40	844.87	329,200.50	233,582.41	73,098.09	3.32	18.88	16.11	277.03	0.00	62.75	36.70	8,864.32
7/5/07 7:41	845.76	329,631.19	233,814.91	73,965.59	5.49	18.77	16.31	277.02	0.00	62.75	36.90	8,098.95
7/5/07 7:42	844.94	323,503.91	230,759.80	72,581.93	6.66	19.13	16.51	276.65	0.00	63.05	36.50	8,136.63
7/5/07 7:43	844.32	333,781.59	234,786.91	73,392.47	3.65	19.13	16.71	275.85	0.00	62.60	36.30	5,834.06
7/5/07 7:44	845.20	323,743.69	230,195.91	72,847.53	4.31	18.97	16.91	275.70	0.00	62.35	37.00	5,906.09
7/5/07 7:45	845.24	334,084.41	235,148.20	73,953.17	4.31	19.78	17.01	275.01	0.00	65.00	38.40	5,562.06
7/5/07 7:46	844.23	330,080.81	234,369.91	72,463.75	4.31	19.34	16.78	274.62	0.00	64.85	37.60	6,239.25
7/5/07 7:47	844.13	339,887.00	236,482.50	73,708.89	4.31	18.13	16.56	274.33	0.00	65.10	38.50	7,628.69
7/5/07 7:48	843.67	335,368.69	235,643.59	73,107.80	7.82	18.75	16.33	274.31	0.00	65.20	38.10	8,033.18
7/5/07 7:49	842.82	330,134.19	236,772.00	73,666.00	6.60	19.88	16.11	274.31	0.00	65.20	38.30	8,080.65
7/5/07 7:50	842.89	335,329.00	236,310.30	73,743.30	5.38	19.25	15.89	274.31	0.00	65.40	38.50	7,827.01
7/5/07 7:51	843.18	327,138.91	231,331.70	72,777.72	6.63	18.97	15.68	274.62	0.00	65.25	37.80	0.00
7/5/07 7:52	843.60	335,051.09	234,050.50	73,780.29	4.11	19.84	15.45	274.31	0.00	65.20	38.60	0.00
7/5/07 7:53	843.22	321,477.50	230,595.30	73,043.20	5.63	20.00	15.22	274.31	0.00	64.70	37.50	0.00
7/5/07 7:54	842.84	324,173.50	231,707.41	73,613.27	3.50	20.13	14.99	274.34	0.00	64.40	38.00	0.00
7/5/07 7:55	842.62	331,929.50	232,795.91	73,457.36	5.53	19.75	14.91	274.31	0.00	63.85	37.10	0.00
7/5/07 7:56	843.82	335,265.81	232,169.30	72,863.64	5.69	20.88	14.64	274.62	0.00	63.05	37.30	0.00
7/5/07 7:57	845.22	326,301.91	230,678.30	73,452.83	4.64	20.47	14.41	274.62	0.00	63.00	37.40	0.00
7/5/07 7:58	845.38	323,930.31	229,470.91	72,295.38	4.43	21.13	14.19	274.98	0.00	62.85	36.80	0.00
7/5/07 7:59	845.84	329,238.81	234,032.70	72,827.88	2.73	20.75	14.27	275.01	0.00	61.75	36.80	0.00
7/5/07 8:00	846.31	334,039.81	235,445.91	72,788.74	3.79	21.00	14.25	274.98	0.00	61.45	35.70	0.00
7/5/07 8:01	846.49	339,363.19	237,850.70	73,562.42	5.21	20.84	14.22	275.34	0.00	61.40	35.60	0.00
7/5/07 8:02	846.63	325,286.19	234,948.09	72,721.86	5.83	20.88	14.20	275.70	0.00	61.70	36.70	0.00
7/5/07 8:03	846.80	341,043.81	239,444.30	73,346.41	3.41	20.97	14.14	275.70	0.00	62.05	35.80	0.00
7/5/07 8:04	846.65	331,587.50	236,581.59	73,047.51	5.46	20.75	14.11	275.70	0.00	63.00	37.00	0.00
7/5/07 8:05	846.24	336,297.81	234,531.09	72,181.66	5.46	22.00	14.15	275.85	0.00	64.90	38.30	0.00
7/5/07 8:06	846.22	327,492.69	233,050.50	73,143.49	5.46	21.38	14.19	275.70	0.00	65.15	37.60	0.00
7/5/07 8:07	847.38	328,629.19	232,330.91	72,730.73	5.46	20.88	14.23	276.01	0.00	65.15	38.30	0.00
7/5/07 8:08	847.63	340,250.31	233,927.30	73,018.51	4.45	22.88	14.27	276.01	0.00	65.55	37.90	0.00
7/5/07 8:09	847.66	324,847.69	234,653.20	73,679.31	4.83	22.13	14.30	275.34	0.00	65.20	38.30	0.00
7/5/07 8:10	848.79	338,609.81	236,861.59	73,166.84	3.20	19.88	14.34	275.01	0.00	64.70	37.70	0.00
7/5/07 8:11	848.20	329,705.09	234,059.70	72,927.58	5.31	20.88	14.38	275.16	0.00	64.70	37.80	0.00
7/5/07 8:12	847.56	329,880.41	234,557.00	72,652.59	3.65	20.91	14.42	275.34	0.00	63.35	37.00	0.00
7/5/07 8:13	846.70	337,146.81	239,640.59	72,766.84	4.02	20.50	14.46	275.34	0.00	63.00	37.20	0.00
7/5/07 8:14	845.97	331,853.41	237,373.80	73,320.01	4.00	20.59	14.50	275.34	0.00	61.20	35.80	0.00
7/5/07 8:15	845.61	325,571.41	235,741.91	72,375.84	3.79	20.78	14.50	275.70	0.00	60.05	35.60	0.00
7/5/07 8:16	845.06	336,872.81	240,994.00	72,677.25	3.12	21.34	14.41	275.35	0.00	59.35	34.10	0.00
7/5/07 8:17	845.30	332,321.31	238,425.59	72,661.45	3.83	20.25	14.39	275.01	0.00	58.30	34.20	0.00
7/5/07 8:18	844.90	337,164.69	240,675.30	72,029.93	3.72	19.88	14.38	275.70	0.00	58.30	34.00	0.00
7/5/07 8:19	843.93	337,327.50	241,424.50	72,179.66	4.70	20.03	14.53	275.70	0.00	58.55	33.80	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 8:20	842.99	347,605.50	241,946.20	72,275.52	4.20	18.97	14.86	276.34	0.00	58.25	34.40	0.00
7/5/07 8:21	842.94	323,898.81	241,546.59	72,974.81	4.81	19.38	15.19	276.65	0.00	58.30	34.70	0.00
7/5/07 8:22	842.66	331,976.69	240,613.80	72,220.64	4.75	20.69	15.52	276.65	0.00	58.70	34.60	0.00
7/5/07 8:23	842.94	348,213.91	246,390.91	73,161.58	2.65	19.22	15.84	276.34	0.00	58.40	34.10	0.00
7/5/07 8:24	843.61	330,566.59	241,525.50	72,697.33	4.99	18.78	16.24	276.33	0.00	61.25	36.00	0.00
7/5/07 8:25	842.93	335,451.09	242,447.80	71,574.33	4.99	19.00	16.46	276.16	0.00	65.10	38.10	0.00
7/5/07 8:26	842.30	338,600.19	245,669.41	72,256.34	4.99	17.88	16.68	276.34	0.00	65.00	38.30	5,662.03
7/5/07 8:27	842.48	339,273.31	242,359.09	72,400.73	4.99	17.88	16.90	276.65	0.00	65.15	37.60	0.00
7/5/07 8:28	842.90	342,159.81	245,543.20	73,132.45	4.75	18.75	17.12	276.65	0.00	65.30	38.60	6,758.32
7/5/07 8:29	842.62	340,064.69	241,167.41	73,545.11	5.26	19.78	17.34	276.65	0.00	64.65	37.60	0.00
7/5/07 8:30	842.23	341,034.59	241,290.59	72,335.66	5.13	19.88	17.56	276.34	0.00	63.95	37.50	5,930.85
7/5/07 8:31	841.94	341,708.59	242,962.00	73,293.70	5.15	19.84	17.78	275.70	0.00	63.60	36.70	0.00
7/5/07 8:32	841.60	342,996.19	245,343.00	73,399.66	5.76	20.00	17.64	274.62	0.00	62.95	37.40	5,832.85
7/5/07 8:33	841.48	345,962.09	242,866.91	73,370.25	5.56	19.13	17.37	274.33	0.00	62.75	36.10	0.00
7/5/07 8:34	840.96	332,612.31	240,647.30	72,124.74	6.23	18.91	17.10	274.31	0.00	60.90	35.90	0.00
7/5/07 8:35	839.89	336,973.91	240,198.59	72,972.71	3.95	18.95	17.11	274.63	0.00	60.58	35.10	0.00
7/5/07 8:36	839.43	337,630.31	241,897.59	72,115.84	4.65	18.99	17.17	275.01	0.00	59.60	34.30	0.00
7/5/07 8:37	840.47	332,696.41	237,046.50	72,845.44	3.98	19.00	17.22	275.01	0.00	59.00	34.70	3,967.41
7/5/07 8:38	839.53	339,632.09	245,045.50	74,075.10	5.40	18.88	17.28	276.00	0.00	58.85	34.90	0.00
7/5/07 8:39	838.23	336,682.41	239,903.80	72,829.03	6.29	18.88	17.34	276.34	0.00	58.80	34.30	7,033.03
7/5/07 8:40	838.15	354,075.81	250,487.00	74,519.36	3.52	18.80	17.40	276.34	0.00	58.45	34.70	0.00
7/5/07 8:41	838.08	338,615.09	240,999.50	72,971.84	9.75	18.00	17.50	276.34	0.00	58.20	34.40	6,814.74
7/5/07 8:42	837.51	340,108.31	240,877.91	72,574.37	7.22	19.00	17.61	276.01	0.00	58.75	34.00	0.00
7/5/07 8:43	837.75	340,943.31	243,233.41	73,019.80	5.59	18.50	17.73	275.70	0.00	58.65	33.90	10,279.26
7/5/07 8:44	838.41	335,069.69	236,848.20	73,460.22	5.98	18.50	17.92	275.70	0.00	61.60	36.80	0.00
7/5/07 8:45	838.03	335,702.91	239,513.50	73,045.48	5.98	18.84	17.98	275.70	0.00	64.85	37.70	3,196.03
7/5/07 8:46	838.32	330,160.19	235,603.80	72,181.23	5.98	19.00	18.05	275.70	0.00	65.05	38.20	0.00
7/5/07 8:47	838.30	338,686.19	239,464.09	72,478.06	5.98	18.88	18.11	275.01	0.00	64.95	37.70	0.00
7/5/07 8:48	837.78	325,669.09	237,612.80	72,515.55	4.84	18.91	17.94	275.01	0.00	64.80	38.20	3,627.43
7/5/07 8:49	837.20	330,284.31	236,230.50	72,560.44	5.08	19.50	17.72	275.01	0.00	63.35	36.90	0.00
7/5/07 8:50	836.60	343,873.00	240,146.00	73,269.62	4.26	19.96	17.50	274.31	0.00	62.50	36.90	6,305.16
7/5/07 8:51	836.19	338,337.41	239,603.80	72,813.33	6.81	19.75	17.32	274.64	0.00	61.15	36.10	0.00
7/5/07 8:52	834.54	322,471.09	236,359.00	72,335.20	6.24	19.63	17.16	274.31	0.00	59.85	35.60	6,019.80
7/5/07 8:53	833.48	342,346.41	239,514.30	72,415.37	4.28	20.00	17.00	274.31	0.00	58.40	34.70	0.00
7/5/07 8:54	833.64	329,374.91	235,277.20	72,215.45	5.29	19.22	16.84	274.99	0.00	58.65	34.70	6,727.30
7/5/07 8:55	833.80	329,922.59	235,111.20	72,368.97	3.95	19.03	16.74	275.34	0.00	58.85	34.20	0.00
7/5/07 8:56	832.46	332,911.69	236,648.80	71,959.33	4.91	19.13	16.85	275.33	0.00	58.65	33.80	0.00
7/5/07 8:57	832.54	334,616.81	238,206.91	72,679.61	3.37	20.00	16.96	275.70	0.00	58.65	33.80	0.00
7/5/07 8:58	832.84	335,640.91	244,038.91	73,586.86	5.99	19.91	17.06	276.00	0.00	58.25	33.90	0.00
7/5/07 8:59	833.17	332,328.31	238,433.59	71,828.87	7.60	19.84	17.17	276.00	0.00	58.35	34.50	3,713.04
7/5/07 9:00	833.94	353,444.59	248,429.30	73,097.55	5.03	19.88	17.28	276.67	0.00	58.60	34.60	0.00
7/5/07 9:01	834.16	337,508.91	237,574.70	73,669.17	9.13	19.81	17.47	277.03	0.00	58.20	34.50	5,749.35
7/5/07 9:02	834.40	330,113.41	238,477.50	72,844.02	4.69	19.84	17.56	276.50	0.00	58.70	34.00	0.00
7/5/07 9:03	834.38	341,493.81	241,134.00	72,391.96	5.13	20.91	17.71	275.70	0.00	58.40	33.90	6,468.43
7/5/07 9:04	834.31	327,932.00	235,079.00	72,716.52	6.34	20.13	17.69	275.70	0.00	62.15	36.20	0.00
7/5/07 9:05	833.72	333,973.59	236,584.91	72,087.46	6.34	20.00	17.59	274.62	0.00	65.35	37.90	8,754.77
7/5/07 9:06	834.35	331,395.00	235,165.41	72,277.23	6.34	19.78	17.50	274.62	0.00	65.35	38.10	0.00
7/5/07 9:07	833.95	334,350.81	241,809.70	73,484.48	6.34	19.63	17.40	274.62	0.00	65.00	37.40	9,056.03
7/5/07 9:08	833.32	336,377.50	238,140.00	71,878.53	5.72	19.13	17.30	274.31	0.00	63.95	37.90	0.00
7/5/07 9:09	832.22	338,875.00	236,937.30	71,697.65	4.84	18.75	17.10	274.64	0.00	62.05	36.20	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 9:10		831.16	338,946.31	239,223.09	72,461.80	4.11	18.91	17.07	274.62	0.00	60.50	35.70
7/5/07 9:11		831.15	335,774.91	239,789.00	72,475.70	5.16	19.00	17.20	275.34	0.00	58.75	34.10
7/5/07 9:12		831.36	331,577.91	239,665.50	72,834.08	3.54	18.88	17.33	275.34	0.00	58.75	34.60
7/5/07 9:13		831.27	335,634.69	239,561.80	72,597.23	5.38	18.16	17.47	275.70	0.00	58.70	34.60
7/5/07 9:14		829.84	336,987.81	240,947.20	72,507.97	4.95	18.00	17.60	276.00	0.00	58.80	34.20
7/5/07 9:15		829.43	329,916.81	241,970.59	72,795.67	3.85	18.13	17.74	275.98	0.00	58.45	33.80
7/5/07 9:16		829.09	339,082.59	244,218.30	73,082.14	3.64	17.97	17.87	276.35	0.00	58.75	33.70
7/5/07 9:17		829.56	345,630.00	247,084.30	73,038.20	4.21	17.78	18.01	276.66	0.00	58.60	34.20
7/5/07 9:18		829.74	340,467.59	244,045.80	71,854.85	6.98	17.84	18.15	276.65	0.00	58.55	34.40
7/5/07 9:19		829.03	345,613.81	245,361.00	72,117.53	5.06	17.93	18.30	276.34	0.00	58.30	34.50
7/5/07 9:20		828.98	352,173.69	247,597.50	72,931.84	3.40	18.52	18.50	276.34	0.00	58.50	34.70
7/5/07 9:21		828.49	351,996.31	245,764.41	71,918.41	6.14	20.88	18.29	275.70	0.00	58.30	33.70
7/5/07 9:22		828.15	344,211.19	242,272.70	72,308.58	5.45	21.95	17.96	274.62	0.00	58.90	33.80
7/5/07 9:23		829.23	352,474.00	241,907.30	72,429.33	4.88	21.47	17.73	273.67	0.00	58.45	33.90
7/5/07 9:24		831.69	341,930.19	239,467.20	72,104.57	4.91	20.97	17.42	273.00	0.00	60.65	36.70
7/5/07 9:25		833.41	347,926.31	243,114.20	72,022.97	4.91	20.88	17.11	273.40	0.00	64.80	37.50
7/5/07 9:26		834.23	346,061.91	239,891.41	72,206.59	4.91	19.88	16.80	273.83	0.00	65.05	38.60
7/5/07 9:27		834.06	353,368.41	242,530.80	71,899.20	4.91	19.63	16.49	274.33	0.00	64.80	37.80
7/5/07 9:28		833.78	349,092.09	240,708.41	71,956.98	6.34	18.88	16.18	275.70	0.00	64.45	38.00
7/5/07 9:29		833.36	345,363.31	240,315.20	72,465.39	4.59	18.75	15.97	276.65	0.00	63.25	36.80
7/5/07 9:30		833.26	339,954.09	249,721.70	72,603.38	4.93	18.88	16.31	277.02	0.00	62.45	36.10
7/5/07 9:31		832.44	342,323.69	238,561.80	72,002.99	6.57	20.63	16.65	277.02	0.00	61.05	35.80
7/5/07 9:32		832.37	364,881.91	247,200.41	71,957.30	5.45	20.97	16.99	276.33	0.00	59.55	35.40
7/5/07 9:33		834.22	349,021.59	242,161.70	71,228.72	7.14	20.88	17.33	275.70	0.00	58.40	34.40
7/5/07 9:34		836.80	359,406.09	250,886.80	72,854.48	3.66	20.13	17.55	275.70	0.00	58.60	34.60
7/5/07 9:35		837.65	340,234.41	239,478.91	71,137.88	8.29	19.03	17.70	275.32	0.00	58.65	34.30
7/5/07 9:36		837.13	343,003.19	241,097.41	71,625.35	3.84	19.88	17.89	275.33	0.00	58.55	34.10
7/5/07 9:37		838.37	354,378.81	241,807.59	71,174.69	3.64	19.75	17.90	275.70	0.00	58.65	33.80
7/5/07 9:38		840.62	344,972.19	240,779.70	71,379.06	4.88	19.66	17.93	275.69	0.00	58.45	34.00
7/5/07 9:39		843.32	353,487.41	241,581.80	71,913.35	4.42	20.00	17.96	275.32	0.00	58.85	34.00
7/5/07 9:40		845.08	354,804.09	238,874.59	71,012.48	6.26	19.91	17.99	275.34	0.00	58.75	34.50
7/5/07 9:41		845.89	357,244.81	240,837.00	72,433.46	5.35	19.88	18.05	275.41	0.00	58.75	34.70
7/5/07 9:42		846.55	349,152.81	238,222.30	71,306.54	5.54	19.91	18.11	275.70	0.00	58.15	34.20
7/5/07 9:43		846.62	343,157.09	237,053.09	71,202.54	5.09	19.68	18.17	275.70	0.00	58.50	34.00
7/5/07 9:44		846.22	350,018.50	239,439.91	72,074.23	4.91	19.93	18.30	275.70	0.00	59.70	35.30
7/5/07 9:45		845.86	342,829.50	236,091.30	71,453.28	4.91	20.03	18.18	275.70	0.00	64.90	38.25
7/5/07 9:46		845.22	342,576.31	237,536.70	73,010.10	4.91	20.20	18.07	275.34	0.00	65.00	37.70
7/5/07 9:47		845.61	344,568.31	241,062.91	72,533.21	4.91	20.88	17.95	275.35	0.00	65.10	37.95
7/5/07 9:48		846.18	347,896.19	239,578.80	72,562.65	4.91	21.00	17.83	275.01	0.00	64.80	38.05
7/5/07 9:49		847.07	348,139.41	235,843.41	71,251.66	4.91	21.63	17.72	274.64	0.00	65.20	37.90
7/5/07 9:50		846.75	341,617.50	233,701.91	71,878.63	4.91	20.84	17.60	274.31	0.00	64.70	38.20
7/5/07 9:51		846.59	345,164.41	234,741.80	72,722.80	4.91	21.00	17.48	274.98	0.00	65.30	37.75
7/5/07 9:52		847.12	346,746.31	235,135.09	72,315.80	4.91	20.89	17.37	274.98	0.00	65.10	38.25
7/5/07 9:53		846.17	331,347.59	233,062.09	71,848.51	4.91	21.91	17.25	274.99	0.00	65.10	38.00
7/5/07 9:54		845.59	342,618.00	230,879.00	72,094.64	4.91	21.13	17.14	274.99	0.00	65.10	37.95
7/5/07 9:55		846.32	350,465.59	238,651.30	72,539.06	4.91	20.91	17.18	275.34	0.00	65.20	38.05
7/5/07 9:56		847.50	351,043.31	242,283.70	73,601.36	4.91	20.75	17.31	276.01	0.00	65.10	37.95
7/5/07 9:57		846.96	348,094.00	235,927.30	71,874.83	4.91	20.75	17.44	276.00	0.00	65.20	38.00
7/5/07 9:58		845.17	344,849.00	235,272.00	72,586.90	4.91	21.91	17.57	275.98	0.00	64.90	37.75
7/5/07 9:59		843.94	343,801.81	234,874.20	71,993.70	4.91	20.88	17.70	276.34	0.00	65.10	38.25

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/5/07 10:00	844.98	340,400.31	232,109.20	71,685.26	4.91	21.00	17.83	276.34	0.00	64.90	38.40	0.00
7/5/07 10:01	844.61	342,396.50	234,404.50	72,412.86	4.91	21.99	18.04	276.00	0.00	64.80	37.90	4,015.04
7/5/07 10:02	844.73	343,621.69	236,607.50	72,115.82	4.91	21.13	18.24	275.70	0.00	65.10	38.15	0.00
7/5/07 10:03	844.57	344,671.31	235,309.30	71,886.88	5.40	21.63	18.43	275.70	0.00	64.50	37.80	6,371.00
7/5/07 10:04	844.57	337,976.59	234,442.00	71,828.92	5.04	21.34	18.44	274.99	0.00	64.80	37.70	0.00
7/5/07 10:05	844.20	355,129.31	241,317.00	72,651.60	5.04	19.65	18.55	274.82	0.00	65.10	37.75	6,903.81
7/5/07 10:06	843.86	347,852.00	233,462.91	72,080.51	5.04	19.88	18.94	275.33	0.00	65.00	38.15	0.00
7/5/07 10:07	844.34	353,281.41	235,627.50	72,768.63	5.04	21.55	19.33	275.33	0.00	65.20	38.15	0.00
7/5/07 10:08	844.72	346,027.50	235,812.50	72,090.76	6.42	-0.01	22.88	277.99	0.00	64.50	38.10	0.00
7/5/07 10:09	846.17	337,375.81	234,516.70	71,939.80	4.74	0.02	24.18	283.02	0.00	64.10	37.35	0.00
7/5/07 10:10	847.08	333,974.09	234,390.70	71,742.66	4.94	6.94	26.89	285.71	0.00	64.20	37.60	0.00
7/5/07 10:11	847.38	337,042.81	232,552.70	71,655.91	2.79	10.73	29.88	284.18	0.00	63.80	37.20	0.00
7/5/07 10:12	847.20	340,711.69	237,951.80	71,723.27	2.91	10.77	29.82	279.35	0.00	62.90	36.65	0.00
7/5/07 10:13	846.98	349,328.31	235,998.70	72,289.73	3.02	9.88	29.77	275.01	0.00	61.50	36.05	0.00
7/5/07 10:14	847.37	341,214.19	236,078.50	72,312.32	4.56	9.75	29.71	272.03	0.00	60.70	35.00	0.00
7/5/07 10:15	847.23	339,357.31	233,612.20	72,176.10	5.37	11.19	28.19	269.16	0.00	59.40	34.60	0.00
7/5/07 10:16	846.77	350,714.00	240,647.91	73,117.49	3.91	11.94	25.72	267.67	0.00	59.00	34.90	0.00
7/5/07 10:17	846.06	344,231.00	235,020.00	71,581.23	6.65	12.30	23.25	268.00	0.00	58.40	33.95	0.00
7/5/07 10:18	846.29	351,425.09	242,537.70	72,739.92	3.62	14.02	21.47	269.31	0.00	58.70	34.20	0.00
7/5/07 10:19	846.10	359,150.19	244,041.09	72,659.05	7.21	14.02	20.39	271.48	0.00	59.00	34.40	0.00
7/5/07 10:20	847.67	346,239.69	235,293.80	72,279.84	6.72	16.13	19.31	273.00	0.00	58.50	34.55	0.00
7/5/07 10:21	849.04	346,361.41	237,146.80	72,252.14	5.39	16.38	18.76	274.65	0.00	57.90	34.35	0.00
7/5/07 10:22	850.60	336,695.91	234,469.50	71,924.71	4.83	16.88	19.04	275.70	0.00	58.40	33.80	0.00
7/5/07 10:23	851.33	350,396.31	237,951.09	71,780.34	3.55	18.00	19.32	276.19	0.00	58.10	33.85	0.00
7/5/07 10:24	852.15	344,504.81	238,061.50	73,266.35	5.69	17.88	19.59	276.66	0.00	59.00	35.20	0.00
7/5/07 10:25	853.22	342,512.41	236,539.09	71,737.68	5.69	18.72	19.87	277.01	0.00	64.70	38.05	0.00
7/5/07 10:26	853.50	329,104.41	237,107.50	72,036.55	5.69	18.03	20.00	276.65	0.00	64.90	38.30	0.00
7/5/07 10:27	854.12	346,764.31	237,617.50	72,524.37	5.69	18.88	19.81	276.33	0.00	64.90	37.80	0.00
7/5/07 10:28	854.12	351,555.91	244,611.50	72,737.99	6.05	19.72	19.61	275.70	0.00	64.80	38.35	0.00
7/5/07 10:29	853.48	356,325.09	235,599.50	71,927.98	8.90	21.00	19.42	274.64	0.00	64.60	37.65	0.00
7/5/07 10:30	853.02	355,439.09	238,977.59	73,777.20	5.40	21.47	19.22	273.38	0.00	64.20	37.45	0.00
7/5/07 10:31	852.66	344,905.00	234,456.09	71,612.96	6.93	20.75	18.73	272.38	0.00	63.30	36.80	0.00
7/5/07 10:32	851.60	336,802.41	237,764.30	72,651.31	5.25	21.09	17.97	272.32	0.00	63.50	37.20	0.00
7/5/07 10:33	851.34	348,122.09	237,408.20	72,532.91	4.44	20.78	17.67	273.00	0.00	63.10	36.50	0.00
7/5/07 10:34	851.00	346,104.81	236,545.80	72,448.93	6.76	21.00	17.37	273.00	0.00	62.90	36.95	4,464.23
7/5/07 10:35	849.21	343,725.50	235,036.59	72,347.34	5.18	20.91	17.06	273.66	0.00	62.60	36.80	5,575.96
7/5/07 10:36	848.21	347,941.69	242,791.41	72,244.57	5.22	20.88	16.76	274.33	0.00	62.40	36.75	6,140.84
7/5/07 10:37	847.19	344,160.09	237,184.09	71,781.98	7.52	20.88	16.46	274.62	0.00	61.70	36.15	7,534.58
7/5/07 10:38	847.90	343,653.00	231,937.41	71,825.05	5.30	20.78	15.98	275.35	0.00	61.70	34.40	8,429.81
7/5/07 10:39	847.22	332,891.91	225,608.00	71,707.01	7.32	22.08	16.09	276.01	0.00	60.40	33.75	8,824.91
7/5/07 10:40	848.08	326,608.09	223,366.80	71,897.34	3.70	22.00	15.84	275.70	0.00	59.60	32.05	8,031.11
7/5/07 10:41	846.89	337,530.81	225,477.91	72,430.27	5.52	21.88	15.71	275.33	0.00	59.10	33.55	8,371.13
7/5/07 10:42	846.29	336,481.59	231,150.70	72,288.25	6.02	21.91	15.58	275.34	0.00	58.60	31.10	6,002.77
7/5/07 10:43	846.31	344,947.59	229,844.50	72,401.16	6.13	21.88	15.44	274.62	0.00	58.10	32.45	5,894.15
7/5/07 10:44	845.10	330,423.09	223,813.41	72,223.00	6.74	21.14	15.31	274.31	0.00	59.10	33.15	5,439.31
7/5/07 10:45	842.84	319,208.31	221,659.50	71,243.81	6.74	22.00	15.18	274.33	0.00	64.70	32.05	5,859.35
7/5/07 10:46	840.35	332,757.41	227,259.30	71,445.61	6.74	21.69	14.96	273.37	0.00	65.20	33.20	6,837.84
7/5/07 10:47	839.93	322,653.31	229,038.20	72,118.53	6.74	21.25	14.57	273.00	0.00	65.50	34.20	7,845.73
7/5/07 10:48	838.99	326,194.19	229,949.59	71,872.00	6.34	21.41	14.17	273.66	0.00	64.70	33.95	7,910.94
7/5/07 10:49	837.69	319,757.69	228,205.30	71,682.84	7.03	21.50	13.92	273.66	0.00	64.20	31.55	7,826.53

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 10:50		836.85	332,343.69	233,325.91	71,738.80	3.93	21.00	13.85	273.83	0.00	63.70	31.15
7/5/07 10:51		835.71	316,139.41	222,244.80	71,050.14	6.86	20.84	13.77	274.31	0.00	63.60	31.00
7/5/07 10:52		834.74	329,529.31	229,768.20	71,536.41	4.84	20.88	13.70	274.64	0.00	63.20	34.00
7/5/07 10:53		836.24	332,899.31	232,852.30	71,322.14	4.85	20.96	13.62	275.35	0.00	62.10	35.90
7/5/07 10:54		837.67	323,885.59	231,263.41	71,184.81	7.16	20.90	13.55	275.70	0.00	61.20	35.85
7/5/07 10:55		837.71	324,317.31	231,643.00	71,214.30	5.44	21.25	13.47	275.70	0.00	60.80	35.50
7/5/07 10:56		838.10	326,054.09	226,004.70	71,655.50	5.60	20.78	13.40	275.34	0.00	59.60	34.65
7/5/07 10:57		838.14	325,287.09	230,842.59	71,651.99	5.90	20.75	13.33	274.64	0.00	59.10	33.95
7/5/07 10:58		838.47	338,597.59	228,289.41	71,449.61	5.74	21.25	13.25	274.62	0.00	58.70	33.80
7/5/07 10:59		837.65	321,280.81	224,015.30	71,292.38	6.95	20.88	13.18	274.62	0.00	58.60	34.15
7/5/07 11:00		838.22	298,513.50	230,252.30	71,002.82	3.91	20.88	13.10	274.62	0.00	57.90	34.50
7/5/07 11:01		839.27	315,444.19	223,122.80	72,096.22	4.44	21.22	13.03	274.31	0.00	58.40	34.30
7/5/07 11:02		841.40	315,813.00	228,121.91	71,905.47	5.37	21.00	12.95	274.62	0.00	58.90	30.60
7/5/07 11:03		844.29	332,025.59	232,534.80	71,513.82	4.78	20.78	12.88	274.99	0.00	58.60	31.15
7/5/07 11:04		847.09	335,032.00	230,435.59	72,326.63	6.69	19.88	12.80	275.34	0.00	58.60	28.60
7/5/07 11:05		849.19	335,351.81	229,074.00	71,220.41	6.69	19.88	12.73	275.70	0.00	64.80	27.70
7/5/07 11:06		850.88	330,749.69	226,898.50	71,128.70	6.69	19.95	12.65	275.98	0.00	65.10	27.65
7/5/07 11:07		849.09	324,619.19	233,069.20	71,843.35	6.69	19.88	12.58	276.00	0.00	64.90	26.45
7/5/07 11:08		844.64	318,852.50	227,367.59	72,068.56	6.11	19.88	12.62	276.65	0.00	59.10	23.60
7/5/07 11:09		841.25	330,336.19	232,255.50	72,173.68	5.04	20.00	12.89	276.65	0.00	62.60	24.15
7/5/07 11:10		838.08	333,513.31	233,899.80	72,145.41	6.02	19.84	13.15	276.33	0.00	62.60	24.40
7/5/07 11:11		834.20	321,722.69	228,694.91	71,586.45	6.98	19.88	13.41	276.34	0.00	61.10	23.60
7/5/07 11:12		834.45	330,394.59	231,369.50	71,756.10	5.06	19.75	13.64	275.98	0.00	60.10	26.20
7/5/07 11:13		836.72	318,652.50	228,259.50	71,103.24	6.43	19.63	13.64	275.70	0.00	59.50	23.40
7/5/07 11:14		838.92	320,910.69	228,944.91	71,324.79	5.27	19.70	13.70	275.69	0.00	59.00	23.55
7/5/07 11:15		841.23	323,591.31	227,339.70	70,704.52	5.40	19.50	13.72	275.34	0.00	58.40	23.65
7/5/07 11:16		842.72	319,024.91	228,227.80	70,970.99	5.92	19.75	13.67	274.65	0.00	56.70	22.30
7/5/07 11:17		840.12	328,130.69	229,217.80	72,209.39	6.07	18.59	13.49	274.62	0.00	53.50	21.45
7/5/07 11:18		836.47	331,158.41	235,210.00	71,977.71	6.38	18.63	13.26	274.47	0.00	56.60	21.90
7/5/07 11:19		834.09	314,338.00	218,926.41	71,911.85	7.51	18.53	13.38	274.99	0.00	52.90	21.15
7/5/07 11:20		830.69	305,857.91	214,482.30	71,542.30	5.16	18.66	13.84	275.01	0.00	52.90	20.90
7/5/07 11:21		827.41	304,660.41	210,141.09	71,425.31	6.19	17.15	14.30	275.34	0.00	46.50	20.15
7/5/07 11:22		826.38	307,078.81	206,551.50	72,196.89	7.19	0.02	0.05	277.18	0.00	48.00	19.15
7/5/07 11:23		826.92	304,577.31	206,518.00	71,795.62	5.77	0.02	18.00	289.00	0.00	43.60	18.20
7/5/07 11:24		826.03	297,938.59	201,914.09	71,187.34	8.90	0.84	23.32	295.33	0.00	40.50	18.55
7/5/07 11:25		826.62	305,725.19	208,874.30	71,542.20	8.90	4.74	28.76	293.90	0.00	45.10	19.35
7/5/07 11:26		827.66	301,303.09	206,715.20	72,301.84	8.90	4.58	31.65	287.00	0.00	45.10	20.55
7/5/07 11:27		825.82	294,828.50	203,405.00	71,108.48	8.90	4.16	32.80	277.68	0.00	44.50	19.45
7/5/07 11:28		822.96	297,159.19	203,221.59	71,494.11	6.70	3.03	31.74	270.02	0.00	44.70	20.25
7/5/07 11:29		820.21	299,022.41	199,519.80	70,724.47	7.48	3.11	30.48	264.49	0.00	43.70	19.10
7/5/07 11:30		817.62	293,210.50	194,043.20	70,846.77	5.88	2.97	26.45	261.00	0.00	43.20	17.45
7/5/07 11:31		814.97	287,267.31	193,782.59	71,249.01	8.12	3.49	21.76	261.01	0.00	42.30	15.75
7/5/07 11:32		813.43	286,150.19	195,164.09	71,289.64	4.63	4.94	17.81	263.63	0.00	41.80	18.05
7/5/07 11:33		812.37	304,004.59	186,161.30	71,530.32	4.48	6.11	16.18	268.00	0.00	40.90	17.98
7/5/07 11:34		810.75	297,296.59	185,670.50	71,359.66	7.42	7.90	14.55	272.31	0.00	40.50	15.60
7/5/07 11:35		809.30	310,122.69	189,030.30	73,046.48	6.72	8.14	14.74	275.33	0.00	40.60	15.85
7/5/07 11:36		808.94	301,493.91	180,320.20	70,718.89	8.60	8.00	15.49	277.99	0.00	40.60	16.50
7/5/07 11:37		808.35	294,962.59	179,611.30	72,226.86	7.30	8.30	16.23	279.65	0.00	37.10	5.95
7/5/07 11:38		806.65	298,294.09	177,083.91	71,121.08	7.18	8.94	16.98	280.01	0.00	35.70	51.15
7/5/07 11:39		804.31	289,155.81	176,018.09	71,169.38	6.55	8.95	18.10	280.02	0.00	35.40	50.60

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/5/07 11:40		803.36	294,548.31	175,061.09	71,127.74	4.95	9.94	19.22	279.35	0.00	37.10	9.30
7/5/07 11:41		804.76	283,213.69	171,423.41	71,012.78	7.13	9.83	19.98	278.00	0.00	32.70	0.00
7/5/07 11:42		807.47	282,397.00	172,113.50	71,217.22	6.37	9.98	20.29	275.85	0.00	29.90	0.00
7/5/07 11:43		810.69	298,528.00	174,617.00	72,008.08	3.68	10.00	19.58	274.31	0.00	33.00	0.00
7/5/07 11:44		813.74	286,670.09	166,890.50	70,571.66	6.99	10.14	18.86	272.69	0.00	31.70	0.00
7/5/07 11:45		816.55	296,141.81	178,037.91	71,031.93	6.99	10.02	18.14	271.48	0.00	34.60	0.00
7/5/07 11:46		816.55	342,356.09	204,076.00	70,506.77	6.99	10.00	17.22	271.33	0.00	33.30	0.00
7/5/07 11:47		814.33	320,294.81	197,070.91	71,344.94	6.99	10.04	16.32	272.00	0.00	33.30	0.00
7/5/07 11:48		813.16	307,077.69	190,151.30	71,252.34	7.36	10.15	15.78	273.38	0.00	31.60	0.00
7/5/07 11:49		811.60	293,570.81	187,207.59	71,680.52	7.78	10.90	15.56	274.62	0.00	33.20	0.00
7/5/07 11:50		809.27	297,032.69	185,597.20	71,494.45	5.53	11.00	15.53	275.34	0.00	33.70	0.00
7/5/07 11:51		809.07	303,072.09	185,205.30	72,053.13	7.35	10.94	15.76	276.35	0.00	33.40	0.00
7/5/07 11:52		810.51	303,119.41	185,807.91	72,515.94	8.16	10.92	15.95	276.34	0.00	32.50	0.00
7/5/07 11:53		812.44	305,445.31	182,017.41	71,779.58	8.30	11.06	16.22	276.65	0.00	34.10	0.00
7/5/07 11:54		814.71	288,494.00	176,091.30	71,027.70	8.39	11.00	16.61	276.65	0.00	33.50	0.00
7/5/07 11:55		815.66	292,708.91	176,983.70	71,659.64	5.95	11.92	16.78	276.33	0.00	34.20	0.00
7/5/07 11:56		813.28	291,858.81	177,160.20	71,086.42	8.55	11.88	16.52	274.99	0.00	35.20	0.00
7/5/07 11:57		808.92	286,339.31	186,571.50	72,047.77	6.15	11.88	16.26	274.30	0.00	35.00	0.00
7/5/07 11:58		806.30	303,488.31	198,683.70	71,281.84	6.70	11.94	16.00	273.65	0.00	36.70	0.00
7/5/07 11:59		802.53	305,836.91	203,069.91	71,003.21	10.02	11.88	15.74	273.65	0.00	34.80	0.00
7/5/07 12:00		799.73	302,779.19	198,059.30	70,885.57	9.38	11.68	15.48	273.65	0.00	35.60	0.00
7/5/07 12:01		800.55	299,497.69	197,583.30	70,930.58	8.92	11.77	15.23	274.30	0.00	34.80	0.00
7/5/07 12:02		802.23	291,903.31	198,458.91	72,052.72	8.51	11.94	15.03	274.62	0.00	33.90	0.00
7/5/07 12:03		802.44	294,687.59	196,672.00	70,584.13	7.31	12.08	14.81	275.01	0.00	35.40	0.00
7/5/07 12:04		803.91	293,571.69	205,063.20	70,817.12	6.20	12.11	14.75	275.51	0.00	35.80	0.00
7/5/07 12:05		806.29	297,284.09	207,185.80	70,867.30	6.20	12.06	14.70	275.34	0.00	34.90	0.00
7/5/07 12:06		805.77	308,737.41	210,753.80	71,423.91	6.20	12.81	14.64	275.70	0.00	39.20	0.00
7/5/07 12:07		804.31	304,472.31	203,315.91	70,149.96	6.20	12.98	14.62	275.70	0.00	41.30	0.00
7/5/07 12:08		803.32	301,654.59	204,616.50	70,022.90	8.90	13.90	14.59	275.70	0.00	44.30	0.00
7/5/07 12:09		801.16	293,377.19	203,136.91	70,329.51	7.08	14.00	14.56	275.70	0.00	43.30	0.00
7/5/07 12:10		799.80	304,131.50	204,421.30	70,289.68	8.12	13.94	14.60	274.62	0.00	43.20	0.00
7/5/07 12:11		802.00	298,635.91	205,254.80	70,932.30	6.52	14.25	14.32	274.30	0.00	42.80	0.00
7/5/07 12:12		803.38	303,708.69	206,421.00	70,900.80	6.59	13.97	14.05	273.98	0.00	42.90	0.00
7/5/07 12:13		804.68	309,524.81	207,992.50	70,029.06	7.83	14.66	13.77	273.97	0.00	42.40	0.00
7/5/07 12:14		807.46	314,680.91	216,276.80	70,797.29	7.69	14.94	13.49	274.30	0.00	43.20	0.00
7/5/07 12:15		811.42	316,615.41	216,149.41	70,490.82	7.67	15.00	13.22	274.62	0.00	44.80	0.00
7/5/07 12:16		811.49	318,318.69	214,815.00	70,567.77	7.47	16.00	12.94	274.62	0.00	45.50	19.10
7/5/07 12:17		809.86	311,404.50	216,266.30	71,339.97	6.54	16.88	12.69	274.62	0.00	45.30	19.65
7/5/07 12:18		808.53	310,154.31	214,960.91	70,386.44	6.95	17.00	12.60	274.62	0.00	45.40	20.20
7/5/07 12:19		806.46	322,533.19	218,370.30	71,734.30	5.71	17.00	12.54	274.99	0.00	44.70	19.30
7/5/07 12:20		805.22	311,306.91	214,658.09	70,594.48	9.07	17.53	12.37	274.62	0.00	44.20	19.55
7/5/07 12:21		806.27	311,967.31	222,949.59	70,489.64	4.07	17.85	12.12	274.64	0.00	44.10	19.90
7/5/07 12:22		808.95	321,849.41	226,672.00	71,512.20	3.65	19.10	12.05	275.01	0.00	50.30	20.80
7/5/07 12:23		812.34	317,350.81	227,033.41	71,063.54	6.74	18.97	11.75	275.01	0.00	49.60	19.95
7/5/07 12:24		816.32	325,673.91	232,642.80	70,800.97	4.78	19.72	11.53	274.62	0.00	47.60	19.50
7/5/07 12:25		818.86	348,732.41	241,133.80	70,626.84	4.78	19.22	11.32	274.79	0.00	60.00	23.60
7/5/07 12:26		818.55	340,879.19	242,889.80	70,511.86	4.78	19.13	10.15	274.99	0.00	56.00	22.85
7/5/07 12:27		817.89	331,839.09	244,448.70	71,300.19	4.78	21.13	10.33	276.00	0.00	55.40	22.85
7/5/07 12:28		817.35	340,146.59	243,385.80	71,701.24	5.39	20.88	10.51	276.33	0.00	55.00	22.70
7/5/07 12:29		817.16	349,583.69	253,297.30	72,393.91	5.77	21.90	10.68	277.02	0.00	55.90	22.90

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 12:30	818.93	340,892.31	248,069.59	71,432.80	9.12	21.88	10.86	276.64	0.00	50.10	21.10	10,373.43
7/5/07 12:31	821.90	348,171.91	251,098.80	71,551.42	6.56	21.88	11.04	276.65	0.00	52.60	21.25	10,341.64
7/5/07 12:32	825.65	339,686.09	248,462.41	71,741.48	8.06	22.50	11.18	277.03	0.00	51.80	21.50	10,347.64
7/5/07 12:33	829.34	341,714.91	247,961.50	71,835.13	6.72	22.84	11.09	276.64	0.00	50.70	20.40	10,229.79
7/5/07 12:34	831.88	349,207.09	249,269.59	71,545.70	7.69	23.13	11.18	275.98	0.00	51.80	20.92	6,819.71
7/5/07 12:35	832.10	334,753.19	240,514.09	71,240.17	6.72	23.00	11.27	275.51	0.00	54.10	21.60	9,098.14
7/5/07 12:36	830.22	342,017.50	249,503.70	71,757.94	4.67	22.88	11.36	275.01	0.00	59.90	24.15	9,135.66
7/5/07 12:37	827.49	344,101.09	246,417.91	71,110.07	9.08	22.97	11.44	275.01	0.00	59.60	23.75	8,859.78
7/5/07 12:38	824.22	337,333.81	239,145.09	71,870.25	6.21	23.00	11.24	274.64	0.00	59.20	25.05	8,978.05
7/5/07 12:39	822.06	337,403.19	242,455.30	71,036.39	6.52	23.03	11.07	274.62	0.00	58.70	27.85	12,695.06
7/5/07 12:40	823.87	325,556.50	237,435.41	71,070.70	4.12	23.84	10.89	274.62	0.00	58.90	29.95	11,574.77
7/5/07 12:41	826.44	329,725.09	241,414.30	71,568.79	3.90	24.13	10.72	273.96	0.00	58.90	31.10	11,546.99
7/5/07 12:42	827.62	335,213.91	238,529.91	70,664.07	5.78	24.13	10.55	274.31	0.00	58.70	32.90	11,296.10
7/5/07 12:43	830.33	340,194.81	241,673.59	71,729.63	4.44	24.13	10.37	274.64	0.00	58.20	33.95	11,297.22
7/5/07 12:44	832.64	333,941.19	242,327.00	71,310.57	7.52	24.41	10.20	274.64	0.00	58.60	32.70	12,430.25
7/5/07 12:45	835.15	329,127.81	241,050.09	70,981.85	7.52	25.00	10.07	274.65	0.00	64.90	35.50	11,196.89
7/5/07 12:46	836.97	344,128.19	246,371.70	71,193.46	7.52	23.91	10.05	275.01	0.00	65.00	37.10	10,696.79
7/5/07 12:47	838.81	329,178.19	240,056.30	71,021.39	7.52	24.88	10.03	275.34	0.00	65.10	34.30	10,777.98
7/5/07 12:48	840.88	341,282.59	248,856.91	71,910.35	4.55	24.88	10.00	275.70	0.00	64.40	34.65	10,937.44
7/5/07 12:49	842.84	343,316.59	247,599.91	71,373.82	7.26	24.88	9.98	275.70	0.00	63.50	34.30	9,286.93
7/5/07 12:50	841.45	344,487.59	243,943.80	71,340.45	7.79	24.88	9.96	275.70	0.00	62.50	31.85	8,700.92
7/5/07 12:51	837.94	342,966.09	249,695.30	71,368.08	6.95	24.88	9.96	275.70	0.00	61.90	31.85	9,038.89
7/5/07 12:52	835.10	339,524.81	244,312.50	71,051.40	6.54	24.91	9.94	275.34	0.00	60.80	32.35	8,926.37
7/5/07 12:53	833.29	342,497.41	248,683.91	71,674.75	4.75	26.00	9.93	275.70	0.00	59.90	34.95	9,030.58
7/5/07 12:54	832.43	329,254.69	239,995.50	71,199.73	6.51	26.00	9.91	275.70	0.00	59.20	35.00	11,977.95
7/5/07 12:55	832.28	338,294.59	242,576.20	71,484.00	5.15	26.03	9.89	275.33	0.00	58.20	34.60	11,578.49
7/5/07 12:56	834.35	342,213.00	244,674.30	71,833.62	4.65	26.00	9.78	274.99	0.00	58.80	34.00	11,370.55
7/5/07 12:57	837.56	353,446.50	243,520.00	71,490.14	4.84	26.00	9.68	274.99	0.00	58.50	33.85	11,118.30
7/5/07 12:58	839.31	327,064.09	241,879.00	72,080.83	5.95	26.50	9.58	274.99	0.00	58.70	33.90	7,362.10
7/5/07 12:59	838.64	328,414.50	238,682.59	71,253.86	4.76	26.78	9.48	274.99	0.00	57.90	34.10	10,048.83
7/5/07 13:00	835.35	347,963.50	248,947.80	72,392.72	2.96	27.03	9.39	274.65	0.00	58.50	34.50	10,519.02
7/5/07 13:01	830.19	336,795.19	241,891.50	72,129.50	7.14	26.05	9.29	274.62	0.00	58.00	34.45	10,443.71
7/5/07 13:02	825.20	345,719.69	246,503.30	71,142.06	5.23	27.00	9.28	274.64	0.00	58.50	34.30	10,467.82
7/5/07 13:03	821.99	352,395.81	247,072.80	72,678.97	6.30	27.13	9.35	274.65	0.00	59.10	34.05	4,092.67
7/5/07 13:04	823.08	334,247.00	240,463.50	71,513.52	4.61	26.49	9.43	274.65	0.00	58.80	33.85	10,492.97
7/5/07 13:05	824.42	333,588.59	242,082.80	71,766.82	4.61	26.34	9.51	274.62	0.00	64.70	38.05	10,555.46
7/5/07 13:06	826.78	342,998.19	244,272.70	71,311.69	4.61	25.53	9.59	275.34	0.00	65.20	37.80	10,470.09
7/5/07 13:07	829.08	338,146.50	243,646.00	72,257.63	4.61	26.25	9.66	275.34	0.00	64.80	38.20	10,438.60
7/5/07 13:08	830.75	335,433.81	244,229.09	71,304.54	5.19	25.97	9.74	276.01	0.00	64.80	37.40	6,458.08
7/5/07 13:09	830.55	346,766.31	249,779.50	71,524.33	4.69	25.75	9.82	276.34	0.00	63.90	37.50	9,140.36
7/5/07 13:10	827.16	338,859.41	246,211.09	71,860.45	5.86	24.97	9.90	276.66	0.00	62.60	36.35	9,501.84
7/5/07 13:11	825.03	340,590.81	243,502.09	72,211.51	3.73	24.97	9.97	276.65	0.00	61.00	35.75	9,170.47
7/5/07 13:12	821.86	349,734.81	252,698.09	71,357.45	5.28	24.75	10.05	276.65	0.00	60.20	35.25	9,271.68
7/5/07 13:13	821.59	343,482.19	247,154.00	71,566.38	4.93	24.96	10.14	276.66	0.00	59.90	34.25	12,306.42
7/5/07 13:14	823.50	342,423.69	247,973.50	71,151.24	3.87	24.88	10.22	276.34	0.00	58.20	34.65	11,109.93
7/5/07 13:15	824.74	336,665.91	250,419.91	71,545.89	4.08	24.91	10.31	276.64	0.00	58.60	34.55	11,263.90
7/5/07 13:16	824.42	362,964.50	259,311.91	71,440.64	4.55	25.00	10.40	276.66	0.00	58.80	33.75	10,857.70
7/5/07 13:17	825.01	359,023.81	256,550.80	71,639.41	7.37	25.00	10.49	276.34	0.00	58.20	33.80	10,912.73
7/5/07 13:18	826.27	323,676.59	253,430.00	71,138.75	6.34	25.09	10.58	276.00	0.00	58.30	33.85	10,164.11
7/5/07 13:19	826.34	350,956.50	256,655.30	72,224.75	4.55	25.03	10.67	275.70	0.00	58.50	34.25	9,401.54

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 13:20		826.30	351,240.31	254,652.00	71,071.48	6.60	24.88	10.76	275.70	0.00	58.60	34.70
7/5/07 13:21		826.76	351,029.50	254,897.50	70,973.93	4.86	24.97	10.85	276.01	0.00	58.80	34.45
7/5/07 13:22		827.52	362,182.81	262,693.31	71,841.83	5.10	24.88	10.93	276.01	0.00	59.10	34.30
7/5/07 13:23		829.01	346,595.19	256,674.91	71,607.57	7.21	25.09	11.02	276.02	0.00	58.20	33.75
7/5/07 13:24		832.36	348,787.19	255,198.80	71,267.83	4.36	24.83	11.11	276.01	0.00	58.40	33.80
7/5/07 13:25		834.50	361,329.69	263,497.50	72,819.68	4.36	25.67	11.20	275.70	0.00	65.30	38.00
7/5/07 13:26		835.49	343,788.19	252,905.09	71,071.77	4.36	25.88	11.29	276.01	0.00	64.90	37.90
7/5/07 13:27		837.18	353,897.31	255,896.09	71,386.65	4.36	25.66	11.38	276.00	0.00	65.00	37.90
7/5/07 13:28		839.34	353,479.50	259,216.30	71,253.79	5.66	25.38	11.47	275.34	0.00	64.60	37.90
7/5/07 13:29		840.42	347,305.59	255,534.50	71,025.97	6.71	24.91	11.56	275.34	0.00	65.00	37.65
7/5/07 13:30		840.38	352,640.91	254,201.20	71,021.59	4.95	25.00	11.64	275.35	0.00	64.80	38.20
7/5/07 13:31		841.17	348,661.81	253,530.59	70,916.78	5.60	25.00	11.73	275.34	0.00	64.30	37.75
7/5/07 13:32		842.84	371,155.59	253,675.09	71,751.17	4.38	24.63	11.82	275.34	0.00	64.20	37.70
7/5/07 13:33		845.40	345,733.31	252,412.00	71,827.13	5.18	25.09	11.91	275.70	0.00	63.70	37.10
7/5/07 13:34		847.29	351,711.00	257,250.09	71,444.22	5.03	25.77	12.00	275.70	0.00	63.40	36.70
7/5/07 13:35		847.87	341,969.50	248,295.91	70,749.25	6.05	25.66	12.07	275.33	0.00	61.40	36.10
7/5/07 13:36		847.90	343,076.91	250,666.41	71,600.36	3.86	25.73	12.12	275.35	0.00	60.60	35.70
7/5/07 13:37		848.49	343,303.69	251,080.91	70,654.87	4.11	24.38	12.02	275.01	0.00	59.20	34.30
7/5/07 13:38		846.44	341,631.19	251,243.80	71,355.76	4.29	24.53	12.04	274.64	0.00	58.40	34.50
7/5/07 13:39		842.07	355,076.09	253,949.30	71,567.28	6.37	24.66	12.06	274.62	0.00	58.10	34.55
7/5/07 13:40		838.23	349,229.31	259,562.50	72,066.41	6.28	23.75	12.08	274.64	0.00	58.50	34.35
7/5/07 13:41		834.72	350,651.09	251,195.30	71,563.90	6.22	23.88	12.10	274.65	0.00	58.10	33.80
7/5/07 13:42		831.66	353,841.00	255,983.09	71,031.62	7.12	23.25	12.12	275.32	0.00	58.70	33.85
7/5/07 13:43		831.56	345,304.69	250,981.20	71,096.23	6.47	22.63	12.13	275.70	0.00	58.30	34.10
7/5/07 13:44		833.63	363,230.91	261,109.91	72,332.13	5.69	22.72	12.15	275.70	0.00	57.90	34.45
7/5/07 13:45		835.51	347,491.50	257,434.80	71,611.23	5.69	22.53	12.17	276.00	0.00	65.10	36.75
7/5/07 13:46		836.45	345,376.31	250,943.70	71,090.27	5.69	22.59	12.19	276.34	0.00	64.80	28.85
7/5/07 13:47		836.31	345,871.59	255,208.30	71,318.48	5.69	22.50	12.21	275.70	0.00	55.80	22.55
7/5/07 13:48		836.12	336,129.09	254,345.09	71,208.91	7.56	22.47	12.22	275.70	0.00	44.50	20.55
7/5/07 13:49		835.23	358,894.00	257,382.09	72,364.75	8.48	21.50	12.24	275.01	0.00	44.30	19.15
7/5/07 13:50		834.15	339,496.31	244,948.91	71,946.03	10.02	21.63	12.26	274.62	0.00	35.90	52.25
7/5/07 13:51		832.19	327,550.69	233,884.80	71,211.40	10.06	20.75	12.28	274.30	0.00	29.10	49.30
7/5/07 13:52		829.73	325,850.09	236,672.20	71,301.50	9.86	20.75	12.07	273.65	0.00	28.80	49.95
7/5/07 13:53		828.69	331,957.00	240,619.70	71,943.88	6.08	19.97	11.82	273.65	0.00	27.80	0.00
7/5/07 13:54		828.26	351,331.69	242,678.50	72,509.68	8.30	19.88	11.57	273.96	0.00	27.50	0.00
7/5/07 13:55		826.86	324,530.50	230,210.09	71,492.60	11.77	19.88	11.56	274.31	0.00	27.70	0.00
7/5/07 13:56		825.57	321,515.81	230,721.91	71,315.13	8.57	18.66	11.73	274.30	0.00	27.70	0.00
7/5/07 13:57		824.69	332,385.00	232,010.50	72,484.88	9.01	18.50	11.90	274.62	0.00	28.20	0.00
7/5/07 13:58		824.15	327,366.41	227,736.20	71,416.10	9.54	17.38	12.07	275.34	0.00	28.50	0.00
7/5/07 13:59		824.32	316,925.50	224,365.30	71,469.17	8.47	17.50	12.24	276.00	0.00	28.30	0.00
7/5/07 14:00		824.96	321,907.41	222,713.91	71,028.30	6.38	17.38	12.41	276.65	0.00	30.80	0.00
7/5/07 14:01		826.19	314,214.19	219,079.41	70,991.25	6.01	16.00	12.58	277.34	0.00	37.50	0.00
7/5/07 14:02		826.30	316,289.09	223,655.41	71,126.54	6.59	16.00	12.83	277.69	0.00	42.50	0.00
7/5/07 14:03		826.81	324,303.81	230,368.50	70,995.26	6.09	16.34	13.27	278.30	0.00	47.00	19.35
7/5/07 14:04		827.63	322,799.81	227,506.50	71,444.10	5.59	15.89	13.71	278.33	0.00	59.60	23.10
7/5/07 14:05		828.03	323,508.69	228,956.30	71,042.57	5.59	16.72	13.99	278.30	0.00	64.80	25.55
7/5/07 14:06		828.55	342,465.31	242,254.91	71,294.38	5.59	17.00	14.18	277.68	0.00	64.90	28.85
7/5/07 14:07		829.11	339,437.81	241,550.41	71,268.50	5.59	16.00	14.36	277.01	0.00	65.50	29.40
7/5/07 14:08		829.56	328,784.81	232,871.30	70,655.30	7.83	16.25	14.54	276.33	0.00	64.40	26.95
7/5/07 14:09		829.89	321,863.00	234,198.20	71,560.76	6.46	16.75	14.72	275.98	0.00	63.10	25.20

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 14:10	830.56	336,588.91	238,241.50	70,784.60	4.58	17.00	14.90	274.99	0.00	62.00	25.35	0.00
7/5/07 14:11	830.42	336,560.91	244,055.20	71,469.24	7.00	16.75	15.08	275.01	0.00	60.10	23.85	0.00
7/5/07 14:12	830.81	338,186.81	239,024.09	71,363.97	7.35	16.84	15.08	274.31	0.00	58.20	22.45	0.00
7/5/07 14:13	831.76	341,795.31	242,003.20	71,717.22	6.65	16.88	14.89	274.33	0.00	58.50	22.85	0.00
7/5/07 14:14	833.21	339,247.41	235,886.20	70,546.59	6.51	16.59	14.71	274.31	0.00	58.70	23.05	0.00
7/5/07 14:15	833.88	335,779.50	238,898.50	71,629.97	7.80	17.00	14.53	274.34	0.00	57.70	22.65	0.00
7/5/07 14:16	834.70	343,202.59	240,301.91	70,823.37	6.51	17.09	14.34	274.33	0.00	58.50	24.30	0.00
7/5/07 14:17	835.53	338,411.09	246,583.91	71,444.73	6.22	16.50	14.16	275.01	0.00	58.10	23.80	0.00
7/5/07 14:18	836.25	344,066.50	243,520.41	71,097.46	6.91	17.00	13.98	275.01	0.00	58.70	23.05	0.00
7/5/07 14:19	836.46	339,874.31	245,519.00	70,797.84	7.25	17.13	13.88	275.01	0.00	58.60	22.95	0.00
7/5/07 14:20	837.23	339,294.19	242,310.59	70,755.41	6.13	16.97	13.89	275.34	0.00	58.70	23.15	0.00
7/5/07 14:21	838.22	347,025.50	248,558.09	71,818.68	5.86	16.97	13.85	275.70	0.00	58.20	23.55	0.00
7/5/07 14:22	838.67	342,975.00	245,423.41	71,019.51	7.14	17.38	13.79	275.34	0.00	58.90	22.50	0.00
7/5/07 14:23	838.41	346,504.41	245,556.00	70,361.23	8.26	17.81	13.74	275.34	0.00	55.80	21.75	0.00
7/5/07 14:24	838.19	334,632.19	242,017.70	71,231.28	8.53	18.25	13.72	274.62	0.00	50.40	20.15	0.00
7/5/07 14:25	838.25	341,377.09	248,340.80	71,024.02	8.53	18.00	13.55	274.65	0.00	49.40	20.80	0.00
7/5/07 14:26	837.90	350,348.31	252,155.20	71,617.09	8.53	17.97	13.38	274.22	0.00	44.90	19.95	0.00
7/5/07 14:27	837.70	337,706.19	248,433.50	70,841.50	8.53	17.75	13.21	273.98	0.00	44.80	20.20	0.00
7/5/07 14:28	837.57	348,435.91	245,090.59	70,865.01	9.68	17.75	13.05	273.98	0.00	44.80	19.70	0.00
7/5/07 14:29	838.21	341,921.31	243,421.70	70,812.46	8.48	17.91	12.88	274.62	0.00	44.00	18.95	0.00
7/5/07 14:30	838.54	331,226.59	241,987.00	71,742.30	6.35	18.13	12.71	274.99	0.00	43.50	19.35	0.00
7/5/07 14:31	838.00	338,405.19	246,539.20	70,518.41	9.18	18.72	12.55	274.99	0.00	42.70	15.35	0.00
7/5/07 14:32	838.08	337,197.50	242,647.80	71,722.38	7.40	18.88	12.45	275.67	0.00	42.10	16.20	0.00
7/5/07 14:33	837.80	330,880.69	244,807.59	71,404.39	7.74	19.00	12.40	275.69	0.00	41.30	15.40	0.00
7/5/07 14:34	837.62	348,085.09	248,213.59	72,288.56	7.44	19.00	12.41	275.33	0.00	41.10	14.55	0.00
7/5/07 14:35	837.69	345,758.41	240,006.91	70,694.77	9.76	19.00	12.30	275.01	0.00	40.70	15.75	0.00
7/5/07 14:36	837.54	340,960.41	238,669.09	71,325.34	9.22	19.00	12.19	275.01	0.00	39.50	14.90	0.00
7/5/07 14:37	837.17	325,266.09	236,329.00	70,634.63	9.67	19.88	12.08	275.01	0.00	40.80	14.75	0.00
7/5/07 14:38	838.00	334,270.31	242,451.80	71,885.27	5.44	19.88	11.97	274.62	0.00	40.60	17.25	0.00
7/5/07 14:39	838.72	337,488.09	240,753.50	71,879.94	7.50	20.05	11.86	274.64	0.00	40.40	17.25	0.00
7/5/07 14:40	838.65	340,339.91	243,057.00	71,765.20	8.33	20.03	11.75	274.62	0.00	39.90	17.65	0.00
7/5/07 14:41	838.24	326,111.69	233,578.30	70,528.68	9.37	19.91	11.64	274.62	0.00	40.90	18.40	0.00
7/5/07 14:42	838.14	323,766.59	234,495.80	71,031.07	7.11	19.78	11.46	273.96	0.00	41.10	18.65	0.00
7/5/07 14:43	837.98	316,400.69	228,592.09	70,303.51	7.28	19.97	11.29	273.98	0.00	40.80	18.30	0.00
7/5/07 14:44	837.69	334,035.50	236,978.41	70,702.30	7.07	20.09	11.03	273.96	0.00	40.10	17.83	0.00
7/5/07 14:45	838.36	331,407.31	235,363.41	70,940.12	7.07	19.75	10.90	274.31	0.00	45.10	20.60	0.00
7/5/07 14:46	839.24	348,608.41	232,769.59	70,853.22	7.07	21.00	10.77	275.01	0.00	45.00	19.75	0.00
7/5/07 14:47	839.40	330,544.50	233,961.41	71,213.16	7.07	20.88	10.72	274.99	0.00	45.00	20.25	0.00
7/5/07 14:48	839.03	324,946.81	232,335.30	71,038.88	7.35	20.78	10.55	274.33	0.00	44.60	19.45	0.00
7/5/07 14:49	838.31	313,325.81	224,287.80	70,141.45	7.27	20.59	10.38	273.97	0.00	44.00	19.75	0.00
7/5/07 14:50	837.73	326,223.19	228,671.09	70,629.55	4.48	20.75	10.24	273.98	0.00	44.10	18.65	0.00
7/5/07 14:51	837.32	328,534.09	232,410.80	71,003.13	6.33	20.50	10.02	273.66	0.00	43.20	19.20	0.00
7/5/07 14:52	837.41	324,418.00	229,057.00	70,287.42	6.25	20.50	9.80	274.31	0.00	42.70	19.55	0.00
7/5/07 14:53	837.44	325,950.69	234,939.50	70,730.43	6.57	20.38	9.58	274.31	0.00	49.70	20.25	0.00
7/5/07 14:54	838.04	322,400.19	229,926.59	70,192.23	4.91	20.53	9.56	274.99	0.00	50.30	20.80	0.00
7/5/07 14:55	838.39	336,202.19	242,181.59	71,451.76	5.77	20.84	9.59	275.34	0.00	56.30	21.70	0.00
7/5/07 14:56	839.39	334,032.59	237,553.70	71,019.25	7.05	20.84	9.62	275.34	0.00	55.60	21.70	0.00
7/5/07 14:57	840.19	355,636.19	242,569.00	72,177.21	7.82	21.00	9.65	276.00	0.00	58.20	22.75	0.00
7/5/07 14:58	840.88	326,242.19	230,595.20	70,662.37	9.17	21.00	9.68	276.34	0.00	57.60	22.10	0.00
7/5/07 14:59	841.64	320,852.69	232,023.41	70,824.11	4.77	21.13	9.81	276.00	0.00	57.60	22.20	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/5/07 15:00	842.21	330,456.81	238,854.80	71,829.05	4.23	21.00	9.78	275.69	0.00	58.50	23.30	0.00
7/5/07 15:01	842.66	337,620.69	242,100.91	71,265.08	4.89	20.84	9.76	275.69	0.00	58.40	23.05	0.00
7/5/07 15:02	842.86	327,600.69	234,545.80	70,421.81	6.87	21.13	9.74	275.84	0.00	58.00	22.80	6,208.87
7/5/07 15:03	840.46	334,029.41	236,284.59	70,663.00	6.76	21.00	9.72	275.98	0.00	58.30	22.55	6,236.32
7/5/07 15:04	840.35	327,355.81	239,589.59	71,126.77	4.94	20.91	9.69	276.28	0.00	58.40	22.35	6,061.88
7/5/07 15:05	841.65	342,678.59	238,902.50	71,139.82	4.94	21.61	9.67	276.34	0.00	64.40	25.50	6,017.74
7/5/07 15:06	842.79	327,739.09	234,341.59	71,018.09	4.94	21.75	9.65	276.00	0.00	65.10	25.20	7,674.28
7/5/07 15:07	842.92	337,662.81	242,784.41	71,545.08	4.94	22.28	9.63	275.34	0.00	64.70	24.75	8,754.71
7/5/07 15:08	843.14	335,322.00	241,701.70	71,722.91	6.68	22.13	9.60	275.01	0.00	64.40	25.25	8,332.17
7/5/07 15:09	844.13	329,262.91	234,134.80	71,107.29	5.45	22.72	9.58	275.01	0.00	63.30	24.70	8,522.44
7/5/07 15:10	844.20	326,559.81	235,597.70	70,678.77	5.95	22.06	9.56	274.77	0.00	62.10	24.30	6,454.87
7/5/07 15:11	844.39	335,030.00	240,704.50	71,965.88	4.97	22.88	9.53	274.62	0.00	60.90	24.05	6,610.52
7/5/07 15:12	844.80	328,751.31	233,409.41	71,318.36	6.44	22.75	9.51	273.97	0.00	60.00	23.15	6,197.75
7/5/07 15:13	845.51	314,415.91	233,046.70	70,776.27	5.99	22.88	9.49	273.66	0.00	59.00	23.00	5,727.58
7/5/07 15:14	846.87	321,542.00	231,045.80	71,554.27	5.25	23.25	9.29	273.54	0.00	58.40	23.20	5,826.47
7/5/07 15:15	848.44	334,228.69	233,214.00	72,165.77	3.75	22.91	9.02	273.66	0.00	58.60	23.70	6,228.78
7/5/07 15:16	850.05	331,814.91	238,872.80	72,687.60	6.62	23.55	8.74	273.65	0.00	58.30	23.60	7,827.01
7/5/07 15:17	851.86	330,303.41	238,121.00	71,850.59	7.06	24.13	8.47	273.81	0.00	58.00	23.85	8,196.81
7/5/07 15:18	853.85	341,694.41	238,123.50	72,115.41	5.84	24.00	8.18	273.65	0.00	58.30	24.45	0.00
7/5/07 15:19	854.72	330,289.19	230,779.41	71,231.71	9.07	25.00	7.91	273.65	0.00	58.20	24.25	0.00
7/5/07 15:20	855.46	330,366.81	236,340.09	71,714.59	6.42	24.50	7.64	273.38	0.00	58.50	24.55	0.00
7/5/07 15:21	856.50	329,934.69	236,571.80	71,504.98	6.10	24.70	7.37	273.00	0.00	58.10	26.00	0.00
7/5/07 15:22	857.41	328,388.00	233,346.09	71,067.59	6.24	24.88	7.10	273.18	0.00	58.40	25.70	0.00
7/5/07 15:23	857.65	325,004.31	228,362.20	71,605.02	6.78	25.00	6.83	273.38	0.00	58.50	23.95	0.00
7/5/07 15:24	857.82	323,987.09	231,335.80	71,379.64	5.75	25.16	6.56	273.97	0.00	58.40	24.15	0.00
7/5/07 15:25	858.64	339,911.81	239,278.59	71,557.66	5.75	24.88	6.43	273.97	0.00	65.20	28.70	0.00
7/5/07 15:26	858.86	321,660.00	229,024.80	70,768.98	5.75	24.88	6.45	273.96	0.00	64.70	28.05	0.00
7/5/07 15:27	859.49	326,445.50	232,374.91	70,846.34	5.75	26.00	6.46	274.31	0.00	64.90	28.15	0.00
7/5/07 15:28	859.70	333,649.31	235,215.50	72,369.35	6.46	26.22	6.48	274.62	0.00	64.30	29.90	0.00
7/5/07 15:29	859.88	325,701.31	232,931.09	71,590.89	6.89	25.63	6.49	274.99	0.00	63.00	28.35	0.00
7/5/07 15:30	859.25	324,490.91	226,038.00	71,142.59	7.76	26.22	6.51	274.99	0.00	62.80	27.15	0.00
7/5/07 15:31	859.27	327,940.50	231,144.30	71,666.54	5.09	25.88	6.52	275.34	0.00	60.90	27.40	0.00
7/5/07 15:32	859.05	321,383.31	232,619.30	71,707.63	6.71	26.03	6.54	275.34	0.00	61.70	27.10	0.00
7/5/07 15:33	858.23	323,770.19	229,650.30	71,078.77	6.42	25.63	6.55	275.01	0.00	60.80	25.95	0.00
7/5/07 15:34	857.38	315,425.91	225,544.20	70,794.31	6.65	26.00	6.57	275.33	0.00	58.70	24.05	0.00
7/5/07 15:35	856.58	322,701.81	229,523.50	70,752.27	5.37	26.13	6.58	274.99	0.00	58.80	23.10	0.00
7/5/07 15:36	856.02	322,604.91	230,986.20	71,861.08	5.72	25.97	6.60	274.82	0.00	58.80	22.50	0.00
7/5/07 15:37	854.95	320,432.09	225,337.80	70,498.19	6.21	25.59	6.61	275.01	0.00	56.00	21.50	0.00
7/5/07 15:38	854.14	322,901.41	225,979.41	71,531.23	6.75	25.47	6.63	275.34	0.00	55.20	21.65	0.00
7/5/07 15:39	854.00	319,861.00	230,392.50	71,168.98	5.45	25.34	6.64	275.34	0.00	56.90	22.10	0.00
7/5/07 15:40	854.28	345,705.41	232,641.41	71,695.21	5.16	25.36	6.66	275.70	0.00	58.70	22.90	0.00
7/5/07 15:41	853.83	316,858.59	223,927.41	71,291.86	10.06	24.63	6.68	275.98	0.00	57.50	22.20	0.00
7/5/07 15:42	853.61	318,137.00	225,174.20	71,247.10	5.62	25.06	6.69	275.98	0.00	58.40	22.85	0.00
7/5/07 15:43	854.01	318,392.41	227,488.09	71,673.27	4.89	23.84	6.71	276.32	0.00	58.50	23.75	0.00
7/5/07 15:44	854.36	327,608.69	229,638.41	71,244.27	4.30	23.91	6.72	277.32	0.00	58.60	24.50	0.00
7/5/07 15:45	854.09	317,934.50	222,510.70	71,133.56	4.30	24.00	6.74	277.34	0.00	64.80	26.35	0.00
7/5/07 15:46	854.13	317,187.69	224,127.80	71,140.30	4.30	23.88	6.75	277.68	0.00	65.40	26.80	0.00
7/5/07 15:47	853.50	314,224.31	224,522.59	71,770.85	4.30	23.00	6.97	277.32	0.00	65.00	26.10	0.00
7/5/07 15:48	852.71	324,777.00	227,169.09	70,885.34	5.84	23.38	7.22	276.65	0.00	64.20	25.85	0.00
7/5/07 15:49	852.83	325,939.00	219,858.09	70,856.85	7.40	22.88	7.47	276.65	0.00	63.60	25.55	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/5/07 15:50	852.24	312,096.91	219,533.00	71,115.27	8.27	23.00	7.72	276.63	0.00	62.20	24.40	0.00
7/5/07 15:51	851.63	318,850.91	224,921.80	71,261.97	5.06	22.91	7.97	276.64	0.00	61.70	24.30	6,361.56
7/5/07 15:52	850.84	324,852.81	225,406.09	71,586.11	6.06	21.88	8.22	277.03	0.00	59.50	23.77	0.00
7/5/07 15:53	851.19	322,604.31	223,098.91	71,871.13	6.80	21.97	8.47	276.65	0.00	58.80	23.10	8,374.70
7/5/07 15:54	850.78	326,206.81	222,909.09	70,462.59	8.89	22.05	8.58	277.02	0.00	58.20	22.35	0.00
7/5/07 15:55	850.50	315,299.41	223,422.30	70,908.92	7.96	21.99	8.85	277.01	0.00	58.50	23.00	2,016.54
7/5/07 15:56	850.94	313,968.50	221,000.09	71,348.55	4.91	21.88	9.13	276.65	0.00	58.40	23.25	0.00
7/5/07 15:57	850.92	313,284.91	222,964.00	71,362.46	5.22	21.72	9.39	276.34	0.00	58.80	23.80	0.00
7/5/07 15:58	850.62	321,021.91	221,398.41	71,172.08	5.06	21.75	9.58	276.34	0.00	58.00	24.35	2,450.28
7/5/07 15:59	850.93	316,626.50	216,563.70	71,642.19	6.49	20.91	9.77	276.34	0.00	58.50	25.35	0.00
7/5/07 16:00	851.13	307,727.19	216,749.00	70,866.43	6.34	20.63	9.95	276.34	0.00	58.40	24.80	4,592.13
7/5/07 16:01	851.14	330,814.31	225,798.80	71,704.15	4.21	20.63	10.14	276.01	0.00	58.60	25.50	0.00
7/5/07 16:02	852.00	306,982.91	218,053.80	71,057.23	6.13	20.47	10.33	276.65	0.00	58.20	25.25	5,863.40
7/5/07 16:03	851.91	311,851.41	218,202.50	71,226.00	5.76	20.38	10.53	276.32	0.00	58.30	25.35	0.00
7/5/07 16:04	851.61	315,304.31	219,304.59	71,030.19	6.19	20.38	10.65	276.34	0.00	58.40	25.50	8,637.67
7/5/07 16:05	850.82	315,427.19	219,155.20	71,223.58	6.18	20.38	10.76	275.98	0.00	65.30	30.05	0.00
7/5/07 16:06	851.07	309,888.00	218,556.20	72,174.77	6.18	20.40	10.88	275.98	0.00	64.80	29.55	6,814.70
7/5/07 16:07	850.77	327,016.69	221,105.41	70,969.84	6.18	20.75	10.96	275.98	0.00	65.30	29.50	0.00
7/5/07 16:08	850.29	313,216.19	215,089.70	70,788.63	8.79	20.78	11.08	275.01	0.00	63.90	29.05	0.00
7/5/07 16:09	850.16	312,430.81	219,453.41	71,027.11	4.67	20.75	11.02	274.98	0.00	62.20	28.55	570.68
7/5/07 16:10	850.38	320,823.19	223,791.20	71,559.70	5.27	20.75	10.95	274.98	0.00	60.70	27.90	0.00
7/5/07 16:11	850.61	312,984.81	218,525.09	71,043.09	6.77	20.78	10.89	275.01	0.00	59.60	27.70	3,970.21
7/5/07 16:12	850.59	320,398.50	223,876.20	71,689.91	3.90	19.13	10.94	274.98	0.00	58.30	27.10	0.00
7/5/07 16:13	850.38	313,523.41	224,077.80	71,487.71	7.58	18.91	11.04	275.70	0.00	58.70	26.85	6,290.48
7/5/07 16:14	850.14	322,581.09	226,832.50	71,129.20	4.11	19.50	11.15	275.98	0.00	58.60	26.60	0.00
7/5/07 16:15	851.05	334,070.69	225,547.80	71,352.51	5.00	19.03	11.26	276.65	0.00	58.20	26.15	8,397.11
7/5/07 16:16	850.10	295,656.81	226,335.41	71,026.40	6.60	19.03	11.36	276.64	0.00	58.50	25.25	0.00
7/5/07 16:17	850.00	317,290.09	224,253.80	71,672.13	3.69	19.13	11.68	276.65	0.00	58.50	25.90	4,859.00
7/5/07 16:18	850.21	322,355.31	223,048.20	70,830.68	5.39	18.88	11.76	276.65	0.00	58.90	25.75	0.00
7/5/07 16:19	850.72	318,343.69	229,611.80	71,185.88	5.45	18.72	12.01	276.64	0.00	58.10	25.30	0.00
7/5/07 16:20	850.89	323,634.41	229,846.50	71,446.30	5.27	18.75	12.26	276.65	0.00	58.70	24.95	3,035.86
7/5/07 16:21	851.80	335,820.50	236,023.59	70,397.84	5.11	18.88	12.51	276.66	0.00	58.60	25.50	0.00
7/5/07 16:22	853.15	330,683.91	233,446.41	71,124.45	7.65	19.09	12.76	276.34	0.00	58.30	25.15	4,406.65
7/5/07 16:23	854.26	324,913.50	230,482.59	71,007.20	6.58	19.09	12.98	276.33	0.00	58.80	25.45	0.00
7/5/07 16:24	855.62	325,659.19	233,936.91	71,732.65	4.99	19.00	13.11	276.34	0.00	58.30	26.05	5,525.11
7/5/07 16:25	856.40	327,587.91	232,102.70	71,239.06	4.99	18.88	13.25	275.98	0.00	64.60	28.70	0.00
7/5/07 16:26	856.55	321,616.09	233,366.70	71,503.63	4.99	18.22	13.39	276.01	0.00	64.90	29.15	8,767.94
7/5/07 16:27	856.73	327,748.19	232,242.41	71,603.61	4.99	17.75	13.52	275.70	0.00	65.10	30.20	0.00
7/5/07 16:28	857.53	339,669.81	237,294.91	71,403.48	4.86	17.88	13.66	276.00	0.00	64.80	30.10	6,705.46
7/5/07 16:29	856.35	321,264.41	229,070.70	71,001.72	9.40	17.88	13.80	275.34	0.00	63.00	28.15	0.00
7/5/07 16:30	856.17	320,880.50	227,786.80	70,847.30	4.80	18.13	13.78	275.34	0.00	61.50	28.10	8,106.76
7/5/07 16:31	856.31	333,245.09	236,431.59	71,825.59	4.87	17.88	13.78	275.34	0.00	60.10	27.05	0.00
7/5/07 16:32	856.86	328,691.69	228,955.50	70,809.32	6.67	18.00	13.77	275.34	0.00	59.00	26.05	0.00
7/5/07 16:33	856.78	329,381.59	233,466.00	70,792.06	7.47	18.13	13.76	275.01	0.00	58.20	25.65	3,990.74
7/5/07 16:34	857.41	330,201.59	233,696.30	71,565.73	6.37	17.88	13.75	275.34	0.00	58.70	26.15	0.00
7/5/07 16:35	858.05	326,858.59	232,161.70	72,363.46	5.96	18.00	13.74	275.34	0.00	58.20	25.85	6,550.54
7/5/07 16:36	858.11	325,253.81	233,315.00	71,783.43	6.87	18.00	13.73	275.70	0.00	58.90	26.10	0.00
7/5/07 16:37	858.53	312,271.00	230,560.09	70,986.03	6.52	17.91	13.72	275.16	0.00	58.20	25.40	8,282.45
7/5/07 16:38	857.92	321,933.19	227,381.30	71,188.96	3.39	17.88	13.58	275.01	0.00	58.80	25.65	0.00
7/5/07 16:39	858.12	326,126.69	232,835.70	71,543.93	5.58	16.88	13.66	275.35	0.00	58.80	26.20	9,791.67

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 16:40	858.05	322,943.50	230,535.09	71,714.91	6.23	16.89	13.74	276.01	0.00	58.20	25.70	0.00
7/5/07 16:41	858.51	323,303.91	228,863.70	71,359.08	5.60	17.13	13.82	276.01	0.00	58.80	26.20	965.99
7/5/07 16:42	858.26	319,426.09	228,057.91	71,754.84	6.31	16.88	14.02	276.34	0.00	58.10	25.50	572.00
7/5/07 16:43	858.03	320,586.50	226,391.09	70,901.67	5.48	16.84	14.13	276.34	0.00	58.70	25.20	0.00
7/5/07 16:44	858.54	331,125.81	232,153.00	71,651.29	4.44	16.88	14.23	276.00	0.00	58.50	25.95	5,730.78
7/5/07 16:45	858.66	322,485.31	230,874.41	71,683.19	4.44	17.16	14.34	276.34	0.00	65.00	27.90	0.00
7/5/07 16:46	859.27	320,606.41	229,991.20	71,609.38	4.44	16.89	14.45	276.65	0.00	64.60	28.40	6,693.33
7/5/07 16:47	859.24	335,167.81	229,441.30	71,375.12	4.44	16.75	14.57	276.65	0.00	65.00	27.30	0.00
7/5/07 16:48	858.92	325,410.41	231,881.00	70,771.98	9.47	16.72	14.71	276.65	0.00	64.10	26.45	6,383.65
7/5/07 16:49	859.77	335,514.91	236,531.50	71,337.93	4.62	15.83	14.84	276.65	0.00	62.80	26.65	0.00
7/5/07 16:50	860.71	333,689.81	235,692.20	72,475.79	6.44	15.75	14.98	276.65	0.00	61.10	26.50	6,740.59
7/5/07 16:51	861.09	338,142.41	240,165.70	71,279.02	7.03	16.00	15.12	275.98	0.00	60.30	25.85	0.00
7/5/07 16:52	861.63	323,544.00	231,808.70	71,719.09	7.62	16.75	15.25	276.01	0.00	58.10	25.25	0.00
7/5/07 16:53	861.74	340,991.59	241,852.20	71,632.21	4.75	16.00	15.39	275.70	0.00	58.60	25.20	0.00
7/5/07 16:54	861.15	329,721.69	233,153.30	70,771.84	7.51	15.81	15.52	275.34	0.00	58.50	24.80	0.00
7/5/07 16:55	860.90	334,747.59	232,882.59	70,717.21	6.29	15.92	15.66	274.62	0.00	58.50	24.45	4,874.83
7/5/07 16:56	859.67	330,443.19	236,625.59	72,258.56	3.88	16.00	15.54	274.62	0.00	58.50	24.40	0.00
7/5/07 16:57	859.05	326,415.09	232,267.20	71,210.73	7.15	15.92	15.40	274.62	0.00	58.30	24.10	0.00
7/5/07 16:58	859.13	318,825.19	236,442.70	70,808.92	5.92	16.00	15.29	274.14	0.00	58.80	24.45	0.00
7/5/07 16:59	859.95	336,869.41	238,336.50	72,161.43	5.96	16.00	15.12	274.62	0.00	58.30	24.40	0.00
7/5/07 17:00	860.60	330,011.00	230,954.20	70,226.70	7.75	15.98	15.01	275.01	0.00	58.60	24.20	0.00
7/5/07 17:01	861.46	322,960.91	229,226.80	70,767.04	6.39	16.13	15.03	275.12	0.00	58.70	23.70	0.00
7/5/07 17:02	862.09	332,211.09	234,745.70	71,115.63	5.83	16.00	15.05	276.26	0.00	58.60	23.33	0.00
7/5/07 17:03	862.18	319,421.81	232,020.91	70,854.31	7.61	15.95	15.33	276.34	0.00	55.10	21.63	0.00
7/5/07 17:04	862.18	318,466.00	228,286.91	70,842.13	4.33	15.75	15.39	276.34	0.00	55.70	21.65	0.00
7/5/07 17:05	862.24	330,020.81	230,615.09	71,459.12	4.33	16.00	15.45	275.70	0.00	64.90	25.10	0.00
7/5/07 17:06	862.63	323,838.59	220,477.80	70,706.54	4.33	16.88	15.50	275.32	0.00	61.30	24.20	0.00
7/5/07 17:07	862.39	324,399.00	221,302.20	70,598.02	4.33	16.88	15.56	274.65	0.00	61.30	24.15	0.00
7/5/07 17:08	862.01	339,074.59	227,198.30	73,153.97	5.49	16.75	15.62	273.98	0.00	62.40	24.05	0.00
7/5/07 17:09	861.63	331,473.50	220,443.09	70,890.59	7.40	16.88	15.44	273.66	0.00	61.40	24.15	0.00
7/5/07 17:10	861.06	314,173.81	215,161.59	70,192.11	6.80	16.88	15.24	273.66	0.00	55.70	22.45	0.00
7/5/07 17:11	859.52	330,054.09	220,618.59	71,100.78	7.03	16.88	15.04	272.99	0.00	53.60	21.10	0.00
7/5/07 17:12	858.70	334,512.31	220,206.30	71,875.83	7.07	16.63	14.84	273.65	0.00	53.80	20.95	0.00
7/5/07 17:13	857.84	314,562.00	214,353.09	70,181.01	8.50	14.82	14.64	273.96	0.00	42.70	18.90	0.00
7/5/07 17:14	856.54	330,258.50	219,517.80	70,610.20	7.41	16.34	14.45	275.01	0.00	43.50	18.70	0.00
7/5/07 17:15	855.86	325,363.91	221,173.09	72,284.55	7.72	14.94	14.25	275.84	0.00	40.60	18.55	0.00
7/5/07 17:16	854.98	319,418.59	210,919.30	70,819.81	7.59	15.06	14.05	276.33	0.00	40.50	18.75	0.00
7/5/07 17:17	854.04	321,335.31	212,813.50	71,735.12	7.49	14.88	14.31	277.01	0.00	40.30	17.65	0.00
7/5/07 17:18	854.06	323,085.41	216,501.50	71,345.02	6.77	14.94	14.64	277.02	0.00	40.80	17.10	0.00
7/5/07 17:19	853.70	311,041.69	205,659.41	71,504.22	7.19	14.94	14.97	276.65	0.00	40.90	18.05	0.00
7/5/07 17:20	851.80	304,911.31	201,132.09	72,330.71	8.15	15.00	15.29	275.70	0.00	38.70	13.05	0.00
7/5/07 17:21	849.10	323,097.59	197,383.20	70,819.09	8.27	15.19	15.31	275.01	0.00	33.10	51.60	0.00
7/5/07 17:22	845.24	296,245.81	194,318.20	71,403.98	9.97	14.17	14.94	273.97	0.00	27.00	50.70	0.00
7/5/07 17:23	840.97	291,039.81	193,091.80	71,423.56	8.27	13.98	14.54	272.70	0.00	26.70	49.80	0.00
7/5/07 17:24	838.37	296,323.69	189,267.00	71,057.80	6.20	12.86	14.13	272.69	0.00	26.90	0.00	0.00
7/5/07 17:25	836.25	284,609.41	200,454.91	71,728.95	6.19	13.00	13.73	272.69	0.00	29.80	0.00	0.00
7/5/07 17:26	834.23	305,938.19	210,891.80	71,093.61	6.19	13.23	13.26	273.37	0.00	29.50	0.00	0.00
7/5/07 17:27	833.54	308,589.81	212,785.50	70,421.05	6.19	13.00	12.91	273.38	0.00	29.30	0.00	0.00
7/5/07 17:28	833.40	312,060.41	215,787.80	71,186.69	8.10	12.86	12.89	274.33	0.00	33.00	0.00	0.00
7/5/07 17:29	833.79	321,112.31	220,582.70	71,901.21	7.27	12.81	12.93	275.34	0.00	38.50	0.00	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 17:30	834.23	306,802.41	216,138.50	71,023.35	7.90	12.94	12.95	276.34	0.00	38.50	0.00	0.00
7/5/07 17:31	834.58	319,338.00	217,905.30	71,682.63	6.94	14.17	12.97	276.34	0.00	40.40	0.00	0.00
7/5/07 17:32	834.62	285,671.81	213,920.80	70,962.23	8.82	13.88	13.23	276.33	0.00	38.80	0.00	0.00
7/5/07 17:33	834.91	311,110.59	215,662.50	70,371.95	6.02	13.91	13.51	276.34	0.00	41.00	0.00	0.00
7/5/07 17:34	835.20	314,554.50	214,594.41	69,947.79	7.66	13.84	13.66	275.98	0.00	37.50	0.00	0.00
7/5/07 17:35	834.96	311,371.81	213,688.41	70,418.42	8.61	13.84	13.64	276.00	0.00	37.90	0.00	3,144.42
7/5/07 17:36	835.29	312,900.59	215,979.70	70,846.03	6.23	14.09	13.67	276.00	0.00	38.10	0.00	0.00
7/5/07 17:37	835.41	313,503.41	214,403.50	70,772.61	8.20	14.00	13.69	275.70	0.00	36.30	0.00	6,347.42
7/5/07 17:38	834.08	306,499.59	213,305.80	70,143.97	9.95	14.00	13.72	274.77	0.00	34.90	0.00	0.00
7/5/07 17:39	833.90	320,900.91	218,791.80	71,769.25	7.19	14.15	13.65	274.62	0.00	34.50	0.00	8,916.53
7/5/07 17:40	834.04	321,130.09	207,358.70	70,601.09	8.25	13.13	13.43	274.62	0.00	36.60	0.00	0.00
7/5/07 17:41	834.33	304,613.41	204,704.09	70,508.59	8.74	13.19	13.39	275.01	0.00	37.70	0.00	10,156.62
7/5/07 17:42	833.79	312,876.09	209,829.50	71,217.98	6.13	14.06	13.35	274.99	0.00	38.40	0.00	0.00
7/5/07 17:43	834.65	320,451.81	208,754.59	71,270.45	5.97	14.05	13.30	275.34	0.00	40.30	18.10	0.00
7/5/07 17:44	835.94	327,177.31	207,916.70	70,790.98	6.91	14.05	13.26	275.34	0.00	40.70	18.40	1,155.71
7/5/07 17:45	837.01	340,468.19	211,193.30	70,988.04	6.92	14.81	13.22	276.34	0.00	44.90	19.80	0.00
7/5/07 17:46	838.64	315,898.19	215,067.80	71,095.73	6.92	14.34	14.76	276.33	0.00	51.50	21.90	5,928.14
7/5/07 17:47	839.73	345,107.31	223,545.41	71,011.20	6.92	14.01	14.93	275.70	0.00	51.10	21.05	0.00
7/5/07 17:48	840.85	350,112.91	230,399.30	70,599.22	9.24	15.00	15.10	275.70	0.00	51.40	21.20	7,941.89
7/5/07 17:49	842.04	357,131.31	232,463.70	71,338.38	6.41	14.84	15.03	275.01	0.00	52.70	21.10	0.00
7/5/07 17:50	844.47	342,688.91	228,018.20	70,398.90	7.80	14.95	14.84	274.62	0.00	48.00	21.05	8,141.66
7/5/07 17:51	846.01	344,801.31	229,060.70	71,208.66	7.33	15.04	14.65	274.62	0.00	43.20	18.75	0.00
7/5/07 17:52	848.07	346,047.50	226,870.20	70,408.12	6.56	14.94	14.47	274.62	0.00	45.40	19.70	6,479.38
7/5/07 17:53	850.02	352,993.50	232,383.80	70,341.12	6.29	15.89	14.28	274.98	0.00	45.50	18.80	0.00
7/5/07 17:54	851.84	343,776.09	228,767.59	71,341.84	7.47	15.96	14.38	275.01	0.00	43.20	18.15	0.00
7/5/07 17:55	853.61	366,830.19	240,872.70	73,010.79	6.41	15.98	14.43	274.61	0.00	56.10	21.75	2,908.49
7/5/07 17:56	855.43	350,296.91	232,285.59	71,448.81	8.40	17.45	14.48	275.34	0.00	56.00	22.10	0.00
7/5/07 17:57	856.26	345,090.69	232,282.20	72,440.88	8.37	16.91	14.36	274.62	0.00	52.30	20.40	8,191.88
7/5/07 17:58	856.77	357,385.50	233,847.80	71,594.84	5.21	17.13	14.13	274.64	0.00	53.30	21.15	0.00
7/5/07 17:59	857.79	349,202.09	231,599.30	71,307.71	8.86	17.00	13.94	274.31	0.00	50.50	20.45	8,343.04
7/5/07 18:00	857.63	348,887.69	227,518.00	71,457.16	7.87	17.72	13.88	274.62	0.00	52.40	20.75	0.00
7/5/07 18:01	858.53	344,987.81	229,941.30	71,944.42	5.68	18.13	13.82	275.34	0.00	58.10	22.65	5,563.64
7/5/07 18:02	860.49	362,671.69	232,965.41	71,461.39	4.42	18.03	13.76	275.70	0.00	58.40	24.60	0.00
7/5/07 18:03	862.31	346,569.69	227,530.59	70,698.26	8.14	18.88	13.71	276.33	0.00	58.10	24.60	0.00
7/5/07 18:04	863.09	350,148.91	232,206.59	71,220.72	7.40	19.75	13.72	275.98	0.00	58.60	25.45	4,216.71
7/5/07 18:05	863.70	351,146.69	238,380.30	71,326.34	7.31	19.00	13.71	275.70	0.00	64.40	26.50	0.00
7/5/07 18:06	864.77	361,767.00	243,153.41	71,692.56	7.31	19.75	13.69	275.34	0.00	64.80	25.85	6,068.81
7/5/07 18:07	866.23	369,924.31	242,258.50	71,360.27	7.31	20.00	13.68	275.35	0.00	65.70	26.75	0.00
7/5/07 18:08	867.98	359,797.31	245,207.50	71,452.08	7.98	19.88	13.66	275.01	0.00	64.30	25.85	7,567.91
7/5/07 18:09	868.53	373,773.19	249,264.80	72,542.73	7.89	20.72	13.64	274.99	0.00	62.90	25.30	0.00
7/5/07 18:10	870.09	369,003.19	246,476.50	71,580.47	7.98	20.38	13.63	274.99	0.00	62.10	25.00	0.00
7/5/07 18:11	871.87	360,379.81	244,367.50	71,970.99	7.97	20.09	13.63	275.34	0.00	59.90	24.15	0.00
7/5/07 18:12	873.20	359,538.81	237,960.20	71,351.73	7.62	20.84	13.57	275.70	0.00	58.90	23.50	0.00
7/5/07 18:13	874.12	362,750.31	241,443.80	71,509.02	7.48	20.88	13.57	275.70	0.00	58.50	23.00	0.00
7/5/07 18:14	874.67	371,068.09	242,742.00	71,384.61	8.28	20.91	13.60	275.34	0.00	58.20	22.85	0.00
7/5/07 18:15	874.88	361,732.41	236,809.20	71,097.24	9.16	20.88	13.57	275.34	0.00	57.30	22.25	0.00
7/5/07 18:16	874.64	352,639.41	240,214.50	70,810.14	7.80	20.88	13.55	275.01	0.00	49.90	20.95	0.00
7/5/07 18:17	873.66	351,406.41	235,194.59	71,008.80	7.09	21.01	13.52	274.33	0.00	46.50	19.10	8,751.09
7/5/07 18:18	871.48	359,843.41	235,341.70	70,474.31	7.49	20.88	13.49	274.64	0.00	47.80	19.85	7,617.14
7/5/07 18:19	870.99	364,864.91	236,563.09	70,666.49	7.49	20.94	13.47	275.01	0.00	42.70	19.15	5,819.08

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/5/07 18:20	871.34	353,473.69	236,054.59	71,452.20	7.70	20.88	13.44	275.70	0.00	40.80	17.60	6,239.20
7/5/07 18:21	871.57	350,748.69	234,277.91	70,699.70	6.83	20.75	13.41	276.01	0.00	40.70	18.50	6,500.13
7/5/07 18:22	872.36	352,934.91	233,966.80	70,885.88	5.14	20.88	13.39	276.34	0.00	40.60	18.40	8,305.31
7/5/07 18:23	872.23	348,676.81	232,999.00	71,019.59	7.57	20.75	13.36	276.00	0.00	40.50	17.60	8,389.40
7/5/07 18:24	871.83	354,905.09	237,929.80	71,170.67	6.99	20.91	13.33	275.70	0.00	40.40	17.50	8,376.49
7/5/07 18:25	872.11	360,912.19	236,153.09	69,490.99	7.01	21.13	13.31	275.34	0.00	45.60	20.05	8,346.44
7/5/07 18:26	872.46	353,535.09	236,571.50	70,938.85	7.01	20.88	13.28	275.70	0.00	44.90	19.75	6,306.96
7/5/07 18:27	872.79	354,029.19	236,834.30	71,920.20	7.01	21.68	13.25	275.34	0.00	45.80	20.65	6,568.13
7/5/07 18:28	873.52	347,747.91	232,098.50	70,717.95	6.47	21.25	13.23	274.64	0.00	46.90	20.20	5,741.03
7/5/07 18:29	874.03	349,594.00	228,568.91	69,998.68	7.02	21.13	13.15	273.67	0.00	50.70	21.25	6,066.19
7/5/07 18:30	874.79	354,351.69	234,020.41	71,947.81	6.05	20.84	12.92	273.67	0.00	57.90	22.60	5,942.50
7/5/07 18:31	875.53	360,596.31	232,559.80	71,323.33	7.31	22.91	12.34	273.83	0.00	60.00	23.50	7,292.81
7/5/07 18:32	876.05	350,125.69	227,572.50	70,192.11	8.71	23.03	12.05	273.66	0.00	60.20	23.70	7,220.50
7/5/07 18:33	876.81	364,494.50	236,865.50	72,365.52	6.24	22.88	11.74	273.38	0.00	58.60	25.25	0.00
7/5/07 18:34	877.17	350,191.31	230,845.09	70,694.13	7.54	22.78	11.43	272.99	0.00	58.70	24.60	0.00
7/5/07 18:35	876.94	347,416.59	225,416.20	70,729.79	7.48	23.92	11.12	272.99	0.00	59.10	25.05	0.00
7/5/07 18:36	876.14	349,222.41	231,267.30	72,287.30	7.16	22.84	10.81	272.31	0.00	58.80	25.05	0.00
7/5/07 18:37	875.94	343,541.50	230,189.91	71,063.87	5.98	23.34	10.50	272.69	0.00	58.50	24.75	0.00
7/5/07 18:38	875.35	352,209.69	228,106.20	70,736.45	5.90	23.62	10.19	273.00	0.00	58.60	24.55	0.00
7/5/07 18:39	874.29	347,660.31	232,296.80	71,992.95	7.93	24.00	9.88	273.38	0.00	58.20	24.50	0.00
7/5/07 18:40	873.72	349,706.50	231,712.30	71,790.98	6.51	23.54	9.57	273.97	0.00	58.40	24.00	0.00
7/5/07 18:41	873.69	349,195.00	229,322.91	71,304.19	5.35	23.63	9.26	274.62	0.00	58.60	23.60	0.00
7/5/07 18:42	873.14	344,939.91	228,860.41	71,508.70	7.59	23.75	8.95	275.70	0.00	58.50	23.05	0.00
7/5/07 18:43	873.01	352,965.81	231,520.09	72,099.35	6.27	23.97	8.88	276.34	0.00	58.20	23.20	2,619.78
7/5/07 18:44	871.83	354,261.91	231,167.09	71,408.19	7.62	23.78	9.01	276.66	0.00	54.80	21.65	1,141.08
7/5/07 18:45	870.40	346,414.81	227,541.30	71,239.73	7.74	23.95	9.15	277.01	0.00	60.20	23.65	0.00
7/5/07 18:46	868.99	346,666.81	229,783.20	71,113.13	7.73	23.25	9.28	276.65	0.00	60.30	23.85	4,170.76
7/5/07 18:47	867.88	348,902.91	231,554.70	71,799.88	7.73	23.53	9.41	276.33	0.00	60.40	23.80	0.00
7/5/07 18:48	867.46	349,333.00	228,939.59	71,223.14	5.96	23.38	9.54	275.70	0.00	61.30	23.90	5,667.37
7/5/07 18:49	867.65	352,286.59	227,537.70	71,060.37	6.11	23.38	9.67	274.99	0.00	62.80	24.30	0.00
7/5/07 18:50	867.68	343,032.81	231,497.00	72,043.93	6.95	23.34	9.80	275.01	0.00	59.40	23.15	6,259.22
7/5/07 18:51	866.77	343,933.50	234,014.50	71,444.34	5.14	23.25	9.84	274.64	0.00	59.50	23.10	0.00
7/5/07 18:52	867.55	365,941.00	234,935.59	70,531.78	6.15	23.38	9.82	275.01	0.00	58.50	23.65	8,633.47
7/5/07 18:53	867.98	362,686.41	242,049.80	71,115.69	8.01	23.38	9.90	275.70	0.00	58.30	23.10	0.00
7/5/07 18:54	869.47	368,721.81	245,609.09	71,467.43	6.75	24.00	9.99	276.34	0.00	58.40	23.05	8,927.06
7/5/07 18:55	870.91	366,952.69	238,690.41	71,146.95	8.08	23.78	10.06	276.65	0.00	58.70	23.40	0.00
7/5/07 18:56	871.77	355,817.19	239,541.80	71,129.96	7.06	24.00	10.34	277.22	0.00	58.60	22.60	624.59
7/5/07 18:57	871.62	357,714.50	242,176.59	71,944.35	6.42	23.88	10.67	277.03	0.00	54.10	21.60	611.25
7/5/07 18:58	872.05	355,657.91	239,030.50	71,014.45	7.58	23.84	11.05	277.34	0.00	58.00	22.05	0.00
7/5/07 18:59	872.72	357,715.50	238,062.09	71,916.80	5.58	23.00	11.40	277.33	0.00	52.80	21.45	5,674.29
7/5/07 19:00	872.45	363,607.91	244,994.80	72,890.18	7.28	22.75	11.74	277.02	0.00	49.90	20.00	0.00
7/5/07 19:01	872.52	359,329.50	240,184.59	72,086.17	7.24	22.75	12.04	276.34	0.00	53.20	21.25	6,871.04
7/5/07 19:02	871.50	354,894.91	234,934.59	71,134.46	7.09	23.00	12.10	275.70	0.00	48.80	19.85	0.00
7/5/07 19:03	871.00	360,563.31	237,338.20	71,044.41	7.42	23.00	12.15	275.35	0.00	50.00	20.30	8,349.10
7/5/07 19:04	869.53	363,077.59	241,404.41	70,976.22	7.51	23.00	12.20	275.35	0.00	50.30	20.00	0.00
7/5/07 19:05	868.99	348,389.50	231,637.00	71,240.51	7.54	22.98	12.03	275.01	0.00	49.00	20.85	9,620.72
7/5/07 19:06	867.80	357,349.31	234,327.09	70,644.89	7.54	22.11	11.93	274.65	0.00	52.70	22.30	0.00
7/5/07 19:07	867.48	358,930.19	238,760.80	71,948.19	7.54	22.03	11.83	274.65	0.00	53.00	22.25	1,633.74
7/5/07 19:08	866.55	350,903.31	237,490.20	71,093.85	7.63	21.97	11.73	274.62	0.00	46.00	19.80	1,382.90
7/5/07 19:09	865.83	351,919.81	236,240.50	71,066.27	6.33	22.00	11.75	274.98	0.00	44.50	19.55	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 19:10	865.82	357,631.81	237,238.59	71,658.63	6.34	21.91	11.88	275.01	0.00	48.80	19.95	5,646.57
7/5/07 19:11	865.47	354,505.19	234,995.70	70,790.59	7.42	21.59	12.02	275.34	0.00	47.20	19.50	0.00
7/5/07 19:12	865.98	352,188.81	234,642.80	71,015.93	7.81	21.75	12.16	275.70	0.00	48.60	20.25	0.00
7/5/07 19:13	864.78	366,123.59	237,065.59	71,395.89	7.05	21.69	12.30	276.34	0.00	50.90	20.30	7,268.21
7/5/07 19:14	863.20	352,725.41	231,691.59	70,532.23	9.54	21.09	12.44	276.34	0.00	46.00	19.55	9,599.86
7/5/07 19:15	863.08	356,470.41	236,517.20	72,130.65	7.74	20.88	12.57	276.65	0.00	50.10	20.85	8,376.91
7/5/07 19:16	864.14	359,030.69	235,343.50	71,653.56	6.21	20.82	12.71	276.65	0.00	48.00	20.20	8,373.25
7/5/07 19:17	864.94	341,700.41	228,501.59	70,602.00	8.39	20.88	12.85	276.34	0.00	46.10	18.60	7,247.36
7/5/07 19:18	865.47	347,190.00	235,230.00	71,515.48	6.00	21.00	12.91	276.65	0.00	45.50	18.85	6,223.35
7/5/07 19:19	865.48	353,497.91	232,577.30	71,795.19	6.40	22.00	13.12	276.34	0.00	42.80	18.70	5,973.95
7/5/07 19:20	865.49	346,163.81	225,308.50	70,540.70	8.78	21.84	13.23	275.70	0.00	40.70	17.25	6,092.28
7/5/07 19:21	865.86	352,407.19	233,332.30	71,405.92	7.23	20.88	13.42	275.32	0.00	40.40	18.33	6,127.88
7/5/07 19:22	866.05	364,794.69	233,091.41	71,605.28	8.57	21.22	13.35	275.01	0.00	40.50	18.80	6,521.33
7/5/07 19:23	866.47	346,161.41	225,600.30	71,460.30	9.45	21.00	13.14	274.31	0.00	40.10	18.40	7,472.75
7/5/07 19:24	866.92	346,850.09	225,769.70	71,356.16	7.14	20.66	12.92	274.31	0.00	40.60	17.20	7,575.94
7/5/07 19:25	867.57	344,843.69	229,656.41	71,938.03	7.07	20.91	12.70	274.33	0.00	45.00	20.50	8,106.72
7/5/07 19:26	867.84	342,180.00	223,178.20	70,921.78	7.07	22.00	12.48	274.33	0.00	44.80	19.40	8,183.73
7/5/07 19:27	868.77	349,594.19	226,278.70	72,132.84	7.07	20.75	12.26	274.33	0.00	47.40	21.10	6,168.65
7/5/07 19:28	869.58	343,685.81	228,237.09	72,996.55	5.56	21.66	12.04	274.64	0.00	51.30	22.00	4,090.34
7/5/07 19:29	870.47	343,834.91	226,104.41	71,635.15	5.83	21.98	11.82	274.31	0.00	60.60	23.50	0.00
7/5/07 19:30	871.17	359,953.31	230,988.30	72,343.95	6.78	22.13	11.60	274.31	0.00	62.50	24.65	0.00
7/5/07 19:31	870.60	342,988.50	224,971.20	71,842.34	8.96	22.25	11.38	274.36	0.00	60.90	24.45	0.00
7/5/07 19:32	871.02	355,914.91	231,071.09	72,273.82	6.10	22.88	11.27	275.01	0.00	59.50	25.75	0.00
7/5/07 19:33	871.66	354,084.09	228,128.09	72,171.34	6.94	22.75	11.20	275.01	0.00	58.10	25.45	0.00
7/5/07 19:34	872.24	346,570.09	229,531.80	71,790.05	6.62	22.91	11.14	275.01	0.00	58.80	26.10	0.00
7/5/07 19:35	872.65	341,666.59	223,058.91	71,644.52	4.97	23.00	11.08	275.01	0.00	58.40	26.70	0.00
7/5/07 19:36	872.39	347,347.91	228,298.20	72,060.30	6.01	23.00	10.96	274.98	0.00	58.80	27.10	0.00
7/5/07 19:37	870.52	355,820.19	233,225.00	71,533.91	6.12	24.09	10.95	274.62	0.00	58.40	26.90	0.00
7/5/07 19:38	870.01	350,874.31	235,879.50	71,903.90	5.18	22.50	10.79	274.31	0.00	58.60	27.20	0.00
7/5/07 19:39	870.29	376,328.31	250,351.80	72,138.34	4.29	23.53	10.60	274.31	0.00	58.30	27.25	0.00
7/5/07 19:40	869.79	364,007.81	246,478.80	71,376.68	7.50	24.00	10.37	274.62	0.00	58.20	26.35	0.00
7/5/07 19:41	869.74	372,460.50	248,480.70	70,902.91	4.69	24.13	10.35	274.62	0.00	58.20	26.30	0.00
7/5/07 19:42	868.86	380,556.50	251,095.50	71,411.63	6.75	24.88	10.09	274.62	0.00	58.60	25.20	0.00
7/5/07 19:43	868.85	370,717.31	255,432.09	72,179.13	8.38	24.88	9.99	274.62	0.00	58.30	24.85	0.00
7/5/07 19:44	869.56	378,875.59	250,093.41	71,559.14	5.88	24.79	9.99	275.01	0.00	58.70	24.40	0.00
7/5/07 19:45	869.07	372,653.19	252,543.20	71,377.81	6.10	24.88	9.88	275.01	0.00	64.90	26.10	0.00
7/5/07 19:46	869.09	376,547.69	253,591.20	72,429.91	6.10	25.00	9.84	275.01	0.00	65.00	27.00	8,316.24
7/5/07 19:47	870.64	368,369.41	250,075.80	70,968.05	6.10	24.97	9.86	275.34	0.00	64.70	26.65	13,528.53
7/5/07 19:48	872.11	353,116.31	252,876.70	71,359.55	6.39	24.88	9.87	275.36	0.00	64.40	26.90	13,628.04
7/5/07 19:49	873.63	368,828.09	249,461.91	71,341.27	5.69	24.88	9.87	276.01	0.00	62.40	24.85	13,543.80
7/5/07 19:50	875.84	375,289.91	251,329.09	70,481.80	6.92	24.75	9.93	276.65	0.00	61.10	25.00	13,686.83
7/5/07 19:51	878.14	374,359.59	250,374.80	71,730.58	6.91	24.88	10.31	277.01	0.00	59.50	24.60	10,017.30
7/5/07 19:52	876.07	375,433.81	251,074.30	71,004.69	7.22	24.89	10.82	277.99	0.00	58.30	24.40	11,274.67
7/5/07 19:53	872.35	366,447.91	248,925.30	71,149.16	6.72	24.97	11.38	278.01	0.00	58.60	24.95	12,088.87
7/5/07 19:54	868.97	365,189.19	249,982.41	71,349.89	5.99	24.83	11.82	278.03	0.00	58.30	25.50	11,485.88
7/5/07 19:55	865.41	361,557.31	248,267.80	70,919.53	4.96	24.97	12.20	277.68	0.00	58.40	26.05	11,606.34
7/5/07 19:56	861.62	366,576.81	248,087.50	70,818.63	4.66	24.84	12.50	277.01	0.00	58.60	26.05	12,539.42
7/5/07 19:57	862.91	375,522.00	254,616.41	72,900.11	5.39	24.88	12.68	276.01	0.00	58.30	26.95	11,091.48
7/5/07 19:58	865.73	395,056.91	251,665.50	71,053.07	6.74	25.13	12.71	275.70	0.00	58.40	26.45	10,710.24
7/5/07 19:59	866.93	379,281.31	252,450.80	72,330.91	8.28	25.09	12.74	275.70	0.00	58.60	26.25	10,845.37

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 20:00		868.35	371,083.31	249,822.20	71,622.02	7.85	24.81	12.76	275.01	0.00	58.20	26.10
7/5/07 20:01		868.69	371,533.19	248,586.59	71,688.06	7.94	24.88	12.68	274.31	0.00	58.50	25.50
7/5/07 20:02		865.83	360,700.50	247,655.00	71,453.52	6.29	24.88	12.45	274.31	0.00	58.80	26.00
7/5/07 20:03		862.47	371,733.50	255,027.80	73,394.17	6.75	24.72	12.33	274.62	0.00	58.50	26.40
7/5/07 20:04		861.41	372,857.50	246,771.20	71,303.91	4.67	24.88	12.20	275.34	0.00	58.10	26.05
7/5/07 20:05		859.57	370,522.81	248,436.09	72,011.85	5.30	24.65	12.19	275.70	0.00	64.90	29.40
7/5/07 20:06		858.54	362,436.41	246,928.50	71,001.26	5.30	25.13	12.17	276.01	0.00	65.00	28.50
7/5/07 20:07		859.72	378,623.09	255,665.59	73,215.88	5.30	24.66	12.40	276.01	0.00	64.50	29.85
7/5/07 20:08		861.30	370,426.00	248,429.20	71,474.93	7.02	25.13	12.61	276.67	0.00	64.20	29.30
7/5/07 20:09		863.25	364,657.31	250,512.50	71,985.76	7.35	25.88	12.82	276.65	0.00	63.00	28.55
7/5/07 20:10		866.00	366,876.19	250,732.00	72,232.37	4.36	24.88	13.05	276.65	0.00	60.90	28.00
7/5/07 20:11		867.29	368,101.19	253,000.70	72,264.38	5.67	25.19	13.18	276.34	0.00	59.80	27.10
7/5/07 20:12		865.64	380,165.91	247,145.91	71,983.83	7.02	25.75	13.20	275.70	0.00	58.40	25.60
7/5/07 20:13		863.50	375,590.41	251,392.20	72,091.16	6.42	25.34	13.12	275.01	0.00	58.70	25.95
7/5/07 20:14		861.50	370,574.00	248,095.09	72,276.98	7.21	24.86	13.13	274.62	0.00	58.20	25.40
7/5/07 20:15		858.66	377,099.50	250,448.00	72,279.13	7.66	24.84	12.99	274.31	0.00	58.40	25.75
7/5/07 20:16		858.66	371,376.81	250,686.80	71,764.50	5.86	25.00	12.84	274.62	0.00	58.60	26.05
7/5/07 20:17		859.57	374,564.50	250,286.41	71,813.79	6.18	25.41	12.60	274.62	0.00	58.50	25.25
7/5/07 20:18		860.36	381,006.19	252,197.59	72,044.79	8.55	26.00	12.54	274.62	0.00	58.70	27.00
7/5/07 20:19		862.14	372,933.69	248,130.09	71,688.55	6.30	25.63	12.53	274.62	0.00	58.40	26.35
7/5/07 20:20		863.58	375,735.41	249,962.91	71,875.91	7.53	26.00	12.51	274.62	0.00	58.90	26.75
7/5/07 20:21		862.39	382,113.50	250,202.80	72,434.81	6.39	26.13	12.49	274.62	0.00	58.90	26.90
7/5/07 20:22		859.65	341,814.31	248,883.70	71,656.83	8.79	25.88	12.47	274.62	0.00	58.40	26.05
7/5/07 20:23		858.11	371,527.59	249,371.20	71,328.33	3.79	26.00	12.46	274.65	0.00	58.80	27.05
7/5/07 20:24		856.39	367,688.09	250,789.00	71,766.70	7.42	26.00	12.44	275.01	0.00	58.80	26.65
7/5/07 20:25		855.10	371,801.69	250,755.41	71,394.18	7.26	26.56	12.42	274.98	0.00	65.00	29.70
7/5/07 20:26		855.73	385,024.31	255,557.59	72,844.63	7.26	26.00	12.41	275.70	0.00	65.10	28.85
7/5/07 20:27		855.71	368,894.31	247,740.30	71,525.58	7.26	25.88	12.39	276.01	0.00	65.20	26.50
7/5/07 20:28		856.27	367,183.19	249,637.09	71,332.34	7.85	26.63	12.37	276.01	0.00	64.30	25.80
7/5/07 20:29		858.81	375,242.69	253,106.91	71,593.13	4.92	26.88	12.36	276.34	0.00	62.60	25.75
7/5/07 20:30		862.23	363,367.69	251,543.00	71,528.25	6.89	26.09	12.34	276.34	0.00	61.50	23.75
7/5/07 20:31		861.62	369,883.31	250,105.59	71,138.03	5.76	26.40	12.33	276.34	0.00	60.10	23.92
7/5/07 20:32		858.83	382,026.50	251,370.80	72,630.36	6.37	26.16	12.34	276.34	0.00	58.60	23.65
7/5/07 20:33		856.21	384,930.19	252,597.20	72,238.05	7.57	26.96	12.34	276.34	0.00	58.60	23.05
7/5/07 20:34		853.44	380,262.59	248,870.00	71,566.35	6.23	27.03	12.35	276.01	0.00	58.60	24.05
7/5/07 20:35		851.53	364,392.19	247,074.59	71,607.31	7.17	26.48	12.36	275.34	0.00	58.20	24.65
7/5/07 20:36		852.43	363,515.09	248,680.20	71,646.45	5.20	26.25	12.36	275.01	0.00	58.70	25.50
7/5/07 20:37		852.42	381,974.31	249,793.80	71,780.38	5.99	26.82	12.37	274.34	0.00	59.00	26.15
7/5/07 20:38		853.45	362,331.50	249,643.50	72,247.66	7.05	26.66	12.37	274.62	0.00	58.40	26.00
7/5/07 20:39		854.81	368,348.50	249,162.91	71,452.78	6.11	27.03	12.38	274.31	0.00	58.40	25.60
7/5/07 20:40		854.83	384,192.31	249,853.59	71,425.77	5.23	26.53	12.43	274.34	0.00	58.20	26.30
7/5/07 20:41		851.73	363,190.50	249,725.70	70,878.72	9.19	26.88	12.31	274.65	0.00	58.40	26.55
7/5/07 20:42		849.17	375,817.09	249,786.20	70,744.52	3.98	27.00	12.19	275.01	0.00	59.00	27.25
7/5/07 20:43		846.76	364,659.59	249,468.20	72,127.89	7.17	26.63	12.07	275.01	0.00	58.30	27.00
7/5/07 20:44		844.61	379,903.09	251,736.09	72,035.34	5.42	27.00	11.91	275.98	0.00	58.70	27.25
7/5/07 20:45		843.92	365,457.91	250,757.30	72,340.45	5.38	27.00	11.94	275.98	0.00	65.50	30.05
7/5/07 20:46		843.31	353,429.31	251,038.30	72,097.45	5.38	26.88	12.00	275.70	0.00	65.10	29.15
7/5/07 20:47		843.21	380,097.19	253,549.50	71,962.80	5.38	27.00	12.05	275.70	0.00	64.80	30.45
7/5/07 20:48		843.51	373,582.31	251,608.80	71,967.41	5.69	26.84	12.17	276.34	0.00	64.40	29.90
7/5/07 20:49		843.02	366,795.81	251,468.09	72,270.25	6.30	27.75	12.33	276.36	0.00	63.20	28.80

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 20:50		843.58	369,977.09	251,180.70	71,794.98	4.85	27.89	12.57	276.65	0.00	60.90	28.60
7/5/07 20:51		841.55	365,383.31	251,241.30	72,416.41	6.54	28.19	12.76	276.36	0.00	59.30	27.05
7/5/07 20:52		837.40	367,566.19	251,885.91	71,754.68	6.98	27.92	12.94	276.01	0.00	58.80	26.10
7/5/07 20:53		833.82	374,329.09	254,165.50	73,589.55	5.39	27.75	13.21	275.70	0.00	58.30	27.05
7/5/07 20:54		830.99	367,267.09	249,554.30	71,033.11	5.39	27.86	13.31	275.70	0.00	58.30	25.55
7/5/07 20:55		830.52	370,036.81	250,963.50	72,443.77	6.55	28.00	13.42	275.70	0.00	58.60	26.30
7/5/07 20:56		831.08	375,876.41	251,435.59	72,325.79	6.94	27.13	13.52	275.70	0.00	58.40	25.75
7/5/07 20:57		831.85	381,341.31	253,622.50	73,007.71	6.87	26.91	13.63	275.70	0.00	58.70	25.80
7/5/07 20:58		832.40	372,863.09	252,310.91	73,053.47	7.61	26.97	13.74	275.01	0.00	58.60	25.40
7/5/07 20:59		833.24	370,527.50	252,651.41	72,629.63	5.83	27.13	13.84	275.34	0.00	58.50	25.25
7/5/07 21:00		832.88	367,340.41	251,115.70	72,598.22	5.42	26.91	13.95	276.01	0.00	58.70	26.00
7/5/07 21:01		829.98	379,130.19	252,535.80	73,001.06	6.93	26.63	14.05	276.34	0.00	58.30	26.40
7/5/07 21:02		827.19	368,213.41	250,315.91	71,606.45	6.34	27.13	14.16	276.67	0.00	58.70	26.25
7/5/07 21:03		824.77	386,573.91	251,348.00	71,930.50	6.50	26.63	14.27	276.67	0.00	58.60	26.90
7/5/07 21:04		822.74	371,886.09	251,687.80	72,385.97	8.40	27.00	14.37	276.67	0.00	58.40	26.65
7/5/07 21:05		822.41	358,721.91	248,776.50	71,555.15	8.38	26.88	14.48	276.01	0.00	65.30	29.60
7/5/07 21:06		823.62	376,189.09	251,474.30	71,953.37	8.38	26.47	14.58	275.70	0.00	65.30	29.65
7/5/07 21:07		824.69	362,409.19	248,115.59	71,909.34	8.38	26.50	14.69	275.70	0.00	65.00	29.20
7/5/07 21:08		825.77	373,500.50	248,764.80	71,809.74	5.88	26.84	14.80	275.34	0.00	64.60	29.85
7/5/07 21:09		827.52	376,763.81	252,157.00	72,363.22	7.08	26.20	14.89	275.34	0.00	62.90	29.30
7/5/07 21:10		827.16	365,770.50	248,367.30	71,496.39	7.15	26.88	14.98	275.01	0.00	60.80	28.10
7/5/07 21:11		824.25	363,611.59	248,342.41	71,181.65	6.60	26.47	15.06	275.01	0.00	59.40	26.75
7/5/07 21:12		821.44	382,470.41	251,941.50	72,207.25	6.48	26.63	15.15	274.62	0.00	58.30	26.55
7/5/07 21:13		818.46	371,706.31	248,042.50	71,576.27	8.02	26.15	15.24	275.01	0.00	58.40	25.70
7/5/07 21:14		817.10	373,095.19	250,282.41	71,985.84	6.49	25.13	15.33	275.34	0.00	58.90	26.00
7/5/07 21:15		819.21	376,504.59	247,415.70	71,639.87	6.45	24.75	15.42	275.34	0.00	58.70	25.35
7/5/07 21:16		820.53	370,828.00	248,054.41	71,834.90	7.95	24.88	15.51	276.34	0.00	58.20	25.45
7/5/07 21:17		822.06	353,617.91	245,751.70	71,053.98	6.38	24.75	15.60	276.34	0.00	58.40	26.15
7/5/07 21:18		824.09	366,447.00	248,344.20	71,265.61	5.93	24.63	15.68	276.34	0.00	58.40	25.95
7/5/07 21:19		825.39	392,215.69	252,225.20	72,547.98	6.20	25.16	15.77	276.34	0.00	58.30	26.65
7/5/07 21:20		824.40	357,329.69	247,528.30	71,348.27	8.46	24.88	15.87	276.36	0.00	58.10	27.05
7/5/07 21:21		822.19	365,275.31	247,961.80	71,779.40	4.45	24.95	16.00	276.36	0.00	58.70	27.10
7/5/07 21:22		820.49	358,323.31	248,099.50	71,845.70	5.02	24.53	16.33	276.67	0.00	58.40	27.05
7/5/07 21:23		818.05	372,137.81	250,034.70	72,336.48	5.12	24.75	16.68	276.67	0.00	58.20	27.10
7/5/07 21:24		817.21	366,417.91	244,815.50	71,590.98	6.07	24.00	17.02	276.34	0.00	58.40	27.05
7/5/07 21:25		817.45	370,615.91	249,319.80	71,917.05	6.36	23.84	17.18	275.70	0.00	64.90	29.90
7/5/07 21:26		818.88	377,928.81	249,778.00	71,842.36	6.36	23.00	17.31	275.01	0.00	65.10	29.65
7/5/07 21:27		819.29	371,742.69	248,516.80	72,418.82	6.36	22.50	17.21	275.01	0.00	64.60	29.70
7/5/07 21:28		820.42	362,694.31	247,935.09	72,281.96	5.99	22.75	17.20	275.27	0.00	64.70	29.55
7/5/07 21:29		821.12	350,488.00	245,848.20	71,265.73	5.74	23.03	17.20	275.34	0.00	62.10	28.95
7/5/07 21:30		821.27	372,792.09	248,910.59	72,365.66	6.64	22.63	17.20	275.03	0.00	60.60	27.60
7/5/07 21:31		821.79	365,124.91	248,781.70	71,993.51	6.61	22.88	17.32	274.98	0.00	59.00	26.80
7/5/07 21:32		822.26	374,188.31	250,348.80	72,384.86	5.37	23.50	17.23	275.70	0.00	58.30	26.05
7/5/07 21:33		823.25	385,024.81	250,613.41	72,424.16	7.25	23.03	17.14	276.01	0.00	58.40	25.75
7/5/07 21:34		823.40	377,057.91	250,500.80	73,514.33	8.32	22.88	17.05	276.01	0.00	58.80	25.55
7/5/07 21:35		821.59	367,208.31	248,530.50	72,438.06	7.09	22.75	17.24	276.32	0.00	58.80	25.85
7/5/07 21:36		819.18	371,142.81	248,690.09	72,542.34	5.12	22.75	17.46	277.03	0.00	58.60	26.10
7/5/07 21:37		817.27	381,040.81	249,002.00	72,403.73	5.52	22.88	17.68	276.65	0.00	58.30	26.90
7/5/07 21:38		815.37	358,273.41	247,507.00	72,346.97	7.61	22.88	17.89	276.65	0.00	58.60	26.95
7/5/07 21:39		815.39	362,431.09	248,774.80	73,343.20	4.48	23.09	18.11	276.65	0.00	58.80	26.85

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 21:40	817.00	392,786.91	247,406.20	71,830.83	4.83	23.00	18.33	276.01	0.00	58.40	26.90	11,396.73
7/5/07 21:41	818.26	367,248.59	246,871.30	72,398.79	7.78	22.84	18.55	275.70	0.00	58.20	27.02	11,362.12
7/5/07 21:42	819.07	368,940.00	244,658.20	71,800.09	5.99	22.84	18.77	275.01	0.00	58.90	26.90	11,215.90
7/5/07 21:43	820.31	375,973.50	245,692.70	72,083.21	6.56	22.28	18.94	274.62	0.00	58.30	27.17	1,398.41
7/5/07 21:44	821.68	372,816.91	247,768.00	73,491.64	5.88	22.50	18.66	274.65	0.00	58.70	26.95	10,018.08
7/5/07 21:45	820.98	367,702.41	246,592.09	72,379.84	5.92	23.03	18.37	274.31	0.00	64.90	30.15	9,854.03
7/5/07 21:46	820.25	385,823.81	250,552.91	72,965.91	5.92	21.91	18.22	274.31	0.00	64.40	30.45	9,913.15
7/5/07 21:47	818.67	375,962.50	250,876.20	72,881.55	5.92	21.95	18.23	274.62	0.00	64.70	30.05	10,287.27
7/5/07 21:48	818.99	373,373.69	248,401.41	72,309.36	5.81	22.49	18.02	274.29	0.00	64.20	30.00	10,023.91
7/5/07 21:49	822.32	369,312.50	246,764.80	72,058.62	5.27	21.88	17.80	274.98	0.00	62.70	28.90	10,494.42
7/5/07 21:50	826.94	375,458.91	248,508.09	73,307.23	2.71	22.47	17.59	275.01	0.00	61.00	28.10	10,453.67
7/5/07 21:51	829.07	364,294.31	248,401.41	72,000.70	5.72	23.88	17.37	275.32	0.00	58.80	27.55	10,551.02
7/5/07 21:52	831.16	377,798.09	250,247.91	72,782.37	3.86	23.88	17.16	274.98	0.00	58.60	26.65	10,484.30
7/5/07 21:53	833.66	355,157.19	247,002.80	71,872.19	4.96	23.78	16.94	274.29	0.00	58.50	26.80	9,206.95
7/5/07 21:54	834.39	375,147.41	250,685.20	72,583.38	4.96	24.13	16.72	273.96	0.00	57.90	26.60	8,983.89
7/5/07 21:55	832.78	376,396.69	250,359.41	72,550.06	3.90	24.06	16.51	273.96	0.00	58.70	26.75	9,430.14
7/5/07 21:56	831.26	353,346.31	247,570.41	73,087.44	4.96	24.63	16.29	274.31	0.00	58.50	26.75	9,097.17
7/5/07 21:57	828.97	368,181.50	248,690.41	71,696.23	5.74	24.88	16.08	274.31	0.00	58.50	26.80	9,194.25
7/5/07 21:58	829.44	384,705.50	251,061.80	72,551.14	3.80	24.91	15.86	275.01	0.00	58.20	26.60	11,578.28
7/5/07 21:59	829.30	358,366.09	249,463.30	71,698.29	5.00	25.70	15.65	275.01	0.00	58.70	26.70	11,210.42
7/5/07 22:00	828.53	374,767.41	250,451.41	72,595.73	6.40	25.88	15.43	275.01	0.00	58.70	26.50	10,872.50
7/5/07 22:01	827.30	370,455.31	253,469.50	72,246.13	5.54	26.00	15.24	275.01	0.00	58.20	26.60	11,209.11
7/5/07 22:02	827.15	385,920.81	253,495.70	72,822.87	3.58	26.00	15.06	275.01	0.00	58.60	26.85	10,616.96
7/5/07 22:03	825.83	363,521.41	250,159.59	72,580.61	8.20	26.66	14.88	275.34	0.00	58.70	26.70	9,959.32
7/5/07 22:04	823.73	379,802.81	253,787.30	72,691.37	4.42	26.88	14.70	274.62	0.00	58.60	26.65	9,559.14
7/5/07 22:05	821.88	380,167.41	251,026.50	72,793.32	4.41	27.25	14.52	274.65	0.00	65.20	30.30	10,228.95
7/5/07 22:06	819.12	380,161.19	253,026.80	72,235.78	4.41	27.50	14.34	273.98	0.00	65.00	30.05	9,792.67
7/5/07 22:07	816.45	376,881.19	253,486.59	73,011.88	4.41	26.80	14.16	273.67	0.00	65.10	29.35	4,727.96
7/5/07 22:08	816.77	370,369.31	250,751.59	71,875.13	5.27	26.95	13.99	273.96	0.00	64.50	29.50	8,727.17
7/5/07 22:09	819.57	377,865.09	252,076.00	72,704.50	6.91	26.75	13.81	273.98	0.00	62.90	28.15	8,718.76
7/5/07 22:10	822.24	367,171.41	250,332.91	71,771.30	6.93	26.88	13.73	274.31	0.00	61.70	26.35	8,683.64
7/5/07 22:11	824.29	370,936.50	250,490.50	72,197.96	7.22	27.00	13.65	274.62	0.00	60.30	25.75	8,780.55
7/5/07 22:12	827.25	381,914.31	252,535.80	72,261.85	6.47	26.22	13.56	274.62	0.00	58.50	25.30	4,312.38
7/5/07 22:13	830.02	369,455.09	249,106.20	72,184.47	7.41	26.09	13.48	274.62	0.00	58.80	24.90	8,851.96
7/5/07 22:14	833.17	368,373.19	249,854.30	72,629.98	5.35	26.74	13.39	275.34	0.00	58.50	25.10	9,354.75
7/5/07 22:15	834.30	367,899.09	250,109.50	73,712.83	6.65	26.91	13.31	275.70	0.00	58.10	25.75	9,065.81
7/5/07 22:16	835.89	365,002.59	249,936.70	72,739.62	4.64	27.25	13.23	275.70	0.00	58.70	26.00	9,412.44
7/5/07 22:17	837.85	368,475.81	246,413.91	73,045.43	5.59	26.84	13.18	275.70	0.00	58.50	26.20	11,001.34
7/5/07 22:18	839.67	362,627.19	249,080.00	72,637.84	7.50	26.88	13.11	275.34	0.00	58.50	26.35	10,480.60
7/5/07 22:19	841.75	369,702.41	248,476.20	72,687.49	4.42	26.88	13.04	275.01	0.00	58.60	27.15	10,460.07
7/5/07 22:20	843.15	369,066.69	248,231.80	73,736.25	6.18	27.03	12.98	275.01	0.00	58.70	27.05	10,464.69
7/5/07 22:21	844.25	365,913.09	247,123.50	72,412.98	6.31	27.06	12.91	274.62	0.00	58.10	27.10	10,460.11
7/5/07 22:22	846.11	365,038.00	246,435.20	72,174.40	5.39	26.88	12.85	275.01	0.00	58.20	27.00	9,859.87
7/5/07 22:23	846.22	371,587.81	246,378.59	72,577.85	5.18	26.69	12.92	275.01	0.00	58.70	26.85	9,232.45
7/5/07 22:24	844.31	369,243.91	246,131.91	72,063.77	7.71	27.00	12.85	275.34	0.00	58.70	27.00	9,917.97
7/5/07 22:25	842.34	365,721.00	243,889.41	72,499.71	7.54	27.00	12.79	275.34	0.00	64.90	30.40	9,863.32
7/5/07 22:26	840.25	363,432.31	245,309.30	72,950.97	7.54	27.00	12.72	275.98	0.00	64.90	30.20	9,960.67
7/5/07 22:27	837.85	363,112.91	244,758.00	72,877.04	7.54	27.75	12.66	276.01	0.00	65.00	29.75	0.00
7/5/07 22:28	836.56	368,154.50	242,880.70	72,306.60	5.62	27.58	12.60	276.01	0.00	64.20	29.75	0.00
7/5/07 22:29	837.33	345,695.31	240,905.59	72,650.57	6.33	27.13	12.53	275.34	0.00	63.00	29.10	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 22:30	837.92	350,528.69	242,093.00	72,265.22	5.84	27.03	12.47	275.01	0.00	61.00	28.15	0.00
7/5/07 22:31	839.69	378,856.00	243,950.91	72,765.63	3.77	27.69	12.40	274.98	0.00	59.80	27.60	0.00
7/5/07 22:32	842.41	390,147.69	240,769.30	73,018.59	6.36	28.75	12.34	275.01	0.00	58.50	26.55	0.00
7/5/07 22:33	844.22	348,150.50	240,037.70	72,185.51	6.55	29.41	12.22	273.96	0.00	58.20	26.80	0.00
7/5/07 22:34	845.68	362,619.50	238,280.20	72,556.30	4.71	29.00	12.03	273.96	0.00	58.30	26.80	0.00
7/5/07 22:35	847.55	362,418.50	239,356.41	72,356.54	5.84	28.98	11.85	273.67	0.00	58.90	26.80	0.00
7/5/07 22:36	848.99	366,502.81	241,209.41	72,714.27	5.42	28.85	11.66	273.98	0.00	58.40	26.80	0.00
7/5/07 22:37	849.38	365,159.31	240,578.00	72,565.97	7.55	29.88	11.48	273.38	0.00	58.20	26.75	0.00
7/5/07 22:38	850.68	354,543.81	238,545.09	72,275.42	5.52	29.11	11.29	273.38	0.00	58.40	26.80	0.00
7/5/07 22:39	851.39	355,087.19	241,354.59	72,694.58	5.31	29.53	11.11	273.38	0.00	58.70	26.65	0.00
7/5/07 22:40	851.51	361,296.50	241,467.70	72,366.55	5.63	29.72	10.92	273.38	0.00	58.00	26.75	0.00
7/5/07 22:41	849.58	360,812.91	240,425.20	72,441.91	5.27	29.19	10.74	273.65	0.00	58.30	26.70	7,885.96
7/5/07 22:42	848.61	360,307.00	240,455.09	73,299.23	6.35	28.74	10.55	274.62	0.00	58.80	26.25	8,527.18
7/5/07 22:43	849.32	367,281.69	242,277.00	72,457.82	5.89	28.95	10.37	275.01	0.00	58.10	26.45	8,448.53
7/5/07 22:44	850.11	350,564.31	240,690.80	72,276.95	5.14	28.88	10.18	275.98	0.00	58.60	24.95	7,350.20
7/5/07 22:45	850.49	367,556.91	243,591.41	72,398.05	5.53	29.88	10.00	276.34	0.00	64.80	27.27	7,647.93
7/5/07 22:46	850.99	375,244.00	243,169.50	72,279.60	5.53	29.13	9.88	276.65	0.00	65.00	26.95	5,884.86
7/5/07 22:47	851.46	365,055.81	239,487.30	70,562.95	5.53	29.13	9.79	276.65	0.00	64.70	27.20	5,833.27
7/5/07 22:48	851.85	358,668.50	242,768.80	72,283.54	7.64	29.79	9.71	275.70	0.00	64.70	27.05	5,970.90
7/5/07 22:49	852.13	364,381.91	242,055.30	72,600.72	5.07	30.00	9.63	275.70	0.00	62.90	26.40	5,637.51
7/5/07 22:50	852.77	365,109.19	241,036.00	71,963.44	6.18	30.00	9.54	274.62	0.00	61.40	26.15	7,116.63
7/5/07 22:51	853.27	348,310.50	240,266.30	71,917.34	7.62	30.25	9.46	273.96	0.00	60.10	25.20	7,427.20
7/5/07 22:52	853.90	374,854.81	244,046.00	73,218.72	4.35	29.91	9.37	273.96	0.00	58.70	26.05	8,660.78
7/5/07 22:53	854.61	363,631.19	239,618.41	72,231.59	6.83	30.30	9.29	273.38	0.00	58.60	25.60	8,058.82
7/5/07 22:54	854.56	355,723.59	240,713.59	71,870.63	8.22	31.00	9.20	273.00	0.00	58.50	25.20	7,608.25
7/5/07 22:55	854.93	368,591.00	242,858.00	72,869.46	4.44	31.00	8.80	273.00	0.00	58.50	25.75	6,720.74
7/5/07 22:56	855.14	368,452.41	240,902.20	72,517.25	6.58	31.00	8.40	272.31	0.00	58.70	25.20	0.00
7/5/07 22:57	855.17	358,729.19	239,299.70	71,277.05	7.87	30.95	7.99	272.03	0.00	58.70	25.60	0.00
7/5/07 22:58	855.54	357,812.00	239,142.41	71,435.51	6.19	31.13	7.59	271.64	0.00	58.50	26.35	0.00
7/5/07 22:59	854.95	359,011.19	240,457.70	72,574.55	7.54	30.97	7.19	271.62	0.00	58.70	25.55	0.00
7/5/07 23:00	854.46	370,321.91	240,491.09	73,071.76	6.72	31.03	6.79	271.62	0.00	58.40	25.55	0.00
7/5/07 23:01	854.26	355,701.41	238,321.80	71,752.35	7.26	30.97	6.38	272.00	0.00	58.60	25.70	0.00
7/5/07 23:02	854.83	348,360.81	238,175.00	72,644.72	5.44	30.99	5.98	272.69	0.00	58.30	25.70	0.00
7/5/07 23:03	854.70	350,212.41	238,658.09	73,029.70	5.68	31.53	5.58	273.38	0.00	58.60	25.15	0.00
7/5/07 23:04	854.00	360,137.59	239,363.09	72,277.13	5.38	31.66	5.17	273.65	0.00	58.80	25.20	0.00
7/5/07 23:05	854.46	380,013.09	239,048.50	72,447.63	5.57	31.75	4.77	273.98	0.00	64.70	28.75	0.00
7/5/07 23:06	853.65	354,716.00	236,898.80	72,132.40	5.57	31.88	4.37	274.65	0.00	65.00	29.15	6,701.77
7/5/07 23:07	852.20	359,154.19	238,199.50	72,040.74	5.57	32.00	4.15	275.01	0.00	64.80	28.70	5,431.13
7/5/07 23:08	852.26	372,040.50	241,997.80	73,277.20	6.05	31.78	4.13	275.34	0.00	64.70	29.00	6,005.44
7/5/07 23:09	852.87	357,080.31	233,321.00	71,574.05	5.95	32.25	4.11	275.70	0.00	62.90	27.70	8,689.79
7/5/07 23:10	852.70	352,631.41	236,375.09	71,837.01	8.41	31.63	4.09	275.70	0.00	61.80	26.50	8,377.79
7/5/07 23:11	852.87	331,276.59	237,105.70	72,734.38	5.32	31.88	4.07	275.34	0.00	59.40	26.55	8,358.48
7/5/07 23:12	853.46	359,812.50	237,123.80	72,044.13	3.53	31.42	4.05	275.34	0.00	58.30	26.50	7,947.84
7/5/07 23:13	852.82	359,034.09	237,308.20	71,826.64	7.05	31.75	4.03	275.34	0.00	58.70	25.50	7,476.39
7/5/07 23:14	852.74	355,220.19	234,642.91	71,798.96	6.74	31.46	4.01	275.34	0.00	58.70	25.20	6,558.37
7/5/07 23:15	853.12	359,359.91	237,426.41	73,359.71	5.53	30.61	3.99	276.01	0.00	58.40	25.30	5,293.02
7/5/07 23:16	853.20	356,441.31	235,924.70	71,118.04	6.28	31.13	3.97	275.70	0.00	58.50	23.95	5,565.35
7/5/07 23:17	852.90	348,048.69	234,425.50	71,098.11	7.31	30.75	3.94	275.98	0.00	58.80	24.00	5,865.22
7/5/07 23:18	853.01	361,862.00	239,739.30	72,774.03	5.57	31.09	3.92	275.98	0.00	58.40	24.15	7,256.98
7/5/07 23:19	853.08	367,742.00	240,893.50	72,878.13	5.24	31.44	3.90	276.01	0.00	58.00	23.95	7,915.25

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/5/07 23:20	853.06	361,029.19	235,858.70	71,456.45	7.06	31.91	3.88	275.98	0.00	58.20	24.10	8,036.56
7/5/07 23:21	853.99	366,179.41	236,667.30	72,240.66	6.26	31.63	3.86	276.01	0.00	58.50	24.35	8,289.63
7/5/07 23:22	853.81	347,916.81	234,540.30	71,583.05	7.74	31.91	3.84	275.01	0.00	58.30	24.40	0.00
7/5/07 23:23	853.75	344,429.50	233,642.59	71,294.03	4.96	31.88	3.82	274.65	0.00	58.80	25.25	0.00
7/5/07 23:24	854.11	379,395.41	233,823.30	71,395.16	5.22	32.00	3.80	274.31	0.00	58.70	27.10	0.00
7/5/07 23:25	854.65	355,860.59	233,215.20	72,319.23	4.76	31.81	3.78	274.31	0.00	64.80	30.45	0.00
7/5/07 23:26	854.50	345,022.31	232,286.30	72,701.41	4.76	32.50	3.76	274.31	0.00	64.90	30.40	0.00
7/5/07 23:27	853.44	358,540.69	232,716.91	70,860.27	4.75	32.00	3.74	273.38	0.00	64.90	30.00	0.00
7/5/07 23:28	852.37	351,453.41	230,040.50	71,395.20	7.49	29.47	3.72	272.69	0.00	64.40	30.10	5,203.25
7/5/07 23:29	850.46	350,644.41	229,966.91	70,848.83	5.20	30.88	3.70	272.69	0.00	63.10	29.30	0.00
7/5/07 23:30	848.25	359,973.31	234,819.59	72,707.13	4.17	30.72	3.68	273.38	0.00	61.70	28.05	0.00
7/5/07 23:31	846.89	344,425.00	230,939.30	71,405.48	5.95	31.13	3.66	273.98	0.00	59.80	27.10	3,097.55
7/5/07 23:32	846.37	353,416.31	231,920.70	72,042.71	5.03	32.25	3.64	273.96	0.00	58.60	26.90	0.00
7/5/07 23:33	847.01	359,261.00	233,292.41	72,070.78	4.98	31.13	3.62	274.31	0.00	58.50	26.90	5,597.55
7/5/07 23:34	847.49	348,461.81	231,422.70	71,592.50	5.90	31.13	3.60	274.31	0.00	58.30	26.50	0.00
7/5/07 23:35	848.26	365,627.81	234,987.59	73,126.17	4.95	30.75	3.58	274.62	0.00	58.70	26.70	6,035.30
7/5/07 23:36	848.53	352,213.69	229,539.00	71,903.48	5.48	30.97	3.56	274.98	0.00	58.40	26.80	0.00
7/5/07 23:37	848.29	332,038.31	228,641.20	71,745.63	6.76	31.75	3.54	275.01	0.00	58.10	26.80	8,529.36
7/5/07 23:38	846.50	354,608.31	235,001.91	73,052.24	5.02	31.13	3.52	274.98	0.00	58.20	26.75	0.00
7/5/07 23:39	846.49	352,259.41	230,462.30	71,082.16	2.52	30.56	3.50	275.01	0.00	58.70	26.85	8,225.72
7/5/07 23:40	846.29	357,345.81	232,508.91	71,965.31	5.57	30.63	3.48	275.34	0.00	58.20	26.55	0.00
7/5/07 23:41	843.86	356,901.19	231,527.20	72,105.95	8.68	31.09	3.46	275.70	0.00	58.40	26.70	3,099.27
7/5/07 23:42	841.30	349,729.59	231,579.20	72,026.37	5.86	30.63	3.44	275.34	0.00	58.10	26.50	0.00
7/5/07 23:43	839.29	370,833.31	236,057.00	73,275.39	5.25	29.75	3.42	275.70	0.00	58.70	26.70	0.00
7/5/07 23:44	837.54	358,640.00	234,676.70	73,161.55	7.20	29.76	3.40	276.01	0.00	58.60	26.35	4,631.54
7/5/07 23:45	836.74	344,584.00	231,882.50	71,739.37	7.67	29.00	3.38	275.98	0.00	65.10	28.63	0.00
7/5/07 23:46	836.71	364,812.09	237,826.00	74,033.27	7.67	29.03	3.36	277.01	0.00	64.70	29.55	6,515.48
7/5/07 23:47	836.30	359,702.69	234,425.00	72,515.21	7.67	29.13	3.34	277.01	0.00	65.10	29.00	0.00
7/5/07 23:48	836.76	351,504.81	232,909.20	72,691.45	7.10	29.38	3.32	277.68	0.00	64.00	28.95	7,248.36
7/5/07 23:49	837.27	365,046.50	235,717.20	72,907.27	4.84	28.63	3.42	277.99	0.00	63.00	28.30	0.00
7/5/07 23:50	837.40	340,441.31	231,953.50	71,895.77	6.31	29.13	3.61	277.99	0.00	60.60	27.85	8,595.71
7/5/07 23:51	836.85	351,940.59	234,952.09	72,091.15	5.30	28.72	3.80	277.32	0.00	59.00	27.20	0.00
7/5/07 23:52	835.58	368,430.59	239,118.30	73,828.80	4.24	27.81	3.99	277.01	0.00	58.40	26.90	4,704.29
7/5/07 23:53	835.31	354,471.00	232,664.59	72,489.93	3.99	28.01	4.19	277.01	0.00	59.00	26.90	0.00
7/5/07 23:54	835.03	345,494.31	231,208.00	72,629.86	7.89	27.72	4.38	277.01	0.00	58.50	25.90	0.00
7/5/07 23:55	834.57	354,584.00	234,822.50	73,052.63	5.44	28.23	4.57	277.03	0.00	58.60	26.45	5,043.61
7/5/07 23:56	833.86	359,956.50	236,090.30	72,973.44	3.39	27.28	4.76	277.01	0.00	58.50	26.70	0.00
7/5/07 23:57	832.85	350,719.50	233,921.00	72,111.70	6.16	26.90	4.95	277.01	0.00	58.40	26.15	0.00
7/5/07 23:58	831.40	353,005.59	234,895.09	73,052.69	5.61	27.00	5.16	276.65	0.00	58.40	26.45	0.00
7/5/07 23:59	830.90	357,799.00	237,594.70	74,064.43	4.96	27.00	5.25	276.65	0.00	58.70	26.60	0.00
7/6/07 0:00	832.10	357,309.59	234,020.30	72,590.59	3.53	26.91	5.41	276.65	0.00	58.60	25.85	0.00
7/6/07 0:01	833.70	356,482.81	234,677.50	72,720.38	6.32	26.78	5.57	276.67	0.00	58.30	26.00	5,758.50
7/6/07 0:02	834.17	352,988.00	234,644.20	72,207.19	5.78	26.41	5.72	276.65	0.00	58.40	26.25	0.00
7/6/07 0:03	835.65	346,525.31	233,998.59	72,358.58	5.48	26.56	5.87	276.01	0.00	58.80	25.90	6,130.83
7/6/07 0:04	835.83	367,825.31	238,814.59	73,354.21	6.85	26.59	6.09	276.01	0.00	58.50	25.55	0.00
7/6/07 0:05	835.66	348,464.19	235,618.50	72,980.20	6.42	26.38	6.25	275.70	0.00	65.00	27.15	7,721.31
7/6/07 0:06	836.38	365,051.19	238,776.00	73,097.43	6.42	25.88	6.41	276.01	0.00	65.10	27.70	0.00
7/6/07 0:07	837.78	354,115.41	236,318.59	72,124.67	6.42	25.50	6.57	275.98	0.00	65.10	28.70	0.00
7/6/07 0:08	838.78	351,941.69	232,770.91	71,405.48	6.80	25.34	6.73	276.65	0.00	64.60	26.15	0.00
7/6/07 0:09	840.04	364,951.59	238,606.80	73,032.51	7.25	25.13	6.89	276.67	0.00	63.00	25.95	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/6/07 0:10	841.37	361,956.50	234,602.59	71,934.33	5.82	24.97	7.05	277.34	0.00	61.00	25.90	1,718.27
7/6/07 0:11	842.35	360,555.19	237,086.80	73,159.08	7.20	25.52	7.21	277.34	0.00	59.50	25.30	0.00
7/6/07 0:12	843.36	355,610.00	235,428.70	73,461.94	7.42	25.58	7.38	277.32	0.00	58.60	24.70	6,009.24
7/6/07 0:13	843.60	348,602.31	233,940.20	72,680.88	5.34	26.13	7.54	277.32	0.00	58.30	24.65	0.00
7/6/07 0:14	844.52	368,406.91	237,389.70	73,492.13	5.59	25.88	7.70	276.65	0.00	58.80	25.70	7,523.65
7/6/07 0:15	844.95	344,485.50	228,991.80	72,285.42	6.66	25.00	7.86	276.34	0.00	58.50	24.90	0.00
7/6/07 0:16	845.80	347,667.81	232,747.80	73,524.88	5.54	25.88	8.02	276.01	0.00	58.80	25.70	8,654.88
7/6/07 0:17	846.95	352,899.50	231,219.30	72,953.85	4.14	25.00	8.18	276.01	0.00	58.20	26.50	0.00
7/6/07 0:18	847.54	351,390.91	232,495.59	73,405.35	7.40	25.92	8.27	275.98	0.00	58.30	26.90	4,101.92
7/6/07 0:19	847.18	359,551.31	231,211.20	72,740.60	4.96	25.88	8.25	275.34	0.00	58.90	27.15	0.00
7/6/07 0:20	847.38	352,659.00	230,034.80	72,499.79	6.43	26.09	8.24	275.01	0.00	58.70	27.10	0.00
7/6/07 0:21	847.99	366,500.81	231,968.59	73,041.33	5.10	25.50	8.22	275.01	0.00	58.90	27.25	553.32
7/6/07 0:22	846.89	348,432.59	229,046.50	73,058.29	7.16	25.75	8.21	274.98	0.00	58.60	27.05	0.00
7/6/07 0:23	845.54	349,203.00	231,299.70	73,817.69	3.97	25.97	8.20	274.98	0.00	58.40	27.05	5,779.72
7/6/07 0:24	844.83	346,763.00	227,994.09	72,344.34	4.08	25.88	8.18	274.98	0.00	58.30	26.95	0.00
7/6/07 0:25	845.08	353,396.59	230,863.70	72,975.36	4.96	26.23	8.17	275.32	0.00	64.90	30.10	6,852.74
7/6/07 0:26	845.51	348,407.91	228,690.00	72,361.95	4.96	26.13	8.16	275.32	0.00	65.20	30.30	0.00
7/6/07 0:27	845.79	335,583.09	233,608.80	72,409.73	4.96	25.88	8.14	275.32	0.00	64.80	29.95	8,403.92
7/6/07 0:28	844.70	333,376.91	232,566.91	72,218.07	5.57	25.91	8.13	274.98	0.00	64.50	30.00	0.00
7/6/07 0:29	842.55	349,181.81	237,948.59	72,883.54	6.49	26.00	8.11	274.62	0.00	63.00	29.10	0.00
7/6/07 0:30	841.38	354,196.91	238,687.30	73,197.37	4.20	25.25	8.10	275.34	0.00	60.80	27.65	0.00
7/6/07 0:31	839.40	341,115.19	234,560.30	72,130.92	8.50	26.50	8.09	275.34	0.00	58.90	25.55	0.00
7/6/07 0:32	838.32	345,493.19	236,749.59	72,716.64	7.53	25.97	8.07	275.34	0.00	58.90	25.10	2,105.57
7/6/07 0:33	839.19	341,605.91	238,392.20	73,608.86	5.81	25.88	8.06	275.32	0.00	58.90	25.45	0.00
7/6/07 0:34	841.10	352,322.91	237,771.00	72,931.91	3.44	25.88	8.04	275.34	0.00	58.80	25.65	5,581.68
7/6/07 0:35	841.81	349,291.91	237,507.50	72,667.03	7.43	25.88	8.03	275.70	0.00	58.40	25.60	0.00
7/6/07 0:36	842.85	332,558.00	235,836.09	71,941.85	5.20	25.88	8.02	275.98	0.00	58.60	25.30	7,887.45
7/6/07 0:37	843.46	381,277.91	239,832.70	73,814.45	5.43	26.13	8.00	275.70	0.00	58.20	26.60	0.00
7/6/07 0:38	844.42	340,546.81	237,367.50	72,734.72	5.89	26.09	7.98	275.34	0.00	58.60	26.50	8,107.74
7/6/07 0:39	844.24	339,587.19	236,728.00	72,594.89	4.40	25.97	7.99	275.34	0.00	58.60	26.90	0.00
7/6/07 0:40	842.07	340,580.19	235,670.41	72,572.81	5.26	25.22	7.99	275.36	0.00	58.80	27.10	8,970.05
7/6/07 0:41	841.14	353,915.59	239,962.59	72,778.49	3.38	24.66	7.99	275.34	0.00	58.60	27.35	0.00
7/6/07 0:42	841.60	339,699.09	234,349.09	72,257.38	5.96	25.84	8.00	275.34	0.00	58.40	27.15	3,126.19
7/6/07 0:43	842.09	357,226.81	239,062.80	73,074.55	5.01	25.02	8.00	275.70	0.00	58.50	27.15	0.00
7/6/07 0:44	842.03	338,455.09	234,014.50	71,642.63	5.78	25.69	8.01	276.01	0.00	58.40	27.25	0.00
7/6/07 0:45	841.92	341,251.31	236,664.20	72,917.66	6.31	25.13	8.01	275.34	0.00	64.60	29.77	3,796.26
7/6/07 0:46	841.23	344,517.31	236,882.91	72,205.88	6.31	24.83	8.01	275.70	0.00	65.00	29.40	0.00
7/6/07 0:47	841.94	343,043.81	238,295.00	73,446.16	6.31	25.00	8.02	275.70	0.00	65.10	29.45	6,438.55
7/6/07 0:48	841.05	347,788.50	236,820.50	72,520.69	5.32	25.00	8.02	275.98	0.00	64.30	29.20	0.00
7/6/07 0:49	839.24	344,091.59	238,601.30	72,770.64	5.23	24.91	8.03	275.70	0.00	62.90	28.90	8,403.49
7/6/07 0:50	838.02	350,130.81	238,144.41	72,629.13	5.13	24.88	8.03	275.70	0.00	60.70	27.35	0.00
7/6/07 0:51	838.65	336,440.69	238,080.70	73,185.82	4.57	24.83	8.03	276.01	0.00	59.60	27.25	9,169.48
7/6/07 0:52	839.20	358,946.09	242,669.41	74,194.45	3.50	25.25	8.04	276.01	0.00	58.30	27.00	0.00
7/6/07 0:53	839.60	349,305.81	239,621.59	72,641.93	5.84	24.88	8.04	275.70	0.00	58.30	26.30	0.00
7/6/07 0:54	839.66	351,657.41	240,128.91	73,436.24	6.38	25.00	8.05	275.70	0.00	58.30	26.60	3,789.20
7/6/07 0:55	838.50	340,130.69	238,943.00	73,656.78	5.65	24.97	8.07	275.70	0.00	58.20	26.50	0.00
7/6/07 0:56	837.15	352,178.69	241,353.59	72,993.42	3.43	24.73	8.13	275.46	0.00	58.40	26.45	5,680.32
7/6/07 0:57	835.96	367,688.81	240,636.00	73,024.07	5.77	25.09	8.20	275.70	0.00	58.60	26.75	0.00
7/6/07 0:58	836.12	341,993.31	237,694.30	72,431.14	9.37	23.84	8.26	275.70	0.00	58.40	26.25	7,288.50
7/6/07 0:59	837.44	351,419.50	241,688.50	73,407.96	5.71	25.13	8.32	275.70	0.00	57.90	27.20	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	STEAM FLOW (LB/HR)
7/6/07 1:00	839.41	330,240.09	239,741.70	72,893.99	4.12	24.13	8.39	276.01	0.00	58.60	26.95	7,993.70
7/6/07 1:01	839.94	353,403.50	244,139.80	73,939.13	7.53	24.75	8.45	275.98	0.00	58.90	26.45	0.00
7/6/07 1:02	841.36	359,244.00	243,092.59	73,242.05	4.90	24.37	8.52	276.34	0.00	58.80	26.65	6,202.47
7/6/07 1:03	843.17	351,725.31	243,053.09	72,817.80	5.41	24.22	8.58	276.67	0.00	58.20	26.20	0.00
7/6/07 1:04	844.95	339,075.81	240,959.00	72,645.90	5.28	24.75	8.65	277.34	0.00	58.00	25.80	0.00
7/6/07 1:05	845.95	359,685.09	244,987.50	73,093.31	5.44	24.63	8.85	277.34	0.00	65.20	29.55	1,472.86
7/6/07 1:06	845.47	346,766.41	241,005.00	72,874.44	5.43	24.38	9.20	277.34	0.00	64.70	28.35	0.00
7/6/07 1:07	845.75	359,500.31	243,469.70	73,877.46	5.44	24.88	9.54	277.32	0.00	65.00	30.05	5,166.85
7/6/07 1:08	847.31	350,003.41	241,072.00	73,545.27	5.37	24.90	9.60	276.65	0.00	64.50	30.20	0.00
7/6/07 1:09	849.28	343,885.91	239,712.20	72,848.37	5.50	24.88	9.61	276.65	0.00	62.80	28.55	6,088.16
7/6/07 1:10	849.33	354,026.59	240,910.09	73,934.48	6.50	25.00	9.61	276.34	0.00	61.80	28.25	0.00
7/6/07 1:11	850.26	354,167.41	238,149.80	72,943.55	3.90	24.97	9.62	275.98	0.00	60.20	27.70	9,017.71
7/6/07 1:12	850.62	348,941.50	239,207.50	73,005.31	6.40	26.00	9.62	275.34	0.00	58.40	27.05	0.00
7/6/07 1:13	848.61	349,465.69	239,771.80	72,436.00	7.98	25.00	9.63	275.01	0.00	58.50	27.50	10,258.83
7/6/07 1:14	847.28	353,415.50	240,594.00	73,917.34	4.79	25.00	9.63	274.62	0.00	58.50	27.30	0.00
7/6/07 1:15	847.66	348,277.91	237,765.91	72,503.95	4.88	25.03	9.64	274.31	0.00	58.50	27.40	0.00
7/6/07 1:16	847.17	347,479.31	241,318.59	73,480.10	7.29	24.68	9.64	274.31	0.00	58.40	27.15	2,985.86
7/6/07 1:17	847.29	350,689.19	241,791.20	73,814.95	2.93	24.66	9.69	274.31	0.00	58.70	27.20	0.00
7/6/07 1:18	848.07	377,708.09	246,199.91	74,935.12	4.52	24.75	9.67	274.62	0.00	58.70	27.25	6,871.92
7/6/07 1:19	847.88	351,583.50	241,038.91	73,358.44	7.01	25.00	9.65	274.62	0.00	58.80	27.15	0.00
7/6/07 1:20	848.86	342,432.81	241,519.91	72,574.56	5.34	24.91	9.63	274.62	0.00	58.10	27.30	7,553.60
7/6/07 1:21	850.06	355,953.19	243,854.00	73,822.05	1.92	25.00	9.61	274.62	0.00	58.90	27.20	0.00
7/6/07 1:22	850.77	346,836.50	242,714.20	73,130.36	4.48	25.88	9.59	274.60	0.00	58.70	27.10	9,040.91
7/6/07 1:23	850.75	354,901.31	242,100.80	72,663.82	5.23	26.00	9.57	275.01	0.00	58.70	27.10	0.00
7/6/07 1:24	851.95	336,730.91	243,167.09	72,963.06	4.45	25.63	9.55	274.98	0.00	58.20	27.35	0.00
7/6/07 1:25	852.93	346,763.59	242,455.50	72,973.92	4.09	25.72	9.53	274.98	0.00	65.40	29.85	0.00
7/6/07 1:26	854.95	362,728.81	243,944.00	72,582.48	4.09	25.97	9.51	274.98	0.00	65.10	29.55	0.00
7/6/07 1:27	856.66	368,332.09	247,423.50	73,831.15	4.09	25.88	9.50	275.70	0.00	65.00	29.55	4,242.74
7/6/07 1:28	858.04	339,187.31	241,843.09	72,553.70	5.80	25.97	9.48	276.65	0.00	64.50	29.15	0.00
7/6/07 1:29	859.65	350,120.59	243,198.30	72,569.71	4.62	27.09	9.46	277.01	0.00	62.90	29.15	8,227.31
7/6/07 1:30	861.63	359,049.50	244,186.30	73,989.41	3.70	26.22	9.65	277.03	0.00	61.60	28.25	0.00
7/6/07 1:31	863.14	343,273.19	242,186.50	72,749.70	5.48	27.75	9.80	276.65	0.00	59.80	28.10	9,642.12
7/6/07 1:32	863.12	355,332.31	246,499.50	73,387.59	4.88	26.91	9.94	276.65	0.00	58.75	27.00	0.00
7/6/07 1:33	864.10	362,494.00	246,830.50	73,709.48	3.79	26.96	10.09	276.65	0.00	58.55	27.10	0.00
7/6/07 1:34	865.28	366,527.09	245,730.30	73,260.13	4.78	26.97	10.31	276.34	0.00	58.80	27.30	1,600.25
7/6/07 1:35	865.32	352,669.19	244,403.50	73,390.90	8.31	27.64	10.31	275.70	0.00	58.65	27.20	0.00
7/6/07 1:36	865.97	354,109.41	246,180.00	73,095.06	4.17	27.50	10.30	275.70	0.00	58.35	27.20	5,727.85
7/6/07 1:37	866.41	356,211.69	246,529.20	73,532.23	3.95	27.30	10.30	275.70	0.00	58.20	27.50	0.00
7/6/07 1:38	866.44	347,302.31	245,462.80	72,977.95	5.71	28.32	10.30	275.34	0.00	58.75	27.30	6,197.93
7/6/07 1:39	866.31	365,380.09	249,762.20	74,477.55	3.46	27.13	10.29	275.01	0.00	58.85	27.10	0.00
7/6/07 1:40	866.48	355,548.81	246,015.91	72,216.59	6.14	27.00	10.29	275.01	0.00	58.30	27.00	8,638.36
7/6/07 1:41	866.17	350,220.81	246,787.41	72,573.98	6.12	26.81	10.28	275.01	0.00	58.55	27.10	0.00
7/6/07 1:42	865.73	355,001.81	247,962.30	72,684.76	5.38	26.84	10.30	274.98	0.00	58.55	27.00	0.00
7/6/07 1:43	865.35	354,615.91	250,141.41	73,649.77	4.11	27.09	10.40	275.34	0.00	58.50	27.20	0.00
7/6/07 1:44	865.70	366,381.50	248,555.59	72,682.10	4.68	27.88	10.44	275.34	0.00	58.35	27.20	0.00
7/6/07 1:45	865.76	343,222.00	246,992.50	72,000.51	5.15	28.03	10.47	275.01	0.00	65.00	30.40	0.00
7/6/07 1:46	866.00	356,304.09	249,610.20	73,128.23	5.15	27.31	10.50	275.01	0.00	65.00	30.40	0.00
7/6/07 1:47	867.81	367,682.81	250,332.80	73,566.23	5.15	27.38	10.53	275.70	0.00	65.15	30.50	0.00
7/6/07 1:48	868.38	367,522.81	251,255.80	73,778.69	6.83	28.06	10.56	276.01	0.00	64.60	30.20	0.00
7/6/07 1:49	867.70	356,069.50	248,970.41	73,488.27	5.68	27.59	10.59	276.65	0.00	63.70	29.40	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/6/07 1:50	867.04	356,731.31	247,714.41	73,155.64	4.38	27.83	10.62	276.65	0.00	62.30	29.00	0.00
7/6/07 1:51	866.39	353,846.59	247,593.30	73,237.13	6.35	27.88	10.71	276.34	0.00	60.90	27.60	7,887.60
7/6/07 1:52	864.79	354,712.69	248,217.00	73,405.63	4.52	28.34	10.84	276.34	0.00	60.00	27.30	5,596.19
7/6/07 1:53	864.78	351,795.69	245,812.30	72,175.77	4.70	27.75	10.90	276.65	0.00	58.80	26.60	6,305.92
7/6/07 1:54	865.31	348,356.81	246,411.00	72,690.00	6.05	27.88	10.96	276.65	0.00	58.65	26.60	8,480.59
7/6/07 1:55	866.64	366,732.59	250,615.59	74,020.12	5.03	27.78	11.01	276.34	0.00	58.25	26.70	8,516.74
7/6/07 1:56	868.51	358,641.50	247,189.30	72,582.46	5.95	27.91	11.07	276.34	0.00	58.35	26.60	8,206.41
7/6/07 1:57	869.00	351,069.19	247,846.59	73,289.35	8.27	28.44	11.13	276.34	0.00	58.55	26.50	8,073.89
7/6/07 1:58	869.53	350,681.19	246,511.20	72,814.22	3.91	28.19	11.19	276.34	0.00	58.25	26.70	8,079.85
7/6/07 1:59	870.41	359,801.19	250,161.41	74,112.73	5.21	28.63	11.25	276.32	0.00	58.75	26.70	7,104.25
7/6/07 2:00	871.25	356,854.09	247,028.20	72,729.02	5.10	28.98	11.31	275.34	0.00	58.70	26.50	5,634.85
7/6/07 2:01	871.82	344,967.91	246,563.09	73,209.90	5.89	28.94	11.36	275.32	0.00	58.55	26.70	5,699.74
7/6/07 2:02	872.28	357,424.41	247,505.59	73,152.63	4.71	29.47	11.42	274.65	0.00	58.50	26.70	5,501.73
7/6/07 2:03	873.16	359,204.00	249,830.91	73,935.25	4.82	29.55	11.48	273.65	0.00	58.40	26.60	6,713.85
7/6/07 2:04	874.35	362,291.91	247,796.50	73,595.05	4.59	30.25	11.31	273.65	0.00	58.80	26.60	7,508.29
7/6/07 2:05	873.58	355,110.59	248,505.59	74,620.73	5.70	29.64	11.03	273.00	0.00	64.80	29.40	8,226.17
7/6/07 2:06	873.48	362,547.00	246,036.20	72,635.30	5.70	30.04	10.75	272.72	0.00	65.10	29.80	7,929.48
7/6/07 2:07	873.43	346,691.31	245,784.59	73,297.15	5.71	29.88	10.46	272.69	0.00	65.05	29.60	0.00
7/6/07 2:08	873.98	355,365.59	246,252.80	72,382.05	5.40	30.42	10.18	272.69	0.00	64.75	29.40	0.00
7/6/07 2:09	874.71	349,177.59	244,759.80	72,474.95	4.67	30.78	9.90	272.69	0.00	63.25	28.80	0.00
7/6/07 2:10	874.67	351,559.31	245,735.20	73,162.01	6.16	31.06	9.62	273.00	0.00	62.80	29.60	0.00
7/6/07 2:11	874.16	360,499.69	246,592.00	74,064.69	5.38	31.09	9.34	273.00	0.00	61.35	28.00	0.00
7/6/07 2:12	872.34	354,214.09	244,443.91	73,110.49	6.89	30.66	9.06	273.38	0.00	60.20	28.20	0.00
7/6/07 2:13	871.13	375,985.81	243,293.20	73,590.41	6.62	30.88	8.78	273.38	0.00	59.10	27.10	0.00
7/6/07 2:14	870.95	357,923.31	245,876.70	73,560.88	7.75	31.03	8.49	273.38	0.00	58.40	27.60	0.00
7/6/07 2:15	871.16	352,526.19	244,627.50	73,167.73	5.82	30.65	8.21	273.67	0.00	58.55	27.60	0.00
7/6/07 2:16	869.01	346,568.59	245,460.30	72,723.53	5.72	31.88	7.93	273.96	0.00	58.85	27.60	5,511.23
7/6/07 2:17	867.67	355,205.91	246,976.50	72,836.73	3.48	31.07	7.65	273.98	0.00	58.25	27.60	8,232.88
7/6/07 2:18	868.44	362,549.59	247,089.80	72,786.88	3.90	31.03	7.37	274.62	0.00	58.65	27.60	8,765.42
7/6/07 2:19	869.24	351,629.09	245,174.41	73,009.44	6.21	30.88	7.09	275.01	0.00	58.65	27.50	8,719.58
7/6/07 2:20	869.76	345,731.19	245,039.30	72,564.57	4.31	30.88	6.96	275.34	0.00	58.50	27.60	8,326.64
7/6/07 2:21	869.80	356,844.00	247,950.59	74,122.50	3.55	30.75	6.97	275.98	0.00	58.70	27.60	7,441.19
7/6/07 2:22	869.61	357,354.91	247,520.41	73,265.38	3.33	31.75	6.98	276.34	0.00	58.35	27.60	6,557.08
7/6/07 2:23	869.69	353,502.19	247,322.41	72,582.68	4.33	31.77	6.99	276.34	0.00	58.65	27.70	5,898.54
7/6/07 2:24	870.08	358,099.91	247,839.50	73,396.17	5.96	32.25	7.00	276.34	0.00	58.35	27.70	5,719.42
7/6/07 2:25	870.05	352,542.41	248,147.00	73,190.26	5.27	31.75	7.00	275.98	0.00	65.05	30.40	5,627.24
7/6/07 2:26	868.49	362,698.41	250,546.30	73,691.75	5.27	32.15	7.01	276.34	0.00	65.10	30.40	7,325.16
7/6/07 2:27	867.97	359,018.41	248,792.59	73,543.16	5.27	31.66	7.02	275.70	0.00	65.15	30.10	7,281.21
7/6/07 2:28	868.87	363,201.00	251,418.59	74,076.63	5.55	32.75	7.03	275.70	0.00	64.65	30.00	8,323.29
7/6/07 2:29	869.79	335,889.31	249,384.70	72,801.93	4.90	32.75	7.04	275.70	0.00	63.50	29.00	8,319.65
7/6/07 2:30	871.06	359,539.69	248,499.41	73,407.05	3.82	33.00	7.05	275.67	0.00	62.55	28.90	6,566.44
7/6/07 2:31	872.26	365,275.59	249,686.70	73,454.95	4.66	33.00	7.06	275.32	0.00	60.90	28.20	3,370.75
7/6/07 2:32	873.12	359,317.31	252,179.91	74,765.81	5.39	33.75	7.06	274.65	0.00	59.65	28.10	0.00
7/6/07 2:33	874.03	360,005.19	249,913.20	73,629.59	4.48	33.77	7.07	273.96	0.00	58.70	27.60	6,705.33
7/6/07 2:34	873.51	354,575.41	248,175.00	73,117.49	5.25	33.94	7.08	273.98	0.00	58.40	26.50	0.00
7/6/07 2:35	871.83	354,231.50	250,380.20	74,455.90	4.61	33.00	7.07	273.67	0.00	58.50	26.50	8,509.22
7/6/07 2:36	869.58	375,587.09	253,024.91	73,858.87	6.33	33.00	6.87	273.38	0.00	58.60	26.50	0.00
7/6/07 2:37	868.11	361,553.31	247,470.59	73,487.88	6.35	32.75	6.68	273.98	0.00	58.45	26.40	0.00
7/6/07 2:38	866.86	357,351.81	246,687.91	73,197.37	6.74	33.06	6.57	273.98	0.00	58.40	26.60	0.00
7/6/07 2:39	867.42	363,378.09	249,817.91	73,823.64	6.13	33.31	6.57	274.62	0.00	58.45	26.70	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/6/07 2:40	867.88	361,104.09	247,178.20	73,140.60	6.84	33.50	6.58	274.31	0.00	58.15	26.40	2,754.57
7/6/07 2:41	868.94	359,551.81	249,955.00	73,324.63	5.78	34.00	6.59	275.34	0.00	58.75	26.30	0.00
7/6/07 2:42	870.23	362,801.19	248,214.50	73,559.16	4.77	33.50	6.59	275.34	0.00	58.55	26.50	4,949.55
7/6/07 2:43	870.77	376,114.69	251,371.50	74,185.31	6.68	33.75	6.60	275.70	0.00	58.50	26.30	0.00
7/6/07 2:44	870.15	354,908.00	247,294.41	72,835.01	7.33	33.50	6.61	275.70	0.00	58.80	26.50	5,747.70
7/6/07 2:45	869.49	347,674.69	246,563.30	73,489.30	8.24	33.25	6.61	275.70	0.00	64.65	29.60	0.00
7/6/07 2:46	870.65	356,321.09	246,893.91	73,138.39	8.24	33.50	6.62	275.70	0.00	65.25	29.60	8,380.64
7/6/07 2:47	870.15	355,137.19	249,540.41	74,183.99	8.24	34.00	6.63	276.01	0.00	64.95	30.00	0.00
7/6/07 2:48	869.46	354,805.50	247,091.30	73,839.94	3.74	34.00	6.63	275.70	0.00	64.45	29.50	6,884.70
7/6/07 2:49	868.39	359,833.09	246,086.70	73,058.38	6.49	33.50	6.64	275.70	0.00	63.30	29.70	0.00
7/6/07 2:50	868.47	372,676.59	248,373.00	74,008.66	6.53	33.50	6.65	275.70	0.00	62.15	28.10	0.00
7/6/07 2:51	867.77	356,837.50	247,188.41	73,230.23	6.02	33.44	6.65	275.70	0.00	60.65	28.50	0.00
7/6/07 2:52	867.39	353,325.00	246,094.80	73,359.91	5.42	32.75	6.66	275.70	0.00	58.95	27.70	0.00
7/6/07 2:53	866.96	356,394.00	247,541.70	74,231.05	5.56	32.56	6.67	275.70	0.00	58.80	27.00	3,890.49
7/6/07 2:54	865.27	364,499.31	249,067.80	74,503.80	4.75	32.50	6.67	275.70	0.00	58.60	26.30	0.00
7/6/07 2:55	864.68	359,795.50	248,947.70	73,715.56	6.52	32.00	6.68	275.34	0.00	58.75	26.50	6,398.32
7/6/07 2:56	865.24	363,992.81	248,304.50	73,585.11	4.45	31.75	6.69	276.01	0.00	58.60	26.70	0.00
7/6/07 2:57	865.61	341,713.91	247,980.91	73,634.36	7.29	31.53	6.69	276.01	0.00	58.40	26.60	8,383.00
7/6/07 2:58	865.58	363,385.91	250,098.20	73,963.99	3.15	31.91	6.70	276.03	0.00	58.60	26.40	0.00
7/6/07 2:59	866.21	360,634.69	250,206.50	73,573.43	5.64	31.25	6.71	276.65	0.00	58.85	26.60	0.00
7/6/07 3:00	867.21	353,558.81	249,731.70	73,119.09	4.74	31.06	6.78	276.65	0.00	58.45	26.70	0.00
7/6/07 3:01	867.58	363,708.09	252,338.00	74,125.74	5.82	30.59	6.91	277.03	0.00	58.50	26.40	0.00
7/6/07 3:02	868.80	362,681.41	249,639.70	73,499.41	3.68	30.03	7.03	277.06	0.00	58.70	26.70	0.00
7/6/07 3:03	869.33	346,278.00	249,052.80	72,899.78	6.61	30.25	7.15	277.01	0.00	58.55	26.60	0.00
7/6/07 3:04	869.96	355,693.09	252,032.00	73,415.48	6.10	30.28	7.27	276.65	0.00	58.45	26.50	0.00
7/6/07 3:05	871.79	367,199.19	251,944.30	73,565.02	5.48	29.88	7.39	277.01	0.00	64.95	29.80	0.00
7/6/07 3:06	873.32	362,368.69	250,017.09	73,286.16	5.48	30.00	7.51	277.34	0.00	65.00	29.40	0.00
7/6/07 3:07	873.79	342,651.41	249,238.70	73,181.83	5.48	30.88	7.64	277.03	0.00	64.90	29.60	0.00
7/6/07 3:08	874.22	362,493.41	251,425.70	73,989.73	4.60	30.91	7.76	276.65	0.00	64.75	29.60	0.00
7/6/07 3:09	874.92	355,927.69	251,324.91	73,553.15	5.85	30.73	7.88	275.98	0.00	63.30	29.70	0.00
7/6/07 3:10	875.26	365,858.69	249,256.70	72,701.96	5.58	30.63	8.00	275.70	0.00	62.35	28.10	0.00
7/6/07 3:11	875.34	358,608.91	250,496.50	72,983.87	8.42	30.63	8.12	275.70	0.00	61.25	28.80	0.00
7/6/07 3:12	875.86	357,988.19	250,461.00	73,077.98	5.14	30.53	8.24	275.34	0.00	59.70	27.80	0.00
7/6/07 3:13	876.64	356,296.41	250,938.20	74,006.48	5.62	29.93	8.37	275.34	0.00	58.85	27.50	0.00
7/6/07 3:14	876.57	351,209.41	252,318.59	73,916.92	5.62	29.66	8.49	275.01	0.00	58.70	26.40	0.00
7/6/07 3:15	876.41	377,432.31	251,033.50	73,671.11	4.49	29.59	8.61	275.70	0.00	58.40	26.60	0.00
7/6/07 3:16	876.11	358,557.81	250,544.09	73,824.45	8.08	29.63	8.73	275.34	0.00	58.40	26.70	0.00
7/6/07 3:17	876.83	359,032.00	251,238.91	74,299.69	4.56	29.63	8.85	275.70	0.00	58.45	26.50	0.00
7/6/07 3:18	876.59	347,308.31	248,142.41	74,066.85	5.78	29.53	8.96	275.70	0.00	58.15	26.40	0.00
7/6/07 3:19	875.80	364,942.41	252,057.59	74,435.44	5.84	29.47	9.07	275.70	0.00	58.10	26.60	0.00
7/6/07 3:20	876.00	360,147.69	250,199.30	74,066.41	5.09	28.89	9.18	275.70	0.00	58.70	26.50	0.00
7/6/07 3:21	876.63	365,850.91	248,543.00	74,322.04	5.12	28.72	9.29	275.70	0.00	58.60	26.60	0.00
7/6/07 3:22	875.88	349,228.41	246,894.80	73,851.63	8.02	28.84	9.40	275.70	0.00	58.65	26.30	0.00
7/6/07 3:23	876.13	365,442.31	250,071.59	73,534.75	4.11	28.66	9.51	276.01	0.00	58.35	26.50	0.00
7/6/07 3:24	876.97	349,396.31	246,558.09	73,585.58	5.58	28.63	9.62	275.98	0.00	58.30	26.60	15,056.63
7/6/07 3:25	878.63	362,873.59	248,210.91	73,561.12	5.83	28.91	9.74	276.65	0.00	65.00	29.40	13,571.89
7/6/07 3:26	879.81	349,873.59	246,280.80	73,121.90	5.83	28.78	9.87	277.03	0.00	64.90	30.10	13,576.82
7/6/07 3:27	880.13	356,936.31	246,592.20	73,586.13	5.83	28.97	10.06	277.01	0.00	64.90	30.00	13,663.62
7/6/07 3:28	880.95	353,064.69	246,244.30	73,924.76	6.45	28.97	10.24	277.01	0.00	64.80	30.20	13,621.81
7/6/07 3:29	882.36	353,105.41	244,700.80	73,309.54	4.22	28.84	10.42	276.65	0.00	63.50	29.20	11,439.12

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS TEMP (DEGF)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	AIR FLOW (LB/HR)	CEMS STACK FLOW (SCFM)	SLURRY FLOW (GPM)	WATER FLOW (GPM)	SDA OUTLET TEMP (DEGF)	INJECTION PUMP 1	INJECTION PUMP 2	INJECTION PUMP 3	STEAM FLOW (LB/HR)
7/6/07 3:30	879.25	351,753.19	245,734.50	73,361.85	5.08	28.63	10.60	276.65	0.00	61.95	28.60	12,095.29
7/6/07 3:31	873.88	349,385.00	246,354.80	73,293.55	6.48	28.84	10.77	276.34	0.00	60.60	28.00	11,734.25
7/6/07 3:32	870.51	359,820.50	245,894.30	74,507.41	4.84	27.75	10.86	276.34	0.00	59.30	26.90	11,865.78
7/6/07 3:33	867.17	345,973.31	242,688.41	73,275.78	4.44	27.91	10.95	276.67	0.00	58.35	26.60	12,056.25
7/6/07 3:34	863.20	342,750.19	245,570.00	73,807.02	6.21	28.19	11.04	275.98	0.00	58.35	26.60	12,673.12
7/6/07 3:35	862.83	344,235.69	243,572.91	73,847.02	3.63	27.80	11.13	275.70	0.00	58.40	26.60	11,083.43
7/6/07 3:36	864.61	352,898.69	242,985.20	73,507.81	4.55	27.75	11.22	275.34	0.00	58.55	26.70	10,941.22
7/6/07 3:37	866.66	365,351.09	246,157.50	74,418.72	5.40	28.00	11.31	275.70	0.00	58.35	26.70	11,079.72
7/6/07 3:38	867.18	346,643.91	245,662.50	73,593.12	7.88	28.00	11.40	275.70	0.00	58.70	26.50	11,165.75
7/6/07 3:39	867.36	361,393.09	245,796.30	73,067.98	4.38	28.00	11.50	274.98	0.00	58.30	26.60	9,363.12
7/6/07 3:40	864.76	352,516.69	248,186.30	73,804.84	6.94	27.09	11.59	276.01	0.00	58.15	26.70	8,805.33
7/6/07 3:41	862.52	354,608.91	250,321.41	73,816.63	4.27	27.00	11.68	276.01	0.00	58.63	26.70	8,938.62
7/6/07 3:42	860.67	353,444.41	247,395.00	73,645.46	5.35	26.75	11.85	276.01	0.00	58.35	26.50	9,544.21
7/6/07 3:43	857.05	351,582.19	250,329.20	73,684.70	5.24	26.84	11.94	276.36	0.00	58.50	26.60	9,131.85
7/6/07 3:44	856.26	368,051.31	251,360.80	74,355.03	4.23	27.22	12.05	275.98	0.00	58.35	26.40	11,148.68
7/6/07 3:45	858.37	368,466.31	249,747.30	73,945.68	4.41	27.03	12.29	276.34	0.00	65.15	29.60	10,539.25
7/6/07 3:46	859.63	351,817.59	248,362.80	73,697.73	4.41	27.83	12.34	275.70	0.00	64.95	29.40	10,365.19
7/6/07 3:47	860.54	356,890.41	252,802.41	74,575.38	4.41	27.38	12.39	275.70	0.00	65.00	29.70	10,588.88
7/6/07 3:48	862.70	360,890.91	249,798.09	73,445.08	3.70	27.28	12.44	275.70	0.00	64.90	29.80	5,357.42
7/6/07 3:49	863.27	362,449.81	249,647.80	73,792.45	5.92	27.28	12.48	275.70	0.00	63.45	29.70	9,083.99
7/6/07 3:50	861.59	354,674.59	249,793.09	72,474.04	7.53	27.44	12.52	275.34	0.00	62.00	28.20	9,033.14
7/6/07 3:51	861.25	361,637.69	252,867.41	74,927.41	4.06	27.26	12.51	275.36	0.00	60.65	27.50	9,044.37
7/6/07 3:52	860.38	370,120.09	250,913.50	73,311.38	6.53	28.19	12.49	275.36	0.00	59.55	27.00	8,735.74
7/6/07 3:53	859.33	364,033.09	250,612.80	74,103.77	7.89	26.88	12.47	275.34	0.00	58.35	27.40	4,280.87
7/6/07 3:54	859.55	351,123.31	249,523.20	73,869.35	5.17	27.25	12.46	275.01	0.00	58.30	27.60	10,686.41
7/6/07 3:55	859.11	358,807.69	251,019.30	73,944.59	5.13	26.97	12.44	275.01	0.00	58.25	27.60	10,392.91
7/6/07 3:56	859.44	379,693.31	252,489.30	73,456.77	5.91	26.80	12.42	274.98	0.00	58.10	27.40	10,344.11
7/6/07 3:57	859.67	347,423.50	250,146.30	73,619.83	7.93	26.93	12.41	275.34	0.00	58.85	27.50	10,629.73
7/6/07 3:58	859.25	365,704.09	252,005.00	73,684.42	5.43	27.38	12.39	275.70	0.00	58.30	27.40	0.00
7/6/07 3:59	858.23	353,838.00	249,092.20	74,039.69	6.55	26.90	12.37	275.98	0.00	58.20	27.40	8,511.51
7/6/07 4:00	857.88	356,504.81	252,321.80	73,499.46	5.00	26.81	12.43	276.01	0.00	58.10	27.60	8,906.41

APPENDIX C

CALIBRATION GAS CERTIFICATIONS

CERTIFICATE of ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121

Section 2.2

Procedure: G-1

Cylinder Number: CC162006

Customer: Air Hygiene
 P.O. Number:
 Item Number: SGZCAH094
 Notes:

Shipping Order #: 24669211
 Transfer #: 24669211
 LOT #: LPX218867
 Valve: CGA590
 Cyl. Pressure: * 1900psig

Assay Date: 26-Mar-07

Expiration Date: 25-Mar-10

*Cylinder should not be used when gas pressure is below 150 psig

Component	Requested Concentration	Assay Concentration
Carbon Dioxide	9 %	8.97 ±0.05 %
Oxygen	12 %	12.0 ±0.1 %
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS328	GMIS328	14.01	%	0.06	CO2	N2	CC203023	7/24/2008	N.A.
GMIS203	GMIS203	19.0	%	0.2	O2	N2	CC57985	5/12/2007	N.A.

Analysis Information:

Component 1: Carbon Dioxide		First Triad Analysis On: 3/26/2007				Second Triad Analysis On:			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	KVB/Analect	Zero	0.27	0.28	0.28	Zero			
Model Number:	EN3024	Reference	14.46	14.49	14.45	Reference			
Serial Number:	3024	Candidate	9.39	9.36	9.32	Candidate			
Analytical Principle:	FTIR	Result	8.99	8.97	8.93	Result			
MPC Calibrated:	03/01/07	Mean Result:		8.97	%	Mean Result:			

Component 2: Oxygen		First Triad Analysis On: 3/26/2007				Second Triad Analysis On:			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	Servomex	Zero	-0.01	-0.01	-0.01	Zero			
Model Number:	4605C	Reference	18.70	18.69	18.70	Reference			
Serial Number:	1101	Candidate	11.82	11.82	11.82	Candidate			
Analytical Principle:	Paramag.	Result	12.02	12.02	12.02	Result			
MPC Calibrated:	03/14/07	Mean Result:		12.02	%	Mean Result:			

Analyst Signature: Warren Pereira Warren Pereira Calculated by: Warren Pereira Warren Pereira



CERTIFICATE of ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121

Section 2.2

Procedure: G-1

Cylinder Number: CC16039

Customer: Air Hygiene
P.O. Number:
Item Number: AH095
Notes:

Shipping Order #: 18651280
Transfer #: 18651280
LOT #: LPX129537
Valve: CGA590
Cyl. Pressure: 1900psig

Assay Date: 23-Nov-05

Expiration Date: 22-Nov-08

*Cylinder should not be used when gas pressure is below 150 psig

Component	Requested Concentration	Assay Concentration
Carbon Dioxide	19 %	19.0 ±0.2 %
Oxygen	21 %	21.0 ±0.2 %
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS301	GMIS301	14.0	%	0.1	CO2	N2	CC71493	8/24/2007	N.A.
GMIS204	GMIS204	19.0	%	0.2	O2	N2	CC115413	5/12/2007	N.A.

Analysis Information:

Component 1: Carbon Dioxide		First Triad Analysis On: 11/18/2005				Second Triad Analysis On:			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	KVB/Analect	Zero	0.19	0.29	0.27	Zero			
Model Number:	EN3024	Reference	13.26	13.42	13.39	Reference			
Serial Number:	3024	Candidate	17.99	18.05	18.07	Candidate			
Analytical Principle:	FTIR	Result	18.94	19.01	19.03	%	Mean Result:	19.00	%
MPC Calibrated:	11/10/05								

Component 2: Oxygen		First Triad Analysis On: 11/23/2005				Second Triad Analysis On:			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	Servomex	Zero	0.03	0.03	0.04	Zero			
Model Number:	4605C	Reference	18.61	18.61	18.62	Reference			
Serial Number:	1101	Candidate	20.56	20.57	20.57	Candidate			
Analytical Principle:	Paramag.	Result	20.99	21.00	21.00	%	Mean Result:	21.00	%
MPC Calibrated:	11/03/05								

Analyst Signature: Warren Pereira Warren Pereira

Calculated by: Warren Pereira Warren Pereira

01590036D

CERTIFICATE of ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121

Section 2.2

Procedure: G-1

Cyl. Number: CC17607

Customer: AIR HYGIENE
P.O. Number:
Item Number: SGZCAH045
Notes:

Shipping Order #: 24745990
Transfer #: 24745990
LOT #: LPX219434
Valve CGA350
Cyl. Pressure:* 1900psig

Assay Date: 17-Apr-07

Expiration Date: 16-Apr-10

*Cylinder should not be used when gas pressure is below 150 psig

Component	Requested Concentration	Assay Concentration
Carbon Monoxide	210 ppm	220 ±2 ppm
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS339	GMIS339	99.44	ppm	0.48	CO	N2	CC82421	11/14/2008	N.A.

Analysis Information:


Component 1: Carbon Monoxide		First Triad Analysis On: 4/10/2007			Second Triad Analysis On: 4/17/2007			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	
Manufacturer:	KVB/Analect	-0.14	-0.01	0.17		-0.12	-0.05	
Model Number:	EN3024	105.21	104.57	103.96		105.44	105.12	
Serial Number:	3024	230.54	231.66	231.12		231.16	232.51	
Analytical Principle:	FTIR							
03/15/07								
MPC Calibrated:	04/12/07	Result	219.22	220.28	219.77	ppm	218.50	219.77
				Mean Result:	219.76	ppm		220.06
							Mean Result:	219.44
								ppm

Analyst Signature:



Bryan Leger

Calculated by:



M. Adnane



AIR LIQUIDE

CERTIFICATE of ANALYSIS

EPA Protocol Gases

Cyl. Number:	Cyl. Pressure: [*]	Lot Number:	COMPONENT	REQUESTED Concentration	ASSAY Concentration
CC148606	2000 PSIG	SFS75790	Name	450 ppm	457 ± 6 ppm
Assay Date:	Expiration Date:	Document Number:	Carbon Monoxide	Balance	Balance
01/14/05	01/14/08	14680051	Nitrogen		

Customer:

ALA-CSL-CENTENNIAL

CENTENNIAL, CO

*Mixture is valid only to 150 psig

EPA Protocol
Section No. 2.2, Procedure . G-1

REFERENCE STANDARD EMPLOYED FOR ANALYSIS

Concentration	Component	Balance	SRM or GMIS	Cyl. No.	NTRM No.	Exp. Date	Sample No.	Type
500 ± 4 ppm	Carbon Monoxide	Nitrogen		CC 150327	SFS48669	04/02/05	LU	GMIS

Analyst: Eric Barron
Approved by: Thuan TranCarbon Monoxide
GAS ANALYZER EMPLOYED
Manufacturer: Varian(A)
Model Number: 3400
Serial Number: 2805
MPR Last Calibrated: 12/22/04
Analytical Principle: FID & TCD

ANALYSIS SUMMARY

01/07/05				01/07/05				01/07/05 Carbon Monoxide				01/14/05				01/14/05				01/14/05 Carbon Monoxide				
	Triad 1	Triad 2	Triad 3		Triad 4	Triad 5	Triad 6			Triad 4	Triad 5	Triad 6			Triad 4	Triad 5	Triad 6			Triad 4	Triad 5	Triad 6		
Zero	0	0	0	Units	Zero	0	0	0	Area	Zero	0	0	0	Area	Zero	0	0	0	Area	Zero	0	0	0	
Reference	20715159	20739129	20771211	Area	Reference	21588952	21601768	21615114	Area	Reference	21588952	21601768	21615114	Area	Reference	21588952	21601768	21615114	Area	Reference	21588952	21601768	21615114	Area
Candidate	18925811	18984831	19018555	Area	Candidate	19769458	19740611	19750175	Area	Candidate	19769458	19740611	19750175	Area	Candidate	19769458	19740611	19750175	Area	Candidate	19769458	19740611	19750175	Area
Result	456.8	457.7	457.8	ppm	Result	457.9	456.9	456.9	ppm	Result	457.9	456.9	456.9	ppm	Result	457.9	456.9	456.9	ppm	Result	457.9	456.9	456.9	ppm
Evaluation	VALID	VALID	VALID		Evaluation	VALID	VALID	VALID		Evaluation	VALID	VALID	VALID		Evaluation	VALID	VALID	VALID		Evaluation	VALID	VALID	VALID	
MEAN ANALYTICAL RESULT:				457.4 ppm				MEAN ANALYTICAL RESULT:				457.2 ppm				MEAN ANALYTICAL RESULT:				457.2 ppm				

Analyst:

Approved by:



AIR LIQUIDE

CERTIFICATE OF ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

Note: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121
Section No. 2.2, Procedure . G-1

Customer: AIR HYGIENE
HUMBLE, TX
P.O. Number: RECERTIFICATION
Item Number: AH043

Assay Date: 25-Jul-05

Cylinder Number: CC171920

Shipping Order Number 16169268
Transfer Number:
Lot Number: SFS85767
Valve: CGA 350
Cyl. Pressure: 1667 PSIG

Expiration Date: 25-Jul-08

*Cylinder should not be used when
gas pressure is below 150 psig

Component	REQUESTED Concentration	ASSAY Concentration
Carbon Monoxide	4000 ppm	4010 ± 60 ppm
Nitrogen	Balance	Balance

Reference Standard Employed For Analysis:

Concentration	Component	Balance	Cyl. No.	SRM or GMIS	NTRM No.	Exp. Date	Sample No.	Type
4980 ± 50 ppm	Carbon Monoxide	Nitrogen	AL-1927	12223	06/02/07		BY	GMIS

Analysis Information:

Component	Carbon Monoxide	First Triad Analysis 07/18/05						Second Triad Analysis 07/25/05					
		Trial 1	Trial 2	Trial 3	Units	Trial 4	Trial 5	Trial 6	Units				
Manufacturer:	Varian(B)	Zero	0	0	0	ppm	Zero	0	0	0	ppm		
Model Number:	3400	Reference	5000	5008	5000	ppm	Reference	5004	5010	4994	ppm		
Serial Number:	2806	Candidate	4024	4027	4025	ppm	Candidate	4023	4024	4018	ppm		
MPR Last Calibrated:	06/27/05	Result	4008	4004	4009	ppm	Result	4004	4000	4007	ppm		
Analytical Principle:	FID & TCD	Evaluation	VALID	VALID	VALID		Evaluation	VALID	VALID	VALID		MEAN ANALYTICAL RESULT:	4003 ppm

Analyst Signature:

Eric Barron

Approved by:

David Connolly

CERTIFICATE of ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121

Section 2.2

Procedure: G-1

Cyl. Number: CC178135

Customer: Air Hygiene
P.O. Number: 5021102
Item Number: AH-042
Notes:

Shipping Order #: 15321147
Transfer #: 15321147
LOT #: LPX114669
Valve CGA350
Cyl. Pressure: * 1900psig

*Cylinder should not be used when gas pressure is below 150 psig

Assay Date: 8-Mar-05 Expiration Date: 7-Mar-08

Component	Requested Concentration	Assay Concentration
Carbon Monoxide	1800 ppm	1810 ±10 ppm
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS233	GMIS233	2452.0	ppm	10.0	CO	N2	CC108277	4/17/2005	N.A.

Analysis Information:

Component 1: Carbon Monoxide		First Triad Analysis On: 3/1/2005				Second Triad Analysis On: 3/8/2005			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	KVB/Analect	-0.54	0.50	0.17		-0.02	0.13	0.11	
Model Number:	EN3024	2359.69	2367.34	2371.32		2344.65	2347.36	2352.17	
Serial Number:	3024	1748.98	1748.03	1741.12		1737.56	1730.56	1734.16	
Analytical Principle:	FTIR	1812.45	1811.46	1804.30	ppm	1814.45	1807.14	1810.90	ppm
MPC Calibrated:	02/21/05	Mean Result:		1809.40	ppm	Mean Result:		1810.83	ppm

Analyst Signature:

Bryan Leger

Calculated by:

Yang Qin

APPENDIX D

QUALITY ASSURANCE AND QUALITY CONTROL DATA

QA/QC PROGRAM

Air Hygiene ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses five major areas:

1. QA reviews of reports, laboratory work, and field testing
2. Equipment calibration and maintenance
3. Chain-of-custody
4. Training
5. Knowledge of current test methods

Each of these areas is discussed individually below.

QA Reviews

Air Hygiene's review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program.

Chain-of-Custody

Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

Training

Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3. A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describe each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within \pm two percent of the range of predicted values. NO₂ to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO₂ in a balance of nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one in. Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

INSTRUMENTAL ANALYSIS QUALITY ASSURANCE DATA

Date: July 4-6, 2007
Company: Fibrominn, LLC
Location: Benson, Minnesota
Techs: TKG

Sample System Leak Check

Date	Sample System	Leak Rate (l/min)
July 4-6, 2007	1	0
July 4-6, 2007	2	0



Air Hygiene International, Inc.
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
(888) 461-8778
www.airhygiene.com

SAMPLE DESCRIPTION AND CHAIN OF CUSTODY RECORD

Project Number:		snc-07-benson.mn-comp#1			Laboratory Analysis Requested:			
Person Taking Samples:		TP/TKG			Reference Method 23 (Dioxins)			
Sample Number	Location		Date	Volume	Analysis Method			
					RM 23			
OUT-Diox-1-F	Outlet-Dioxins-Run 1-Filter		7/4/2007	N/A	X			
OUT-Diox-2-F	Outlet-Dioxins-Run 2-Filter		7/4/2007	N/A	X			
OUT-Diox-3-F	Outlet-Dioxins-Run 3-Filter		7/4/2007	N/A	X			
OUT-Diox-1-#2	Outlet-Dioxins-Run 1-Acetone&MeCl Rinse		7/4/2007	as marked	X			
OUT-Diox-2-#2	Outlet-Dioxins-Run 2-Acetone&MeCl Rinse		7/4/2007	as marked	X			
OUT-Diox-1-#2	Outlet-Dioxins-Run 3-Acetone&MeCl Rinse		7/4/2007	as marked	X			
OUT-Diox-1-#3	Outlet-Dioxins-Run 1-Toluene Rinse		7/4/2007	as marked	X			
OUT-Diox-2-#3	Outlet-Dioxins-Run 2-Toluene Rinse		7/4/2007	as marked	X			
OUT-Diox-3-#3	Outlet-Dioxins-Run 3-Toluene Rinse		7/4/2007	as marked	X			
OUT-Diox-1-XAD	Outlet-Dioxins-Run 1-Cartridge		7/4/2007	as marked	X			
OUT-Diox-2-XAD	Outlet-Dioxins-Run 2-Cartridge		7/4/2007	as marked	X			
OUT-Diox-3-XAD	Outlet-Dioxins-Run 3-Cartridge		7/4/2007	as marked	X			
A-B	Acetone Blank		7/4/2007	as marked	X			
MC-B	MeCl Blank		7/4/2007	as marked	X			
T-B	Toluene Blank		7/4/2007	as marked	X			
<u>G. Rama K. Brahman</u>		Date: 07/07/07	Time: 19:00	<u>Dandu Satyika</u>		Date: 07/07/07	Time: 19:00	
Relinquished by: (Signature)		Date: _____	Time: _____	Received by: (Signature)		Date: _____	Time: _____	
Relinquished by: (Signature)		Date: _____	Time: _____	Received by: (Signature)		Date: _____	Time: _____	



Air Hygiene International, Inc.
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
(888) 461-8778
www.airhygiene.com

SAMPLE DESCRIPTION AND CHAIN OF CUSTODY RECORD

Project Number:		snc-07-benson.mn-comp#1	Laboratory Analysis Requested:			
Person Taking Samples:		TP	Dioxin Analysis (Reference Method 23)			
Sample Number	Location		Date	Volume	Analysis Method	
					RM 23	
in-ohm-1-container1	Run 1 - Filter		7/5/2007	N/A	X	
in-ohm-1-container2	Run 1 - Nozzle, Glass liner and Front half of filter housing and connecting glasswares rinsed with 0.1 N HNO ₃		7/5/2007	as marked	X	
in-ohm-1-container3	Run 1 - Impingers 1, 2, and 3 contents (KCl) + Back half of the filter housing, impingers and connecting glasswares rinsed with 10% HNO ₃		7/5/2007	as marked	X	
in-ohm-1-container4	Run 1 - Impinger 4 contents (HNO ₃ - H ₂ O ₂ solution) + impinger and connecting glassware rinsed with 0.1 N HNO ₃		7/5/2007	as marked	X	
in-ohm-1-container5	Run 1 - Impingers 5, 6, and 7 contents (H ₂ SO ₄ - KMnO ₄) + impingers and connecting glasswares rinsed with 0.1N HNO ₃		7/5/2007	as marked	X	
in-ohm-2-container1	Run 2 -Filter		7/5/2007	N/A	X	
in-ohm-2-container2	Run 2 -Nozzle, Glass liner and Front half of filter housing and connecting glasswares rinsed with 0.1 N HNO ₃		7/5/2007	as marked	X	
in-ohm-2-container3	Run 2 -Impingers 1, 2, and 3 contents (KCl) + Back half of the filter housing, impingers and connecting glasswares rinsed with 10% HNO ₃		7/5/2007	as marked	X	
in-ohm-2-container4	Run 2 -Impinger 4 contents (HNO ₃ - H ₂ O ₂ solution) + impinger and connecting glassware rinsed with 0.1 N HNO ₃		7/5/2007	as marked	X	
in-ohm-2-container5	Run 2 -Impingers 5, 6, and 7 contents (H ₂ SO ₄ - KMnO ₄) + impingers and connecting glasswares rinsed with 0.1N HNO ₃		7/5/2007	as marked	X	
in-ohm-3-container1	Run 3 -Filter		7/5/2007	N/A	X	
in-ohm-3-container2	Run 3 -Nozzle, Glass liner and Front half of filter housing and connecting glasswares rinsed with 0.1 N HNO ₃		7/5/2007	as marked	X	
in-ohm-3-container3	Run 3 -Impingers 1, 3, and 3 contents (KCl) + Back half of the filter housing, impingers and connecting glasswares rinsed with 10% HNO ₃		7/5/2007	as marked	X	
in-ohm-3-container4	Run 3 -Impinger 4 contents (HNO ₃ - H ₃ O ₃ solution) + impinger and connecting glassware rinsed with 0.1 N HNO ₃		7/5/2007	as marked	X	
in-ohm-3-container5	Run 3 -Impingers 5, 6, and 7 contents (H ₃ SO ₄ - KMnO ₄) + impingers and connecting glasswares rinsed with 0.1N HNO ₃		7/5/2007	as marked	X	
<u>G. Roma K. Sharabha</u>		07/06/07	12:00	<u>Pandu Sattvika</u>	07/06/07	12:00
Relinquished by: (Signature)		Date:	Time:	Received by: (Signature)	Date:	Time:
Relinquished by: (Signature)		Date:	Time:	Received by: (Signature)	Date:	Time:



Air Hygiene International, Inc.
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
(888) 461-8778
www.airhygiene.com

SAMPLE DESCRIPTION AND CHAIN OF CUSTODY RECORD

Project Number:	snc-07-benson.mn-comp#1	Laboratory Analysis Requested:				
Person Taking Samples:		TP	Dioxin Analysis (Reference Method 23)			
Sample Number	Location		Date	Volume	Analysis Method	
					RM 23	
out-ohm-1-container1	Run 1 - Filter		7/5/2007	N/A	X	
out-ohm-1-container2	Run 1 - Nozzle, Glass liner and Front half of filter housing and connecting glasswares rinsed with 0.1 N HNO3		7/5/2007	as marked	X	
out-ohm-1-container3	Run 1 - Impingers 1, 2, and 3 contents (KCl) + Back half of the filter housing, impingers and connecting glasswares rinsed with 10% HNO3		7/5/2007	as marked	X	
out-ohm-1-container4	Run 1 - Impinger 4 contents (HNO3 - H2O2 solution) + impinger and connecting glassware rinsed with 0.1 N HNO3		7/5/2007	as marked	X	
out-ohm-1-container5	Run 1 - Impingers 5, 6, and 7 contents (H2SO4 - KMnO4) + impingers and connecting glasswares rinsed with 0.1N HNO3		7/5/2007	as marked	X	
out-ohm-2-container1	Run 2 -Filter		7/5/2007	N/A	X	
out-ohm-2-container2	Run 2 -Nozzle, Glass liner and Front half of filter housing and connecting glasswares rinsed with 0.1 N HNO3		7/5/2007	as marked	X	
out-ohm-2-container3	Run 2 -Impingers 1, 2, and 3 contents (KCl) + Back half of the filter housing, impingers and connecting glasswares rinsed with 10% HNO3		7/5/2007	as marked	X	
out-ohm-2-container4	Run 2 -Impinger 4 contents (HNO3 - H2O2 solution) + impinger and connecting glassware rinsed with 0.1 N HNO3		7/5/2007	as marked	X	
out-ohm-2-container5	Run 2 -Impingers 5, 6, and 7 contents (H2SO4 - KMnO4) + impingers and connecting glasswares rinsed with 0.1N HNO3		7/5/2007	as marked	X	
out-ohm-3-container1	Run 3 -Filter		7/5/2007	N/A	X	
out-ohm-3-container3	Run 3 -Nozzle, Glass liner and Front half of filter housing and connecting glasswares rinsed with 0.1 N HNO3		7/5/2007	as marked	X	
out-ohm-3-container3	Run 3 -Impingers 1, 3, and 3 contents (KCl) + Back half of the filter housing, impingers and connecting glasswares rinsed with 10% HNO3		7/5/2007	as marked	X	
out-ohm-3-container4	Run 3 -Impinger 4 contents (HNO3 - H3O3 solution) + impinger and connecting glassware rinsed with 0.1 N HNO3		7/5/2007	as marked	X	
out-ohm-3-container5	Run 3 -Impingers 5, 6, and 7 contents (H3SO4 - KMnO4) + impingers and connecting glasswares rinsed with 0.1N HNO3		7/5/2007	as marked	X	
h-b-ohm-container7	50 ml of 0.1 N HNO3 blank		7/5/2007	as marked	X	
k-b-ohm-container8	50 ml of 1 N KCl blank		7/5/2007	as marked	X	
hh-b-ohm-container9	50 ml of HNO3-H2O2 blank		7/5/2007	as marked	X	
hk-b-ohm-container10	50 ml of H2SO4 - KMnO4 blank		7/5/2007	as marked	X	
hxm-b-ohm-container11	100 ml of Hydroxylamine blank		7/5/2007	as marked	X	
f-b-ohm-container12	Sample blank filter		7/5/2007	N/A	X	
<u>John K. Satchwell</u>		07/07/07	19:00	<u>Pandu Satyika</u>	07/07/07	19:00
Relinquished by: (Signature)		Date:	Time:	Received by: (Signature)	Date:	Time:
<u>John K. Satchwell</u>		07/07/07	19:00	<u>Pandu Satyika</u>	07/07/07	19:00
Relinquished by: (Signature)		Date:	Time:	Received by: (Signature)	Date:	Time:

APPENDIX E

FUEL ANALYSIS

Client: Fibrominn, LLC

Location: Fibrominn Biomass Power Plant

Date: July 3, 2007

Project #: snc-07-benson.mn-comp#1

Biomass - Fuel Analysis

Characteristics of Fuel Gas		
Btu per lb. of biomass =	4,372	gross (HHV)
Btu per lb. of biomass =	4,415	gross (HHV)
Btu per lb. of biomass =	4,203	gross (HHV)
Btu per lb. of biomass =	4,346	gross (HHV)
Btu per lb. of biomass =	4,334	gross (HHV)

Component	Wt%	Sample
carbon	25.65	LOT 10
carbon	25.50	LOT 11
carbon	25.34	LOT 12
carbon	25.60	LOT 13
carbon	25.52	AVERAGE

F_c -Factor (SCF dry exhaust per MMBtu [HHV]) =	1,883.27	LOT 10
F_c -Factor (SCF dry exhaust per MMBtu [HHV]) =	1,854.02	LOT 11
F_c -Factor (SCF dry exhaust per MMBtu [HHV]) =	1,935.32	LOT 12
F_c -Factor (SCF dry exhaust per MMBtu [HHV]) =	1,890.84	LOT 13
F_c-Factor (SCF dry exhaust per MMBtu [HHV]) =	1,890.34	AVERAGE
(Based on EPA RM-19) at 68 deg F and 14.696 psia		

**Hazen Research, Inc.**

4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Date July 11 2007
HRI Project 002-UD9
HRI Series No. G30/07-1
Date Rec'd. 07/06/07
Cust. P.O.#

McHale & Associates, Inc.
Gary Anderson
1635 235th Ave SE
Sammamish, WA 98075

Sample Identification
Turkey Litter Sample 10

Reporting Basis > As Rec'd Dry Air Dry

Proximate (%)

Moisture	37.60	0.00	5.26
Ash	12.51	20.05	19.00
Volatile			
Fixed C			
Total			
Sulfur	0.31	0.50	0.47
Btu/lb (HHV)	4372	7007	6639
MMF Btu/lb	5048	8944	
MAF Btu/lb		8765	
Air Dry Loss (%)	34.14		

Ultimate (%)

Moisture	37.60	0.00	5.26
Carbon	25.65	41.10	38.94
Hydrogen	3.26	5.23	4.95
Nitrogen	2.66	4.26	4.04
Sulfur	0.31	0.50	0.47
Ash	12.51	20.05	19.00
Oxygen*	18.01	28.86	27.34
Total	100.00	100.00	100.00
Chlorine**	0.450	0.721	0.683

Forms of Sulfur (as S,%)

Sulfate	
Pyritic	
Organic	
Total	0.31

Water Soluble Alkalies (%)

Na₂O
K₂O

Lb. Alkali/MM Btu= 28.62
Lb. Ash/MM Btu= 1.42
Lb. SO₂/MM Btu= % Moisture
HGI= @ % Moisture
As Rec'd. Sp.Gr.=
Free Swelling Index=
F-Factor(dry), DSCF/MM BTU= 9,920

Report Prepared By:

Vickie Buster for
Gerard H. Cunningham
Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.

**Hazen Research, Inc.**

4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Date July 11 2007
HRI Project 002-UD9
HRI Series No. G30/07-2
Date Rec'd. 07/06/07
Cust. P.O.#

McHale & Associates, Inc.
Gary Anderson
1635 235th Ave SE
Sammamish, WA 98075

Sample Identification
Turkey Litter Sample 11

Reporting Basis > As Rec'd Dry Air Dry

Proximate (%)

Moisture	34.00	0.00	0.64
Ash	14.35	21.74	21.60
Volatile			
Fixed C			
Total			
Sulfur	0.30	0.45	0.45
Btu/lb (HHV)	4415	6689	6646
MMF Btu/lb	5217	8740	
MAF Btu/lb		8547	
Air Dry Loss (%)	33.57		

Ultimate (%)

Moisture	34.00	0.00	0.64
Carbon	25.50	38.64	38.39
Hydrogen	3.45	5.22	5.19
Nitrogen	2.76	4.18	4.15
Sulfur	0.30	0.45	0.45
Ash	14.35	21.74	21.60
Oxygen*	19.64	29.77	29.58
Total	100.00	100.00	100.00
Chlorine**	0.428	0.648	0.644

Forms of Sulfur (as S,%)

Sulfate	
Pyritic	
Organic	
Total	0.30

Water Soluble Alkalies (%)

Na₂O
K₂O

Lb. Alkali/MM Btu= 32.50
Lb. Ash/MM Btu= 1.35
Lb. SO₂/MM Btu= % Moisture
HGI= @ % Moisture
As Rec'd. Sp.Gr.=
Free Swelling Index=
F-Factor(dry), DSCF/MM BTU= 9,758

Report Prepared By:

Vince Buster for
Gerard H. Cunningham
Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.

**Hazen Research, Inc.**

4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Date July 11 2007
HRI Project 002-UD9
HRI Series No. G30/07-3
Date Rec'd. 07/06/07
Cust. P.O.#

McHale & Associates, Inc.
Gary Anderson
1635 235th Ave SE
Sammamish, WA 98075

Sample Identification
Turkey Litter Sample 12

Reporting
Basis >

As Rec'd

Dry

Air Dry

Proximate (%)

Moisture	33.32	0.00	2.86
Ash	15.51	23.27	22.60
Volatile			
Fixed C			
Total			
Sulfur	0.34	0.51	0.50
Btu/lb (HHV)	4203	6303	6123
MMF Btu/lb	5040	8416	
MAF Btu/lb		8215	
Air Dry Loss (%)	31.36		

Ultimate (%)

Moisture	33.32	0.00	2.86
Carbon	25.34	38.01	36.92
Hydrogen	3.51	5.26	5.11
Nitrogen	2.92	4.38	4.25
Sulfur	0.34	0.51	0.50
Ash	15.51	23.27	22.60
Oxygen*	19.06	28.57	27.76
Total	100.00	100.00	100.00
Chlorine**	0.499	0.748	0.727

Forms of Sulfur (as S,%)

Sulfate	
Pyritic	
Organic	
Total	0.34

Water Soluble Alkalies (%)

Na2O
K2O

Lb. Alkali/MM Btu=
Lb. Ash/MM Btu= 36.91
Lb. SO₂/MM Btu= 1.63
HGI= @ % Moisture
As Rec'd. Sp.Gr.=
Free Swelling Index=
F-Factor(dry), DSCF/MM BTU= 10,321

Report Prepared By:

Vickie Buster for
Gerard H. Cunningham
Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.

**Hazen Research, Inc.**

4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Date July 11 2007
HRI Project 002-UD9
HRI Series No. G30/07-4
Date Rec'd. 07/06/07
Cust. P.O.#

McHale & Associates, Inc.
Gary Anderson
1635 235th Ave SE
Sammamish, WA 98075

Sample Identification
Turkey Litter Sample 13

Reporting
Basis >

As Rec'd

Dry

Air Dry

Proximate (%)

Moisture	34.95	0.00	3.59
Ash	13.15	20.22	19.49
Volatile			
Fixed C			
Total			
Sulfur	0.36	0.55	0.53
Btu/lb (HHV)	4346	6681	6441
MMF Btu/lb	5056	8545	
MAF Btu/lb		8374	
Air Dry Loss (%)	32.53		

Ultimate (%)

Moisture	34.95	0.00	3.59
Carbon	25.60	39.35	37.94
Hydrogen	3.57	5.49	5.29
Nitrogen	3.22	4.95	4.77
Sulfur	0.36	0.55	0.53
Ash	13.15	20.22	19.49
Oxygen*	19.15	29.44	28.39
Total	100.00	100.00	100.00
Chlorine**	0.462	0.711	0.685

Forms of Sulfur (as S, %)

Sulfate	
Pyritic	
Organic	
Total	0.36

Water Soluble Alkalies (%)

Na2O
K2O

Lb. Alkali/MM Btu= 30.26
Lb. Ash/MM Btu= 1.65
Lb. SO2/MM Btu= % Moisture
HGI= @ % Moisture
As Rec'd. Sp.Gr.=
Free Swelling Index=
F-Factor(dry), DSCF/MM BTU= 10,123

Report Prepared By:

Vicie Buster for
Gerard H. Cunningham
Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.

APPENDIX F

TEST PROTOCOL



Air Hygiene International, Inc.

The Clear Choice

**COMPLIANCE TEST
PROTOCOL**

**FOR
ONE BIOMASS BOILER
(SPRAY DRYER ABSORBER
INLET AND STACK OUTLET)**

**PREPARED FOR
SNC – LAVALIN, POWERMINN 9090
LLC, AND FIBROMINN LLC**

**AT THE
FIBROMINN BIOMASS
POWER PLANT
BENSON, MINNESOTA**

**Minnesota Pollution
Control Agency
Permit No: 15100038-004**

April 25, 2007



Air Hygiene International, Inc.

Corporate Headquarters
5634 S. 122nd E. Ave. Ste. F
Tulsa, Oklahoma 74146

Las Vegas Office
5925 E. Lake Mead Blvd.
Las Vegas, Nevada 89156

Philadelphia Office
8900 State Road
Philadelphia, Pennsylvania 19136

Houston Office
1920 Treble Drive
Humble, Texas 77338

(918) 307-8865 or (888) 461-8778
www.airhygiene.com



Air Hygiene International, Inc.

The Clear Choice

**COMPLIANCE TEST
PROTOCOL**

**FOR
ONE BIOMASS BOILER
(SPRAY DRYER ABSORBER
INLET AND STACK OUTLET)**

**PREPARED FOR
SNC – LAVALIN, POWERMINN 9090
LLC, AND FIBROMINN LLC**

**AT THE
FIBROMINN BIOMASS
POWER PLANT
BENSON, MINNESOTA**

**Minnesota Pollution
Control Agency
Permit No: 15100038-004**

April 25, 2007

Prepared By:

A handwritten signature in black ink, appearing to read "Thomas K. Graham".

Thomas K. Graham, PE, Director of Operations

rev - 0



Air Hygiene International, Inc.

Corporate Headquarters
5634 S. 122nd E. Ave. Ste. F
Tulsa, Oklahoma 74146

Las Vegas Office
5925 E. Lake Mead Blvd.
Las Vegas, Nevada 89156

Philadelphia Office
8900 State Road
Philadelphia, Pennsylvania 19136

Houston Office
1920 Treble Drive
Humble, Texas 77338

(918) 307-8865 or (888) 461-8778
www.airhygiene.com

Table of Contents

1.0	<u>INTRODUCTION</u>	1
1.1	General Facility Description	1
1.2	Reason for Testing	1
2.0	<u>SUMMARY</u>	1
2.1	Owner Information	1
2.2	Operator Information	2
2.3	Site Information	2
2.4	Engineering Consultant Information	2
2.5	Test Contractor Information	2
2.6	Expected Test Start Date	2
2.7	Testing Schedule	3
2.8	Test Report Content	5
2.9	Equipment and Procedures	5
2.10	Proposed Variations	5
2.11	Compliance Sampling Strategy	6

Appendix A QA/QC PROGRAM

Appendix B TEST EQUIPMENT CONFIGURATION and DESCRIPTION

- Figure 1 – Emissions Testing Setup
- Figure 2 – Wet Chemistry Setup
- Table 1 – Testing Matrix
- Table 2 – Analytical Instrumentation
- Table 2 – Analytical Instrumentation Testing Configuration

Appendix C STACK DRAWINGS

Appendix D EXAMPLE TEMPLATES AND CALCULATIONS

Appendix E AIR HYGIENE STATEMENT OF QUALIFICATIONS

1.0 INTRODUCTION

1.1 General Facility Description

PowerMinn 9090, LLC (PowerMinn) owns and Fibrominn, LLC (Fibrominn) operates the Fibrominn Biomass Power Plant (FBPP) in Swift County, Benson, Minnesota. FBPP comprises one boiler, fueled principally with poultry litter. Vegetative biomass may also be burned. The facility generates an average of 50 megawatts (MW) of electricity for export and has a peak electrical export capacity of 55 MW.

Emissions from the boiler are controlled by a baghouse spray dryer to control particulate matter and particulate matter less than 10 micron in diameter (PM/PM₁₀), sulfur dioxide (SO₂), sulfuric acid mist (H₂SO₄), and hydrochloric acid (HCl). Selective non-catalytic reduction (SNCR) is used to control nitrogen oxides (NOx). Good combustion practices are used to control carbon monoxide (CO) and volatile organic compounds (VOCs).

Air emissions testing on the unit will occur at the spray dryer absorber (SDA) inlet and the stack outlet. The SDA inlet duct is circular and measures 10.8 feet (ft) (129 inches) in diameter at the test ports which are approximately 120 ft above grade level. The test ports are located approximately 101.8 ft (1,222 inches) downstream and approximately 29.2 ft (350 inches) upstream from the nearest disturbances.

The stack exhaust is circular and measures 9 feet (ft) (108 inches) in diameter at the test ports which are approximately 104 ft above grade level with an exit elevation of approximately 300 ft above grade level. The test ports are located approximately 75.8 ft (910 inches) downstream and approximately 196.5 ft (2,358 inches) upstream from the nearest disturbances.

1.2 Reason for Testing

FBPP is required to perform air emissions testing in conjunction with the requirements of the Minnesota Pollution Control Agency (MPCA) air emissions permit (Permit No. 15100038-004) and the requirements of the United States Environmental Protection Agency (EPA); to determine the concentrations, rates, and reductions of certain pollutants. Pollutants measured at the stack exhaust will include HCl, mercury (Hg), PM/PM₁₀, dioxins/furans (PCDD/PCDF), SO₂, NOx, CO, opacity, carbon dioxide (CO₂), and oxygen (O₂). A reduced number of pollutants will be measured at the SDA inlet (SO₂, HCl, and Hg) to calculate capture efficiencies. All common stack exhaust and SDA pollutant tests will be performed simultaneously.

This protocol will be submitted to the MPCA at least 30 days before the first test.

2.0 SUMMARY

2.1 Owner Information

Company:	PowerMinn 9090, LLC
Mailing address:	2295 Corporate Boulevard, Suite 222 Boca Raton, Florida 33431

2.2 Operator Information

Company: Fibrominn, LLC
Contact Person: Chuck Wagoner, Owners Site Construction Rep.
Mailing address: 900 Industrial Drive
PO Box 265
Benson, Minnesota 56215
Office: (320) 843-9013
Fax: (320) 843-9014
Email: chuck.wagoner@fibrowattusa.com

2.3 Site Information

Site Name: Fibrominn Biomass Power Plant
Contact Person: Victor Myers, Commissioning Manager
Location: 900 Industry Drive Benson
Swift County, Minnesota 56215
Office: (320) 843-5170
Cell: (425) 922-9018
Fax: (320) 843-4193
Email: victor.myers@slthermal.com

2.4 Engineering Consultant Information

Company: SNC – Lavalin (SNC)
Contact Person: Robert Dolesky, Project Engineer
Mailing Address: 1200-1075 West Georgia St
Vancouver, British Columbia
Canada V6E 3C9
Office: (604) 605-4927
Fax: (604) 683-1672
E-mail: robert.dolesky@snc.lavalin.com

2.5 Test Contractor Information

Company: Air Hygiene International, Inc.
Contact Person: Thomas K. Graham, PE, Director of Operations
Mailing Address: 5634 South 122nd East Ave., Suite F
Tulsa, Oklahoma 74146
Office: (918) 307-8865
Cell: (918) 407-5168
Fax: (918) 307-9131
E-mail: tom@airhygiene.com
Website: www.airhygiene.com

2.6 Expected Test Start Date

Thursday, June 14, 2007

2.7 Testing Schedule

The following schedule indicates specific activities required to be done each day; however, the schedule may require flexibility and will be extended as necessary. If there are no operational delays, this schedule can be completed as detailed by the testing crew on the two sources (stack outlet and SDA inlet). The details below describe the activities to be conducted on each source.

Pre-test Activities

1. Conduct site inspection
2. Prepare draft test protocol (Air Hygiene)
3. Submit final approved test plan to SNC (Air Hygiene)
4. Pre-test meeting with SNC, MPCA, etc.
5. Receive site safety training

Due Date

- | |
|--------------------------------|
| per SNC and Air Hygiene |
| prior to testing |
| 3 days after comments on draft |
| Prior to testing |
| Day of arrival for setup |

On-Site Pre-testing Schedule

Day 0 – Initial Site Mobilization and Setup

- | | |
|--------------------------------|---------------|
| • Arrive at site | 09:00 |
| • Attend safety training class | 09:00 – 10:00 |
| • Setup on inlet and outlet | 10:00 – 18:00 |

Time

Activities below will be conducted at the SDA inlet and stack exhaust outlet. Testing will be conducted as appropriate run conditions are available and the testing schedule may move up each day if conditions permit. The schedule assumes 12 hour days with no overtime.

All tests will be conducted under representative operation conditions with the biomass fired boiler steam load between 90 and 100 percent of the nominal rating (490,000 lb/hr). Operation during periods of boiler and air pollution control system malfunctions or upset conditions will not be considered representative conditions and will be reason for delaying, interrupting, aborting, or invalidating a test run. The following are typical malfunctions or upset conditions that will be reason for delaying, interrupting, or invalidating a test run.

1. Crane outage
2. Fan outage
3. Spray dryer absorber or lime slaker problem
4. Carbon system malfunction
5. Broken or frozen grate bar
6. Plugged feed chute
7. Plugged ash discharge
8. Plugged ash conveyor system
9. Turbine trip
10. Hydraulic failure of system
11. Fabric filter malfunction
12. Steam flow not within 10 percent of steam flow set point
13. Boiler tube leak or rupture
14. Plug or bridge in refuse feed hopper

When the malfunction or upset condition has been cleared, testing will resume from that point at which it was stopped. If the malfunction or upset condition results in an extended test delay, then the affected test run(s) may be aborted and a new run(s) conducted when the malfunction has been corrected or process upset cleared. The above list represents but not entirely encompasses the most typical malfunctions or process upsets potentially encountered.

On-site Testing Activities

Time

Day 1 – Compliance / Performance Testing

- Daily setup and calibrations 06:00 – 07:00
- Conduct stratification test
 - Collect outlet data for NO_x and O₂ to determine sample collection location(s) 07:00 – 09:00
- Conduct preliminary cyclonic testing and flow measurements 07:00 – 09:00
 - Collect inlet and outlet data for differential pressures, temperatures, and null angles
- Conduct testing for NO_x, CO, SO₂, CO₂, and O₂ 09:00 – 13:00
 - Collect outlet data for NO_x, CO, SO₂, CO₂, and O₂ (3, 60-minute runs)
 - Collect simultaneous inlet data for SO₂ and O₂ (3, 60-minute runs)
- Conduct testing for opacity 09:00 – 13:00
 - Collect outlet data for opacity (3, 60-minute runs)
- Conduct simultaneous testing for HCl 09:00 – 14:00
 - Collect inlet data for HCl (3, 60-minute runs with setup)
 - O₂, CO₂, and CO data will be monitored by periodic Tedlar bag collection
 - Collect outlet data for HCl (3, 60-minute runs with setup)
 - O₂, CO₂, and CO data will be monitored by the RM analyzers



Day 2 – Compliance / Performance Testing

- Daily setup and calibrations 06:00 – 07:00
- Conduct simultaneous testing for Hg 07:00 – 16:00
 - Collect inlet data for Hg (3, 120-minute runs with setup)
 - O₂, CO₂, and CO data will be monitored by periodic Tedlar bag collection
 - Collect outlet data for Hg (3, 120-minute runs with setup)
 - O₂, CO₂, and CO data will be monitored by the RM analyzers

Day 3 – Compliance / Performance Testing

- Daily setup and calibrations 06:00 – 07:00
- Conduct testing for PCDD/PCDF (Runs 1 and 2) 07:00 – 18:00
 - Collect outlet data for PCDD/PCDF (2, 240-min runs with setup)
 - O₂, CO₂, and CO data will be monitored by the RM analyzers

Day 4 – Compliance / Performance Testing

- Daily setup and calibrations 06:00 – 07:00
- Conduct testing for PCDD/PCDF (Run 3) 07:00 – 13:00
 - Collect outlet data for PCDD/PCDF (1, 240-min run with setup)
 - O₂, CO₂, and CO data will be monitored by the RM analyzers

Day 5 – Compliance / Performance Testing

- Daily setup and calibrations 06:00 – 07:00
- Conduct testing for PM/PM₁₀ 07:00 – 18:00
 - Collect outlet data for PM/PM₁₀ (3, approx. 150-min, min. 100dscf runs with setup)
 - O₂, CO₂, and CO data will be monitored by the RM analyzers

Activities after Testing

- | | |
|--|--------------|
| • Demobilization of Testing Crew (Air Hygiene) | Day 5 |
| • Preparation of draft test report (Air Hygiene) | Days 6 – 14* |
| • Submit for review to SNC (Air Hygiene) | Day 15 |
| • Review and comment on draft (SNC) | Days 16 – 17 |
| • Prepare final hard copy test reports (Air Hygiene) | Days 17 – 18 |
| • Final reports delivered to SNC (Air Hygiene) | Day 19 |

* Draft report timeline may depend on out-sourced laboratory analysis timeline. PCDD/PCDF analysis in particular typically takes from 17 to 21 days to complete a full analysis.

2.8 Test Report Content

The test report methods and content will meet the requirements of the MPCA and the EPA for compliance and certification testing. The reports will include discussion of the following:

- Introduction
- Plant and Sampling Location Description
- Summary and Discussion of Test Results Relative to Acceptance Criteria
- Sampling and Analytical Procedures
- QA/QC Activities
- Test Results and Related Calculations
- Stack and Testing Equipment Drawings
- Raw Field Data and Calibration Data Sheets
- Sampling Log and Chain-of-Custody Records
- Audit Data Sheets

2.9 Equipment and Procedures

Test Methods and Parameters to Satisfy 40 CFR Part 60

- EPA Method 1 for sample location [inlet and outlet]
- EPA Method 2 for exhaust flow [inlet and outlet]
- EPA Method 3a for oxygen (O_2) [inlet and outlet]
- EPA Method 3a for carbon dioxide (CO_2) [inlet and outlet]
- EPA Method 4 for exhaust gas moisture [inlet and outlet]
- EPA Method 5 for particulate matter (PM – front half filterable) [outlet]
- EPA Method 6c for sulfur dioxide (SO_2) [inlet and outlet, simultaneous]
- EPA Method 7e for nitrogen oxides (NOx) [outlet]
- EPA Method 9 for opacity [outlet]
- EPA Method 10 for carbon monoxide (CO) [outlet]
- EPA Method 23 for dioxins and furans (PCDD/PCDF) [outlet]
- EPA Method 26a for hydrogen chloride (HCl) [inlet and outlet, simultaneous]
- EPA Method 202 for particulate matter (PM_{10} – back half condensable) [outlet]
- Ontario Hydro Method for mercury (Hg) [inlet and outlet, simultaneous]

2.10 Proposed Variations

- Stainless steel nozzles and inconel liners will be used instead of borosilicate glass (to prevent breakage) in the Method 5/202 sampling assembly.

- Due to test matrix restrictions, schedule, and operations availability; wet chemistry (isokinetic) runs may be stopped before a run is complete. In this case a delay of more than two hours will constitute cooling and capping off the impinger train. Also, wet chemistry test runs may not be run consecutively.
- Method 26a testing will be from a single point.

2.11 Compliance Sampling Strategy

All compliance testing will be performed while the unit is operating between 90 and 100 percent of the nominal throughput. During the dioxin/furan testing, the temperature ($^{\circ}$ F) at the inlet to the baghouse spray dryer will be recorded by the plant. In addition to this parameter, for all testing, plant personnel will also track boiler measurements including: turbine output (MW), steam flow (lb/hr), feed water flow (gpm), ambient temperature ($^{\circ}$ F), ambient relative humidity (%), barometric pressure (in. Hg), fuel flow (tph), feed water temperature ($^{\circ}$ F), super heater outlet steam temperature ($^{\circ}$ F), super heater outlet steam pressure (psig), super heater outlet flue gas temperature ($^{\circ}$ F), total over fire and under fire combustion air flow (Kacfpm); and spray dryer absorber measurements including: total slurry feed (gpm), dilution water feed (gpm), inlet and outlet flue gas temperature ($^{\circ}$ F), slurry concentration (%).

A. Gases (NO_x, SO₂, CO, CO₂, and O₂) – EPA Methods 7e, 6c, 10, and 3a

NO_x, SO₂, CO, CO₂, and O₂ testing will be conducted on the stack outlet. Each test run will be 60 minutes in duration. Simultaneously, SO₂ and O₂ testing will be conducted on the SDA inlet to calculate control efficiency.

B. PM/PM₁₀ Testing – EPA Methods 5/202

Total Particulate matter (PM) and particulate matter less than 10 microns in diameter (PM₁₀) testing will be conducted on the stack outlet. Each test run will be approximately 150 minutes in duration pulling at least 100 dry standard cubic feet (dscf) of sample volume. An S-type pitot tube will be used to measure cyclonic flow and velocity pressure in accordance with EPA Method 2. This data will be correlated with meter coefficients, temperatures, barometric pressure, and stack gas moisture (EPA Method 4) to determine the stack gas dry exhaust flow rate. PM/PM₁₀ samples will be collected following EPA Method 5 (front half filterables) and EPA Method 202 (back half condensables) with an isokinetic sampling train utilizing a stainless steel nozzle and inconel probe liner. A scale will be used to measure net weight gain from each impinger to determine moisture gain. Gravimetric analysis by Air Hygiene's in-house laboratory will provide PM/PM₁₀ results.

The exit of the filter holder is connected to a series of four full size impingers. The first three impingers each contain 100 milliliters of de-ionized water. The fourth contains a tared quantity of silica gel. The impingers are maintained at a temperature below 68 $^{\circ}$ F for the duration of each test. In accordance with EPA Method 202 requirements, all glassware is cleaned prior to testing with soap and water, rinsed with de-ionized water, acetone and finally methylene chloride.

Procedures for selecting sampling locations and for operation of the apparatus are derived from EPA Method 5/202 and associated EPA Methods 1 through 4. The sampling apparatus is leak-checked before and after each test run. Sampling is performed at an isokinetic rate greater than 90 percent and less than 110 percent.

At the conclusion of each test run, the filter is removed from the filter holder and placed in a labeled Petri dish (container No. 1). Any particles adhering to the filter holder gasket are also transferred to the dish. The probe liner, nozzle, probe fittings and front half of the filter holder are washed three times with acetone to remove any particulate matter or condensate. These rinses are saved in a pre-cleaned glass sample jar (container No. 2).

As soon as possible after the post-test leak check the probe and filter will be detached from the impinger train and the nitrogen (N_2) purge will begin. During the purge, N_2 will flow through the back half of the sample train at 20 liters per min for one hour. The purge will effectively remove any SO_2 in the sample train which may solidify and cause the laboratory to over-report the amount of particulate matter.

The first three impinger catches are measured, their weights recorded, and the catches transferred to container No. 3. The weight gain is added to the silica gel weight gain of the forth impinger to determine the stack gas moisture content. The impingers and all connecting glassware are then rinsed twice with de-ionized water. These rinses are added to container No. 3. A final rinse, of the above components, with methylene chloride is saved in glass sample container No. 4.

Sample bottles are sealed, shaken and labeled, and the liquid level is marked. At that time, approximately 200-ml each of de-ionized water, acetone and methylene chloride are prepared for analysis as reagent blanks.

Particulate samples collected on the glass fiber filters are analyzed gravimetrically to a constant weight. The front half wastes are transferred to tared beakers, evaporated to dryness, and brought to constant weights.

The impinger water is extracted by adding the contents of the methylene chloride rinse to the impinger water, and separating the layers in a separatory funnel. Two additional 75 milliliter portions of methylene chloride are added to the funnel to complete the extraction. The organic extract fraction is then placed into a tared beaker and evaporated at room temperature to dryness. It is then desiccated for 24 hours and brought to a constant weight. The aqueous inorganic fraction is taken to dryness at a slightly elevated temperature and allowed to air dry at room temperature. The residue is then desiccated for 24 hours and brought to a constant weight. The weight differentials for the organic and inorganic fractions are combined to determine the total condensable particulate matter.

The particulate analysis is performed by Air Hygiene's in house laboratory.

C. Mercury Testing – Ontario Hydro Method

Mercury (Hg) testing will be conducted simultaneously on the SDA inlet and stack outlet. Each test run will be 120 minutes in duration. An S-type pitot tube will be used to measure cyclonic flow and velocity pressure in accordance with EPA Method 2. This data will be correlated with meter coefficients, temperatures, barometric pressure, and stack gas moisture (EPA Method 4) to determine the stack gas dry exhaust flow rate. Mercury samples will be collected following the Ontario Hydro Method (ASTM D6784-02) with an isokinetic sampling train utilizing a glass nozzle and probe liner.

The exit of the filter holder is connected to a series of eight full size impingers. The first three impingers each contain 100 mL of 1.0 N potassium chloride (KCl). The fourth impinger contains 100 mL of 5% nitric acid (HNO_3) / 10% hydrogen peroxide (H_2O_2). The fifth, sixth, and seventh impinger contain 100 mL of 10% sulfuric acid (H_2SO_4) / 4% potassium permanganate (KMnO_4). The eighth contains a tared quantity of silica gel. The impingers are maintained at a temperature below 68 °F for the duration of each test.

Procedures for selecting sampling locations and for operation of the apparatus are derived from Ontario Hydro Method and associated EPA RMs 1 though 4. The sampling apparatus is leak-checked before and after each test run. Sampling is performed at an isokinetic rate greater than 90 percent and less than 110 percent.

At the conclusion of each test run, the probe and nozzle will be rinsed and brushed with 0.1 normal nitric acid to remove any particulate matter. These rinses will be collected into polyethylene sample containers. The quartz fiber filter will be recovered and placed into a polyethylene sample container. The volume of liquid collected in each of the impingers will be quantified.

The liquid from the first three impingers will be transferred to a leak-free polyethylene storage container. The first three impingers and all connecting glassware will be rinsed with 0.1 normal nitric acid which will be added to the storage container. The liquid from the fourth impinger will be transferred to a separate polyethylene container, and the impinger will be rinsed into the container with 0.1 normal nitric acid. The contents of impingers 5, 6, and 7 will be collected into an amber glass container. All impingers 5, 6, and 7 and the connecting glassware will then be rinsed with 0.1 normal nitric acid and 8.0 normal hydrochloric acid. These rinses will also be collected in the glass container.

All containers will be sealed, labeled and liquid levels marked prior to transport to the laboratory. The silica gel weight and the volume of condensate collected in the impingers will be used to determine moisture content of the stack gas. A scale will be used to measure net weight gain from each impinger to determine moisture gain. An out-sourced laboratory will be used to provide mercury results.

D. Dioxin/Furan Testing – EPA Method 23

Dioxin/Furan (PCDD/PCDF) testing will be conducted on the stack outlet. Each test run will be 240 minutes in duration. An S-type pitot tube will be used to measure cyclonic flow and velocity pressure in accordance with EPA Method 2. This data will be correlated with meter coefficients, temperatures, barometric pressure, and stack gas moisture (EPA Method 4) to determine the stack gas dry exhaust flow rate. Dioxin/Furan samples will be collected following EPA Method 23 with an isokinetic sampling train utilizing a glass nozzle and probe liner. Particulate will be collected on a filter and a sorbent cartridge will retain vaporous emissions. Following sampling, the appropriate components of the train will be recovered and transferred to the laboratory for analysis. The components will be extracted and the extracts will be cleaned to remove excessive levels of potential interference. A scale will be used to measure net weight gain from each impinger to determine moisture gain. An out-sourced laboratory will be used to provide dioxin/furan results.

All sampling train components that contact the recovered sample will be composed of borosilicate glass, polytetrafluoroethylene (PTFE) or similar materials to avoid potential sample contamination or reactions with PCDDs and PCDFs.

The exit of the filter holder will be connected to a water jacketed glass coil condenser and adsorbent trap unit, configured such that the flue gas and condensed moisture will flow down through the resin in the cartridge. The adsorbent trap will contain an XAD resin cartridge to adsorb the PCDDs and PCDFs present in the vapor and condensed portion of the sample. The resin cartridges will be pre-cleaned and spiked with isotopically labeled surrogates by an outsourced laboratory prior to use in the field. During operation, a leak-free submersible pump will be used to re-circulate cooling water through the coil condenser to ensure proper cooling of the condenser and resin cartridge unit.

Immediately following the adsorbent cartridge will be a series of four full size leak-free glass impingers. All impingers will be of the Greenburg-Smith design, with the first impinger being further modified to have a short stem, to prevent the sample gas from bubbling through the collected condensate. The first impinger will be empty, the second and third impingers each contained 100 milliliters of HPLC-grade distilled water, the fourth empty and the fifth will be charged with silica gel. The impingers will be immersed in an ice bath for the duration of the test.

All train components will be cleaned before use to avoid organic contamination. This cleaning will include a hot soapy wash, three deionized water rinses, two hours of heating at 450 °F, three acetone rinses, and three methylene chloride rinses. All glassware components are then covered with hexane rinsed aluminum foil until assembled at the site.

The impingers will be connected to the metering system via an umbilical. The metering system includes a vacuum gauge, a leak-free pump, thermometers accurate to within ±5.4 °F, and a dry gas meter accurate to within two percent.

Procedures for selecting sampling locations and for operation of the train will be derived from EPA Method 23 and associated Methods 1 through 5. The flue gas sample will be collected by operating the train according to the Method 5 specifications, including leak-checking, isokinetic sampling rates, and stack traversing. Sampling will be performed isokinetically (within plus or minus 10 percent).

At the conclusion of each test run, the probe and umbilical will be carefully removed from the sampling train. The inlet to the sampling train will be removed to a clean field laboratory for sample recovery. The sample from the probe nozzle and probe liner will be recovered at the sampling location. The recovered sample will consist of the following components:

- ◆ Glass fiber filter and particulate catch;
- ◆ Adsorbent trap containing the XAD-2 resin;
- ◆ Acetone/Methylene chloride rinse: Probe liner and nozzle rinsed and brushed three times with acetone and rinsed three times with methylene chloride combined with three rinses of the filter holder, coil condenser and all interconnecting glassware, with three soaks of the condenser with acetone and methylene chloride each;

- ◆ Toluene rinse: Probe liner and nozzle rinsed three times combined with three rinses of the filter holder, coil condenser and all interconnecting glassware with three soaks of the condenser with toluene;
- ◆ The volume of water collected in the impinger train will be measured gravimetrically.

One field train blank will be assembled, recovered and analyzed in the same manner as a sample train.

The samples will be analyzed for PCDDs and PCDFs in accordance with EPA Method 23 protocol using high resolution gas chromatography and high resolution mass spectrometry (GC/MS). All Method 23 samples will be analyzed with the DB-5S column with modified calibration and additional quality assurance procedures as a direct substitute for the DB-5 and DB-225 columns. Confirmation of the 2,3,7,8 TCDF and 2,3,7,8 isomers will be performed on the DB-5S column and modified calibration procedures meets the column separation requirement and can be used as a direct substitute for the DB-5 and DB-225 columns in accordance with Method 23 as approved by the USEPA.

All of the organic analytical work will be performed by an outsourced laboratory. All components of the recovered sampling train, including the toluene rinse, will be pooled and extracted for one analysis.

E. Hydrogen Chloride Testing – EPA Method 26/26a

Hydrogen chloride (HCl) testing will be conducted simultaneously on the SDA inlet and stack outlet. Each test run will be 60 minutes in duration. Each test will be conducted from a single point in the stack. This data will be correlated with meter coefficients, temperatures, barometric pressure, and stack gas moisture (EPA Method 4) to determine the stack gas dry exhaust flow rate. HCl samples will be collected following EPA Method 26a with an isokinetic sampling train utilizing a glass nozzle and probe liner. A scale will be used to measure net weight gain from each impinger to determine moisture gain. An out-sourced laboratory will be used to provide HCl results.

The train components will include a glass nozzle, heated glass lined probe, heated quartz fiber filter, and four full size impingers. The first impinger will have 50 milliliters of 0.1 N sulfuric acid solution and a short stem. The second and third impingers will each have 100 milliliters of 0.1 N sulfuric acid solution. The forth impinger will be empty and the fifth will contain silica gel. The sodium hydroxide impingers will not be used as chlorine (Cl_2), does not need to be determined.

An integrated sample of at least 30 dry standard cubic feet will be extracted from the gas stream and passed through the dilute sulfuric acid. In the dilute acid, the HCl gas dissolves and forms chloride (Cl^-) ions. The train will be leak checked as described in Method 5 from the end of the glass probe liner after testing. After the one hour test the first four impingers, all connecting glassware and back half of the filter housing will be rinsed into one polyethylene container. The probe liner, filter and filter housing will not be recovered. The liquid level of the one sample container will be marked. The Cl^- concentration will be determined by ion chromatography.

As part of the quality assurance program, one duplicate analysis will be performed as specified in Method 26a. In addition, a spike analysis will be performed on one of the

samples. Three runs will be performed for each unit. The hydrogen chloride removal efficiency will be calculated using the ppmdv @ 7% O₂ concentration at the SDA inlet and stack outlet.

F. Opacity – EPA Method 9

Visual opacity from the stack outlet will be determined using EPA Method 9. This method determines the level of any visible emissions that occur during the observation period. It requires that the opacity of emission be determined by a trained and certified individual. Three one hour runs will be observed from the proper location(s) on the stack outlet. The opacity level is recorded every 15 seconds.

**APPENDIX A
QA/QC PROGRAM**

QA/QC PROGRAM

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses five major areas:

1. QA reviews of reports, laboratory work, and field testing;
2. Equipment calibration and maintenance;
3. Chain-of-custody;
4. Training; and
5. Knowledge of current test methods.

QA Reviews

AIR HYGIENE's review procedure includes a review of each source test report, along with laboratory and fieldwork by the QA Team.

The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program.

Chain-of-Custody

AIR HYGIENE maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, AIR HYGIENE documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only AIR HYGIENE personnel have access. Field data sheets are secured at AIR HYGIENE's offices upon return from the field.

Training

Personnel training is essential to ensure quality testing. AIR HYGIENE has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses;
2. Enrollment in EPA correspondence courses;
3. A requirement for all technicians to read and understand Air Hygiene Incorporated's QA manual;
4. In-house training and QA meetings on a regular basis; and
5. Maintenance of training records.

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. AIR HYGIENE subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

A number of quality assurance activities are undertaken before, during, and after each testing project. The following paragraphs detail the quality control techniques, which are rigorously followed during testing projects.

Each instrument's response is checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity is checked by first adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response is then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within ± 2 percent of range of the predicted values.

After each test run, the analyzers are checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criteria for acceptable data are that the instrument drift is no more than 3 percent of the full-scale response. Quality assurance worksheets are prepared to document the multipoint calibration checks and zero to span checks performed during the tests.

The sampling systems are leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least 1 minute with a decline of less than 1 in. Hg. A leak test is conducted after the sample system is set up and before the system is dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced.

The absence of leaks in the sampling system is also verified by a sampling system bias check. The sampling system's integrity is tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods is attributed to sampling system bias or leakage. The criteria for acceptance are agreement within 5% of the span of the analyzer.

The control gases used to calibrate the instruments are analyzed and certified by the compressed gas vendors to $\pm 1\%$ accuracy for all gases. EPA Protocol No. 1 was used where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials.

AIR HYGIENE maintains a large variety of calibration gases to allow the flexibility to accurately test emissions over a wide range of concentrations.

APPENDIX B
TEST EQUIPMENT CONFIGURATION and DESCRIPTION

INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures to be used conform in principle with the methods outlined in the Code of Federal Regulations, Title 40, Part 60, Appendix A, Methods 1, 2, 3a, 4, 5, 6c, 7e, 9, 10, 23, 26a; 40 CFR 51, Appendix M, Method 202; and the Ontario Hydro Method.

The sample system to be used for the NO_x, SO₂, CO₂, CO, and O₂ tests is configured per the following description. A stainless steel probe will be inserted into the sample port of the stack. The gas sample will be continuously pulled through the probe and transported via 3/8 inch heat-traced Teflon® tubing to a stainless steel, minimum-contact condenser designed to dry the sample and then through Teflon® tubing via a stainless steel/Teflon® diaphragm pump and into the sample manifold within the mobile laboratory. From the manifold, the sample is partitioned to the NO_x, SO₂, CO₂, CO, and O₂ analyzers through rotameters that control the flow rate of the sample.

The schematic (Figure 1) shows that the sample system is also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allows for convenient performance of system bias checks as required by the testing methods.

All instruments are housed in an air-conditioned, trailer-mounted mobile laboratory. Gaseous calibration standards are provided in aluminum cylinders with the concentrations certified by the vendor according to EPA Protocol No. 1.

This general schematic also illustrates the analyzers to be used for the tests (i.e., O₂, CO). All data from the Reference Method continuous monitoring instruments are recorded on a Logic Beach Hyperlogger. The Hyperlogger retrieves calibrated emissions data from each instrument every second. An average value is recorded every 30 seconds.


The stack gas analysis for O₂ and CO₂ concentrations will be performed in accordance with procedures set forth in EPA Method 3a. The O₂ analyzer uses a paramagnetic cell detector. The CO₂ analyzer uses a continuous nondispersive infrared (NDIR) analyzer.

EPA Method 6c will be used to determine the concentrations of SO₂. An ultraviolet analyzer will be used to determine the sulfur dioxide concentrations in the gas stream.

EPA Method 7e will be used to determine concentrations of NO_x. A chemiluminescence analyzer will be used to determine the nitrogen oxides concentration in the gas stream. A NO₂ in nitrogen certified gas cylinder will be used to verify at least a 90 percent NO₂ conversion on the day of the test.

CO emission concentrations will be quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

Figure 2 represents the sample train setup for all of the wet chemistry (isokinetic) sampling. An S-type pitot tube will be used to measure cyclonic flow and velocity pressure in accordance with EPA Method 2. This data will be correlated with meter coefficients, temperatures, barometric pressure, and stack gas moisture (EPA Method 4) to determine the stack gas dry exhaust flow rate. Samples will be collected following EPA Methods with an isokinetic sampling train utilizing a stainless steel or glass nozzles and inconel or glass probe liners as appropriate. A scale will be used to measure net weight gain from each impinger to determine moisture gain.





View of Probe End
(from the bottom)

Figure 2
WET CHEMISTRY ASSEMBLY
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
www.airhygiene.com
(888) 461-8778

TABLE #1: TESTING MATRIX

Target Emission	EPA Test Method	Location	Test Length
O ₂	3a	Inlet / Outlet	3, 60 minute runs [inlet] 3, 60 minute runs [outlet]
SO ₂	6c	Inlet / Outlet	3, 60 minute runs [inlet] 3, 60 minute runs [outlet]
NOx	7e	Outlet	3, 60 minute runs
CO	10	Inlet / Outlet	3, 60 minute runs [inlet] 3, 60 minute runs [outlet]
CO ₂	3a	Inlet / Outlet	3, 60 minute runs [inlet] 3, 60 minute runs [outlet]
PM (front half filterable)	5	Outlet	3, 150-minute runs
PM ₁₀ (back half condensable)	202	Outlet	3, 150-minute runs
Opacity	9	Outlet	3, 60-minute runs
Hg	Ontario Hydro	Outlet	3, 120-minute runs
HCl	26/26a	Inlet / Outlet	3, 60 minute runs [inlet] 3, 60 minute runs [outlet]
Dioxins/Furans	23	Outlet	3, 240-minute runs

TABLE #2: ANALYTICAL INSTRUMENTATION

Parameter	Model and Manufacturer	Common Use Ranges	Sensitivity	Detection Principle
NOx	API 200AH or equivalent	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO ₂ to NO Chemiluminescence of reaction of NO with O ₃ . Detection by PMT. Inherently linear for listed ranges.
SO ₂	Ametek 721M or equivalent	User may select up to 10,000 ppm	0.1 ppm	Ultraviolet
CO	TECO 48C or equivalent	0-10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
CO ₂	Servomex or equivalent	0-20%	0.1%	Nondispersive infrared
O ₂	Servomex or equivalent	0-25%	0.1%	Oxygen - Paramagnetic cell

TABLE #3: ANALYTICAL INSTRUMENTATION TESTING CONFIGURATION

Parameter	Sample Methodology	Example Range	Sensitivity	Calibration Gases (based on example range)
NOx	7e	0-500 ppm	0.1 ppm	Zero = 0 ppm nitrogen Mid = 200 – 300 ppm High = 500 ppm
SO ₂	6c	0-200 ppm	0.1 ppm	Zero = 0 ppm nitrogen Mid = 80 – 120 ppm High = 200 ppm
CO	10	0-200 ppm	0.1 ppm	Zero = 0 ppm nitrogen Mid = 80 – 120 ppm High = 200 ppm
CO ₂	3a	0-20%	0.1%	Zero = 0 ppm nitrogen Mid = 8 – 12% High = 20%
O ₂	3a	0-21%	0.1%	Zero = 0 ppm nitrogen Mid = 8.4 – 12.6% High = 21%


APPENDIX C
STACK DRAWINGS

METHOD 1 - ISOKINETIC TRAVERSE FOR A CIRCULAR SOURCE


Company	SNC - Lavalin	Date	2007
Plant Name	Fibrominn Biomass Power Plant	Project #	snc-07-benson.mn-comp#1
Equipment	Biomass Boiler, SDA Inlet	# of Ports Available	4
Location	Benson, Minnesota	# of Ports Used	4

Circular Stack or Duct Diameter		
Distance to Far Wall of Stack	(L_{fw})	141.00 in.
Distance to Near Wall of Stack	(L_{nw})	12.00 in.*
Diameter of Stack	(D)	129.00 in.
Area of Stack	(A_s)	90.76 ft ²

*assume 12 in. reference




Distance from Disturbances to Port		
Distance Upstream	(A)	350.00 in.
Diameters Upstream	(A_D)	2.71 diameters
Distance Downstream	(B)	1222.00 in.
Diameters Downstream	(B_D)	9.47 diameters



Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of ¹ Traverse Points		Minimum Number of Traverse Points	
Down (B_D)	Up (A_D)	Particulate	Velocity	Criteria	Points
2.00-4.99	0.50-1.24	24	16	<input type="checkbox"/> RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	<input type="checkbox"/> Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		12 points
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²		Minimum Number of
	Upstream Spec	12	12		Traverse Points
	Downstream Spec	12	12		RATA Stratification
	Traverse Pts Required	12	12	Criteria	Points
¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.					
² 8 for Circular Stacks 12 to 24 inches 12 for Circular Stacks over 24 inches					
12 points					

Number of Traverse Points Used			
4	Ports by	3	Pts / port
12	Pts Used	12	Required

Traverse Point Locations			
Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
	%	in.	in.
1	4.4%	5 5/8	17 5/8
2	14.6%	18 7/8	30 7/8
3	29.6%	38 1/8	50 1/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			




METHOD 1 - ISOKINETIC TRAVERSE FOR A CIRCULAR SOURCE


Company	SNC - Lavalin	Date	2007
Plant Name	Fibrominn Biomass Power Plant	Project #	snc-07-benson.mn-comp#1
Equipment	Biomass Boiler, Stack Exhaust	# of Ports Available	4
Location	Benson, Minnesota	# of Ports Used	4

Circular Stack or Duct Diameter		
Distance to Far Wall of Stack	(L_{fw})	120.00 in.
Distance to Near Wall of Stack	(L_{nw})	12.00 in.*
Diameter of Stack	(D)	108.00 in.
Area of Stack	(A_s)	63.62 ft ²

*assume 12 in. reference



Distance from Disturbances to Port		
Distance Upstream	(A)	2358.00 in.
Diameters Upstream	(A_D)	21.83 diameters
Distance Downstream	(B)	910.00 in.
Diameters Downstream	(B_D)	8.43 diameters




Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of ¹ Traverse Points		Minimum Number of Traverse Points	
Down (B_D) Stream	Up (A_D) Stream	Particulate Points	Velocity Points	Criteria	Points
2.00-4.99	0.50-1.24	24	16	<input type="checkbox"/> RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	<input type="checkbox"/> Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		12 points
7.00-7.99	1.75-1.99	12	12		
=> 8.00	=>2.00	8 or 12 ²	8 or 12 ²		Minimum Number of
	Upstream Spec	12	12		Traverse Points
	Downstream Spec	12	12		RATA Stratification
	Traverse Pts Required	12	12	Criteria	Points

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.
² 8 for Circular Stacks 12 to 24 inches
 12 for Circular Stacks over 24 inches

Number of Traverse Points Used			
4	Ports by	3	Pts / port
12	Pts Used	12	Required

Traverse Point Locations			
Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
	%	in.	in.
1	4.4%	4 6/8	16 6/8
2	14.6%	15 6/8	27 6/8
3	29.6%	32	44
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



APPENDIX D
EXAMPLE TEMPLATES AND CALCULATIONS

AIR HYGIENE



SINGLE LOAD TEST - FIELD DATA SHEET

Company:			
Location:			
Date:			
Unit Make and Model:			
Unit Number:			
Serial Number:			
Data Recorded By:			
Tested With AHI Unit(s):	Truck(s):	Trailer(s):	
LDEQ Warmup/Cal Req:	On (Day/Time):	Cal (Day/Time):	

CYLINDER SERIAL NUMBERS	O ₂	NOx	CO
	Low		
	Mid		
	High		

CYLINDER SERIAL NUMBERS	THC	CO ₂	SO ₂
	Low		
	Mid		
	High		

RUN INFORMATION	Load		
	% #1	% #2	% #3
Time Start (hh:mm:ss)			
Time Stop (hh:mm:ss)			
Rated Power (MW or hp)			
Actual Power (MW or hp)			
Barometric Pressure (in. Hg)			
Ambient Temperature (°F)			
Relative Humidity (%)			
Fuel Flow (lb/min)			
Fuel Flow (SCF/hr)=(lb/min)*21.7			
Specific Humidity (gr/lb)			
Spec. Hum. (lb H ₂ O/lb air)=(gr/lb)/7000			
PCD (psi)			
PCD (mm Hg)=(psi+14.24)*51.71493			
NOx Water Injection (gpm)			

NO ₂ CONVERSION		
NO ₂ Gas (ppm)		
NO Reading (ppm)		
NOx Reading (ppm)		
Cylinder Num		

REPORT INFORMATION		
O ₂	INSTRUMENT	SERIAL #
NOx		
CO		
THC		
CO ₂		
SO ₂		

RESPONSE TIME		
	TIME (hh:mm)	RESP (min)
1 st Gas Inject		
1 st Inst. @ 95%		
2 nd Inst. @ 95%		
3 rd Inst. @ 95%		
2 nd Gas Inject		
1 st Inst. @ 95%		
2 nd Inst. @ 95%		
3 rd Inst. @ 95%		
3 rd Gas Inject		
1 st Inst. @ 95%		
2 nd Inst. @ 95%		
3 rd Inst. @ 95%		

CALIBRATION	O ₂		NOx		CO		THC		CO ₂		SO ₂	
	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual
Zero Gas												
Low Gas												
Mid Gas												
High Gas												

BIAS	O ₂		NOx		CO		THC		CO ₂		SO ₂	
	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid
Initial Run #1												
Run #1 / Run #2												
Run #2 / Run #3												
Run #3 / Final												

Bias Gas Actual Conc. _____

Method Used (Circle One)		
Method 9	203A	203B
Other: _____		

Company Name		
Facility Name		
Street Address		
City	State	Zip

Process	Unit #	Operating Mode
Control Equipment		Operating Mode

Describe Emissions Point			
Height of Emiss. Pt.	Height of Emiss. Pt. Rel. to Observer		
Start	End	Start	End
Distance to Emiss. Pt.	Direction to Emiss. Pt. (Degrees)		
Start	End	Start	End

Vertical Angle to Obs. Pt.	Direction to Obs. Pt. (Degrees)		
Start	End	Start	End
Distance and Direction to Observation Point from Emission Point			
Start	End	Start	End

Describe Emissions			
Start	End		
Emission Color	Water Droplet Plume		
Start	End	Start	End

Describe Plume Background			
Start	End		
Background Color	Sky Conditions		
Start	End	Start	End
Wind Speed	Wind Direction		
Start	End	Start	End
Ambient Temp.	Wet Bulb Temp.		RH Percent
Start	End		

Source Layout Sketch		
<p>The sketch shows the Emissions Point at the top left, connected by a vertical line to the Observer at the bottom left. A dashed line labeled "Sun Location Line" extends from the Observer. An angle of 140° is indicated between the Sun Location Line and the vertical line to the Emissions Point. To the right, there is a stack with a plume, a sun icon, and a wind icon. A north arrow is also present.</p>		
Latitude	Longitude	Declination

Additional Information		
------------------------	--	--

VISUAL EMISSIONS OBSERVATION FORM

Form Number		Page	of			
Continued on Form Number						
Observation Date		Time Zone		Start Time	End Time	
Min.	Sec.	0	15	30	45	Comments
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

Observer's Name (Print)		
Observer's Signature		Date
Organization		
Certified By		Date

Air Permit # :	
Plant Name or Location:	
Date:	
Project Number:	
Manufacturer & Equipment:	
Model:	
Serial Number:	
Unit Number:	
Test Load:	
Tester(s) / Test Unit(s):	

		RUN																	
	UNITS	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Start Time	hh:mm:ss																		
End Time	hh:mm:ss																		
Bar. Pressure	in. Hg																		
Amb. Temp.	°F																		
Rel. Humidity	%																		
Spec. Humidity	lb water / lb air																		
Comb. Inlet Pres.	psig																		
NOx Water Inj.	gpm																		
Total Fuel Flow	SCFH																		
Heat Input	MMBtu/hr																		
Power Output	megawatts																		
Steam Rate	lb/hr																		


Calibration Date:

Client:

NOx Span (ppm) =

THERMO 42H (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\text{ppm}$)
Linearity =				


THERMO 42H (NOx Analyzer) Linearity Plot



CO Span (ppm) =

API 300 (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\text{ppm}$)
Linearity =				


API 300 (CO Analyzer) Linearity Plot



O2 Span (%) =

SERVOMEX 1400 (O ₂ Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\%$)
Linearity =				


SERVOMEX 1400 (O₂ Analyzer) Linearity Plot



THC Range (ppm) =

THERMO 51 (THC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass or Fail ($\pm 2.5\%$) ¹
Linearity =				


THERMO 51 (THC Analyzer) Linearity Plot



CO2 Span (%) =

FUJI 3300 (CO ₂ Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\%$)
Linearity =				


FUJI 3300 (CO₂ Analyzer) Linearity Plot



SO2 Span (ppm) =

Ametek 721M (SO ₂ Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\text{ppm}$)
Linearity =				

Ametek 721M (SO₂ Analyzer) Linearity Plot



NOx Converter Efficiency**Date:****Analyzer:**

RM 7E, (08-15-06), 8.2.4.1 Introduce a concentration of 40 to 60 ppmv NQ to the analyzer in direct calibration mode and record the NOx concentration displayed by the analyzer. ... Calculate the converter efficiency using Equation 7E-7 in Section 12.7. The specification for converter efficiency in Section 13.5 must be met. ... The NQ must be prepared according to the EPA Traceability Protocol and have an accuracy within 2.0 percent.

Audit Gas: NO₂ Concentration (C_v), ppmvd**Converter Efficiency Calculations:**

Analyzer Reading, NO Channel, ppmvd

Analyzer Reading, NOx Channel, ppmvd

Analyzer Reading, NO₂ Channel (C_{Dir(NO₂)}), ppmvd

Converter Efficiency, %

RM 7E, (08-15-06), 13.5 NO₂ to NO Conversion Efficiency Test (as applicable). The NO₂ to NO conversion efficiency, calculated according to Equation 7E-7 or Equation 7E-9, must be greater than or equal to 90 percent.

$$Eff_{NO_2} = \left(\frac{C_{Dir}}{C_v} \right) \times 100 \quad Eq. 7E-7 = \frac{\text{ppmvd}}{\text{ppmvd}} \times 100 =$$

Date/Time mm/dd/yy hh:mm:ss	Elapsed Time Seconds	NOx ppmvd	NO ppmvd
--------------------------------	-------------------------	--------------	-------------

Fuel Data

Fuel F _d factor		SCF/MMBtu
Fuel Heating Value (HHV)		Btu/SCF

Weather Data

Barometric Pressure	in. Hg
Relative Humidity	%
Ambient Temperature	°F
Specific Humidity	lb H ₂ O / lb air

Unit Data

Unit Load	megawatts
Heat Input	lb/MMBtu
Steam Rate	Steam lb/hr
Combustor Inlet Pres.	psig
NOx Control Water Injection	gpm
Est. Stack Moisture	%
Stack Exhaust Flow (M2)	SCFH
Stack Exhaust Flow (M19)	SCFH

Run - 1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
----------------------------------	---------------------------	-----------------------	----------------	---------------

RAW AVERAGE

Serial Number:	O ₂	NOx	CO
	(%)	(ppmvd)	(ppmvd)
Initial Zero			
Final Zero			
Avg. Zero			
Bias			
Initial UpScale			
Final UpScale			
Avg. UpScale			

Upscale Cal Gas

EMISSIONS DATA	O ₂	NOx	CO
Corrected Raw Average (ppm/% dry basis)			
Corrected Raw Average (ppm/% wet basis)			
Concentration (ppm@ %O ₂)			
Concentration (ppm@ %O ₂ &ISO)			
Emission Rate (lb/hr)			
Emission Rate (tons/day) at 24 hr/day			
Emission Rate (tons/year) at 8760 hr/yr			
Emission Rate (lb/MMBtu)			
Emission Rate (g/hp ^{hr})			

DRIFT AND BIAS CHECK			
Run - 1	O2	NOx	CO
Raw Average			
Corrected Average			
Initial Zero			
Final Zero			
Avg. Zero			
Initial UpScale			
Final UpScale			
Avg. UpScale			
Sys Resp (Zero)			
Sys Resp (Upscale)			
Upscale Cal Gas			
Initial Zero Bias			
Final Zero Bias			
Zero Drift			
Initial Upscale Bias			
Final Upscale Bias			
Upscale Drift			
Alternative Specification	Initial Zero		
Abs Diff	Final Zero		
	Initial Upscale		
	Final Upscale		
Calibration Span			
3% of Range (drift)			
5% of Range (bias)			

DRIFT AND BIAS CHECK			
Run - 2	O2	NOx	CO
Raw Average			
Corrected Average			
Initial Zero			
Final Zero			
Avg. Zero			
Initial UpScale			
Final UpScale			
Avg. UpScale			
Sys Resp (Zero)			
Sys Resp (Upscale)			
Upscale Cal Gas			
Initial Zero Bias			
Final Zero Bias			
Zero Drift			
Initial Upscale Bias			
Final Upscale Bias			
Upscale Drift			
Alternative Specification	Initial Zero		
Abs Diff	Final Zero		
	Initial Upscale		
	Final Upscale		
Calibration Span			
3% of Range (drift)			
5% of Range (bias)			

TABLE A.2
LOAD 1 DATA SUMMARY

Parameter	Run - 1	Run - 2	Run - 3	Average
Start Time (hh:mm:ss)				
End Time (hh:mm:ss)				
Run Duration (min)				
Bar. Pressure (in. Hg)				
Amb. Temp. (°F)				
Rel. Humidity (%)				
Spec. Humidity (lb water / lb air)				
Turbine Fuel Flow (SCFH)				
Stack Flow (RM19) (SCFH)				
Power Output (megawatts)				
NOx (ppmvd)				
NOx (lb/hr)				
NOx (lb/MMBtu)				
NOx (g/hp*hr)				
CO (ppmvd)				
CO (lb/hr)				
CO (lb/MMBtu)				
CO (g/hp*hr)				
O ₂ (%)				

TABLE A.3
LOAD 2 DATA SUMMARY

Parameter	Run - 4	Run - 5	Run - 6	Average
Start Time (hh:mm:ss)				
End Time (hh:mm:ss)				
Run Duration (min)				
Bar. Pressure (in. Hg)				
Amb. Temp. (°F)				
Rel. Humidity (%)				
Spec. Humidity (lb water / lb air)				
Turbine Fuel Flow (SCFH)				
Stack Flow (RM19) (SCFH)				
Power Output (megawatts)				
NOx (ppmvd)				
NOx (lb/hr)				
NOx (lb/MMBtu)				
NOx (g/hp*hr)				
CO (ppmvd)				
CO (lb/hr)				
CO (lb/MMBtu)				
CO (g/hp*hr)				
O ₂ (%)				

EXAMPLE CALCULATIONS (INFORMATION)

Specific Humidity (RH_{sp})

Note: RH_{sp} (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp} \left(lb / lb \right) = \left[\left(\frac{gr}{lb} \right) \times \frac{lb}{7000 gr} \right]$$

$$RH_{sp} = \frac{gr}{lb} \times \frac{1 lb}{7000 gr} = \frac{lb H_2O}{lb Air}$$

Fuel Flow Conversion (Q_f)

Note: Q_f (lb/min) is a value obtained from the source operator.

$$Q_f = \left[Q_f \times G \times \left(\frac{1}{MW_{Fuel}} \right) \right]$$

$$Q_f = \frac{lb}{min} \times \frac{60 min}{hr} \times \frac{ft^3}{lb-mol} \times \frac{lb-mol}{lb} = SCFH$$

Combustor Inlet Pressure / Compressor Discharge Pressure (CIP / CDP)

(corrected from gauge to atmospheric pres. and conv. to mm Hg.)

Note: CIP / CDP (psig) is a value obtained from the source operator.

$$CIP / CDP = \left[(psig + P) \times \frac{51.71493 mmHg}{1 psi} \right]$$

$$CIP / CDP = \left[psig + \right] \times \frac{51.71493 mmHg}{1 psia} = mmHg (abs)$$

Heat Rate (MMBtu/hr)

$$HR = \frac{HHV_{DRY} \times Q_f}{1,000,000}$$

$$\text{Heat Rate} = \frac{Btu}{SCF} \times \frac{SCF}{hr} \times \frac{MMBtu}{10^6 Btu} = \frac{MMBtu}{hr}$$

Estimated Stack Gas Moisture Content (B_{ws})

$$B_{ws} (\%) = \frac{2 \times Q_f}{Q_s} \times 100$$

$$B_{ws} = 2 \times \frac{SCF}{hr} \times \frac{hr}{SCF} \times 100 = \% \quad$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (CALIBRATION)

Analyzer Calibration Error

RM 7E, (08-15-06), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for analyzer mid gas, if applicable)

$$ACE = \left(\frac{C_{Dir} - C_V}{CS} \right) \times 100$$

Eq. 7E-1

$$ACE = \frac{\text{ppm} - \text{ppm}}{\text{ppm}} \times 100 = \% \quad$$

Calibration Error and Estimated Point, RM 25A, THC Analyzer

RM 25A, (07-19-06), 8.4 Calibration Error Test. Immediately prior to the test series (within 2 hours of the start of the test), introduce zero gas and high-level calibration gas at the calibration valve assembly. Adjust the analyzer output to the appropriate levels, if necessary. Calculate the predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response. Then introduce low-level and mid-level calibration gases successively to the measurement system. ... These differences must be less than 5 percent of the respective calibration gas value. (calc for THC analyzer mid gas, if applicable)

$$E_p = \frac{C_{Dir(H)} - C_{Dir(Z)}}{C_{V(H)} - C_{V(Z)}} \times C_{Dir(M)} + C_{Dir(Z)}$$

Eq. of a line
y=mx+b

$$E_p = \frac{\text{ppm} - \text{ppm}}{\text{ppm} - \text{ppm}} \times \text{ppm} + \text{ppm} = \text{ppm}$$

$$ACE = \left(\frac{C_{Dir} - C_V}{CS} \right) \times 100$$

Eq. 7E-1

$$ACE_{THC} = \frac{\text{ppm} - \text{ppm}}{\text{ppm}} \times 100 = \% \quad$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)

System Bias

RM 7E, (08-15-06), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left(\frac{C_s - C_{Dir}}{C_S} \right) \times 100 \quad \text{Eq. 7E-2}$$

$$SB = \frac{\text{ppm} - \text{ppm}}{\text{ppm}} \times 100 = \% \quad \text{ppm}$$

Drift Assessment

RM 7E, (08-15-06), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for analyzer upscale drift, Run 1, if applicable)

$$D = |SB_{final} - SB_i| \quad \text{Eq. 7E-4}$$

$$D = | \% - \% | = \% \quad \text{ppm}$$

Alternative Drift and Bias

RM 7E, (08-15-06), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if $|Cs - Cd_{dir}| \leq 0.5 \text{ ppmv}$ or if $|Cs - Cv| \leq 0.5 \text{ ppmv}$ (as applicable). (calc for analyzer initial upscale, Run 1, if applicable)

$$SB / D_{Alt} = |C_s - C_{Dir}| \quad \text{Eq. Section 13.2 and 13.3}$$

$$SB / D_{Alt} = | \frac{\text{ppm} - \text{ppm}}{\text{ppm}} | = \frac{\text{ppm}}{\text{ppm}}$$

Bias Adjusted Average

RM 7E, (08-15-06), 12.6 Effluent Gas Concentration. For each test run, calculate C_{Avg} , the arithmetic average of all valid concentration values (e.g., 1-minute averages). Then adjust the value of C_{Avg} for bias, using Equation 7E-5. (calc for analyzer, Run 1, if applicable)

$$C_{Gas} = (C_{Avg} - C_o) \times \left(\frac{C_{MA}}{C_M - C_o} \right) \quad \text{Eq. 7E-5}$$

$$C_{Gas} = \left(\frac{\text{ppm} - \text{ppm}}{\text{ppm} - \text{ppm}} \right) \times \left(\frac{\text{ppm}}{\text{ppm} - \text{ppm}} \right) = \frac{\text{ppm}}{\text{ppm}}$$

EXAMPLE CALCULATIONS (BSFC)

Using LHV with Q_f (Btu/hp*hr)

$$BSFC (\text{Btu} / \text{hp} \cdot \text{hr}) = Q_f$$

$$BSFC = \frac{\text{Btu}}{\text{hp}^*\text{hr}} = \frac{\text{Btu}}{\text{hp}^*\text{hr}}$$

Using HHV with Q_f (SCFH)

$$BSFC (\text{Btu} / \text{hp} \cdot \text{hr}) = \frac{HHV \times Q_f}{bhp}$$

$$BSFC = \frac{\text{Btu}}{\text{SCF}} \times \frac{\text{SCF}}{\text{hr}} \times \frac{1}{\text{hp}} = \frac{\text{Btu}}{\text{hp}^*\text{hr}}$$

Using LHV with Q_f (SCFH)

$$BSFC (\text{Btu} / \text{hp} \cdot \text{hr}) = \frac{LHV \times Q_f}{bhp}$$

$$BSFC = \frac{\text{Btu}}{\text{SCF}} \times \frac{\text{SCF}}{\text{hr}} \times \frac{1}{\text{hp}} = \frac{\text{Btu}}{\text{hp}^*\text{hr}}$$

Using HHV with Q_f (Btu/hp*hr)

$$BSFC (\text{Btu} / \text{hp} \cdot \text{hr}) = \frac{Q_f \times HHV}{LHV}$$

$$BSFC = \frac{\text{N/A Btu}}{\text{hp}^*\text{hr}} \times \frac{\text{Btu}}{\text{SCF}} \times \frac{\text{scf}}{\text{Btu}} = \frac{\text{Btu}}{\text{hp}^*\text{hr}}$$

EXAMPLE CALCULATIONS (Emissions based on Table 29 values)

Emission Rate (lb/hr)

$$Q_f (\text{Btu}/\text{hp}^*\text{hr}) \quad E (\text{lb} / \text{hr}) = \frac{E_{g/\text{hp} \cdot \text{hr}} \times bhp}{453.6}$$

$$E (\text{lb}/\text{hr}) = \frac{\text{g}}{\text{hp}^*\text{hr}} \times \frac{\text{lb}}{453.6 \text{ g}} \times \frac{\text{lb}}{\text{hr}}$$

Emission Rate (g/hp-hr)

$$Q_f (\text{Btu}/\text{hp}^*\text{hr}) \quad E (g / \text{hp} \cdot \text{hr}) = CRA \times Q_f \times FFactor \times MW \times \frac{1}{10^6} \times \frac{1}{10^6} \times \frac{453.6}{G} \times \frac{20.9\%}{20.9\% - CRA_{O_2}}$$

$$E (\text{g}/\text{hp-hr}) = \frac{\text{ppm} \times \frac{\text{Btu}}{\text{hp}^*\text{hr}} \times \frac{\text{SCF}}{\text{MMBtu}} \times \frac{\text{lb}}{\text{lb-mol}} \times \frac{1 \text{ parts}}{10^6 \text{ ppm}} \times \frac{1 \text{ MMBtu}}{10^6 \text{ Btu}}}{\frac{453.6 \text{ g}}{\text{lb}} \times \frac{\text{lb-mol}}{\text{scf}} \times \frac{20.9\%}{20.9\% - \%}} = \frac{\text{g}}{\text{hp}^*\text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RUNS)

Stack Exhaust Flow (Q_S) - RM19

$$Q_S = \left(\frac{FFactor \times Q_f \times HHV}{1,000,000} \right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O_2)}} \right)$$

$$Q_S = \frac{\text{SCF}}{\text{MMBtu}} \times \frac{\text{SCF}}{\text{hr}} \times \frac{\text{Btu}}{\text{SCF}} \\ \times \frac{\text{MMBtu}}{10^6 \text{ Btu}} \times \left[\frac{20.90\%}{20.9\% - \%} \right] = \text{SCFH}$$

NO₂ Conversion Efficiency Correction

RM 7E, (08-15-06), 12.8 NO₂ - NO Conversion Efficiency Correction. If desired, calculate the total NOX concentration with a correction for converter efficiency using Equations 7E-8. (calc for non-bias corrected (raw) NOx gas, Run 1, if applicable)

$$NOx_{corr} = NO + \frac{NOx - NO}{Eff_{NO_2}} \times 100 \quad \text{Eq. 7E-8}$$

$$NOx_{corr} = \text{ppm} + \frac{\text{ppm} - \text{ppm}}{\%} \times 100 = \text{ppm}$$

Moisture Correction

RM 7E, (08-15-06), RM7E, (08-15-06), 12.10 Moisture Correction. Use Equation 7E-10 if your measurements need to be corrected to a dry basis. (calc for THC analyzer, Run 1, if applicable) Note: Calculations may not match as Run 1 results are typically also bias adjusted

$$C_D = \frac{C_w}{1 - B_{ws}} \quad \text{Eq. 7E-10}$$

$$C_D = \frac{\text{ppmvw}}{1 - \%} = \text{ppmvd}$$

Diluent-Corrected Pollutant Concentration, O₂ Based

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O₂ Concentration. Calculate the O₂ corrected pollutant concentration, as follows: (calc for gas, Run 1, if applicable)

$$C_{adj} = C_{Gas(T \text{ arg et})} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right) \quad \text{Eq. 20-4} \quad C_{adj} = \text{ppm} \times \left(\frac{20.9\% - \%}{20.9\% - \%} \right) = \text{ppm}@%O_2$$

Diluent-Corrected Pollutant Concentration, CO₂ Based

RM 20, (11-26-02), 7.3.2 Correction of Pollutant Concentration Using CO₂ Concentration. Calculate the CO₂ corrected pollutant concentration, as follows: (calc for gas, Run 1, if applicable)

$$C_{adj} = C_{Gas(T \text{ arg et})} \times \frac{X_{CO_2}}{C_{Gas(CO_2)}} \quad \text{Eq. 20-5} \quad C_{adj} = \text{ppm} \times \frac{\%}{\%} =$$

7.2 CO₂ Correction Factor. If pollutant concentrations are to be corrected to percent O₂ and CO₂ concentration is measured in lieu of O₂ concentration measurement, a CO₂ correction factor is needed. Calculate the CO₂ correction factor as follows: 7.2.1 Calculate the fuel specific F_o, as follows:

$$F_o = \frac{0.209 F_d}{F_c} \quad \text{Eq. 20-2} \quad F_o = \frac{0.209 \times \text{SCF/MMBtu}}{\text{SCF/MMBtu}} =$$

7.2.2. Calculate the CO₂ correction factor for correcting measurement data to percent oxygen, as follows:

$$X_{CO_2} = \frac{20.9\% - AdjFactor}{F_o} \quad \text{Eq. 20-3} \quad X_{CO_2} = \frac{20.9\% - \%}{F_o} = \%$$

Diluent-Corrected Pollutant Concentration Corrected to ISO Conditions

40CFR60.335(b)(1), Conversion for conc. at ISO Conditions (68°F, 1 atm). Calculate, as follows: (calc for @% with Run 1 data, if applicable)

$$C_{ISO} = C_{Adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_o - 0.00633))} \times \left(\frac{288}{T_a} \right)^{1.53} \\ C_{ISO} = \text{ppm}@%O_2 \times \left(\sqrt{\frac{\frac{\text{psig} + 14.69232 \text{ psi}}{0.01933677 \text{ psi/mm Hg.}}}{\frac{\text{psig} + \text{psi}}{0.01933677 \text{ psi/mm Hg.}}}} \right)^{(19 \times (\frac{\text{lb/lb} - 0.00633}{2.718}))} \times \left(\frac{288 \text{ K}}{K} \right)^{1.53} = \text{ppm}@% \text{ and ISO}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RUNS)

Emissions Rate (lb/hr)

Calculation for pound per hour emission rate. Calculate, as follows: (calc for gas Run 1, if applicable)

$$E_{lb/hr} = \frac{C_{Gas} \times Q_S \times MW}{10^6 G}$$

$$E_{lb/hr} = \frac{\text{ppm}}{10^6 \text{ ppm/part}} \times \frac{\text{SCFH} \times \text{lb/lb-mol}}{\text{SCF/lb-mol}} = \frac{\text{lb}}{\text{hr}}$$

Emissions Rate (ton/year)

Calculation for tons per year emission rate based on 8760 hours per year. Calculate, as follows: (calc for gas Run 1, if applicable)

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

$$E_{ton/yr} = \frac{\text{lb}}{\text{hr}} \times \frac{\text{hr}}{\text{year}} \times \frac{\text{ton}}{2000 \text{ lb}} = \frac{\text{ton}}{\text{year}}$$

Emissions Rate (lb/MMBtu)

RM 19, (07-19-06), 12.2 Emission Rates of PM, SO₂, and NOx. Select from the following sections the applicable procedure to compute the PM, SO₂, or NOx emission rate (E) in ng/J (lb/million Btu). (calc for gas Run 1, if applicable)

Oxygen Based

12.2.1 Oxygen-Based F Factor, Dry Basis. When measurements are on a dry basis for both O₂ (%O₂d) and pollutant (Cd) concentrations, use the following equation:

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d \text{ Factor} \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O_2)}} \quad \text{Eq. 19-1}$$

$$E_{lb/MMBtu} = \frac{\text{ppm} \times \text{SCF/MMBtu} \times \text{lb/ppm} \cdot \text{ft}^3 \times 20.9\%}{20.9\% - \%} = \frac{\text{lb}}{\text{MMBtu}}$$

Carbon Dioxide Based

12.2.4 Carbon Dioxide-Based F Factor, Dry Basis. When measurements are on a dry basis for both CO₂ (%CO₂d) and pollutant (Cd) concentrations, use the following equation:

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d \text{ Factor} \times Conv_C \times 100\%}{C_{Gas(CO_2)}} \quad \text{Eq. 19-6}$$

$$E_{lb/MMBtu} = \frac{\text{ppm} \times \text{SCF/MMBtu} \times \text{lb/ppm} \cdot \text{ft}^3 \times 100\%}{\%} = \frac{\text{lb}}{\text{MMBtu}}$$

Conversion Constant

Conv_c for

$$Conv_c (\text{lb} / \text{ppm} \cdot \text{ft}^3) = \frac{MW}{\frac{G}{10^6}} \quad Conv_c = \frac{\text{lb}}{\frac{\text{lb} \cdot \text{mole}}{10^6}} \times \frac{\text{lb} \cdot \text{mole}}{\text{SCF}} = \frac{\text{lb}}{\text{ppm} \cdot \text{ft}^3}$$

Sulfur Dioxide Rate (lb/MMBtu), 40CFR60, App. A, RM 19, Eq. 19-25 (11/20/03)

$$SO_2 (\text{lb} / \text{MMBtu}) = 0.97 \times K \times \frac{S(\text{wt}\%)}{GCV} \quad SO_2 = 0.97 \times \frac{2 \times 10^4 \text{ Btu}}{\text{wt}\% \cdot \text{MMBtu}} \times \frac{\text{wt}\%}{\text{Btu/lb}} = \frac{\text{lb}}{\text{MMBtu}}$$

Emissions Rate (g/hp-hr)

Calculation for grams per horsepower-hour. Calculate, as follows: (calc for gas Run 1, if applicable)

$$E_{g/hp-hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1314.022} \text{ or } \frac{E_{lb/hr} \times 453.6}{hp}$$

$$E_{g/hp-hr} = \frac{\text{lb}}{\text{hr}} \times \frac{453.6 \text{ g}}{\text{lb}} \times \frac{1}{\text{mw}} \times \frac{\text{mw}}{1314.022 \text{ hp}} = \frac{\text{g}}{\text{hp} \cdot \text{hr}}$$

$$E_{g/hp-hr} = \frac{\text{lb}}{\text{hr}} \times \frac{453.6 \text{ g}}{\text{lb}} \times \frac{1}{\text{hp}} = \frac{\text{g}}{\text{hp} \cdot \text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

ACE = Analyzer calibration error, percent of calibration span.
B_{WS} = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.
C_{Avg} = Average unadjusted gas concentration indicated by data recorder for the test run.
C_O = Pollutant concentration adjusted to dry conditions.
C_{Dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.
C_{Gas} = Average effluent gas concentration adjusted for bias.
C_M = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.
C_{MA} = Actual concentration of the upscale calibration gas, ppmv.
C_O = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.
C_S = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.
C_{SS} = Concentration of NOx measured in the spiked sample.
C_{Spike} = Concentration of NOx in the undiluted spike gas.
C_{Calc} = Calculated concentration of NOx in the spike gas diluted in the sample.
C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high).
C_W = Pollutant concentration measured under moist sample conditions, wet basis.
CS = Calibration span.
D = Drift assessment, percent of calibration span.
E_p = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.
Eff_{NO2} = NO₂ to NO converter efficiency, percent.
H = High calibration gas, designator.
L = Low calibration gas, designator.
M = Mid calibration gas, designator.
NOFinal = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.
NOxCorr = The NOx concentration corrected for the converter efficiency.
NOxFinal = The final NOx concentration observed during the converter efficiency test in Section 16.2.2.
NOxPeak = The highest NOx concentration observed during the converter efficiency test in Section 16.2.2.
Q_{Spike} = Flow rate of spike gas introduced in system calibration mode, L/min.
Q_{Total} = Total sample flow rate during the spike test, L/min.
R = Spike recovery, percent.
SB = System bias, percent of calibration span.
SB_i = Pre-run system bias, percent of calibration span.
SB_f = Post-run system bias, percent of calibration span.
SB / D_{All} = Alternative absolute difference criteria to pass bias and/or drift checks.
SCE = System calibration error, percent of calibration span.
SCE_i = Pre-run system calibration error, percent of calibration span.
SCE_{final} = Post-run system calibration error, percent of calibration span.
Z = Zero calibration gas, designator.

40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:

P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg
P_o = observed combustor inlet absolute pressure at test, mm Hg
H_o = observed humidity of ambient air, g H₂O/g air
e = transcendental constant, 2.718
T_a = ambient temperature, K

Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:

bhp = brake horsepower
hp = horsepower
Q_{sys} = system flow (lpm)
Q_m = matrix spike flow (lpm)

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = percent oxygen or carbon dioxide adjustment applied to a target pollutant
 B_{wa} = Moisture fraction of ambient air, percent.
 Btu = British thermal unit
 $\%C$ = Concentration of carbon from an ultimate analysis of fuel, weight percent.
 $\%CO_{2d}, \%CO_{2w}$ = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.
 CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufacturers reference as PCD.
 E = Pollutant emission rate, ng/J (lb/million Btu).
 E_a = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).
 E_{ao}, E_{ai} = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).
 E_{bi} = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).
 E_{bo} = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).
 E_c = Pollutant rate in combined effluent, ng/J (lb/million Btu).
 E_{co} = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).
 E_d = Average pollutant rate for each sampling period (e.g., 24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).
 E_{di} = Average inlet SO₂ rate for each sampling period d, ng/J (lb/million Btu).
 E_g = Pollutant rate from gas turbine, ng/J (lb/million Btu).
 E_{ga} = Daily geometric average pollutant rate, ng/J (lbs/million Btu) or ppm corrected to 7 percent O₂.
 E_{go}, E_{gi} = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O₂.
 E_h = Hourly average pollutant, ng/J (lb/million Btu).
 E_{hj} = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O₂.
 EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.
 FC = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19
 F_d, F_w, F_c = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).
 ft³ = cubic feet
 G = ideal gas conversion factor
 (385.23 SCF/lb-mol at 68 deg F & 14.696 psia)
 GCM = gross Btu per SCF (constant, compound based)
 GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).
 GCV_p, GCV_r = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).
 $\%H$ = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.
 H_o = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).
 H_g = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).
 $\%H_2O$ = Concentration of water from an ultimate analysis of fuel, weight percent.
 H_t = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).
 K = volume of combustion component per pound of component (constant)
 K = Conversion factor, 10⁻⁵ (kJ/J)/(%) [10⁶ Btu/million Btu].
 K_c = (9.57 scm/kg)/% [(1.53 scf/lb)/%].
 K_{cc} = (2.0 scm/kg)/% [(0.321 scf/lb)/%].
 K_{nd} = (22.7 scm/kg)/% [(3.64 scf/lb)/%].
 K_{hw} = (34.74 scm/kg)/% [(5.57 scf/lb)/%].
 K_n = (0.86 scm/kg)/% [(0.14 scf/lb)/%].
 K_s = (2.85 scm/kg)/% [(0.46 scf/lb)/%].
 K_a = (3.54 scm/kg)/% [(0.57 scf/lb)/%].
 K_{sulfur} = 2x10⁴ Btu/wt%-MMBtu
 K_w = (1.30 scm/kg)/% [(0.21 scf/lb)/%].
 lb = pound
 ln = Natural log of indicated value.
 L_p, L_r = Weight of the product and raw fuel lots, respectively, metric ton (ton).
 $\%N$ = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.
 M% = mole percent
 mol = mole
 MW = molecular weight (lb/lb-mol)
 MW_{AIR} = molecular weight of air (28.9625 lb/lb-mole)¹
 NCM = net Btu per SCF (constant based on compound)
 $\%O$ = Concentration of oxygen from an ultimate analysis of fuel, weight percent.
 $\%O_{2d}, \%O_{2w}$ = Concentration of oxygen on a dry and wet basis, respectively, percent.
 P_B = barometric pressure, in Hg
 P_s = Potential SO₂ emissions, percent.
 $\%S$ = Sulfur content of as-fired fuel lot, dry basis, weight percent.
 S_a = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).
 $\%S_{sr}$ = Concentration of sulfur from an ultimate analysis of fuel, weight percent.
 S(wt%) = weight percent of sulfur, per lab analysis by appropriate ASTM standard
 S_i = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).
 S_e = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).
 $\%S_p, \%S_r$ = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.
 SCF = standard cubic feet
 SH = specific humidity, pounds of water per pound of air
 $t_{0.95}$ = Values shown in Table 19-3 for the indicated number of data points n.
 T_{amb} = ambient temperature, °F
 W/D Factor = 1.0236 = conv. at 14.696 psia and
 68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)
 X_{CO_2} = CO₂ Correction factor, percent.
 X_k = Fraction of total heat input from each type of fuel k.

ALARMS EXIST !!! - Check Alarm Sheet

<input type="checkbox"/>	English Units	<input type="radio"/> <input checked="" type="radio"/>	Cells Unprotected
--------------------------	---------------	--	-------------------

Source Information			
Plant Name			
Sampling Location			
Fuel or Source Type	Gas, Natural		
Fuel F-Factor			

Test Information			
Starting Test Date			
Project #			
Operator			
Standard Temperature		68	oF
Standard Pressure		29.92	in Hg
Minimum Required Sample Vol.	indust. spec.	100	scf
Run Duration	chk Subpart	180	minutes
Unit Number			
Load	% or w/DB		
Base Run Number			
Number of Ports Available			
Number of Ports Used			
Port Inside Diameter			in
Circular Stack		<input type="checkbox"/>	

Test Equipment Information				
Run	1	2	3	
Meter Box Number	from ACS			
Meter Calibration Factor	(Y)			
Orifice Meter Coefficient	(ΔH@)			in H ₂ O
Pitot Identification	from ACS			
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840
Orsat Identification	from ACS			
Nozzle Number	from ACS			
Nozzle Diameter	(D _n)			in
Probe Number	from ACS			
Probe Length				in
(SS, Glass) Liner Material	from list	inconel	inconel	inconel
Sample Case / Oven Number	from ACS			
Impinger Case Number	from ACS			
Acetone Lot Number	from bottle			

Testing Company Information				
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)			
Address	5634 S. 122nd East Ave., Suite F			
City, State Country Zip	Tulsa, Oklahoma 74146			
Project Manager				
Phone Number	(918) 307-8865			
Fax Number	(918) 307-9131			

METHOD 1 - SAMPLE AND VELOCITY TRAVERSSES FOR CIRCULAR SOURCES

Plant Name		Date	
Sampling Location		Project #	
Operator		# of Ports Available	
Stack Type	Circular	# of Ports Used	
Stack Size		Port Inside Diameter	

Circular Stack or Duct Diameter		
Distance to Far Wall of Stack	(L _{fw})	in
Distance to Near Wall of Stack	(L _{nw})	in
Diameter of Stack	(D)	in
Area of Stack	(A _s)	ft ²


Distance from Port to Disturbances		
Distance Downstream	(B)	in
Diameters Downstream	(B _D)	diameters
Distance Upstream	(A)	in
Diameters Upstream	(A _D)	diameters

Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of Traverse Points	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²
Upstream Spec			
Downstream Spec			
Traverse Pts Required			

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

² 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

Location of Traverse Points in Circular Stacks										
Traverse		(Fraction of Stack Dimension from Inside Wall to Traverse Point)								
Point		Number of Traverse Points Across the Stack								
Number		2	4	6	8	10	12	14	16	18
1		.146	.067	.044	.032	.026	.021	.018	.016	.014
2		.854	.250	.146	.105	.082	.067	.057	.049	.044
3			.750	.296	.194	.146	.118	.099	.085	.075
4				.933	.704	.323	.226	.177	.146	.125
5					.854	.677	.342	.250	.201	.169
6						.956	.806	.658	.356	.269
7							.895	.774	.644	.366
8								.968	.854	.750
9									.918	.823
10										.799
11										.780
12										.704
										.974
										.979
										.901
										.831
										.764



Number of Traverse Points Used			
	Ports by		Across
Pts Used			Required
			Particulate Traverse

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
1			in
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE				
--	--	--	--	--

Plant Name				Date		
Sampling Location				Project #		
Operator				# of Ports Used		
Stack Type	Circular			Pitot Identification		
Pitot Leak Check	<input type="checkbox"/>	PreTest	<input type="checkbox"/>	PostTest	Pitot Coefficient (C_p)	0.84

Stack Dimensions			Velocity Traverse Data			
Diameter or Length of Stack	(D)		Run Number	V1		
Width of Stack	(W)		Run Time	Start	End	
Area of Stack	(A_s)		Traverse Point	Velocity Head (Δp)	Null Angle (N_a)	Stack Temp (t_s)
				in H ₂ O	deg	oF
						ft/sec
Pressures						
Barometric Pressure	(P_b)					
Static Pressure	(P_{static})					
Absolute Stack Pressure	(P_s)					
Alarms Exist - Enter Static Pressure (see below)!!!						
Stack Gas Composition						
Composition Data:	<input type="text"/>	Estimated Composition				
Carbon Dioxide Concentration	(%CO ₂)					
Oxygen Concentration	(%O ₂)					
Carbon Monoxide Concentration	(%CO)					
Nitrogen Concentration	(%N ₂)					
Stack Moisture Content	(B _{ws})					
Stack Dry Molecular Weight	(M _d)		lb/lb-mole			
Stack Wet Molecular Weight	(M _s)		lb/lb-mole			
Results						
Avg Stack Gas Velocity	(v_s)		ft/sec			
Avg Stack Dry Std Flow Rate	(Q _{sd})		dscf/hr			
Avg Stack Dry Std Flow Rate	(Q _{sd})		dscf/min			
Avg Stack Wet Flow Rate	(Q _{aw})		acf/min			
Avg Stack Wet Std Flow Rate	(Q _{sw})		ascf/hr			
Stack Cross Section Schematic						
Average						= Square roots of Δp
Alarms Exist - Measure Static Pressure, turn side-to side, unplug to get positive reading!!!						

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER									
---	--	--	--	--	--	--	--	--	--

Plant Name					Date				
Sampling Location					Project #				
Operator					# of Ports Used				
Fuel Type	N/A		Minimum Fuel Factor		1.600	Maximum Fuel Factor		1.836	
Orsat Leak Check	<input type="checkbox"/>	PreTest	<input type="checkbox"/>	PostTest	Orsat Identification				

Gas Analysis Data									
Run Number		1		Run Start Time				Run Stop Time	
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole
Results		Averages							
Average Calculated Fuel Factor		(F _o) _{avg}				Molecular Wt Deviation < 0.3?		<input type="checkbox"/>	
Average Excess Air		(%EA) _{avg}		percent		Fuel Factor in Handbook Range?		<input type="checkbox"/>	

Gas Analysis Data									
Run Number		2		Run Start Time				Run Stop Time	
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole
Results		Averages							
Average Calculated Fuel Factor		(F _o) _{avg}				Molecular Wt Deviation < 0.3?		<input type="checkbox"/>	
Average Excess Air		(%EA) _{avg}		percent		Fuel Factor in Handbook Range?		<input type="checkbox"/>	

Gas Analysis Data									
Run Number		3		Run Start Time				Run Stop Time	
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole
Results		Averages							
Average Calculated Fuel Factor		(F _o) _{avg}				Molecular Wt Deviation < 0.3?		<input type="checkbox"/>	
Average Excess Air		(%EA) _{avg}		percent		Fuel Factor in Handbook Range?		<input type="checkbox"/>	

Fuel Factor F _o		
Fuel Type	Minimum	Maximum
Coal, Anthracite	1.016	1.130
Coal, Lignite	1.016	1.130
Coal, Bituminous	1.083	1.230
Oil, Distillate	1.260	1.413
Oil, Residual	1.210	1.370
Gas, Natural	1.600	1.836
Gas, Propane	1.434	1.586
Gas, Butane	1.405	1.553
Wood	1.000	1.120
Wood Bark	1.003	1.130

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES						
---	--	--	--	--	--	--

Plant Name				Date		
Sampling Location				Project #		
Operator				# of Ports Used		
Stack Type	Circular			Meter Box Number		
Train Leak Check	<input type="checkbox"/>	PreTest	<input type="checkbox"/>	PostTest	Meter Cal Factor (Y)	

Moisture Content Data							
Run Number	1		Run Start Time		Run Stop Time		
Total Meter Volume	(V _m)		dcf	Barometric Press.	(P _b)		in Hg
Avg Meter Temp	(t _m) _{avg}		oF	Stack Static Press.	(P _{static})		in H ₂ O
Avg Stack Temp	(t _s) _{avg}		oF	Avg Orifice Press.	(ΔH) _{avg}		in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents	g	g	g	g	g	g	g
DI	DI	DI	Sil Gel				
Final Value	(V _t),(W _t)						
Initial Value	(V _i),(W _i)						
Net Value	(V _n),(W _n)						
Results							
Total Weight	(W _t)		g	Water Vol Weighed	(V _{wsg(std)})		scf
Std Meter Volume	(V _{m(std)})		dscf	Sat. Moisture Content	(B _{ws(svp)})		%
Calc Moisture Content	(B _{ws(calc)})		%	Final Moisture Content	(B _{ws})		%

Moisture Content Data							
Run Number	2		Run Start Time		Run Stop Time		
Total Meter Volume	(V _m)		dcf	Barometric Press.	(P _b)		in Hg
Avg Meter Temp	(t _m) _{avg}		oF	Stack Static Press.	(P _{static})		in H ₂ O
Avg Stack Temp	(t _s) _{avg}		oF	Avg Orifice Press.	(ΔH) _{avg}		in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents	g	g	g	g	g	g	g
DI	DI	DI	Sil Gel				
Final Value	(V _t),(W _t)						
Initial Value	(V _i),(W _i)						
Net Value	(V _n),(W _n)						
Results							
Total Weight	(W _t)		g	Water Vol Weighed	(V _{wsg(std)})		scf
Std Meter Volume	(V _{m(std)})		dscf	Sat. Moisture Content	(B _{ws(svp)})		%
Calc Moisture Content	(B _{ws})		%	Final Moisture Content	(B _{ws})		%

Moisture Content Data							
Run Number	3		Run Start Time		Run Stop Time		
Total Meter Volume	(V _m)		dcf	Barometric Press.	(P _b)		in Hg
Avg Meter Temp	(t _m) _{avg}		oF	Stack Static Press.	(P _{static})		in H ₂ O
Avg Stack Temp	(t _s) _{avg}		oF	Avg Orifice Press.	(ΔH) _{avg}		in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents	g	g	g	g	g	g	g
DI	DI	DI	Sil Gel				
Final Value	(V _t),(W _t)						
Initial Value	(V _i),(W _i)						
Net Value	(V _n),(W _n)						
Results							
Total Weight	(W _t)		g	Water Vol Weighed	(V _{wsg(std)})		scf
Std Meter Volume	(V _{m(std)})		dscf	Sat. Moisture Content	(B _{ws(svp)})		%
Calc Moisture Content	(B _{ws})		%	Final Moisture Content	(B _{ws})		%

ISOKINETIC SAMPLING DATA

Plant Name					Date					Ideal Nozzle Diameter and IsoKinetic Factor Setup															
Sampling Location					Project #					Pitot Tube Coefficient	(C _p)	0.84													
Operator					Run #	1				Avg Stack Temp	(t _s)		oF												
# of Points Across					# of Ports Used					Avg Gas Meter Temp	(t _m)														
Leak Checks					Sampling Equipment					DH @ 0.75 SCFM	(ΔH@)		in H2O												
Train	Pre	ft3/min @		in Hg	Meter #					Avg Pitot Tube Diff. Pressure	(ΔP _{avg})		in H2O												
OK?	<input type="checkbox"/>	Post	ft3/min @	in Hg	Meterbox Cal. Factor	(Y)					Stack Moisture Content	(B _{ws})		%											
Pitot	Pre	in. H ₂ O for		sec	Nozzle #					Stack Dry Molecular Weight	(M _d)		lb/lb-mole												
OK?	<input type="checkbox"/>	Post	in. H ₂ O for	sec	Average Nozzle Diameter	(D _{na})					Estimated Orifice Flow Rate	(Q _m)	0.750	acfm											
Orsat	OK?	<input type="checkbox"/>			Rec. Nozzle Diameter	(D _{nl})					DP to DH Isokinetic Factor	(K)													
Nozzle Measurements					Probe # / Length									Pressures											
Pre				PASS	Liner Material	inconel				Barometric Pressure	(P _b)		in Hg												
Post				PASS	Sample Case / Oven #					Stack Static Pressure	(P _{static})		in H2O												
Run Time					Impinger Case #					Absolute Stack Pressure	(P _s)		in Hg												
Start		End			Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8	Wash Volume	H ₂ O	50.0	ml	Filter #							
					Pre									Volume	MeCl		ml								
Alarms Exist - Enter Run Times!!!																									
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (Δp ^{1/2})	Local Stack Velocity (v _s)	Cumulative Meter Volume (V _m) _{std}	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}						
	min	hh:mm:ss	ft3	in H ₂ O	in H ₂ O	in H ₂ O	oF	oF	oF	oF	oF	oF	oF	in Hg	(in H ₂ O) ^{1/2}	ft/sec	scf	%	scf						
	0.0	0:00:00																							
#VALUE!																									
Final Val	0.0	0:00:00												Max Vac	Final Values										
Average Values																									

- SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name		Date	
Sampling Location		Project #	
Operator		Acetone Lot Number	

Run History Data				
Run Number	1	2	3	
Run Start Time				(hh:mm)
Run Stop Time				(hh:mm)
Train Prepared By				
Train Recovered By				
Recovery Date				(mm/dd/yy)
Relinquished By				
Received By				
Relinquished Date				(mm/dd/yy)
Relinquished Time				(hh:mm)

Equipment Identification Numbers				
Filter				
Acetone Wash				
Silica Gel				
Impinger Case				
Sample Box				
Oven				

**Alarms Exist - Enter
Filter Numbers!!!**

Sample Blank Taken NO

Alarms Exist - Collect Sample
Blanks of at least 75ml each!!!

Moisture Content Data				
Impingers 1, 2, and 3 - Liquid Volume				
Final Volume	(V _f)			ml
Initial Volume	(V _i)			ml
Net Volume	(V _n)			ml
Comments				
Impinger 4 - Silica Gel Weight				
Final Weight	(W _f)			g
Initial Weight	(W _i)			g
Net Weight	(W _n)			g
Comments				
Total Water Collected				
Total Volume	(V _{lc})			ml

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) - SAMPLE ANALYTICAL DATA SHEET						
---	--	--	--	--	--	--

Plant Name			Date			
Sampling Location				Project #		
Operator				Acetone Lot Number		

Analytical Data						
Placed in Desiccator				Run	1	Start Time
	Number	Date	Time	Leakage Evident?		<input type="checkbox"/>
Filter				Estimated Volume		0.00
Probe Wash Beaker #						
Water Beaker #						
MeCl (org) Beaker #						

Weight Data						
Filter and Beaker Weight	Filter	Date	Time	Humidity	Temp	Cal Audit
	g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1 (m _{1f})						
Measurement 2 (m _{2f})						
Measurement 3 (m _{3f})						
Measurement 4 (m _{4f})						
Probe Wash and Beaker Weight	Acetone	Date	Time	Humidity	Temp	Cal Audit
	g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1 (m _{1a})						
Measurement 2 (m _{2a})						
Measurement 3 (m _{3a})						
Measurement 4 (m _{4a})						
Imp Content and Beaker Weight	Imp Water	Date	Time	Humidity	Temp	Cal Audit
	g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1 (m _{1ino})						
Measurement 2 (m _{2ino})						
Measurement 3 (m _{3ino})						
Measurement 4 (m _{4ino})						
Organics and Beaker Weight	MeCl Org	Date	Time	Humidity	Temp	Cal Audit
	g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1 (m _{1org})						
Measurement 2 (m _{2org})						
Measurement 3 (m _{3org})						
Measurement 4 (m _{4org})						

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) - SAMPLE ANALYTICAL DATA SHEET			
---	--	--	--

Plant Name		Date	
Sampling Location		Project #	
Operator		Acetone Lot Number	

Tare (Pre-Particulate) Weights					
Tare	Filter	Filter Beaker	Acetone Beaker	Imp Content Beaker	
					g
Tare		Organics Beaker	PM ₁₀ Beaker		g Run 1

Sample Volume and Blank Concentrations		
Probe Wash Volume	(v _a)	ml
Impinger Content Volume	(v _{ino})	ml
Organics Wash Volume	(v _{org})	ml
Net Wash Volume	(v _n)	ml
Acetone Blank Weight of Solids	(w _{ab})	g
Imp Cont Blank Weight of Solids	(w _{inob})	g
MeCl Blank Weight of Solids	(w _{orgb})	g
Acetone Blank Volume	(v _{ab})	ml
Imp Content Blank Volume	(v _{inob})	ml
MeCl Blank Volume	(v _{orgb})	ml
Acetone Blank Concentration	(C _a)	mg/ml
Imp Content Blank Concentration	(C _{ino})	mg/ml
MeCl Blank Concentration	(C _{org})	mg/ml

Results						
		Filter _f	PM10 _{a1'}	Probe _{a'}	Imp Cont _{ino'}	Organics _{org'}
Final Weight	(m _{fx})					g
Tare Weight	(m _{tx})					g
Weight Gain	(m _x)					mg
Blank Adjustment	(W _x)					mg
Total Particulates	(M _n)					mg

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) - RESULTS						
Plant Name		Date				
Sampling Location		Project #				
Operator		Stack Type	Circular			
Historical Data						
Run Number	1	2	3	Average		
Run Start Time					hh:mm	
Run Stop Time					hh:mm	
Meter Calibration Factor	(Y)					
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840		
Average Nozzle Diameter	(D _{na})		#DIV/0!	#DIV/0!		in
Stack Test Data						
Initial Meter Volume	(V _m) _i				ft ³	
Final Meter Volume	(V _m) _f				ft ³	
Total Meter Volume	(V _m)				ft ³	
Total Sampling Time	(e)	0.0	0.0	0.0	0.0	min
Average Meter Temperature	(t _m) _{avg}					oF
Average Stack Temperature	(t _s) _{avg}					oF
Barometric Pressure	(P _b)					in Hg
Stack Static Pressure	(P _{static})					in H ₂ O
Absolute Stack Pressure	(P _s)					in Hg
Average Orifice Pressure Drop	(ΔH) _{avg}					in H ₂ O
Absolute Meter Pressure	(P _m)					in Hg
Avg Square Root Pitot Pressure	(Δp ^{1/2}) _{avg}					(in H ₂ O) ^{1/2}
Moisture Content Data						
Impingers 1-3 Water Volume Gain	(V _n)				ml	
Impinger 4 Silica Gel Weight Gain	(W _n)				g	
Total Water Volume Collected	(V _c)				ml	
Standard Water Vapor Volume	(V _{wstd})				scf	
Standard Meter Volume	(V _{mstd})				dscf	
Calculated Stack Moisture	(B _{ws(calc)})				%	
Saturated Stack Moisture	(B _{ws(svp)})				%	
Reported Stack Moisture Content	(B _{ws})				%	
Gas Analysis Data						
Carbon Dioxide Percentage	(%CO ₂)				%	
Oxygen Percentage	(%O ₂)				%	
Carbon Monoxide Percentage	(%CO)				%	
Nitrogen Percentage	(%N ₂)				%	
Dry Gas Molecular Weight	(M _d)				lb/lb-mole	
Wet Stack Gas Molecular Weight	(M _s)				lb/lb-mole	
Calculated Fuel Factor	(F _d)				dscf/MMBtu	
Fuel F-Factor	(F _d)				dscf/MMBtu	
Percent Excess Air	(%EA)				%	
Volumetric Flow Rate Data						
Average Stack Gas Velocity	(v _s)				ft/sec	
Stack Cross-Sectional Area	(A _s)				ft ²	
Actual Stack Flow Rate	(Q _{aw})				acf ³	
Wet Standard Stack Flow Rate	(Q _{sw})				wkscfh	
Dry Standard Stack Flow Rate	(Q _{sd})				dscfm	
Percent of Isokinetic Rate	(I)				%	
Emission Rate Data						
Mass of Particulate on Filter	(M _f)				mg	
Mass of Particulate in Acetone	(M _a)'				mg	
Mass of Particulate in Imp Content	(M _{mo})'				mg	
Mass of Particulate in Org Rinse	(M _{org})'				mg	
Total Mass of Particulates	(M _n)				mg	
Stack Particulate Concentration	(c _s)				g/dscf	
	(c _s)'				gr/dscf	
	(E)				kg/hr	
Particulate Emission Rate	(E)				lbs/hr	
	(E)				tons/yr	
	(E)				lbs/MMBtu	
(Pt 75 App F Sect. 5.2.1) Heat Input	(HI)				MMBtu/hr	

SAMPLE DESCRIPTION AND CHAIN OF CUSTODY RECORD



Air Hygiene International, Inc.
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
(888) 461-8778
www.airhygiene.com

Relinquished by: (Signature)

Date:

Time:

Received by: (Signature)

Date:

Time:

Relinquished by: (Signature)

Date:

Time:

Received by: (Signature)

Date:

Time:

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

L_{fw} = distance to far wall of stack (in.)

L_{nw} = distance to near wall of stack (in.) [reference]

D = diameter of stack (in.)

A_s = area of stack (ft^2)

B = distance downstream (in.)

B_D = stack diameters downstream (dia.)

A = distance upstream (in.)

A_D = stack diameters upstream (dia.)

Diameter of Stack (in.)

$$D(\text{in.}) = L_{fw} - L_{nw}$$

$$D(\text{in.}) = 0 \text{ in.} - 0 \text{ in.} = \text{in.}$$

Stack Diameters Downstream

$$B_D(\text{dia.}) = \frac{B}{D}$$

$$B_D(\text{dia.}) = \frac{0 \text{ in.}}{\text{in.}} = \text{diameters}$$

Area of Stack (ft^2)

$$A_s(\text{ft}^2) = \pi \times \left(\frac{D}{2 \times 12} \right)^2$$

$$A_s(\text{ft}^2) = 3.14 \times \left(\frac{\text{in.}}{2 \times 12 \text{ in./ft}} \right)^2 = \text{ft}^2$$



Stack Diameters Upstream

$$A_D(\text{dia.}) = \frac{A}{D}$$

$$A_D(\text{dia.}) = \frac{0 \text{ in.}}{\text{in.}} = \text{diameters}$$

Number of Traverse Points

Based on 40 CFR Part 60, Appendix A, Method 1, Section 2.2



Traverse Point Locations

Based on 40 CFR Part 60, Appendix A, Method 1, Section 2.3

Traverse Point	Location of Traverse Points in Circular Stacks (Fraction of Stack Dimension from Inside Wall to Traverse Point)											
	2	4	6	8	10	12	14	16	18	20	22	24
1	.146	.067	.044	.032	.026	.021	.018	.016	.014	.013	.011	.011
2	.854	.250	.146	.105	.082	.067	.057	.049	.044	.039	.035	.032
3	.750	.296	.194	.146	.118	.098	.085	.075	.067	.060	.056	.055
4	.933	.704	.323	.226	.177	.146	.125	.109	.097	.087	.079	.079
5	.854	.677	.342	.260	.201	.169	.146	.129	.116	.116	.105	.105
6	.956	.806	.658	.566	.469	.369	.220	.188	.165	.146	.132	.132
7	.896	.774	.644	.566	.483	.395	.236	.204	.180	.161	.161	.161
8	.968	.854	.750	.634	.575	.496	.250	.218	.194	.178	.161	.161
9	.918	.823	.731	.625	.562	.462	.306	.262	.230	.208	.186	.186
10	.974	.882	.799	.717	.618	.588	.315	.272	.230	.208	.186	.186
11	.933	.854	.760	.704	.612	.593	.323	.281	.249	.227	.205	.205
12	.979	.901	.831	.764	.694	.607	.398	.356	.324	.292	.270	.270
13	.943	.875	.812	.750	.685	.602	.377	.335	.303	.271	.249	.249
14	.962	.915	.854	.796	.736	.677	.416	.375	.334	.303	.281	.281
15	.951	.891	.835	.782	.728	.677	.416	.375	.334	.303	.281	.281
16	.964	.925	.871	.820	.770	.720	.464	.423	.382	.351	.329	.329
17	.956	.903	.854	.806	.756	.708	.464	.423	.382	.351	.329	.329
18	.968	.933	.884	.839	.786	.738	.464	.423	.382	.351	.329	.329
19	.961	.918	.859	.810	.756	.708	.464	.423	.382	.351	.329	.329
20	.987	.940	.895	.846	.793	.745	.464	.423	.382	.351	.329	.329
21	.965	.921	.865	.816	.763	.715	.464	.423	.382	.351	.329	.329
22	.969	.945	.898	.850	.796	.748	.464	.423	.382	.351	.329	.329
23	.968	.968	.927	.879	.826	.778	.464	.423	.382	.351	.329	.329
24	.969	.969	.927	.879	.826	.778	.464	.423	.382	.351	.329	.329

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2)

P_b = barometric pressure (in. Hg)
 P_{static} = static pressure (in. H₂O)
 P_s = absolute stack pressure (in. Hg)
%N₂ = nitrogen concentration (%)
%CO₂ = carbon dioxide concentration (%)
%O₂ = oxygen concentration (%)
%CO = carbon monoxide concentration (%)
MW = molecular weight (lb/lb-mole)
B_{ws} = stack moisture content (%)
M_d = stack dry molecular weight (lb/lb-mole)
M_s = stack wet molecular weight (lb/lb-mole)
T_{std} = standard temperature, 68°F, 528°R
P_{std} = standard pressure, 29.92 in. Hg
v_{sl} = local velocity (ft/sec)
v_s = average stack gas velocity (ft/sec)
Q_{sd} = average stack dry standard flow rate (dscf/hr)
Q_{aw} = average stack wet flow rate (ascf/min)

C_p = pitot tube coefficient
Δp = velocity head (in. H₂O)
A_s = area of stack (ft²)
N_a = null angle (deg.)
t_s = stack temperature (°F)
T_u = temperature offset, 460°R
K_p = pitot tube constant,
85.49 (ft/sec)((lb/lb-mole)(in. Hg)/((°R)(in. Hg)))^{1/2}

Absolute Stack Pressure (in. Hg)

$$P_s (\text{in. Hg}) = P_b + \frac{P_{\text{static}}}{13.6}$$

$$P_s (\text{in. Hg}) = 0 \text{ in. Hg} + \frac{0.00 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = \text{in. Hg}$$

Nitrogen Concentration (%)

$$\% N_2 = 100 - \% CO_2 - \% O_2 - \% CO$$

$$\% N_2 (\%) = 100 - 0 \% - 0 \% - 0 \% = \%$$

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d (\text{lb / lb - mol}) = \sum \left(\frac{MW_{\text{comp}}}{100} \times \% \text{ component} \right)$$

$$M_d (\text{lb/lb-mol}) = \left[\frac{44 \text{ lb/lb-mol}}{100} \times 0 \% \right] + \left[\frac{32 \text{ lb/lb-mol}}{100} \times 0 \% \right] + \text{etc.} = \frac{\text{lb}}{\text{lb-mol}}$$

Stack Wet Molecular Weight (lb/lb-mole)

$$M_s (\text{lb / lb - mol}) = \left[M_d \times \left(1 - \frac{B_{ws}}{100} \right) \right] + \left[MW_{H_2O} \times \frac{B_{ws}}{100} \right]$$

$$M_s (\text{lb/lb-mol}) = \left[\frac{\text{lb}}{\text{lb-mol}} \times \left(1 - \frac{0 \%}{100} \right) \right] + \left[\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0 \%}{100} \right] = \frac{\text{lb}}{\text{lb-mol}}$$

Local Velocity (ft/sec)

$$v_{sl(l)} (\text{ft / sec}) = K_p \times C_p \times \sqrt{\Delta p} \times \sqrt{\frac{t_s + T_u}{P_s \times M_s}}$$

$$v_{sl} (\text{ft/sec}) = \frac{85.49 \text{ ft}}{\text{sec}} \left[\frac{(\text{lb/lb-mol})(\text{in. Hg})}{(\text{°R})(\text{in. H}_2\text{O})} \right]^{1/2} \times 0.84 \times \sqrt{0.00 \text{ in. H}_2\text{O}} \times \sqrt{\frac{0 + 460 \text{ °R}}{\text{in. Hg} \times \frac{\text{lb/lb-mol}}{1}}} = \frac{\text{ft}}{\text{sec}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2)

P_b = barometric pressure (in. Hg)
 P_{static} = static pressure (in. H₂O)
 P_s = absolute stack pressure (in. Hg)
%N₂ = nitrogen concentration (%)
%CO₂ = carbon dioxide concentration (%)
%O₂ = oxygen concentration (%)
%CO = carbon monoxide concentration (%)
MW = molecular weight (lb/lb-mole)
B_{ws} = stack moisture content (%)
M_d = stack dry molecular weight (lb/lb-mole)
M_s = stack wet molecular weight (lb/lb-mole)
K_p = pitot tube constant,

$$85.49 \text{ (ft/sec)}(((\text{lb/lb-mole})(\text{in. Hg}))(({}^{\circ}\text{R})(\text{in. Hg})))^{1/2}$$

T_{STD} = standard temperature, 68°F

P_{STD} = standard pressure, 29.92 in. Hg

v_{sl} = local velocity (ft/sec)

v_s = average stack gas velocity (ft/sec)

Q_{SD} = average stack dry standard flow rate (dscfh)

Q_{AW} = average stack wet flow rate (ascf/min)

C_p = pitot tube coefficient

Δp = velocity head (in. H₂O)

A_s = area of stack (ft²)

N_A = null angle (deg.)

t_s = stack temperature (°F)

T_u = temperature offset, 460°R

Average Stack Gas Velocity (ft/sec)

$$v_s (\text{ft/sec}) = K_p \times C_p \times \left(\sqrt{\Delta p} \right)_{\text{avg}} \times \sqrt{\frac{(t_s)_{\text{avg}} + T_u}{P_s \times M_s}}^{1/2}$$

$$v_{\text{sl}} (\text{ft/sec}) = \frac{85.49 \text{ ft}}{\text{sec}} \left(\frac{(\text{lb/lb-mol})(\text{in. Hg})}{({}^{\circ}\text{R})(\text{in. H}_2\text{O})} \right)^{1/2} \times 0.84 \times \frac{\text{in. H}_2\text{O}}{\text{in. Hg}} \times \frac{+ 460 {}^{\circ}\text{R}}{\text{lb/lb-mol}} = \frac{\text{ft}}{\text{sec}}$$

Average Stack Dry Standard Flow Rate (dscfh)

$$Q_{sd} (\text{dscfh}) = \frac{60 \times 60 \times \left(1 - \frac{B_{ws}}{100} \right) \times v_s \times A_s \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sd} (\text{dscfh}) = \frac{3600 \text{ sec}}{\text{hr}} \times \left(1 - \frac{0.0 \%}{100} \right) \times \frac{\text{ft}}{\text{sec}} \times \frac{\text{ft}^2}{\text{min}} \times \frac{\text{dscf}}{\frac{68 + 460 {}^{\circ}\text{R}}{+ 460 {}^{\circ}\text{R}} \times \frac{\text{in. Hg}}{29.92 \text{ in. Hg}}} = \frac{\text{dscf}}{\text{hr}}$$

Average Stack Wet Flow Rate (acf m)

$$Q_{aw} (\text{acf m}) = 60 \times v_s \times A_s$$

$$Q_{aw} (\text{acf/min}) = \frac{60 \text{ sec}}{\text{min}} \times \frac{\text{ft}}{\text{sec}} \times \frac{\text{ft}^2}{\text{min}} = \frac{\text{ascf}}{\text{min}}$$

Average Stack Wet Standard Flow Rate (dscfh)

$$Q_{sw} (\text{ascf/h}) = \frac{60 \times Q_{aw} \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sw} (\text{ascf/hr}) = \frac{60 \text{ min}}{\text{hr}} \times \frac{\text{acf}}{\text{min}} \times \frac{\text{ascf}}{\frac{68 + 460 {}^{\circ}\text{R}}{+ 460 {}^{\circ}\text{R}} \times \frac{\text{in. Hg}}{29.92 \text{ in. Hg}}} = \frac{\text{ascf}}{\text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 3a)

%N₂ = nitrogen concentration (%)

%CO₂ = carbon dioxide concentration (%)

%O₂ = oxygen concentration (%)

ppmCO = carbon monoxide concentration (ppm)

%CO = carbon monoxide concentration (%)

M_d = stack dry molecular weight (lb/lb-mole)

(F_o)_{avg} = average calculated fuel factor

(%EA)_{avg} = average excess air (%)

Carbon Monoxide Concentration (%)

$$\% CO = \frac{ppmCO}{10,000}$$

$$\% CO (\%) = \frac{0.00 \text{ ppm}}{10,000 \text{ ppm}/\%} = \text{ %}$$

Nitrogen Concentration (%)

$$\% N_2 = 100 - \% CO_2 - \% O_2 - \% CO$$

$$\% N_2 (\%) = 100 - \% - \% - \% = \%$$

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d (\text{lb / lb-mol}) = \sum \left(\frac{MW_{comp}}{100} \times \% \text{ component} \right)$$

$$M_d (\text{lb/lb-mol}) = \left[\frac{44 \text{ lb/lb-mol}}{100} \times \% \right] + \left[\frac{32 \text{ lb/lb-mol}}{100} \times \% \right] + \text{etc.} = \frac{\text{lb}}{\text{lb-mol}}$$

Average Calculated Fuel Factor

$$F_{o(avg)} = \frac{|20.9 - (\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})|}{(\% CO_2)_{avg} + (\% CO)_{avg}}$$

$$F_{o(avg)} = \frac{20.9\% - \% - [0.5 \times \%]}{\% + \%} =$$

Average Excess Air (%)

$$\% EA_{avg} (\%) = \frac{100 \times [(\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})]}{(0.264 \times (N_2)_{avg}) - [(\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})]}$$

$$(\% EA)_{AVG} = \frac{100 \times \{ \% - [0.5 \times \%] \}}{\{ 0.264 \times \% \} - \{ \% - [0.5 \times \%] \}} = \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4)

V_{mf} = final dry gas meter reading (dcf)

V_{mi} = initial dry gas meter reading (dcf)

V_m = total meter volume (dcf)

$t_{m(\text{avg})}$ = average meter temp. ($^{\circ}\text{F}$)

$t_{s(\text{avg})}$ = average stack temp. ($^{\circ}\text{F}$)

P_b = barometric pressure (in. Hg)

P_{static} = static pressure (in. H_2O)

ΔH_{avg} = average orifice pressure (in. H_2O)

V_i = initial impinger volume (ml)

V_f = final impinger volume (ml)

W_i = initial impinger weight (g)

W_f = final impinger weight (g)

V_t = total impinger volume (ml) = $\Sigma(V_f - V_i)$

W_t = total impinger weight (g) = $\Sigma(W_f - W_i)$

K_5 = water mass to std water vapor, 0.04715 ft^3/g

K_1 = standard volume correction, 17.65 $^{\circ}\text{R}/\text{in. Hg}$

Y = meter calibration factor

T_u = absolute temperature offset, 460 $^{\circ}\text{R}$

B_{ws} = final moisture content (%) = min of $B_{ws(\text{calc})}$ and $B_{ws(\text{svp})}$

Water Volume Weighed (dscf)

$$V_{wsg(\text{std})}(\text{dscf}) = W_t \times K_5$$

$$V_{wsg(\text{std})} = g \times 0.04715 \text{ ft}^3/\text{g} = \text{dscf}$$

Standard Meter Volume (dscf)

$$V_{m(\text{std})}(\text{dscf}) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{\text{avg}}}{13.6} \right)}{(t_{m(\text{avg})} + T_u)}$$

$$V_{m(\text{std})} = \frac{\frac{17.65 \text{ } ^{\circ}\text{R}}{\text{in. Hg}} \times \text{dcf} \times \left[\text{in. Hg} + \frac{\text{in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O / in. Hg}} \right]}{\text{in. Hg} + \frac{460 \text{ } ^{\circ}\text{R}}{17.65 \text{ } ^{\circ}\text{R}}} = \text{dscf}$$

Calculated Moisture Content (%)

$$B_{ws(\text{calc})}(\%) = 100 \times \frac{V_{wsg(\text{std})}}{V_{wsg(\text{std})} + V_{m(\text{std})}}$$

$$B_{ws(\text{calc})} = 100 \times \frac{\text{dscf}}{\text{dscf} + \text{dscf}} = \%$$

Saturated Moisture Content (%)

$$B_{ws(\text{svp})}(\%) = 100 \times \frac{10 \frac{6.691 - \frac{3144}{t_{s(\text{avg})} + 390.86}}{P_b + \frac{P_{\text{static}}}{13.6}}}{10} \leq 100$$

$$B_{ws(\text{svp})} = 100 \times \frac{10 \left[\frac{6.691 - \frac{3144}{t_{s(\text{avg})} + 390.86}}{P_b + \frac{P_{\text{static}}}{13.6}} \right]}{\text{in. Hg} + \frac{\text{in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O / in. Hg}}} \leq 100 = \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling)

C_n = nozzle diameter constant, 0.03575

Q_m = estimated orifice flow rate, 0.750 acfm

else V_m/Θ from previous run

V_m = total meter volume (acf)

Θ = total sampling time (min)

t_m = average gas meter temperature ($^{\circ}\text{F}$)

T_u = absolute temperature

C_p = pitot tube coefficient

B_{wm} = meter moisture content (%)

B_{ws} = stack moisture content (%)

t_s = average stack temperature ($^{\circ}\text{F}$)

M_d = stack dry molecular weight (lb/lb)

P_s = absolute stack pressure (in)

C_k = K Factor Constant. 849.8

Recommended Nozzle Diam.

Δp_{avg} = average pitot tube differential pressure (in. H₂O)

$\Delta H_{\text{at}} = \text{DH} @ 0.75 \text{ SCFM (in. H}_2\text{O)}$

D_{na} = actual nozzle diameter (in.)

Δp = velocity head (in. H₂O)

Desired Orifice (in. H₂O)

$$\Delta H_d (\text{in. } H_2O) = K \times \Delta p$$

$\Delta H_d (\text{in. } H_2O) =$ \times $0 \text{ in. } H_2O =$ $\text{in. } H_2O$

Absolute Meter Pressure (in. Hg)

$$P_m(\text{in.Hg}) = P_b + \frac{\Delta H @}{13.6}$$

$$P_m(\text{in. Hg}) = 0.00 \text{ in. Hg} + \frac{\text{in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = \text{in. Hg}$$

Recommended Nozzle Diameter (in.)

$$D_{ni}(\text{in.}) = \frac{\sqrt{\frac{C_n \times Q_m \times P_m}{(t_m + T_u) \times C_p} \times \left(\frac{1 - \frac{B_{wm}}{100}}{1 - \frac{B_{ws}}{100}} \right) \times \sqrt{(t_s + T_u) \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + (18 \times B_{ws})}{P_s \times \Delta p_{avg}} \right]}}}{\frac{0.03575 (\text{lb-mole} \cdot {}^\circ\text{R} \cdot \text{in. H}_2\text{O})^{1/2} \cdot \text{min} \cdot \text{in.}^2}{\text{acf} \cdot \text{in. Hg}^{3/4} \cdot \text{lb}^{1/2}} \times 0.75 \times \text{acf} \times \text{in. Hg} \times \left(1 - \frac{0.0}{100} \right) \times \left(1 - \frac{0.0}{100} \right)} \\ D_{ni}(\text{in.}) = \frac{\sqrt{\left(0 \cdot {}^\circ\text{F} + 460 {}^\circ\text{R} \right) \times 0.84}}{\left(0 \cdot {}^\circ\text{F} + 460 {}^\circ\text{R} \right) \times \frac{\text{lb}}{\text{lb-mole}} \times \left(1 - \frac{0.0}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times 0.0 \right) \times \left(1 - \frac{0.0}{100} \right)} = \text{in.}$$

DP to DH Isokinetic Factor

$$DP \text{ to DH Isokinetic Factor} \\ K = C_k \times C_p^2 \times \Delta H @ \times D_{na}^4 \times \left[\frac{M_d \times \left(1 - \frac{B_{wm}}{100} \right) + \left(18 \times \frac{B_{wm}}{100} \right)}{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + \left(18 \times \frac{B_{ws}}{100} \right)} \right] \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{wm}}{100}} \right)^2 \times \left(\frac{t_m + T_u}{ts + T_u} \right) \times \frac{P_s}{P_m}$$

$$K = \frac{849.8}{\text{in. H}_2\text{O} \cdot \text{in.}^4} \times 0.84^2 \times \text{in. H}_2\text{O} \times \left(\frac{1 - \frac{0.0 \%}{100}}{1 - \frac{0.0 \%}{100}} \right)^4 \times \left(\frac{0}{0} \frac{\text{°F} + 460^\circ\text{R}}{\text{°F} + 460^\circ\text{R}} \right) \times$$

$$\left\{ \begin{array}{l} \frac{\text{lb}}{\text{lb/mole}} \times \left(1 - \frac{0.0 \%}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0.0 \%}{100} \right) \\ \frac{\text{lb}}{\text{lb/mole}} \times \left(1 - \frac{0.0 \%}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0.0 \%}{100} \right) \end{array} \right\} \times \frac{\text{in. Hg}}{\text{in. Hg}} =$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 5)

K_4 = isokinetic conversion constant, 0.0945 min \cdot in.Hg/sec \cdot $^{\circ}$ R

$m_{\#x}$ = weight measurements (g)

v_a = acetone volume (ml)

v_{ino} = impinger content volume (ml)

v_{org} = organics wash volume (ml)

w_x = blank weight of solids (g)

v_x = blank volume (ml)

m_{fx} = final weight, avg of last two measurements (g)

m_{tx} = tare weight (g)

Total Particulates (mg)

$$M_n (\text{mg}) = \sum (m_x - W_x) \\ M_n (\text{mg}) = \sum [\quad \text{mg} - \quad \text{mg}] + \text{etc...} = \quad \text{mg}$$

Local Stack Velocity (ft/sec)

$$v_{s(l)} (\text{ft/sec}) = K_p \times C_p \times \sqrt{\Delta p} \times \sqrt{\frac{t_s + T_u}{P_s \times \left[M_d \times \left(1 - \frac{B_{ws}}{100} \right) + \left(18 \times \frac{B_{ws}}{100} \right) \right]}} \\ v_{s(l)} (\text{ft/sec}) = \frac{85.49 \text{ ft}}{\text{sec}} \times \frac{(\text{lb/lb-mol})(\text{in. Hg})}{(\text{R})(\text{in. H}_2\text{O})}^{1/2} \times 0.84 \times \sqrt{0.00 \text{ in. H}_2\text{O}} \times \\ \sqrt{\frac{0 \text{ } ^{\circ}\text{F} + 460 \text{ } ^{\circ}\text{R}}{\text{in. Hg} \times \left[\frac{\text{lb}}{\text{lb/mole}} \times \left(1 - \frac{0.0 \%}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0.0 \%}{100} \right) \right]} = \frac{\text{ft}}{\text{sec}}$$

Cumulative Percent Isokinetic (%)

$$I(\%) = \frac{K_4 \times ((t_s)_{avg} + T_u) \times V_m}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12} \right)^2 \right) \times \left(1 - \frac{B_{ws}}{100} \right)} \\ I(\%) = \\ \frac{\frac{0.0945 \text{ min} \cdot \text{in. Hg}}{\text{sec} \cdot \text{R}} \times \#DIV/0! \text{ } ^{\circ}\text{F} + 460 \text{ } ^{\circ}\text{R} \times \text{scf}}{\#\#\#\#\# \text{ min} \times \frac{\#DIV/0! \text{ ft}}{\text{sec}} \times \text{in. Hg} \times 3.14 \times \left(\frac{\text{in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}} \right)^2 \times \left(1 - \frac{0 \%}{100} \right)} = \quad \%$$

Net Wash Volume (ml)

$$v_n (\text{ml}) = v_a + v_{ino} + v_{org} \\ v_n (\text{ml}) = \text{ml} + \text{ml} + \text{ml} = \text{ml}$$

Blank Concentration (mg/ml)

$$C_x (\text{mg/ml}) = \frac{1000 \times w_x}{v_x} \\ C_x (\text{mg/ml}) = \frac{1000 \times \text{g}}{\text{ml}} = \frac{\text{mg}}{\text{ml}}$$

Blank Adjustment (lesser of)

$$W_x (\text{mg}) = m_x \dots \text{or} \dots v_x \times C_x \\ W_x (\text{mg}) = \text{mg or} \\ \text{ml} \times \frac{\text{mg}}{\text{ml}} = \text{mg}$$

Weight Gain (mg)

$$m_x (\text{mg}) = (m_{fx} - m_{tx}) \times 1000 \\ m_x (\text{mg}) = [\quad \text{mg} - \quad \text{mg}] \times 1000 = \quad \text{mg}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 5)

M_n = total particulates (mg)

$V_{m(std)}$ = standard meter volume (dscf)

Q_{sd} = dry standard stack flow rate (dscfm)

F_d = fuel f-factor (dscf/MMBtu)

% O_2 = oxygen percentage (%)

Q_{sw} = wet standard stack flow rate (ascfm)

Stack Particulate Concentration (g/dscf)

$$c_s (g / dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

$$c_s (g/dscf) = \frac{g}{1000 \text{ mg}} \times \frac{\text{mg}}{\text{dscf}} = \frac{g}{\text{dscf}}$$

Stack Particulate Concentration (gr/dscf)

$$c_s' (gr / dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

$$c_s' (\text{gr/dscf}) = \frac{g}{1000 \text{ mg}} \times \frac{\text{mg}}{\text{dscf}} \times \frac{7000 \text{ gr}}{\text{lb}} \times \frac{\text{lb}}{453.592 \text{ g}} = \frac{\text{gr}}{\text{dscf}}$$

Particulate Emissions Rate (kg/hr)

$$E (\text{kg} / \text{hr}) = c_s \times Q_{sd} \times \frac{60}{1000}$$

$$E (\text{kg}/\text{hr}) = \frac{\text{kg}}{1000 \text{ g}} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{\text{g}}{\text{dscf}} \times \frac{\text{dscf}}{\text{min}} = \frac{\text{kg}}{\text{hr}}$$

Particulate Emissions Rate (lb/hr)

$$E' (\text{lb} / \text{hr}) = \frac{M_n \times Q_{sd}}{V_{m(std)}} \times \frac{60}{453.592 \times 1000}$$

$$E' (\text{lb}/\text{hr}) = \frac{\text{g}}{1000 \text{ mg}} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{\text{lb}}{453.592 \text{ g}} \times \frac{\text{mg}}{\text{dscf}} \times \frac{\text{dscf}}{\text{min}} = \frac{\text{lb}}{\text{hr}}$$

Particulate Emissions Rate (ton/yr)

$$E'' (\text{ton} / \text{yr}) = E' \times \frac{8760}{2000}$$

$$E'' (\text{ton}/\text{yr}) = \frac{\text{ton}}{2000 \text{ lb}} \times \frac{8760 \text{ hr}}{\text{yr}} \times \frac{\text{lb}}{\text{hr}} = \frac{\text{ton}}{\text{yr}}$$

Particulate Emissions Rate (lb/MMBtu)

$$E''' (\text{lb} / \text{MMBtu}) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \% O_2} \right)$$

$$E''' (\text{lb}/\text{MMBtu}) = \frac{\text{g}}{1000 \text{ mg}} \times \frac{\text{lb}}{453.592 \text{ g}} \times \frac{\text{mg}}{\text{dscf}} \times \frac{\text{dscf}}{\text{MMBtu}} \times \left(\frac{20.9}{20.9 - \%} \right) = \frac{\text{lb}}{\text{MMBtu}}$$

Heat Input (MMBtu/hr)

$$HI (\text{MMBtu} / \text{hr}) = Q_{sw} \times 1000 \times \left(\frac{100 - B_{ws}}{100 \times F_d} \right) \times \left(\frac{20.9 - \% O_2}{20.9} \right)$$

$$HI (\text{MMBtu}/\text{hr}) = \frac{\text{wksfc}}{\text{hr}} \times \frac{10^3 \text{ scf}}{\text{kscf}} \times \left(\frac{100 - \%}{100 \times \text{dscf/MMBtu}} \right) \times \left(\frac{20.9 - \%}{20.9} \right) = \frac{\text{MMBtu}}{\text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

APPENDIX E
AIR HYGIENE STATEMENT OF QUALIFICATIONS



Air Hygiene International, Inc.

The Clear Choice

STATEMENT OF QUALIFICATIONS POWERPLANT EMISSIONS TESTING – 2006



AIR HYGIENE INT'L

Corporate Headquarters
5634 S. 122nd E. Ave. Ste. F
Tulsa, OK 74146
918-307-8865 or 888-461-8778

Houston, TX Office
1920 Treble Drive, Suite E-5
Humble, TX 77338

Las Vegas Office
5925 E. Lake Mead Blvd
Las Vegas, NV 89156

Philadelphia, PA Office
8900 State Road
Philadelphia, PA 19136



STATEMENT OF QUALIFICATIONS



AIR HYGIENE

AIR TESTING SERVICES FOR POWER PLANTS

www.airhygiene.com

January, 2005

INTRODUCTION

AIR HYGIENE INTERNATIONAL, INC. (**AIR HYGIENE**) is a professional air emission testing services firm with fixed offices in Tulsa, Oklahoma; Houston, Texas; Denver, Colorado; and Orlando, Florida. Additional mobilization points are located in Philadelphia, Atlanta, Chicago, Los Angeles, and Seattle to serve all 50 United States. **AIR HYGIENE** specializes in air emission testing services for combustion sources in both simple and combined cycle operation burning multiple fuels with multiple control devices and supporting equipment.

AIR HYGIENE has testing laboratories which serve all fifty (50) of the United States and North America. Each mobile laboratory can be equipped with the following equipment and capabilities:

1. State-of-the-Art air emission analyzers, computers, and datalogging software. All designed into an efficient system to provide the fastest, most reliable information possible!
2. Dual racks for multiple source testing simultaneously or multiple points on a single source (in/out SCR, etc.)!
3. NIST traceable gases for the most accurate calibration. Ranges as low as 5 ppm!
4. PM₁₀, NH₃, mercury, sulfuric acid mist (H₂SO₄), SO₃, and formaldehyde sampling equipment!
5. VOC testing with on-board gas chromatograph to remove methane and ethane!
6. On-board printers to provide hard copies of testing information on-site!
7. Networking capabilities to provide real-time emission data directly into the control room!

AIR HYGIENE is known for providing professional services which include the following:

- Providing superior, cost saving services to our clients!
- High quality emission testing personnel with service oriented, friendly attitude!
- Meeting our client's needs whether it is 24 hour a day testing or short notice mobilization!
- Using great equipment that is maintained and dependable!
- Understanding the unique startup and operational needs associated with combustion turbines!

MISSION STATEMENT

Our mission is to provide innovative, practical, top-quality services allowing our clients to increase operating efficiency, save money, and comply with federal/state requirements. We believe our first responsibility is to the client. In providing our unique services, the owners of **AIR HYGIENE** demand ethical conduct from each employee of the company. The character and integrity of **AIR HYGIENE** employees allows our clients to feel confidence in the air testing services of **AIR HYGIENE**. Through a long-term commitment to this mission, **AIR HYGIENE** is known as a company committed to improving our clients' operations.

- AIR HYGIENE** ... Does work worth paying for every time!
... Is well known for our emission testing services and uncompromising efforts to serve our clients!
... Does work that matters!
... Is proud of our emission testing capabilities!
... Provides exciting growth opportunities for energetic individuals!




EMISSION TESTING TEAM

Air Hygiene International, Inc. (**AIR HYGIENE**) intends to exceed your expectations on every project. From project management to field-testing teams, we're committed to hard work on your behalf. The job descriptions and flowchart below outline **AIR HYGIENE**'s client management strategy for your testing services.

From the initial request through receipt of the purchase order, the Inquisition To Order (ITO) team strives to inform every client of the benefits gained by using **AIR HYGIENE** for their emission testing project. The ITO team includes representatives from the sales, marketing, and contracts divisions. In addition, several support staff assist to ensure the ITO team provides the support for client needs as requested by a client or project manager.

Project Managers are the primary contact for clients and ultimately responsible for every emission testing project. **AIR HYGIENE**'s Project Managers experience range from masters level, professional engineers to industry experts with over 5,000 testing projects completed. Each project is assigned a Project Manager based primarily upon geographic location, then industry experience, contact history, and availability. The Project Manager prepares the testing strategy and organization for the project. This includes preparation of testing protocol; coordination with state agencies, client representatives, and any interested third parties. The site testing and report preparation are executed under the direction of the Project Manager from start to finish.



Testing Managers have completed Air Hygiene's rigorous demonstration of capability training program and are capable of operating all testing equipment and performing all test methods required for your testing project. Testing Managers assist Project Managers by leading the field testing when required, preparing draft reports, calibrating equipment, and overseeing testing team on-site.

Test Engineers have significant background and understanding of emission testing or related services. Test Engineers prepare pre-test drawings for port location, ensure on-site logistics for electrical and mechanical/structural needs, and conduct on site testing as directed by the Project Manager and/or Testing Manager. Test Engineers often have special understanding of process and/or regulations applicable to specific testing jobs, which provide great value to both the client and Project Manager in testing strategies.

Testing Specialists have performed over 500 emission tests and have a basic understanding of both particulate and gaseous sampling strategies. Testing Specialists have significant testing experience with **AIR HYGIENE** equipment along with a variety of industries and source equipment. Testing Specialists often operate isokinetic sampling trains or gas analyzers on-site under the direction of the Project Manager and assist with preparation of field reports and quality assurance procedures.

Staff Technicians are entry-level personnel who have performed 100 to 500 emission tests. Staff Technicians perform pre-test equipment preparation, on-site test preparation, and testing assistance under the direction of Project Manager and/or Testing Manager. At least one Staff Technician is assigned to every project to assist on-site. Staff Technicians connect sampling probes to ports, assist with leak checks, raise and lower equipment to and from sampling platform, and other support activities under the direction of the Project Manager and/or Testing Manager.

Testing Assistants are entry-level personnel who have performed less than 100 emission tests. Testing Assistants help with equipment set-up, teardown, and simple testing procedures (i.e. move probe, fill ice bath, clean impingers, etc.) as directed.



AIR HYGIENE Emission Services Summary

Air Hygiene International, Inc. (**AIR HYGIENE**) is a privately-held professional services firm headquartered in Tulsa, Oklahoma with additional offices in Denver, Colorado; Houston, Texas; and Orlando, Florida. **AIR HYGIENE** specializes in emission testing services for a variety of industries including natural gas companies, utilities, refineries, printers, glass plants, bulk fuel loading stations, chemical plants, pulp & paper mills, various manufacturers and related industries.

AIR HYGIENE provides turn-key emission testing services which include:

1. Pre-test site visit and consulting for port locations and setup;
2. Preparation of test plan for state agency;
3. Coordination with state agency regarding emission testing;
4. On-site emission testing services; and
5. Preparation of draft and final reports.



AIR HYGIENE has mobile laboratories that serve all 50 United States and around the world. **AIR HYGIENE** employees have performed over 15,000 emission tests on a variety of sources.

AIR HYGIENE performs air emission certification compliance testing on combustion sources (natural gas, coal, fuel oil, jet fuel, etc), NSPS sources, and Title V compliance sites. Our experience ranges from emission testing for new PSD facilities, MACT and RACT required performance certification testing to Relative Accuracy Test Audits (RATA Tests) for Continuous Emission Monitoring Systems (CEMS) and Parametric Emission Monitoring Systems (PEMS).

Air Hygiene has conducted numerous emission testing projects, which involved multiple groups relying upon instantaneous reporting of important test data. These projects relied upon **Air Hygiene's SPIDER** network. The **SPIDER** network provides Simultaneously Produced Information During Emission Readings (**SPIDER**) between the emission monitoring system and multiple locations (i.e. control room, test center, office, etc.). Hence, you can view real-time emission testing data on-demand from any location you choose!

AIR HYGIENE performs FTIR testing by EPA Method 320 for Hazardous Air Pollutants (HAPS) including formaldehyde, benzene, xylene, toluene, hexane, ammonia, hydrogen chloride, etc. This methodology provides real-time analysis of these critical pollutants.

AIR HYGIENE specializes in the following types of pollutants and EPA Reference Methods (RM):

- Nitrogen Oxides (NOx) – RM 7e &/or 20
- Sulfur Dioxide (SO₂) – RM 6c
- Total Hydrocarbons (THC) – RM 25a
- Volatile Organic Compounds (VOC) RM 25a & RM 18
- Particulates (PM) – RM 5(filterable) & 202(condensable)
- PM < 10 microns (PM₁₀) – RM 201a
- PM < 2.5 microns (PM_{2.5}) – RM 201b
- Opacity – RM 9
- Exhaust Flow – RM 2 &/or 19
- Moisture – RM 4
- Carbon Monoxide (CO) – RM 10
- Carbon Dioxide (CO₂) – RM 3a
- Oxygen (O₂) – RM 3a &/or 20
- Dioxin & Furans – RM 23
- Metals – RM 29
- Chrome – RM 306
- Lead – RM 12
- Formaldehyde – RM 320 (FTIR), SW-846 0011, CARB 429, or CTM-037
- H₂S – RM 11
- BTEX – RM 18
- HAPS – FTIR – RM 320 (FTIR)
- Ammonia – CTM-027 or BAAQMD ST-1B
- Mercury – Ontario Hydro Method or RM 29

TESTING EXPERIENCE

AIR HYGIENE testing personnel account for more than sixty-five (65) years of testing experience and over 15,000 emission tests. Our testing services have involved dealings with all 50 state agencies and EPA regional offices. **AIR HYGIENE** testing personnel are rigorously trained on EPA reference test methods from 40 CFR Part 51, 60, 63, and 75. All testing personnel are instructed and tested on test responsibilities and must complete a "Demonstration of Capability" test per the **AIR HYGIENE** Quality Assurance Manual and the **AIR HYGIENE** Emission Testing Standard Operating Procedures Handbook.

AIR HYGIENE has completed testing on over 134 power plants including 315 combustion turbines, 21 coal fired boilers, 17 gas fired boilers representing 64,876 megawatts (MW). *Let us add your project to our list of satisfied customers!*

TESTING SUCCESS STORIES

AIR HYGIENE personnel have performed thousands of testing projects which have yielded significant benefits for our clients. The following project descriptions briefly discuss some of these emission testing projects.


- Conducted numerous projects optimizing SCR performance by conducting inlet & outlet SCR analysis for NH₃, NOx, flow, and Oxygen. Used information to assist with flow optimization and AIG tuning.
- Conducted federal and state required compliance testing for NOx, CO, PM-10 (front & back-half), SO₂, VOC, Ammonia, Formaldehyde, Opacity, RATA testing (NOx and CO) for new and updated power plants with both simple and combined cycle turbines firing natural gas and fuel oil.
- Conducted dry low NOx burner tuning and performance testing for various models of GE, Siemens Westinghouse, Mitsubishi, Pratt & Whitney, and ABB combustion turbines to verify manufacturer's emission guarantees for clients in preparation for compliance testing.
- Conducted emission testing for NOx, CO, and VOC to assist tuning by performance engineers for meeting low-level NOx emissions and balancing combustion turbine performance.
- Performed power plant emission testing for natural gas fired combustion turbines. Tests included federal required testing per 40 CFR Part 75, state air permit requirements, RATA testing, and emission testing to verify manufacturer's guarantee's during electric/heat output performance testing. Other services for combustion turbine testing included preparation of the QA/QC manual, monitoring plan, seven-day drift test report, system linearity test, and cycle time test.



TESTING LOCATIONS

AIR HYGIENE bases mobilization charges on the distance from your site to the closest of nine (9) regional starting points covering all 50 United States. These include Seattle, Los Angeles, Denver, Tulsa, Houston, Chicago, Orlando, Atlanta, and Philadelphia.

Each start point is located such that the **AIR HYGIENE** test teams can mobilize to your site at affordable costs to ensure we are price competitive to any U.S. location.





COMBUSTION TURBINE TESTING SERVICES SUMMARY

Thank you for your consideration of the power and energy industry testing services of Air Hygiene International, Inc. ([AIR HYGIENE](#)). The following list details some of the testing services and extras [AIR HYGIENE](#) includes with each testing job.

Types of Air Testing Services for Combustion Turbines:

- Turbine tuning/mapping for NOx & NH₃ emissions
- Pollutant testing to verify EPC contractual emission guarantees
- Research and Development (R&D) emission data research and turbine optimization
- 40 CFR Part 60 Subpart GG – Turbine Compliance Testing
- 40 CFR Part 75 – Acid Rain Classified Equipment Testing
- 40 CFR Part 75 Appendix E – Peaking Plant CEMS alternative NOx emissions versus Heat Input mapping
- RATA Testing on CEMS systems for NOx, CO, SO₂, CO₂ or O₂, Flow (3-D & Wall effects)
- QA/QC Plans, Monitoring Plans, Linearity Checks, Testing Protocols, etc. are provided with our high quality, service oriented emission testing services
- Initial permit compliance testing for PM, PM-10, PM-2.5, SO₂, NOx, CO, exhaust flow, moisture, O₂, CO₂, Ammonia, Formaldehyde, other HAPs



[AIR HYGIENE](#) will provide the following testing services:

- On-site, real-time test data
- Fuel F-Factor calculation data sheet
- Experienced turbine testing personnel
- Flexible testing schedules to meet your needs
- Electronic reports provided on CD upon request
- Extensive experience with all 50 state agencies in the U.S.
- EPA Protocol 1 Certified Gases (one percent accuracy) for precise calibration
- Low range (0-10 ppm) equipment calibration and measurement available
- Test protocol preparation, coordination with state agency, and site personnel
- Numerous mobile testing labs, which may be used for your projects across the U.S.
- State-of-the-art data logging technology to allow real-time examination of meaningful emission data
- Monitor your emissions data measured in our test lab from your control room via our datalogging network system



[AIR HYGIENE](#) is committed to providing testing teams that will take the time to meet your needs. We ensure the job is completed on time with the least amount of interruption to your job and site operation as possible. Thank you for considering our services.



AIR HYGIENE's Synergistic Approach to Power Plant Air Emissions Testing


Power plants continue to be built, modified, and improved across the United States. These new or modified facilities are at the forefront of clean energy. These units are very efficient yet environmentally friendly, and must be to meet the stringent requirements set forth by the Environmental Protection Agency (EPA) and relevant state agencies. Air Hygiene International, Inc. ([AIR HYGIENE](#)) has developed a unique strategy to help owners deal with these complicated requirements.

Unique Testing Strategy

AIR HYGIENE has developed a synergistic approach to assisting the various groups involved in the completion of a commissioning/startup unit or modification project. **AIR HYGIENE** strives to combine the multiple testing aspects involved with bringing a combustion unit to commercial service. By conducting the various emission tests required for a new combustion unit using one test company, the following benefits are a given:

1. Save money by...
 - a. Reduced mobilizations
 - b. Combined tests yield reduced fuel usage and site time
 - c. Bulk projects receive quantity discounts
2. Improve efficiency through familiarity with site needs
3. Site personnel and testing team are comfortable working together

These projects typically involve some or all of the following groups. There is not a defined set of responsibilities that will match every project. The table below simply suggests a typical list of testing responsibilities.



Responsible Party

Owner
Operator
Turbine/Boiler manufacturer
EPC & Construction Company
CEMS Supplier
Lending Party (i.e. bank)
Environmental Consultant

Testing Responsibilities

Initial and on-going federal and state compliance testing (i.e. NSPS Sub GG, Part 75, Operating Air Permit, etc.)
Initial and on-going federal and state compliance testing (i.e. NSPS Sub GG, Part 75, Operating Air Permit, etc.)
Contractual emission guarantees of unit (i.e. NOx, SO2, CO, VOC, PM-10, NH3, H2SO4)
Contractual emission guarantees including control devices (i.e. NOx, SO2, CO, VOC, PM-10, NH3, H2SO4)
Initial RATA testing (i.e. NOx, CO, SO2, CO2, O2, flow)
No responsibility, but concerned with outcome of all tests
Concerned with air permit and overall compliance; may select the test contractor and provide oversight for testing

Example Project:

A recent project provides a prime example of the synergistic benefits of using **AIR HYGIENE** to perform your commissioning/startup or remodification testing needs for performance and compliance. Eight GE Frame 7FA turbines were taken from performance testing through compliance testing in 20 days. The following tests were performed on each turbine:

- NOx tuning and mapping
- Contractual performance testing for NOx, CO, VOC, SO₂, NH₃, & PM₁₀
- 40 CFR Part 60 Subpart GG: testing for NOx and CO at max load
- 40 CFR Part 75: NOx & CO RATA certification on CEMS
- State required compliance testing for NOx, CO, VOC, NH₃(on-site analysis), formaldehyde (on-site analysis by FTIR), opacity and SO₂ burning natural gas

Test data was provided on-site for all tests, except PM-10. Electronic files were e-mailed for review to the turbine manufacturer, owner & operator, and environmental consultant within 24 hours following completion of site work. Complete reports including PM-10 were submitted to interested parties within 10 days following each blocks completion.

Power Plant Testing Experience

AIR HYGIENE personnel have over sixty-five (65) years of testing experience on combustion turbines, coal fired boilers, gas fired boilers, landfill gas, wood fired, & diesel fired engines across the United States. **AIR HYGIENE** has 10 combustion labs serving all 50 states from four permanent offices (Tulsa, OK; Houston, TX; Denver, CO; & Orlando, FL) and five mobilization points (Los Angeles, CA; Seattle, WA; Chicago, IL; Atlanta, GA; & Philadelphia, PA). **AIR HYGIENE** has tested plants ranging from 50 to 2,000 megawatts in both simple and combined cycle operation with controls including:

- Selective Catalytic Reduction - Ammonia injection
- Steam/Water injection
- Sprint injection
- Dry Low NOx burners (DLN)



AIR HYGIENE has completed testing at 134 plants on 315 combustion turbines, 21 coal fired boilers, 17 gas fired boilers, and others representing 64,876 megawatts (MW). **AIR HYGIENE** tested 5 power plants in 2000 and we have grown since testing 8 in 2001, 19 in 2002, 41 in 2003, and 52 in 2004. **Let us add your upcoming project to our list of satisfied customers!**



INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used by **AIR HYGIENE** during tests conform in principle with the methods outlined in the Code of Federal Regulations, Title 40, Part 60, Appendix A, Methods 3a, 6c, 7e, 10, 18, 19, 20, and 25a.

The flowchart on the next page depicts the sample system used by **AIR HYGIENE** for analysis of oxygen (O_2), carbon dioxide (CO_2), sulfur dioxide (SO_2), carbon monoxide (CO), nitrogen oxides (NOx), and volatile organic compounds (VOC) tests. A heated stainless steel probe is inserted into the sample ports of the stack to extract gas measurements from the emission stream. The gas sample is continuously pulled through the probe and transported via 3/8 inch heat-traced Teflon® tubing to a stainless steel minimum-contact condenser designed to dry the sample through Teflon® tubing via a stainless steel/Teflon® diaphragm pump and into the sample manifold within the mobile laboratory. From the manifold, the sample is partitioned to the O_2 , CO_2 , SO_2 , CO, and NOx analyzers through glass and stainless steel rotameters that control the flow rate of the sample. The VOC sample is measured as a wet gas.

The flowchart shows that the sample system is also equipped with a separate path through which a calibration gas can be delivered to the probe and back through the entire sampling system. This allows for convenient performance of system bias checks as required by the testing methods.

All instruments are housed in an air-conditioned trailer which serves as a mobile laboratory. Gaseous calibration standards are provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 is used to determine the cylinder concentrations where applicable (i.e. NO_x calibration gases).

All data from the continuous monitoring instruments are recorded on a Logic Beach Hyperlogger which retrieves calibrated electronic data from each instrument every second and reports an average of the collected data every 30 seconds and 10 seconds. The averaging time can be selected to meet the clients needs. **This data is available instantaneously for printout, statistical analysis, viewable by actual values, or examined by a trending graph!**

The number of test runs, test loads, and length of runs is based upon federal and state requirements for the facility. Typical run times associated with emission testing are as follows:


Type of Test	# of runs	Length of runs
O_2 Traverse (GG)	1 run @ low load (8 – 48 points)	2 minutes per point
NOx Stratification Test	1 run @ base load (12 points)	2 – 4 minutes per point
Subpart GG	3 runs @ 4 loads (30%, 50%, 75%, & 100%)	15 – 60 minutes per run
RATA	9 – 12 runs @ normal load	21 minutes per run
State Permit Test (gases)	3 runs @ base load	1 hour per run
State Permit Test (particulates)	3 runs @ base load	2 – 4 hours per run



The stack gas analysis for O_2 and CO_2 concentrations are performed in accordance with procedures set forth in EPA Method 3a (EPA Method 20 for O_2 on combustion turbines). The O_2 analyzer uses a paramagnetic cell detector. The CO_2 analyzer uses an infrared detector.

CO emission concentrations are quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer is used for this purpose.

NOx emission concentrations are measured in accordance with procedures set forth in EPA Method 7e and/or 20. A chemiluminescence analyzer is used to determine the nitrogen oxides concentration in the gas stream.

Total hydrocarbons (THC), non-methane, non-ethane hydrocarbons also known as volatile organic compounds (VOC) are analyzed in accordance with procedures set forth in EPA Methods 18 & 25a. A flame ionization detector calibrated with methane is used to determine the THC concentration in the gas stream and VOCs analyzed by GC to determine methane, ethane, and remaining VOCs per EPA Method 18 determination with gas chromatograph using FID detector.





TURBINE TESTING QUALITY ASSURANCE ACTIVITIES

A number of quality assurance activities are undertaken before, during, and after turbine testing projects. This section describes each of those activities.

Each instrument's response is checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity is checked by first adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response is then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within \pm two percent of range of the predicted values.

NO₂ to NO conversion is checked via direct connect with a EPA Protocol certified concentration of NO₂ in a balance of nitrogen. Conversion is verified to be above 90 percent.

Instruments are both factory tested and periodically field challenged with interference gases to verify the instruments have less than a two percent interference from CO₂, SO₂, CO, NO, and O₂.

After each test run, the analyzers are checked for zero and span drift. This allows each test run to be bracketed by calibrations and documents the precision of the data collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. Quality assurance worksheets summarize all multipoint calibration linearity checks and the zero to span checks performed during the tests are included in the test report.

The sampling systems is leak-checked by demonstrating that a vacuum greater than 10 in. Hg can be held for at least one minute with a decline of less than one in. Hg. A leak test is conducted after the sample system is set up and before the system is dismantled. This test is conducted to ensure that ambient air does not dilute the sample. Any leakage detected prior to the tests is repaired and another leak check conducted before testing will commence.

The absence of leaks in the sampling system is also verified by a sampling system bias check. The sampling system's integrity is tested by comparing the responses of the analyzers to the responses of the calibration gases introduced via two paths. The first path is directly into the analyzers and the second path includes the complete sample system with injection at the sample probe. Any difference in the instrument responses by these two methods is attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments are analyzed and certified by the compressed gas vendors to \pm one percent accuracy for all gases. EPA Protocol No. 1 is used, where applicable, to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM). The gas calibration sheets as prepared by the vendor are included in the test report.





TURBINE QUALITY ASSURANCE PROGRAM SUMMARY

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses five major areas:

1. QA reviews of reports, laboratory work, and field testing;
2. Equipment calibration and maintenance;
3. Chain-of-custody;
4. Training; and
5. Knowledge of current test methods.

QA Reviews

AIR HYGIENE's review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program. Finally, **AIR HYGIENE** participates in a PT gas program by analyzing blind gases semi-annually to ensure continued quality.

Chain-of-Custody

AIR HYGIENE maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, **AIR HYGIENE** documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only **AIR HYGIENE** personnel have access. Field data sheets are secured at **AIR HYGIENE**'s offices upon return from the field.

Training

Personnel's training is essential to ensure quality testing. **AIR HYGIENE** has formal and informal training programs, which include:

1. Participation in EPA-sponsored training courses;
2. A requirement for all technicians to read and understand Air Hygiene Incorporated's QA manual;
3. In-house training relating to 40 CFR Part 60 Appendix A methods and QA meetings on a regular basis;
4. OSHA 40 hour Hazwoper Training;
5. Visible Emission (Opacity) Training; and
6. Maintenance of training records.

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. **AIR HYGIENE** subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. **AIR HYGIENE** personnel maintain membership in various relevant organizations associated with gas fired turbines.



AIR HYGIENE INT'L

Experience

F-Factor Datasheet and Fuel Gas Analysis

Company: XYZ Power
 Location: XYZ Power Plant
 Date: April 9, 2001

Values to enter from fuel gas analysis by GPA 2166.

Font Scheme:

Blue Font = enter new data
 Black Font = calculated data
 Green Font = Labels for columns & rows
 Red Font = Important results with notes

Gas Component	Mole (%)	Molecular Weight (lb/lb-mole)	Ib Component per lb-Mole of Gas	Weight % of Component	Fuel Heat Value [HHV] (Btu/scf) ¹	Fuel Heat Value [LHV] (Btu/scf) ¹
Methane	CH4	96.491	16.04	15.477	92.97	974.27
Ethane	C2H6	2.115	30.07	0.636	3.82	37.41
Propane	C3H8	0.186	44.1	0.082	0.49	4.68
iso-Butane	iC4H10	0.019	58.12	0.011	0.07	0.62
n-Butane	nC4H10	0.023	58.12	0.013	0.08	0.75
Iso-Pentane	iC5H12	0.008	72.15	0.006	0.03	0.32
n-Pentane	nC5H12	0.005	72.15	0.004	0.02	0.20
Hexanes	C6H14	0.025	86.18	0.022	0.13	1.19
Heptanes	C7H16	0.000	100.21	0.000	0.00	0.00
Octanes	C8H18	0.000	114.23	0.000	0.00	0.00
Carbon Dioxide	CO2	0.510	44.01	0.224	1.35	0.00
Nitrogen	N2	0.618	28.01	0.173	1.04	0.00
Hydrogen Sulfide	H2S	0.000	34.08	0.000	0.00	0.00
Oxygen	O2	0.000	32	0.000	0.00	0.00
Helium	He	0.000	4	0.000	0.00	0.00
Hydrogen	H2	0.000	2	0.000	0.00	0.00
Totals (dry)		100.000		16.648	1019.44	918.57
Totals (wet)					1001.66	902.55

¹ Standardized to 60°F and 1 atm to match fuel flow data

If total is not 100.000 then the mol% data was either entered incorrectly or the gas analysis is incomplete. Sometimes small differences are due to rounding error.

High Heat Value of dry gas (HHV-dry)
 This is the primary fuel heat value used in emission testing calculations.

Low Heat Value of dry gas. LHV-dry

High Heat Value of wet Gas. HHV-wet

Low Heat Value of wet gas. LHV-wet

Characteristics of Fuel Gas	
Molecular Weight of gas =	16.648 lb/lb-mole
Btu per lb. of gas =	23239.7689 gross (HHV)
Btu per lb. of gas =	20940.2961 net (LHV)
wt % VOC in fuel gas =	0.83 %
Specific Gravity =	0.5749

Value used to convert THC readings to VOC.

Component	Weight %
carbon	73.71
oxygen	0.98
hydrogen	24.27
nitrogen	1.04
helium	0.00
sulfur	0.00
Total	100.00

F-Factor (scf dry exhaust per MMBtu [HHV] = 8641.17
 (Based on EPA RM-19) at 68°F and 1 atm

Fuel Specific F-Factor. Note that EPA Method 19 lists natural gas's F-factor as 8710.

F-Factor Calculation:

$$\text{F-Factor} = 1,000,000 * ((3.64 * \% \text{H}) + (1.53 * \% \text{C}) + (0.57 * \% \text{S}) + (0.14 * \% \text{N}) - (0.46 * \% \text{O})) / \text{GCV}$$

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)%

GCV = Gross Btu per lb. of gas (HHV)

EXAMPLE TESTING DATASHEET FOR GASES

XYZ Power Plant GE GTG Frame 7FA Combustion Turbine Fuel: Natural Gas

Fuel Data

Fuel F-Factor	8,671.5	SCF/MMBtu
Generator Output	172.0	MW
Fuel Flow	515,040.8	SCFH
Fuel Heating Value (HHV)	1,076.5	Btu/SCF
Combustor Inlet Pressure	6,166.5	mm Hg
Heat Input (LHV)	500.6	MMBtu/hr
Stack Moisture Content	8.4	%
Stack Exhaust Flow	13,600,266.4	SCFH

Weather Data

	Barometric Pressure	29.11	in. Hg
	Relative Humidity	82	%
	Dry Bulb Temperature	72	F
	Specific Humidity	0.0142443	lb H ₂ O/lb air
	Wet Bulb Temperature	68	F

yellow - supporting information

gray - raw testing data

green - final results

Run #1 - 100% High Load

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmv)	CO (ppmv)	VOC (ppmvw)	SO ₂ (ppmv)	CO ₂ (%)
06/27/01 11:47:32	16770	13.57	5.05	-0.38	0.59	0.59	5.09
06/27/01 11:48:02	16800	13.57	5.85	-0.26	0.63	0.63	4.83
06/27/01 11:48:32	16830	13.55	6.37	-0.44	0.71	0.71	4.71
06/27/01 11:49:02	16860	13.54	6.83	0.60	0.83	0.83	4.33
06/27/01 11:49:32	16890	13.55	7.26	0.25	0.99	0.99	4.49
06/27/01 11:50:02	16920	13.55	6.44	-0.24	1.14	1.14	4.64
06/27/01 11:50:32	16950	13.54	6.28	-0.75	1.29	1.29	4.79
06/27/01 11:51:02	16980	13.55	5.68	-0.68	1.46	1.46	4.96
06/27/01 11:51:32	17010	13.58	6.01	-1.14	1.60	1.60	5.10
06/27/01 11:52:02	17040	13.49	5.05	1.36	1.69	1.69	5.19
06/27/01 11:52:32	17070	13.60	5.14	-0.47	1.70	1.70	5.20
06/27/01 11:53:02	17100	13.61	4.58	0.69	1.69	1.69	5.19
06/27/01 11:53:32	17130	13.62	4.93	0.90	1.65	1.65	5.15
06/27/01 11:54:02	17160	13.62	4.69	0.54	1.64	1.64	5.14
06/27/01 11:54:32	17190	13.61	4.83	0.64	1.59	1.59	5.09
06/27/01 11:55:02	17220	13.61	4.76	-0.07	1.60	1.60	5.10
06/27/01 11:55:32	17250	13.64	4.86	-0.02	1.59	1.59	5.09
06/27/01 11:56:02	17280	13.63	4.38	0.92	1.51	1.51	5.01
06/27/01 11:56:32	17310	13.61	4.94	-0.01	1.47	1.47	4.97
06/27/01 11:57:02	17340	13.61	4.89	0.27	1.47	1.47	4.97
06/27/01 11:57:32	17370	13.61	4.82	1.28	1.46	1.46	4.96
06/27/01 11:58:02	17400	13.61	4.69	1.55	1.46	1.46	4.96
06/27/01 11:58:32	17430	13.60	4.23	1.16	1.46	1.46	4.96
06/27/01 11:59:02	17460	13.59	4.69	-0.26	1.46	1.46	4.96
06/27/01 11:59:32	17490	13.57	4.89	-1.46	1.49	1.49	4.99
06/27/01 12:00:02	17520	13.58	4.86	-1.49	1.53	1.53	5.03
06/27/01 12:00:32	17550	13.59	4.79	-0.79	1.53	1.53	5.03
06/27/01 12:01:02	17580	13.58	4.76	-1.57	1.54	1.54	5.04
06/27/01 12:01:32	17610	13.57	4.65	1.17	1.53	1.53	5.03
06/27/01 12:02:02	17640	14.24	4.69	0.01	1.52	1.52	5.02
06/27/01 12:02:32	17670	13.54	4.83	1.68	1.52	1.52	5.02
06/27/01 12:03:02	17700	13.55	5.70	1.31	1.53	1.53	5.03
06/27/01 12:03:32	17730	13.55	5.66	-0.73	1.53	1.53	5.03
06/27/01 12:03:32	17760	13.55	5.04	-0.48	1.53	1.53	5.03
RAW AVERAGE		13.6	5.2	0.1	1.4	1.4	5.0

QA/QC Data Control

Bias & Drift Checks	O ₂ (%)	NOx (ppmv)	CO (ppmv)	VOC (ppmvw)	SO ₂ (ppmv)	CO ₂ (%)
Initial Zero	0.2	0.3	-0.2	0.0	0.1	0.1
Final Zero	0.2	0.5	-0.2	0.2	0.2	0.1
Avg. Zero	0.2	0.4	-0.2	0.1	0.2	0.1
Initial UpScale	12.1	5.8	4.0	3.4	28.3	9.0
Final UpScale	12.1	5.7	4.0	3.3	28.2	8.8
Avg. UpScale	12.1	5.8	4.0	3.4	28.3	8.9
Upscale Cal Gas	12.0	5.7	4.0	3.5	28.0	9.0

Emissions Data

	O ₂ (%)	NOx (ppmv)	CO (ppmv)	VOC (ppmv)*	SO ₂ (ppmv)	CO ₂ (%)
Corrected Raw Averages	13.5	5.1	0.3	1.5	1.3	5.0
ppm @ 15% O ₂	N/A	4.2	0.2	1.2	1.0	N/A
ppm @ 15% O ₂ & ISO	N/A	4.7	0.2	1.4	1.1	N/A
Emission Rate (lb/MMBtu)	N/A	0.015	0.000	0.004	0.005	N/A
Emission Rate (lb/hr)	N/A	8,46	0.27	2,40	2,84	N/A
Emission Rate (ton/year) @ 8760 hr/yr	N/A	37,07	1.20	10,49	12,43	N/A
Emission Rate (g/MW*hr)	N/A	0.06	0.00	0.02	0.02	N/A

*VOC data in Emissions Data Table has been converted to dry values by the equation below.

*VOC uncorrected raw average * (100/100-stack moisture content)

CLIENT REFERENCES

The following are current clients who represent the various companies for whom **AIR HYGIENE** has performed testing services.
Please feel free to call and discuss our services with them.

Brian Kearney
Reliant Energy
(814) 533-8261



Kathy Waxman
Keyspan Energy
(516) 545-2579



Jose P. Lozada
Burns and Roe
(201) 986-4261



Gush Singh
Bechtel
(301) 228-7281



Don Fritz
Mirant
(702) 632-8630

Richard Winch
PowerTek (A Subsidiary of Power Technological Services)
(417) 538-9013

Roosevelt Huggins
Black & Veatch
(913) 458-7864



Tracy Patterson
Cogentrix
(804) 541-4246



PK Chelian
Foster Wheeler
(908) 713-2159



Tim Mordhorst
Black Hills
(605) 721-2181



Darin Watson
Transalta
(360) 807-3002



Satoru (Scott) Shishido
Hitachi
(914) 524-6614



Robert Van Engelenhoven
Pacificorp
(801) 220-4402



Jammie Bowen
Utility Engineering
(806) 359-2497



Marilyn Teague
Sempra Energy
(949) 387-5712



Lewis Schuessler
BE&K Engineering
(205) 972-6522



Linda Boyer
Pennsylvania Power & Light
(610) 774-4400



Rex Lee
Kiewit
(434) 589-7224



Kevin Kellie
Calpine
(918) 486-1830



Ron Sigur
Fresh Meadow Mechanical
(516) 546-1656



Jordan M. Haywood
Siemens Westinghouse
(407) 736-3045



Charles Spell
Arizona Public Service Co.
(602) 250-1383



Steve Brooks
Aquila
(816) 387-6266



Rod Klauer
Peerless Manufacturing
(972) 559-6308



Mary Kate Grossman
AES
(817) 579-8201



Mark Finnlay
Alstrom
mark.finlay@power.alstom.com



Mike Geers
Cinergy
(513) 287-3839



Karst Postma
TIC
(970) 879-2561



John Davis
LG Constructors
(702) 644-5896



Joe Elliot
Nooter Erickson
(636) 651-1198



William Stark
RW Beck
(303) 299-5200



Charles Gibbs
PIC World
(678) 627-4467



David Sloat
Sargent & Lundy
(312) 269-2784



Sheila Wheeler
Burns & McDonnell
(816) 822-3250



Mark Chrisos
Intergen
(781) 993-3036



Tom Price
Calpine - Oregon
(541) 667-3222



Ken Welch
Universal Energy
(281) 335-9811



Glenn Atkinson
Zachry Construction
(770) 251-7915



Tim Travers
Florida Power & Light
(610) 859-9591



Terrie Blackburn
Williams Power
(918) 573-9766



Sam Faghih
SNC-Lavalin
(425) 896-3916



David Stackhouse
KM Power (Kinder Morgan)
(303) 914-7517



Monty Wiggins
Modern Continental
(864) 243-0519



Chris Jacobsen
Tenaska Power Partners
(402) 691-9500



J. Neely Ashe
Duke Energy
(713) 989-8325



Richard Hooper
Stone & Webster
(303) 741-7409



Robert Farmer
URS Corporation
(602) 371-1100



Mike Brown
AEP
(724) 449-9700



APPENDIX G

MPCA APPROVALS AND REQUESTED FORMS

Thomas Graham

From: Gorg, Steven [Steven.Gorg@state.mn.us]
Sent: Tuesday, May 29, 2007 3:02 PM
To: chuck.wagoner@fibrowattusa.com
Cc: Terry Walmsley; victor.myers@slthermal.com; robert.dolesky@snclavalin.com; Magee-Hill, Heather; Kilgriff, Sarah; Stock, Curtis; Place, Andrew; tom@airhygiene.com
Subject: Fibrominn, LLC (SV 001): Test Plan Approval Letter (May 29, 2007)
Attachments: Fibrominn (SV 001).pdf; Performance Test Report Completeness Criteria (PTRCC).pdf

Hello Chuck. Attached is the approval letter and referenced form (Performance Test Report Completeness Criteria (PTRCC).pdf) for your recently submitted test plans.

Thanks - Steve

Steven J. Gorg, M.S., P.E.
Environmental Engineer
Industrial Division
Minnesota Pollution Control Agency (MPCA)
520 Lafayette Road, St. Paul, MN 55155-4194
Phone: 651-296-8766
Fax: 651-296-8717
Email: steven.gorg@pca.state.mn.us
MPCA web site: <http://www.pca.state.mn.us>



Minnesota
Pollution
Control
Agency

Performance Test Plan Approval

Minnesota Pollution Control Agency
520 Lafayette Rd. N. Saint Paul, MN 55155-4194 (651) 296-6300
www.pca.state.mn.us

AQ#4065

Facility Name: Fibrominn, LLC
Facility Contact: Chuck Wagoner
Address: 900 Industry Drive
Phone: 320-843-9013
Test Locations: SV 001 (EU 001, MR 001-007; CE 001, 003 and 004)
Scheduled For: June 04 through June 11, 2007, at your facility located in Benson, Minnesota.

Your test plan received on May 07, 2007, and discussed on May 29, 2007, is approved by the Minnesota Pollution Control Agency (MPCA) as follows:

- Shortened test notification approved
- Test plan approved without modification
- Test plan approved with the following provisions:

The performance tests are being performed to measure emissions for determining the compliance status with permitted emission limits/requirements (see the relevant permit requirements for limits/requirements/parameters). Emission units and control equipment associated with the results of the performance test must be operated at maximum capacity/worse case conditions to avoid the establishment of new operational limits. The control equipment operational parameters may change based on the averages recorded during testing.

Include in the final test report(s) the full reference method data record (strip chart and/or datalogger output) used to calculate emissions. The data record should include calibration values for any instrumental analyzer used for emissions compliance testing.

Include in the final test report(s) all process and pollution control equipment operating data collected at 15 minute intervals and averaged for each test period. This information should be easily understood by individuals not familiar with the process.

Include in the final test report and CD-ROM copy; a signed certifications form, the test plan, this test plan approval letter (TPAL) and the email to which the TPAL was attached. The CD-ROM test report copy must be labeled with the AQ File Number, Company Name, Emission Unit Tested and Test Dates as stated on the submittal form. Only one paper copy and one CD-ROM/Microfiche copy of the test report are to be submitted.

Include in the final test report a simplified drawing of the test locations including pollution control equipment, stack orientation and test port locations.

Include the process rates and control equipment rates on the Operating Data Summary Form.

Obtain the required submittal and operating data forms from the website noted below¹.

Required Forms:

Operating Data Summary- Combustion

Operating Data Summary- Waste

Sources¹**Combustors¹**

- | | |
|--|---|
| <input type="checkbox"/> Operating Data Summary- Process Sources ¹ | <input type="checkbox"/> Operating Data Summary- Asphalt Plants ¹ |
| <input checked="" type="checkbox"/> Certifications Form ¹ | <input checked="" type="checkbox"/> Microfiche/CD-ROM Submittal Form ¹ |
| <input checked="" type="checkbox"/> Performance Test Report Completeness Criteria (PTRCC) (attached) | |

1 – Available at: www.pca.state.mn.us/air/performancetest.html

Approved by:**Date: May 29, 2007**

Steven J. Gorg, M.S., P.E.
Environmental Engineer
Industrial Division
Compliance and Enforcement Section

Please contact me at (651) 296-8766 if you have any questions regarding this approval.

Please be aware that enforcement action will be taken for performance test failures indicating emissions above applicable limits (excess actual emissions to the environment). Failures commonly result in assessment of a monetary penalty. Upon the first test failure, the Company should take immediate measures to minimize emissions. The measures taken should be documented, as they will become part of the record of corrective actions.

Hard Copy Performance Test Reports and Microfiche or CD Copy submittals will be addressed to: Compliance Tracking Coordinator, Compliance and Enforcement Unit, Industrial Division, Minnesota Pollution Control Agency, 520 Lafayette Road North, St. Paul, Minnesota 55155-4194

cc: Terry Walmsley, Fibrowatt (email)
Victor Myers, Fibrominn (email)
Robert Dolesky, SNC Lavalin (email)
Thomas Graham, P.E., Air Hygiene International (email)
Heather Magee-Hill, MPCA St. Paul (email)
Sarah Kilgriff, MPCA St. Paul (email)
Curt Stock, MPCA St. Paul (email)
Andy Place, MPCA St. Paul (email)
AQ Correspondence File No. 4065



**Minnesota Pollution
Control Agency**

520 Lafayette Road
St. Paul, MN 55155-4194

Air Performance Test Form
Operating Data Summary for Combustion Sources

Facility Information (please print)

Company name: Fibrominn, LLC Furnace(s) No: 1
Test date(s): July 2-4, 2007

A. Fuel Input and Operating Capacities: Itemize fuels and materials added to the combustion process during the test period. Attach ultimate/proximate analysis of the fuel, if applicable. **List appropriate units.**

Run No.	Fuel type & origin (e.g. Bituminous/Eastern)	Fuel input (list units)	Heat content (list units)	Steam (10 ³ lbs/hr)	Gross MW/hr	Heat input (10 ⁶ Btu/hr)
1	Biomass (turkey litter)	83.9 ton/hr	4,334 Btu/lb	487	61	784.4
2	Biomass (turkey litter)	83.3 ton/hr	4,334 Btu/lb	487	62	774.1
3	Biomass (turkey litter)	88.5 ton/hr	4,334 Btu/lb	490	63	777.9
Avg.	Biomass (turkey litter)	85.22 ton/hr	4,334 Btu/lb	488	62	778.8

B. Operating Data for Furnace and Air Pollution Control Equipment

1. Were the furnace(s) and control equipment operated consistent with normal procedures? Yes No If no, explain _____

2. Date(s) and procedure(s) of last maintenance/cleaning within 6 months:
 Remains unchanged from information provided in test plan

3. Include a copy of chart/data log records during test for the combustion efficiency indices: carbon monoxide (CO), oxygen (O₂), carbon dioxide, (CO₂), combustibles, steam flow, air flow, etc. (Label as appropriate.)

4. Soot blowing and ash pulling information: No soot blowing or ash pulling conducted, go to Item 5.

What is the normal soot blowing frequency for unit(s)? Continuous, no further information required for this column.

a) minutes/shift: 240 b) shifts/day: 2

What were the soot blowing times during the test?

Start: periodic End: _____

Start: _____ End: _____

Last time before testing when soot blown? (date and time) _____

What is the normal ash pulling frequency for unit(s)? Continuous, no further information required for this column.

a) minutes/shift: _____ b) shifts/day: _____

What were the soot blowing times during the test?

Start: _____ End: _____

Start: _____ End: _____

Last time before testing when soot blown? (date and time) _____

5. Summarize control equipment operating data documented during testing. Values reported should reflect maximum, minimum, averages, or as approved in the test plan. (See test plan and approval letter)
- Examples of APC equipment and parameters generally monitored. Monitor as in the test plan and/or approval letter.
- Scrubber (list type of scrubber): ΔP (in. w.c.) and feed rate (gpm and psig)
 - Catalytic Incinerator : ($^{\circ}F_{inlet}$, $^{\circ}F_{outlet}$) and Thermal Incinerator: ($^{\circ}F_{operating}$)
 - Baghouse, Cyclone, and Multi-clone: ΔP (in. w.c.)
 - ESP: Number and identity of operating field(s)

APC equipment and parameter monitored	Run 1	Run 2	Run 3	Average
SDA Slurry Flow (GPM)	27.1	22.3	30.9	26.8
SDA Quench Flow (GPM)	14.4	14.5	8.6	12.5
SH Steam Temp ($^{\circ}F$)	968	971	969	969.2
SH Steam Pres. (psi)	1,500	1,504	1,499	1,501
List pollutant & averaging basis—should reflect permit	Run 1	Run 2	Run 3	Average
Continuous Opacity Monitor(list hourly average): (%)	2.69	2.94	0.83	2.15
NOx Monitor (list averaging basis): lb/MMBtu	0.141	0.118	0.160	0.140
SO2 Monitor (list averaging basis): % reduction	80.88	81.23	80.47	80.86

Abbreviations:

APC = air pollution control

Btu = British thermal units

gpm = gallons per minute

in. w.c. = inches of water column

lbs. = pounds

MW = megawatts

Psig = pressure per square inch gauge

ΔP = pressure drop

NOTE: This form provides only a summary of the operating conditions during the performance test. Additional and more detailed records are required to meet the requirements of Minn. R. 7017.2035. This form is to be submitted as part of the performance test report.

Hard Copy Performance Test Reports and Microfiche or CD Copy submittals will be addressed to:

Air Quality Compliance Tracking Coordinator
 Minnesota Pollution Control Agency
 520 Lafayette Road North
 St. Paul, Minnesota 55155-4194



**Minnesota Pollution
Control Agency**

520 Lafayette Road
St.Paul, MN 55155-4194

Air Performance Test Form
Performance Test Report Completeness Criteria

The owner or operator of an emissions facility is responsible for submitting a complete test report as defined by Minn. R. 7017.2035. A test report may be rejected if it is deemed incomplete. As a result, this form is designed to ensure that your submittal is complete.

- 1) Facility name: Fibrominn Biomass Power Plant
- 2) Air quality facility ID number (first 8 digits of permit number): 15100038
- 3) Air quality file number:
- 4) Facility location address: 900 Industry Drive
City: Benson State: MN Zip code: 56215
- 5) Date of performance test: July 2-4, 2007
- 6) Facility contact person (Individual who is designated to receive agency correspondence related to this test):
Mr./Ms: Robert Dolesky Phone: (604) 605-4927
Title: Project Engineer Fax: (604) 683-1672
Mailing address: 1200-1075 West Georgia St
City: Vancouver, British Columbia State: Canada Zip code: V6E 3C9
e-mail address: robert.dolesky@sncalavalin.com

7) Test report checklist:

Cover:

<input checked="" type="checkbox"/>	Name and location (address) of the emission facility	<input checked="" type="checkbox"/>	Date(s) of the performance test
<input checked="" type="checkbox"/>	Identification of emission unit(s) tested (i.e. GP002, EU031, SV028, or CE001 – Identification of the tested unit which has the emission limit as designated by your permit [source designators])	<input checked="" type="checkbox"/>	Name and address of the testing company or agency
<input checked="" type="checkbox"/>	AQ Facility ID Number (first 8 digits of permit number) and AQ File Number	<input checked="" type="checkbox"/>	Facility contact person (individual designated to receive agency correspondence), and contact information including title, address, phone number, fax number, and email address

Certification:

<input checked="" type="checkbox"/>	Signed and dated certification statements as defined by Minn R. 7017.2040 (An exact duplicate must be included in the CD-ROM copy of the test report)
-------------------------------------	---

Introduction:

<input checked="" type="checkbox"/>	Reason for testing (i.e. Permit condition, notice of violation, etc., including permit number or name of other applicable compliance document, include correct Rule citation as outlined in permit)	<input checked="" type="checkbox"/>	Pollutants tested (for each emission unit tested)
<input checked="" type="checkbox"/>	Test location and type of process including source designators as outlined in permit	<input checked="" type="checkbox"/>	Observers names including industry and agency observers
<input checked="" type="checkbox"/>	Test date(s)	<input checked="" type="checkbox"/>	Changes from test plan, problems experienced during test and any other relevant background information

Summary of Results: (see attached Table 1: Summary of Performance Test Results)

<input checked="" type="checkbox"/>	Emission results expressed in the same units as the emission limits	<input checked="" type="checkbox"/>	Description of collected samples
<input checked="" type="checkbox"/>	Process data as related to determination of compliance (must include process rates, process parameters and pollution control equipment parameters that will be used to determine worst case operating conditions and pollution control equipment limitations during the test [see the relevant operator data forms at http://www.pca.state.mn.us/air/performancetest.html])	<input checked="" type="checkbox"/>	Visible emissions summary if applicable
<input checked="" type="checkbox"/>	Emission limits (as stated in your permit or applicable regulations) and applicable regulations citations as stated in your permit	<input checked="" type="checkbox"/>	Discussion of errors, both real and apparent (If no errors occurred, verify by including statement)

Operating Parameters: (see the relevant operator data forms at <http://www.pca.state.mn.us/air/performancetest.html>)

*Note: Readings of discrete data from monitoring instruments must be recorded at least every 15 minutes, or other reasonable time interval as approved, during the test and strip charts or retrieved electronic data from continuous monitors must be included in the test report.

<input checked="" type="checkbox"/>	Description of process and air pollution control devices including emission unit(s) tested (i.e. GP002, EU031, SV028, or CE001 – Identification of the tested unit which has the emission limit as designated by your permit [source designators])	<input checked="" type="checkbox"/>	Process data and results, with example calculations (Process data must be collected and averaged for each test run and averaged for each series of tests for each unit tested. Process data must be displayed in the same units that were used to determine worst case operating conditions during the test. Process data must be easily understood by personnel not familiar with the process.)
<input checked="" type="checkbox"/>	Process and control equipment flow diagrams	<input checked="" type="checkbox"/>	Any specially required operation demonstrations

Maintenance:

<input checked="" type="checkbox"/>	Description including dates of all maintenance and operational inspections, including major cleaning operations and replacement, repair, or modification of functional components of process or control equipment done in the month prior to the test (Include a statement if no maintenance was performed)
-------------------------------------	---

Sampling and Analysis Procedures:

<input checked="" type="checkbox"/>	Sampling port location and dimensioned cross section showing all flow disturbances including fans, elbows, dampers, constrictions and pollution control equipment. Measurements should be included on diagram(s).	<input checked="" type="checkbox"/>	Brief description of sampling procedures and analytical methods, with discussion of deviations from standard methods (include a statement if no deviations were made), including a statement of source methods used, but not including complete copies of reference methods
<input checked="" type="checkbox"/>	Description of sampling point (including duct orientation, number of test ports, number of sampling points, distances to upstream and downstream flow disturbances)	<input checked="" type="checkbox"/>	If a method other than a US EPA reference method was used: a statement of the detection limit and the level of accuracy of the method under the conditions of the test and at the concentration of air pollutant that is reported.
<input checked="" type="checkbox"/>	Description of sampling train	<input type="checkbox"/>	

Appendix:

<input checked="" type="checkbox"/>	Complete results, including any fuel analysis, with example calculations, showing equations used and actual results in equation form on same or adjacent pages, using applicable equations shown in the reference method	<input checked="" type="checkbox"/>	Test log (include test times, test interruptions and causes, and any other significant events related to the testing)
-------------------------------------	--	-------------------------------------	---

<input checked="" type="checkbox"/>	Copies of raw field data	<input checked="" type="checkbox"/>	Calibration procedures and results including pitot tube, nozzle, meter box, thermometer, barometer calibrations and any other equipment used to collect emissions samples. Instrument calibrations must be performed in accordance to the reference method used and calibration values must be displayed on the same data recorder from which emissions results are calculated.
<input checked="" type="checkbox"/>	Laboratory report with chain of custody record	<input checked="" type="checkbox"/>	Project participants and titles
<input checked="" type="checkbox"/>	Raw production data, signed by plant official who can interpret, and be held accountable for the data	<input checked="" type="checkbox"/>	A copy of the most recent version of the test plan and a copy of the commissioner's written approval of the test plan

Additional Information:

<input checked="" type="checkbox"/>	Any other special requirement of the test method, test plan, applicable requirement or compliance document	<input checked="" type="checkbox"/>	Any other information necessary to evaluate compliance with Minn R. 7017.2020 and 7017.2025 as requested by the commissioner.
-------------------------------------	--	-------------------------------------	---

REFERENCED TABLE

Table 1: Summary of Performance Test Results

1(a) Emission Unit Tested	1(b) Limitation Basis	1(c) Pollutant and Emission Limit	1(d) Test Result
EXAMPLE Boiler No. 3 (EU 042/ SV 440)	Minn. Stat. 116.07, subd. 4a	Particulate (B): 12 lbs/hour	Particulate (B): 4.1 lbs/hour
		VOC: 13 lbs/hour as carbon	VOC: 2.3 lbs/hour as carbon
	Title I Condition: 40 CFR § 52.21(j) (BACT limit); Minn. R. 7007.3000	Carbon Monoxide: 0.090 lbs/MMBtu	Carbon Monoxide: 0.00078 lbs/MMBtu
		Volatile Organic Compounds: 0.0090 lbs/MMBtu	Volatile Organic Compounds: 0.00050 lbs/MMBtu
	Title I Condition: 40 CFR § 52.21(k) (modeling); Minn. R. 7007.3000	Carbon Monoxide: 33.6 lbs/hour	Carbon Monoxide: 0.26 lbs/hour

Table References:

- (A) Filterable particulate matter as determined by U.S. Environmental Protection Agency (EPA) Method 5.
- (B) Filterable plus organic condensable particulate matter as determined by EPA Method 5 and Method 202/ Minn. R. 7011.0725.
- (C) Particles with an aerodynamic diameter less than or equal to a nominal ten micrometers (PM_{10}) as determined by EPA Methods 5 and 202.

Instructions for Completing this Form:

- 1) Facility Name -- Enter your facility name.
- 2) AQ Facility ID No. -- Fill in your Air Quality Facility ID Number. This is the first eight digits of the permit number for all new permits issued under the new operating permit program. In the future, this number will replace the AQ File Number in item 3) below.
- 3) AQ File No. -- Fill in your AQ File Number. This is the first group of characters in your current Air Emission Facility Permit. For example, for permit number 1899AB-93-OT-1, the AQ Facility ID number would be 1899AB. Can be found in the upper right hand corner of the Test Plan Approval.
- 4) Facility Location -- Fill in the facility's street address and the city and county where the facility is located.
- 5) Date of Performance Test -- Enter the date of your performance test.
- 6) Facility Contact Person -- Fill in the contact information for the person that the MPCA may contact regarding this performance test.
- 7) Test Report Check List: This checklist is to ensure that your test submittal includes all of the required information.

Reference Table:

- 1) Summary of Performance Test Results:
 - 1a) Emission Unit Tested: As designated by permit (i.e. EU, SV, etc.)
 - 1b) Limitation Basis: All applicable rule citations from permit that apply to tested unit(s).
 - 1c) Pollutant and Emission Limit: Pollutant to be tested and emission limit as outlined in permit
 - 1d) Test Result: State test result.